

ОТЧЕТ
по архиву изменений базы данных

Тепловычислитель : ТВ7-04.1М серийный номер 22170988

Отчет сформирован: 22.10.2025 09:50:54

№	Дата/Время	Параметр	Старое значение	Новое значение
1	02.09.2022 17:10:06	Дата	02.09.22	12.09.22
2	02.09.2022 17:10:06	Время	17:10:06	11:46:13
3	07.10.2022 09:24:52	Время	09:24:52	11:24:43
4	07.10.2022 11:27:20	Вес импульса (БД1 ТВ1 ТР1)	10.000000	2.500000
5	07.10.2022 11:27:47	Vmax (БД1 ТВ1 ТР1)	100.000000	72.000000
6	07.10.2022 11:28:03	Vmin (БД1 ТВ1 ТР1)	10.000000	0.300000
7	07.10.2022 11:28:25	tдог (БД1 ТВ1 ТР1)	90.000000	85.000000
8	07.10.2022 11:29:37	Вес импульса (БД1 ТВ1 ТР2)	10.000000	2.500000
9	07.10.2022 11:30:07	Vmax (БД1 ТВ1 ТР2)	100.000000	72.000000
10	07.10.2022 11:30:27	Vmin (БД1 ТВ1 ТР2)	10.000000	0.300000
11	07.10.2022 11:30:44	tдог (БД1 ТВ1 ТР2)	60.000000	85.000000
12	07.10.2022 11:31:33	Датчик Р (БД1 ТВ1 ТР1)	Нет	Есть, исп.
13	07.10.2022 11:31:46	Датчик Р (БД1 ТВ1 ТР2)	Нет	Есть, исп.
14	07.10.2022 11:50:34	Термопреобр.	100П	Pt100
15	05.10.2025 08:12:15	Дата	05.10.25	08.10.25
16	08.10.2025 08:12:33	Время	08:12:33	09:37:25

ОТЧЕТ
о суточных параметрах теплоснабжения
25/09/25г.-20/10/25г.

Абонент: _____

Договор N: _____

Адрес: 34 мкр дом 2
Тепловычислитель ВКТ-7 сет. N 001

Тип расходомера: _____

Договорные расходы: _____

Пределы измерений:

М сет. воды=_____ т.сут МГВС=_____ т.сут

G под max = 120.00 м3/ч G под min = 0.32 м3/ч

Тхв= 5.00°C

G обр max = 120.00 м3/ч G обр min = 0.32 м3/ч

Заводской номер 00166490

ВВОД 1

СХЕМА ПОДКЛЮЧЕНИЯ 3

БД 1

ФТ=0

ТЗ=0

КС=0x0419

по 2.7

Дата	t1	t2	dt	V1	M1	V2	M2	Mг	P1	P2	Qo	ВНР	ВОС	НС	DI
	°C	°C	°C	м3	т	м3	т	т	кг/см2	кг/см2	Гкал	ч	ч		м3
25/09/25	-0.01	-208.9	208.95	0.00	0.00	0.00	0.00	0.00	61.16	-224.0	0.000	38	0	*	0.0000
26/09/25	36.87	33.82	3.05	0.00	0.00	0.00	0.00	0.00	4.59	4.07	0.000	24	0	*	0.0000
27/09/25	45.06	39.97	5.09	0.00	0.00	0.00	0.00	0.00	6.24	6.08	0.000	24	0	*	0.0000
28/09/25	44.86	39.32	5.54	0.00	0.00	0.00	0.00	0.00	6.23	6.09	0.000	24	0	*	0.0000
29/09/25	47.27	40.04	7.23	0.00	0.00	0.00	0.00	0.00	6.17	6.07	0.000	24	0	*	0.0000
30/09/25	56.79	46.46	10.33	0.00	0.00	0.00	0.00	0.00	6.59	6.53	0.000	24	0	*	0.0000
01/10/25	50.61	43.13	7.48	0.00	0.00	0.00	0.00	0.00	6.68	6.57	0.000	24	0	*	0.0000
02/10/25	47.55	41.26	6.29	0.00	0.00	0.00	0.00	0.00	6.78	6.64	0.000	24	0	*	0.0000
03/10/25	48.94	42.29	6.65	0.00	0.00	0.00	0.00	0.00	6.83	6.69	0.000	24	0	*	0.0000
04/10/25	51.05	43.81	7.24	0.00	0.00	0.00	0.00	0.00	6.85	6.71	0.000	24	0	*	0.0000
05/10/25	51.59	44.38	7.21	0.00	0.00	0.00	0.00	0.00	6.91	6.76	0.000	24	0	*	0.0000
06/10/25	47.69	41.53	6.16	0.00	0.00	0.00	0.00	0.00	6.76	6.66	0.000	24	0	*	0.0000
07/10/25	43.91	38.47	5.44	114.51	113.45	115.48	114.66	-1.21	6.68	6.60	0.615	24	0	*	0.0000
08/10/25	43.83	38.48	5.35	257.51	255.21	259.77	257.97	-2.76	6.64	6.56	1.363	24	0		0.0000
09/10/25	43.41	38.16	5.25	257.14	254.86	259.45	257.71	-2.85	6.64	6.56	1.337	24	0		0.0000
10/10/25	43.54	38.28	5.26	257.14	254.85	259.51	257.75	-2.90	6.57	6.49	1.337	24	0		0.0000
11/10/25	43.52	38.24	5.28	257.02	254.72	259.36	257.66	-2.94	6.64	6.56	1.342	24	0		0.0000
12/10/25	43.12	37.84	5.28	256.67	254.41	258.88	257.13	-2.72	6.63	6.55	1.341	24	0		0.0000
13/10/25	42.76	37.51	5.25	255.86	253.66	258.11	256.43	-2.77	6.62	6.54	1.328	24	0		0.0000
14/10/25	44.85	39.03	5.82	264.18	261.71	266.44	264.56	-2.85	6.68	6.59	1.522	24	0		0.0000
15/10/25	47.73	41.34	6.39	273.80	270.91	276.15	273.92	-3.01	6.78	6.68	1.730	24	0		0.0000
16/10/25	46.89	40.56	6.33	271.25	268.50	273.52	271.39	-2.89	6.93	6.83	1.698	24	0		0.0000
17/10/25	47.23	40.82	6.41	272.05	269.19	274.37	272.26	-3.07	6.92	6.81	1.722	24	0		0.0000
18/10/25	46.32	40.06	6.26	268.37	265.68	270.64	268.64	-2.96	6.67	6.58	1.659	24	0		0.0000
19/10/25	45.56	39.56	6.00	266.16	263.61	268.47	266.49	-2.88	6.66	6.57	1.580	24	0		0.0000
20/10/25	46.18	40.00	6.18	268.29	265.61	270.56	268.56	-2.95	6.70	6.60	1.641	24	0		0.0000
Итого:				3539.9	3506.37	3570.7	3545.13	-38.76			20.215	638	0		0.0000
Средние:	44.50	30.59	13.91						8.67	-2.40					

Период нормальной работы 638ч

Период отсутств.счета тепл.энергии 0ч

Время работы прибора после сброса 629ч

Представитель абонента

Представитель теплоснабж.организации

34 мкр 2

ОТЧЕТ
о суточных параметрах теплоснабжения
за 08/10/25г.-20/10/25г.

Абонент:34-25
Адрес:г. Октябрьский, 34 мкр д.25
Договор N:000000000
Тепловычислитель ТВ7-04.1М сет.N 001
Договорные расходы:
М сет.воды=_____т.сут Мгвс=_____ т.сут
txb: не исп.

Тип расходомера:_____
Пределы измерений:
G1 max = 72.00 м3/ч G1 min = 0.30 м3/ч
G2 max = 72.00 м3/ч G2 min = 0.30 м3/ч

Серийный номер 22170988, БД=1, ТВ1, СИ=6, КТ3=0, ФРТ=0 KCH=0xBF82

Дата/время	t1 °C	t2 °C	dt °C	P1 кгс/см2	P2 кгс/см2	V1 м3	V2 м3	M1 т	M2 т	dM т	Qтв Гкал	ДП м3	ВНР ч	ВОС ч	НС
08.10.25 23	43.43	38.59	4.83	5.40	5.12	126.015	124.370	124.934	123.549	1.385	0.604	0.000 <	15	0	
09.10.25 23	43.25	38.38	4.87	5.40	5.12	211.572	208.830	209.774	207.472	2.302	1.021	0.000 <	24	0	
10.10.25 23	43.37	38.53	4.84	5.33	5.05	211.765	209.020	209.964	207.651	2.313	1.015	0.000 <	24	0	
11.10.25 23	43.35	38.49	4.86	5.41	5.13	211.663	208.935	209.851	207.565	2.286	1.020	0.000 <	24	0	
12.10.25 23	42.97	38.10	4.87	5.39	5.12	211.255	208.560	209.482	207.217	2.265	1.020	0.000 <	24	0	
13.10.25 23	42.60	37.74	4.86	5.38	5.10	210.607	207.935	208.878	206.627	2.251	1.015	0.000 <	24	0	
14.10.25 23	44.62	39.30	5.31	5.45	5.16	217.605	214.792	215.621	213.302	2.318	1.146	0.000 <	24	0	
15.10.25 23	47.55	41.65	5.90	5.56	5.24	225.865	222.860	223.516	221.115	2.401	1.318	0.000 <	24	0	
16.10.25 23	46.69	40.84	5.85	5.71	5.40	223.577	220.625	221.341	218.970	2.371	1.295	0.000 <	24	0	
17.10.25 23	47.18	41.18	6.00	5.75 <	5.47 <	194.792	192.208	192.787	190.734	2.053	1.157	0.000 <	24	0	*
18.10.25 23	46.12	40.29	5.83	5.44	5.14	221.330	218.410	219.177	216.822	2.354	1.279	0.000 <	24	0	
19.10.25 23	45.38	39.80	5.58	5.43	5.13	219.365	216.505	217.298	214.969	2.329	1.212	0.000 <	24	0	
20.10.25 23	45.99	40.18	5.80	5.47	5.17	214.600	210.853	212.521	209.321	3.200	1.233	0.000 <	24	0	
Итого/Средн	44.87	39.51	5.36	5.47	5.18	2700.012	2663.903	2675.142	2645.313	29.829	14.336	0.000	303	0	

Итоговое потребление на начало и конец периода:

Дата/время	V1 м3	V2 м3	M1 т	M2 т	dM т	Qтв Гкал	ДП м3	ВНР ч	ВОС ч
08.10.25 08	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0	0
20.10.25 23	2700.013	2663.902	2675.142	2645.313	29.829	14.336	0.000	303	0
Итого	2700.013	2663.902	2675.142	2645.313	29.829	14.336	0.000	303	0

Условные обозначения:
(<) параметр < min
(>) параметр > max
(!) отсут.питания
(#) дисбаланс масс
(R) реверс
(o) отсут.теплонос.
(X) аппарат.неиспр.

Представитель абонента _____ Представитель снабжающей организации _____

Тип теплосчётчика:
 Номер теплосчётчика:
 Номер абонента:
 Адрес установки:
 Система

ТЭМ-106
 3060225
 34 мкр дом 7 1 ввод
 Р-Подача

	ДУ	Gmin, м³/ч	Gmax, м³/ч	Kv, л/имп.	Fmax КГц
1	50	0,180	60,0	---	---
2	50	0,177	59,0	---	---

Q = M1(h1 - h2)

**Ведомость учёта параметров теплопотребления.
 Среднесуточные статистические данные
 с 23.09.25 по 20.10.25**

Дата	Энергия Q, Гкал	Масса, т				Температура, °C		Давление, МПа		Время наработки Тнар, ч
		M1	M2	M1-M2		t1	t2	P1	P2	
				-	+					
23.09	---	0,2	0,8	0,6	---	20,15	20,36	0,03	0,50	24,00
24.09	---	0,1	0,8	0,7	---	20,67	20,85	0,03	0,50	24,00
25.09	---	0,2	0,8	0,7	---	20,75	20,90	0,03	0,50	24,00
26.09	0,193	25,7	24,7	---	1,0	45,24	37,74	0,20	0,50	24,00
27.09	0,268	41,6	41,5	---	0,1	44,66	38,23	0,52	0,50	24,00
28.09	0,485	81,5	81,8	0,3	---	44,78	38,83	0,52	0,50	24,00
29.09	0,604	78,2	77,9	---	0,3	46,43	38,70	0,52	0,50	24,00
Итого:	1,55	227,6	228,4	2,2	1,5	45,32	38,51	0,26	0,50	168,00
30.09	0,954	76,4	76,5	0,1	---	56,59	44,11	0,57	0,50	24,00
01.10	0,846	82,0	81,7	---	0,3	50,86	40,55	0,57	0,50	24,00
02.10	0,796	82,8	82,1	---	0,7	47,40	37,79	0,58	0,50	24,00
03.10	0,861	93,5	93,7	0,3	---	48,90	39,70	0,59	0,50	24,00
04.10	1,024	110,5	110,4	---	0,0	50,93	41,68	0,59	0,50	24,00
05.10	1,038	111,7	111,7	---	0,1	51,49	42,22	0,59	0,50	24,00
06.10	0,843	103,5	103,5	---	---	48,31	40,18	0,58	0,50	24,00
Итого:	6,36	660,4	659,6	0,4	1,1	50,53	40,91	0,58	0,50	168,00
07.10	0,664	95,8	96,1	0,3	---	43,42	36,49	0,57	0,50	24,00
08.10	0,666	95,4	95,7	0,3	---	43,81	36,84	0,57	0,50	24,00
09.10	0,650	95,3	95,6	0,3	---	43,37	36,56	0,57	0,50	24,00
10.10	0,650	95,4	95,6	0,3	---	43,46	36,66	0,56	0,50	24,00
11.10	0,654	95,3	95,6	0,3	---	43,45	36,59	0,57	0,50	24,00
12.10	0,656	95,2	95,4	0,2	---	43,14	36,26	0,57	0,50	24,00
13.10	0,648	94,8	95,1	0,3	---	42,72	35,89	0,57	0,50	24,00
Итого:	4,59	667,2	669,1	1,9	0,0	43,34	36,47	0,57	0,50	168,00
14.10	0,729	98,2	98,5	0,3	---	44,52	37,10	0,57	0,50	24,00
15.10	0,849	103,2	103,4	0,2	---	47,74	39,52	0,58	0,50	24,00
16.10	0,829	102,3	102,5	0,2	---	46,79	38,70	0,60	0,50	24,00
17.10	0,845	102,6	102,7	0,2	---	47,19	38,96	0,60	0,50	24,00
18.10	0,811	100,7	100,9	0,1	---	46,23	38,18	0,57	0,50	24,00
19.10	0,778	99,5	99,7	0,2	---	45,55	37,74	0,57	0,50	24,00
20.10	0,802	100,4	100,7	0,3	---	46,09	38,11	0,58	0,50	24,00
Итого:	5,64	707,0	708,4	1,4	0,0	46,32	38,34	0,58	0,50	168,00
	---	---	---	---	---	---	---	---	---	---
	---	---	---	---	---	---	---	---	---	---
	---	---	---	---	---	---	---	---	---	---
Итого:	0,00	0,0	0,0	0,0	0,0	---	---	---	---	0,00
Итого:	18,14	2262,2	2265,6	5,9	2,6	46,57	38,54	0,50	0,50	672,0

dT= 8,03

Общее время работы теплосистемы, ч	672,0	=	Тнар, ч + Тmax, ч + Тmin, ч + Тdt, ч + Ттех.н, ч
	672,0	=	672,0 0,0 0,0 0,0 0,0
Количество тепла, Гкал	Q =	Q т/с +	Qmin + Qmax + Qош. + Qt/в + Qсан.ут.
		18,14	
Показания интеграторов	На 24:00 22.09.25	На 24:00 20.10.25	Результат за период На 15:36 21.10.2025
Количество теплоты, Гкал	4095,41	4113,55	18,14 4114,08
Расход теплоносителя M1, т	391486,7	393748,9	2262,2 393814,4
Расход теплоносителя M2, т	374038,0	376303,6	2265,6 376369,2
Время наработки, ч	90553,2	91225,2	672,0 91240,8
Время неработы Тнер = Тmax + Тmin + Тdt + Ттех.н, ч			0,0

Представитель абонента _____ Представитель теплосети _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 34 микрорайон, 28
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00175254

БД=1, ТВ1, СИ=1, КТЗ=1, ФРТ=0, КСН=0х7BF7

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Мг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	17.87	18.46	-0.59	0.000	0.000	0.000	0.000	0.000	7.00	7.00	0.0000	0.0	24.0
21.09.25	17.81	18.34	-0.53	0.000	0.000	0.000	0.000	0.000	7.00	7.00	0.0000	0.0	24.0
22.09.25	18.35	18.93	-0.58	0.000	0.000	0.000	0.000	0.000	7.00	7.00	0.0000	0.0	24.0
23.09.25	18.71	19.31	-0.60	0.000	0.000	0.000	0.000	0.000	7.00	7.00	0.0000	0.0	24.0
24.09.25	19.19	19.80	-0.61	0.000	0.000	0.000	0.000	0.000	7.00	7.00	0.0000	0.0	24.0
25.09.25	18.26	18.76	-0.50	0.000	0.000	0.000	0.000	0.000	3.51	7.00	0.0000	0.0	24.0
26.09.25	43.70	38.38	5.32	104.920	103.800	103.960	103.100	0.860	1.04	7.00	0.5430	0.0	24.0
27.09.25	44.12	39.07	5.05	183.320	181.910	181.610	180.640	0.970	1.06	7.00	0.8920	0.0	24.0
28.09.25	43.92	38.83	5.09	181.420	179.640	179.740	178.430	1.310	1.06	7.00	0.8910	0.0	24.0
29.09.25	46.24	39.84	6.40	174.560	172.100	172.760	170.840	1.920	1.05	5.76	1.0860	0.0	24.0
30.09.25	55.58	46.37	9.21	172.280	169.860	169.800	168.140	1.660	1.06	1.07	1.5630	0.0	24.0
01.10.25	49.22	42.78	6.44	191.810	188.600	189.570	186.910	2.660	1.06	1.06	1.2180	0.0	24.0
02.10.25	46.60	41.18	5.42	205.120	201.360	202.980	199.680	3.300	1.06	1.06	1.0990	0.0	24.0
03.10.25	48.02	42.36	5.66	207.880	204.200	205.610	202.430	3.180	1.06	1.07	1.1610	0.0	24.0
04.10.25	50.01	43.98	6.03	211.740	207.970	209.180	206.050	3.130	1.06	1.07	1.2610	0.0	24.0
05.10.25	50.66	44.59	6.07	213.750	209.680	211.130	207.710	3.420	1.06	1.07	1.2790	0.0	24.0
06.10.25	47.01	41.77	5.24	199.030	194.530	196.940	192.860	4.080	1.06	1.07	1.0320	0.0	24.0
07.10.25	42.80	38.25	4.55	188.240	183.500	186.560	182.250	4.310	1.06	1.07	0.8460	0.0	24.0
08.10.25	43.08	38.56	4.52	187.860	182.980	186.180	181.660	4.520	1.06	1.07	0.8380	0.0	24.0
09.10.25	42.67	38.24	4.43	187.590	182.390	185.910	181.160	4.750	1.06	1.07	0.8270	0.0	24.0
10.10.25	42.80	38.38	4.42	187.740	182.190	186.060	180.930	5.130	1.06	1.07	0.8210	0.0	24.0
11.10.25	42.79	38.28	4.51	187.920	182.150	186.240	180.950	5.290	1.06	1.07	0.8380	0.0	24.0
12.10.25	42.36	37.86	4.50	187.670	181.630	186.040	180.390	5.650	1.06	1.07	0.8350	0.0	24.0
13.10.25	42.03	37.53	4.50	187.220	180.990	185.600	179.790	5.810	1.06	1.07	0.8330	0.0	24.0
14.10.25	44.11	39.21	4.90	193.580	187.070	191.740	185.680	6.060	1.06	1.07	0.9380	0.0	24.0
15.10.25	46.90	41.51	5.39	200.580	193.680	198.500	192.090	6.410	1.06	1.07	1.0670	0.0	24.0
16.10.25	46.08	40.74	5.34	198.700	191.560	196.690	190.050	6.640	1.06	1.07	1.0490	0.0	24.0
17.10.25	46.32	40.92	5.40	199.230	191.860	197.150	190.300	6.850	1.06	1.07	1.0630	0.0	24.0
18.10.25	45.50	40.20	5.30	196.380	188.820	194.460	187.380	7.080	1.06	1.07	1.0270	0.0	24.0
19.10.25	44.77	39.67	5.10	194.800	187.020	192.910	185.580	7.330	1.06	1.07	0.9820	0.0	24.0
20.10.25	45.34	40.13	5.21	196.350	188.360	194.430	186.920	7.510	1.06	1.07	1.0110	0.0	24.0
Итого	---	---	---	4739.6	4617.8	4691.75	4581.92	109.830	---	---	25.0000	0.0	744.0
Среднее	40.41	36.20	4.21	---	---	---	---	---	2.10	2.94	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Мг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	0	0	0	0	0	0	0	0
20.10.25 24:00	48384.659	65600.379	47757.730	65131.400	341.9350	-17373.670	1920.0	11534.0
Итого за период	48384.659	65600.379	47757.730	65131.400	341.9350	---	1920.0	11534.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ОТЧЕТ
о суточных параметрах теплоснабжения
06/10/25г.-20/10/25г.

Абонент: _____

Договор N: _____

Адрес: 35 мкр дом 26

Тип расходомера: _____

Тепловычислитель ВКТ-7 сет. N 001

Пределы измерений:

Договорные расходы:

G под max = 140.00 м3/ч G под min = 0.42 м3/ч

M сет. воды = _____ т.сут M ГВС = _____ т.сут

G обр max = 140.00 м3/ч G обр min = 0.42 м3/ч

Тхв = 0.00 °C

Заводской номер 00179205

ВВОД 1

СХЕМА ПОДКЛЮЧЕНИЯ 3

БД 1

ФТ=0

ТЗ=0

КС=0x8A04

по 2.7

Дата	t1	t2	dt	V1	M1	V2	M2	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	т	м3	т	т	кг/см2	кг/см2	Гкал	ч	ч	
06/10/25	49.55	43.44	6.11	177.85	175.82	177.85	176.28	-0.46	144.12	232.57	1.073	45	24	*
07/10/25	47.31	41.75	5.56	320.65	317.30	320.65	318.03	-0.73	6.20	6.00	1.761	24	0	*
08/10/25	46.42	41.11	5.31	316.33	313.13	316.33	313.81	-0.68	6.20	6.00	1.657	24	0	*
09/10/25	46.00	40.76	5.24	315.86	312.73	315.86	313.37	-0.64	6.20	6.00	1.638	24	0	*
10/10/25	46.15	40.96	5.19	320.00	316.79	320.00	317.47	-0.68	6.20	6.00	1.642	24	0	*
11/10/25	46.14	40.97	5.17	325.59	322.32	325.59	323.01	-0.69	6.20	6.00	1.662	24	0	*
12/10/25	45.80	40.60	5.20	324.61	321.42	324.61	322.10	-0.68	6.20	6.00	1.669	24	0	*
13/10/25	45.40	40.25	5.15	322.94	319.79	322.94	320.46	-0.67	6.20	6.00	1.645	24	0	*
14/10/25	47.87	42.25	5.62	336.08	332.45	336.08	333.25	-0.80	6.20	6.00	1.869	24	0	*
15/10/25	49.02	43.09	5.93	342.37	338.52	342.37	339.38	-0.86	6.20	6.00	2.005	24	0	*
16/10/25	50.35	44.15	6.20	350.83	346.67	350.83	347.62	-0.95	6.20	6.00	2.148	24	0	*
17/10/25	50.60	44.37	6.23	351.54	347.34	351.54	348.27	-0.93	6.20	6.00	2.162	24	0	*
18/10/25	49.74	43.60	6.14	345.26	341.28	345.26	342.17	-0.89	6.20	6.00	2.095	24	0	*
19/10/25	48.73	42.85	5.88	340.73	336.95	340.73	337.78	-0.83	6.20	6.00	1.974	24	0	*
20/10/25	49.53	43.50	6.03	344.59	340.68	344.59	341.51	-0.83	6.20	6.00	2.050	24	0	*
Итого:				4835.2	4783.19	4835.2	4794.51	-11.32			27.050	381	24	
Средние:	47.90	42.24	5.66						15.39	21.10				

Период нормальной работы 381ч
Период отсутств.счета тепл.энергии 24ч
Время работы прибора после сброса 365ч

Представитель абонента

Представитель теплоснабж.организации

Отчет о потреблении...
от 21-10-2025
За период с 11-10-2025 00:00:00 по 21-10-2025 00:00:00

Потребитель :
Адрес :
Объект :
Прибор :
Назначение :

ОАО "Жилуправление"
35мкр 27
Жилой дом
ИМ 2300 N BA725
Теплосчетчик с ЧД расхода для ЦО и ГВС

Канал	Qt1	T1	Gm1	T2	Gm2	tm1	ts1
Един.измерения.	Гкал	град.С	тонн	град.С	тонн	час:мин	час:мин
Макс.предел	1000000	150	1000000	150	1000000	1000000	1000000
Миним.предел	0	0	0	0	0	0	0

Отчетные данные поинтервально (за 1 сут.)

Дата, время							
11-10-2025 00:00:00	-	-	-	-	-	-	-
12-10-2025 00:00:00	3.23	44.52	505.51	38.12	492.78	24:00	24:00
13-10-2025 00:00:00	3.27	44.24	500.07	37.67	489.21	24:00	24:00
14-10-2025 00:00:00	3.32	43.99	501.34	37.36	489.10	24:00	24:00
15-10-2025 00:00:00	3.90	47.36	513.31	39.76	500.47	24:00	24:00
16-10-2025 00:00:00	4.14	48.79	517.18	40.76	503.98	24:00	24:00
17-10-2025 00:00:00	4.45	49.93	522.74	41.40	509.25	24:00	24:00
18-10-2025 00:00:00	4.54	50.49	524.16	41.81	510.60	24:00	24:00
19-10-2025 00:00:00	4.41	49.84	520.62	41.34	508.19	24:00	24:00
20-10-2025 00:00:00	4.27	49.43	521.35	41.22	507.94	24:00	24:00
21-10-2025 00:00:00	4.37	49.83	522.87	41.45	509.20	24:00	24:00

Итого за отчетный период:

часов:минут	Гкал	град.С	тонн	град.С	тонн	час:мин	час:мин
240:00	39.91	47.84	5149.13	40.09	5020.72	240:00	240:00

Отв. лицо :

Начальник СпОКПУ

Морозов И.Е.

ОТЧЕТ
о суточных параметрах теплоснабжения
19/09/25г.-20/10/25г.

Абонент: _____	Договор N: _____
Адрес: 35 мкр дом 9 1 ввод	Тип расходомера: _____
Тепловычислитель ВКТ-7 сет. N 001	Пределы измерений:
Договорные расходы:	G под max = 120.00 м3/ч G под min = 0.32
м3/ч	
M сет. воды= _____ т.сут Mгвс= _____ т.сут	G обр max = 120.00 м3/ч G обр min = 0.32
м3/ч	
Tхв= 0.00°C	G3 max = 7.00 м3/ч G3 min = 0.14
м3/ч	

Заводской номер 00173721 ВВОД 1 СХЕМА ПОДКЛЮЧЕНИЯ 3 БД 1 ФТ=0 Т3=1 КС=

0хF87B ПО 2.7

Дата	t1	t2	dt	V1	M1	V2	M2	V3	Mг	P1	P2	Qo
ВНР	ВОС	НС										

	°C	°C	°C	м3	т	м3	т	м3	т	кг/см2	кг/см2

Гкал	ч	ч									

19/09/25 17.93 18.30 -0.37 0.00 0.00 0.00 0.00 0.00 0.00 6.90 6.70
0.000 24 0 *
20/09/25 18.04 18.47 -0.43 0.00 0.00 0.00 0.00 0.00 0.00 6.90 6.70
0.000 24 0 *
21/09/25 18.11 18.51 -0.40 0.00 0.00 0.00 0.00 0.00 0.00 6.90 6.70
0.000 24 0 *
22/09/25 18.54 19.06 -0.52 0.00 0.00 0.00 0.00 0.00 0.00 6.90 6.70
0.000 24 0 *
23/09/25 19.01 19.48 -0.47 0.00 0.00 0.00 0.00 0.00 0.00 6.90 6.70
0.000 24 0 *
24/09/25 19.86 20.30 -0.44 0.00 0.00 0.00 0.00 0.00 0.00 6.90 6.70
0.000 24 0 *
25/09/25 31.98 30.58 1.40 100.59 100.12 101.41 100.98 0.00 -0.86 6.90 6.70
0.139 24 0 *
26/09/25 37.87 34.53 3.34 204.35 202.93 203.68 202.54 0.00 0.39 6.90 6.70
0.675 24 0 *
27/09/25 44.64 38.57 6.07 131.03 129.83 130.51 129.55 0.00 0.28 6.90 6.70
0.788 24 0 *
28/09/25 45.29 38.65 6.64 126.50 125.30 125.93 125.00 0.00 0.30 6.90 6.70
0.833 24 0 *
29/09/25 44.75 37.57 7.18 116.55 115.45 115.97 115.19 0.00 0.26 6.90 6.70
0.825 24 0 *
30/09/25 44.69 37.18 7.51 123.85 122.65 123.19 122.47 0.00 0.18 6.90 6.70
0.920 24 0 *
01/10/25 46.25 37.95 8.30 131.53 130.23 130.82 129.99 0.00 0.24 6.90 6.70
1.078 24 0 *
02/10/25 49.37 40.39 8.98 135.53 134.03 134.92 133.96 0.00 0.07 6.90 6.70
1.201 24 0 *
03/10/25 50.13 41.11 9.02 136.48 134.82 136.04 134.96 0.00 -0.14 6.90 6.70
1.215 24 0 *
04/10/25 50.63 41.43 9.20 136.51 134.83 136.37 135.24 0.00 -0.41 6.90 6.70
1.239 24 0 *
05/10/25 49.94 41.19 8.75 134.48 132.89 134.85 133.73 0.00 -0.84 6.90 6.70
1.161 24 0 *
06/10/25 45.52 38.02 7.50 126.03 124.75 126.69 125.88 0.00 -1.13 6.90 6.70
0.933 24 0 *
07/10/25 43.73 36.84 6.89 124.13 122.93 124.91 124.18 0.00 -1.25 6.90 6.70
0.844 24 0 *
08/10/25 43.90 37.02 6.88 122.61 121.45 123.43 122.71 0.00 -1.26 6.90 6.70
0.833 24 0 *

09/10/25	43.57	36.71	6.86	122.33	121.21	123.17	122.45	0.00	-1.24	6.90	6.70	
0.833	24	0	*									
10/10/25	43.62	36.84	6.78	121.91	120.80	122.83	122.11	0.00	-1.31	6.90	6.70	
0.819	24	0	*									
11/10/25	43.67	36.89	6.78	122.00	120.88	122.94	122.22	0.00	-1.34	6.90	6.70	
0.817	24	0	*									
12/10/25	43.39	36.51	6.88	122.01	120.95	122.97	122.25	0.00	-1.30	6.90	6.70	
0.830	24	0	*									
13/10/25	43.14	36.26	6.88	121.91	120.89	122.88	122.16	0.00	-1.27	6.90	6.70	
0.833	24	0	*									
14/10/25	46.51	38.61	7.90	127.48	126.15	128.45	127.58	0.00	-1.43	6.90	6.70	
0.992	24	0	*									
15/10/25	47.88	39.63	8.25	129.06	127.62	130.03	129.07	0.00	-1.45	6.90	6.70	
1.051	24	0	*									
16/10/25	48.98	40.25	8.73	131.60	130.15	132.55	131.59	0.00	-1.44	6.90	6.70	
1.133	24	0	*									
17/10/25	49.53	40.61	8.92	132.19	130.71	133.13	132.17	0.00	-1.46	6.90	6.70	
1.163	24	0	*									
18/10/25	48.94	40.16	8.78	131.49	130.05	132.44	131.48	0.00	-1.43	6.90	6.70	
1.138	24	0	*									
19/10/25	48.56	40.04	8.52	132.55	131.11	133.52	132.56	0.00	-1.45	6.90	6.70	
1.117	24	0	*									
20/10/25	48.93	40.25	8.68	131.57	130.13	132.57	131.61	0.00	-1.48	6.90	6.70	
1.129	24	0	*									

Итого:				3376.2	3342.86	3386.2	3363.63	0.00	-20.77			
24.539	768	0										

Средние:	40.52	34.62	5.90							6.90	6.70	

Период нормальной работы 768ч

Период отсутств.счета тепл.энергии 0ч

Время работы прибора после сброса 10950ч

Представитель абонента

Представитель теплоснабж.организации

35 мкр 9 1ввод

ОТЧЕТ
о суточных параметрах теплоснабжения
19/09/25г.-20/10/25г.

Абонент: _____ Договор N: _____
 Адрес: 35 мкр дом 9 1 ввод Тип расходомера: _____
 Тепловычислитель ВКТ-7 сет. N 001 Пределы измерений: _____
 Договорные расходы: G под max = 120.00 м3/ч G под min = 0.32 м3/ч
 M сет. воды = _____ т.сут M ГВС = _____ т.сут G обр max = 120.00 м3/ч G обр min = 0.32 м3/ч
 Тхв = 0.00 °C G3 max = 7.00 м3/ч G3 min = 0.14 м3/ч

Заводской номер 00173721 ВВОД 1 СХЕМА ПОДКЛЮЧЕНИЯ 3 БД 1 ФТ=0 ТЗ=1 КС=0x87B по 2.7

Дата	t1	t2	dt	V1	M1	V2	M2	V3	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	т	м3	т	м3	т	кг/см2	кг/см2	Гкал	ч	ч	
19/09/25	17.93	18.30	-0.37	0.00	0.00	0.00	0.00	0.00	0.00	6.90	6.70	0.000	24	0	*
20/09/25	18.04	18.47	-0.43	0.00	0.00	0.00	0.00	0.00	0.00	6.90	6.70	0.000	24	0	*
21/09/25	18.11	18.51	-0.40	0.00	0.00	0.00	0.00	0.00	0.00	6.90	6.70	0.000	24	0	*
22/09/25	18.54	19.06	-0.52	0.00	0.00	0.00	0.00	0.00	0.00	6.90	6.70	0.000	24	0	*
23/09/25	19.01	19.48	-0.47	0.00	0.00	0.00	0.00	0.00	0.00	6.90	6.70	0.000	24	0	*
24/09/25	19.86	20.30	-0.44	0.00	0.00	0.00	0.00	0.00	0.00	6.90	6.70	0.000	24	0	*
25/09/25	31.98	30.58	1.40	100.59	100.12	101.41	100.98	0.00	-0.86	6.90	6.70	0.139	24	0	*
26/09/25	37.87	34.53	3.34	204.35	202.93	203.68	202.54	0.00	0.39	6.90	6.70	0.675	24	0	*
27/09/25	44.64	38.57	6.07	131.03	129.83	130.51	129.55	0.00	0.28	6.90	6.70	0.788	24	0	*
28/09/25	45.29	38.65	6.64	126.50	125.30	125.93	125.00	0.00	0.30	6.90	6.70	0.833	24	0	*
29/09/25	44.75	37.57	7.18	116.55	115.45	115.97	115.19	0.00	0.26	6.90	6.70	0.825	24	0	*
30/09/25	44.69	37.18	7.51	123.85	122.65	123.19	122.47	0.00	0.18	6.90	6.70	0.920	24	0	*
01/10/25	46.25	37.95	8.30	131.53	130.23	130.82	129.99	0.00	0.24	6.90	6.70	1.078	24	0	*
02/10/25	49.37	40.39	8.98	135.53	134.03	134.92	133.96	0.00	0.07	6.90	6.70	1.201	24	0	*
03/10/25	50.13	41.11	9.02	136.48	134.82	136.04	134.96	0.00	-0.14	6.90	6.70	1.215	24	0	*
04/10/25	50.63	41.43	9.20	136.51	134.83	136.37	135.24	0.00	-0.41	6.90	6.70	1.239	24	0	*
05/10/25	49.94	41.19	8.75	134.48	132.89	134.85	133.73	0.00	-0.84	6.90	6.70	1.161	24	0	*
06/10/25	45.52	38.02	7.50	126.03	124.75	126.69	125.88	0.00	-1.13	6.90	6.70	0.933	24	0	*
07/10/25	43.73	36.84	6.89	124.13	122.93	124.91	124.18	0.00	-1.25	6.90	6.70	0.844	24	0	*
08/10/25	43.90	37.02	6.88	122.61	121.45	123.43	122.71	0.00	-1.26	6.90	6.70	0.833	24	0	*
09/10/25	43.57	36.71	6.86	122.33	121.21	123.17	122.45	0.00	-1.24	6.90	6.70	0.833	24	0	*
10/10/25	43.62	36.84	6.78	121.91	120.80	122.83	122.11	0.00	-1.31	6.90	6.70	0.819	24	0	*
11/10/25	43.67	36.89	6.78	122.00	120.88	122.94	122.22	0.00	-1.34	6.90	6.70	0.817	24	0	*
12/10/25	43.39	36.51	6.88	122.01	120.95	122.97	122.25	0.00	-1.30	6.90	6.70	0.830	24	0	*
13/10/25	43.14	36.26	6.88	121.91	120.89	122.88	122.16	0.00	-1.27	6.90	6.70	0.833	24	0	*
14/10/25	46.51	38.61	7.90	127.48	126.15	128.45	127.58	0.00	-1.43	6.90	6.70	0.992	24	0	*
15/10/25	47.88	39.63	8.25	129.06	127.62	130.03	129.07	0.00	-1.45	6.90	6.70	1.051	24	0	*
16/10/25	48.98	40.25	8.73	131.60	130.15	132.55	131.59	0.00	-1.44	6.90	6.70	1.133	24	0	*
17/10/25	49.53	40.61	8.92	132.19	130.71	133.13	132.17	0.00	-1.46	6.90	6.70	1.163	24	0	*
18/10/25	48.94	40.16	8.78	131.49	130.05	132.44	131.48	0.00	-1.43	6.90	6.70	1.138	24	0	*
19/10/25	48.56	40.04	8.52	132.55	131.11	133.52	132.56	0.00	-1.45	6.90	6.70	1.117	24	0	*
20/10/25	48.93	40.25	8.68	131.57	130.13	132.57	131.61	0.00	-1.48	6.90	6.70	1.129	24	0	*
Итого:				3376.2	3342.86	3386.2	3363.63	0.00	-20.77			24.539	768	0	
Средние:	40.52	34.62	5.90							6.90	6.70				

35 мкр 9 1ввод

Период нормальной работы 768ч

Период отсутств.счета тепл.энергии 0ч

Время работы прибора после сброса 10950ч

Представитель абонента

Представитель теплоснабж.организации

**ИМ2300, Суточный
с 21.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 13
 Потребитель: АО "Жилуправление"
 Прибор: ИМ2300 Заводской номер: ВА768

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	dQt3 (ГКал)	dGm3 (тонн)
21.09.25	0.00	18.47	0.00	18.66	3.72	0.00	24.00	0.00	0.00
22.09.25	0.00	18.44	0.00	18.61	3.66	0.00	24.00	0.00	0.00
23.09.25	0.00	18.48	0.00	18.66	3.60	0.00	24.00	0.00	0.00
24.09.25	0.00	18.66	0.00	18.83	3.55	0.00	24.00	0.00	0.00
25.09.25	0.00	18.83	0.00	18.99	3.49	0.00	24.00	0.00	0.00
26.09.25	0.00	24.71	0.00	24.32	120.62	9.49	24.00	0.00	0.00
27.09.25	0.00	37.59	0.00	35.05	186.75	23.48	24.00	0.00	0.00
28.09.25	0.00	44.50	0.00	39.04	159.08	24.00	24.00	0.00	0.00
29.09.25	0.00	45.17	0.00	39.17	160.65	24.00	24.00	0.00	0.00
30.09.25	0.00	44.67	0.00	38.53	153.83	24.00	24.00	0.00	0.00
01.10.25	0.00	44.63	0.00	37.93	142.53	24.00	24.00	0.00	0.00
02.10.25	0.00	45.71	0.00	38.64	142.46	24.00	24.00	0.00	0.00
03.10.25	0.00	49.12	0.00	41.35	146.33	24.00	24.00	0.00	0.00
04.10.25	0.00	49.95	0.00	42.12	147.26	24.00	24.00	0.00	0.00
05.10.25	0.00	50.42	0.00	42.45	146.96	24.00	24.00	0.00	0.00
06.10.25	0.00	49.97	0.00	42.24	145.04	24.00	24.00	0.00	0.00
07.10.25	0.00	45.58	0.00	38.98	136.06	24.00	24.00	0.00	0.00
08.10.25	0.30	43.56	49.41	37.50	84.18	24.00	24.00	0.00	0.00
09.10.25	0.80	43.77	131.74	37.66	0.00	24.00	24.00	0.00	0.00
10.10.25	0.78	43.45	128.84	37.38	68.05	23.36	23.36	0.00	0.00
11.10.25	0.78	43.44	130.99	37.47	126.22	24.00	24.00	0.00	0.00
12.10.25	0.78	43.49	131.03	37.51	125.96	24.00	24.00	0.00	0.00
13.10.25	0.79	43.32	130.94	37.29	125.71	24.00	24.00	0.00	0.00
14.10.25	0.79	42.99	130.69	36.96	125.28	24.00	24.00	0.00	0.00
15.10.25	0.93	46.00	135.77	39.18	131.27	24.00	24.00	0.00	0.00
16.10.25	0.99	47.66	137.81	40.43	134.07	24.00	24.00	0.00	0.00
17.10.25	1.06	48.74	139.37	41.14	139.67	23.47	23.47	0.00	0.00
18.10.25	1.09	49.40	141.91	41.72	145.54	24.00	24.00	0.00	0.00
19.10.25	1.06	48.75	140.86	41.21	144.40	24.00	24.00	0.00	0.00
20.10.25	1.04	48.46	142.51	41.14	146.11	24.00	24.00	0.00	0.00
Итого	---	---	1671.87	---	3302.05	583.80	718.83	0.00	0.00
Среднее	---	40.598	---	35.339	---	---	---	---	---

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 21.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 40
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00178765

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0хВСЕЕ

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
21.09.25	20.60	20.07	0.53	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
22.09.25	21.14	20.65	0.49	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
23.09.25	21.68	21.17	0.51	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
24.09.25	22.39	21.69	0.70	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
25.09.25	30.06	28.83	1.23	145.820	145.330	145.230	144.770	0.460	6.20	6.00	0.1770	0.0	24.0
26.09.25	33.42	30.93	2.49	226.600	225.530	225.360	224.480	0.880	6.20	6.00	0.5610	0.0	24.0
27.09.25	37.16	33.36	3.80	210.330	209.840	208.930	208.770	0.160	6.20	6.00	0.7940	0.0	24.0
28.09.25	47.62	40.53	7.09	207.850	207.980	205.670	206.320	-0.650	6.20	6.00	1.4550	0.0	24.0
29.09.25	45.80	38.64	7.16	199.380	200.540	197.440	199.130	-1.690	6.20	6.00	1.4050	0.0	24.0
30.09.25	47.87	39.43	8.44	195.240	196.150	193.140	194.700	-1.560	6.20	6.00	1.6270	0.0	24.0
01.10.25	45.72	38.20	7.52	202.240	203.030	200.280	201.680	-1.400	6.20	6.00	1.5030	0.0	24.0
02.10.25	47.95	40.00	7.95	205.760	206.640	203.600	205.090	-1.490	6.20	6.00	1.6150	0.0	24.0
03.10.25	49.13	40.98	8.15	207.190	207.990	204.910	206.350	-1.440	6.20	6.00	1.6690	0.0	24.0
04.10.25	51.01	42.31	8.70	210.010	210.740	207.450	208.990	-1.540	6.20	6.00	1.8030	0.0	24.0
05.10.25	50.10	41.98	8.12	210.610	211.120	208.130	209.340	-1.210	6.20	6.00	1.6860	0.0	24.0
06.10.25	48.55	40.39	8.16	214.730	118.140	212.360	117.210	95.150	6.20	6.00	1.5850	0.0	24.0
07.10.25	47.31	40.40	6.91	213.180	0.000	210.930	0.000	210.930	6.20	6.00	1.4550	0.0	24.0
08.10.25	46.43	39.81	6.62	210.920	0.000	208.830	0.000	208.830	6.20	6.00	1.3800	0.0	24.0
09.10.25	46.01	39.54	6.47	210.570	0.000	208.490	0.000	208.490	6.20	6.00	1.3450	0.0	24.0
10.10.25	46.15	39.68	6.47	210.450	0.000	208.310	0.000	208.310	6.20	6.00	1.3450	0.0	24.0
11.10.25	46.14	39.60	6.54	210.100	0.000	207.980	0.000	207.980	6.20	6.00	1.3600	0.0	24.0
12.10.25	45.82	39.18	6.64	209.620	0.000	207.590	0.000	207.590	6.20	6.00	1.3730	0.0	24.0
13.10.25	45.41	38.75	6.66	208.690	0.000	206.680	0.000	206.680	6.20	6.00	1.3730	0.0	24.0
14.10.25	47.82	40.57	7.25	215.210	0.000	212.880	0.000	212.880	6.20	6.00	1.5370	0.0	24.0
15.10.25	48.97	41.37	7.60	218.500	0.000	216.070	0.000	216.070	6.20	6.00	1.6380	0.0	24.0
16.10.25	50.30	42.30	8.00	223.010	0.000	220.370	0.000	220.370	6.20	6.00	1.7620	0.0	24.0
17.10.25	50.56	42.49	8.07	223.400	0.000	220.740	0.000	220.740	6.20	6.00	1.7770	0.0	24.0
18.10.25	49.70	41.76	7.94	220.130	0.000	217.590	0.000	217.590	6.20	6.00	1.7240	0.0	24.0
19.10.25	48.71	41.16	7.55	217.780	0.000	215.320	0.000	215.320	6.20	6.00	1.6190	0.0	24.0
20.10.25	49.49	41.72	7.77	219.810	0.000	217.320	0.000	217.320	6.20	6.00	1.6860	0.0	24.0
Итого	---	---	---	5447.1	2343.0	5391.60	2326.83	3064.770	---	---	37.2540	0.0	720.0
Среднее	42.96	36.91	6.05	---	---	---	---	---	6.20	6.00	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
20.09.25 24:00	55856.850	54992.090	55036.940	54415.400	491.7500	621.540	1608.0	7568.0
20.10.25 24:00	61303.979	57335.119	60428.539	56742.229	529.0040	3686.310	1608.0	8288.0
Итого за период	5447.129	2343.029	5391.598	2326.828	37.2540	---	0.0	720.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ИМ2300, Суточный с 19.09.25 по 20.10.25

Объект: г. Октябрьский, 21 мкр., 10
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ752

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	15.50	0.00	15.12	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	15.42	0.00	15.04	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	15.46	0.00	15.06	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	15.53	0.00	15.13	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	15.61	0.00	15.20	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	15.76	0.00	15.34	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	15.92	0.00	15.46	0.00	0.00	24.00	0.00	0.00
26.09.25	0.87	41.30	49.66	31.42	46.15	13.02	24.00	0.00	0.00
27.09.25	1.56	64.09	61.56	38.70	59.55	24.00	24.00	0.00	0.00
28.09.25	1.45	62.09	53.96	35.14	52.24	24.00	24.00	0.00	0.00
29.09.25	1.50	64.37	52.85	35.85	51.23	24.00	24.00	0.00	0.00
30.09.25	1.26	50.93	69.12	32.88	67.14	21.45	24.00	0.00	0.00
01.10.25	1.42	51.48	77.77	31.52	75.43	23.84	24.00	0.00	0.00
02.10.25	1.31	52.48	76.10	32.06	74.32	22.33	22.33	0.00	0.00
03.10.25	1.68	42.55	237.09	34.11	236.28	22.80	24.00	0.00	0.00
04.10.25	2.18	47.35	319.86	40.50	319.49	23.38	24.00	0.00	0.00
05.10.25	2.17	47.34	349.21	41.11	349.18	24.00	24.00	0.00	0.00
06.10.25	2.17	47.62	349.33	41.39	350.36	24.00	24.00	0.00	0.00
07.10.25	2.17	47.68	348.08	41.43	351.96	24.00	24.00	0.00	0.00
08.10.25	2.05	46.92	348.01	41.02	350.21	24.00	24.00	0.00	0.00
09.10.25	1.89	45.34	351.05	39.95	351.44	24.00	24.00	0.00	0.00
10.10.25	1.89	45.26	356.10	39.94	356.49	24.00	24.00	0.00	0.00
11.10.25	1.88	45.43	356.06	40.14	360.07	24.00	24.00	0.00	0.00
12.10.25	1.88	45.43	356.29	40.13	359.02	24.00	24.00	0.00	0.00
13.10.25	1.90	45.18	356.31	39.85	360.07	24.00	24.00	0.00	0.00
14.10.25	1.91	45.11	356.28	39.74	360.42	24.00	24.00	0.00	0.00
15.10.25	1.88	45.10	355.91	39.82	358.85	24.00	24.00	0.00	0.00
16.10.25	1.88	44.79	355.70	39.50	357.46	24.00	24.00	0.00	0.00
17.10.25	1.94	44.96	355.82	39.50	358.31	24.00	24.00	0.00	0.00
18.10.25	1.97	45.13	355.75	39.58	357.56	24.00	24.00	0.00	0.00
19.10.25	2.03	45.52	355.78	39.80	359.31	24.00	24.00	0.00	0.00
20.10.25	2.02	45.59	355.74	39.91	357.26	24.00	24.00	0.00	0.00
Итого	44.86	---	6659.39	---	6679.80	582.82	766.33	0.00	0.00
Среднее	---	41.195	---	33.167	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	1918.75	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

ИМ2300, Суточный **с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 21 мкр., 11
 Потребитель: АО "Жилуправление"
 Прибор: ИМ2300 Заводской номер: ВА649

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	0.00	15.81	4.52	15.63	0.00	24.00	24.00	0.00	0.00
22.09.25	0.00	15.73	4.59	15.56	0.00	24.00	24.00	0.00	0.00
23.09.25	0.00	16.06	2.36	16.14	0.00	14.40	24.00	0.00	0.00
24.09.25	0	15.98	0.18	15.73	0.00	24.00	24.00	0.00	0.00
25.09.25	0	16.13	0.01	15.82	0.00	24.00	24.00	0.00	0.00
26.09.25	1.53	41.63	149.62	35.82	141.99	23.59	24.00	0.00	0.00
27.09.25	3.31	66.18	193.41	48.97	184.22	24.00	24.00	0.00	0.00
28.09.25	3.24	64.29	171.12	45.32	163.35	24.00	24.00	0.00	0.00
29.09.25	3.44	66.64	167.71	46.10	159.93	24.00	24.00	0.00	0.00
30.09.25	2.47	55.63	248.69	41.88	241.28	23.50	24.00	0.00	0.00
01.10.25	2.62	52.89	282.14	41.57	276.05	23.50	24.00	0.00	0.00
02.10.25	2.51	52.89	312.43	41.72	305.57	23.42	24.00	0.00	0.00
03.10.25	1.88	43.55	380.29	38.37	374.08	24.00	24.00	0.00	0.00
04.10.25	2.21	48.23	314.47	41.19	308.54	24.00	24.00	0.00	0.00
05.10.25	2.21	48.16	311.75	41.05	306.44	24.00	24.00	0.00	0.00
06.10.25	2.23	48.45	311.90	41.27	306.93	24.00	24.00	0.00	0.00
07.10.25	2.23	48.50	310.61	41.31	305.99	24.00	24.00	0.00	0.00
08.10.25	2.10	47.72	310.37	40.95	305.80	24.00	24.00	0.00	0.00
09.10.25	1.93	46.12	311.42	39.90	306.64	24.00	24.00	0.00	0.00
10.10.25	1.94	46.05	312.39	39.83	307.68	24.00	24.00	0.00	0.00
11.10.25	1.93	46.21	312.44	40.01	307.74	24.00	24.00	0.00	0.00
12.10.25	1.93	46.22	312.34	40.04	307.93	24.00	24.00	0.00	0.00
13.10.25	1.94	45.96	312.53	39.74	308.10	24.00	24.00	0.00	0.00
14.10.25	1.95	45.89	312.78	39.65	308.12	24.00	24.00	0.00	0.00
15.10.25	1.92	45.88	312.60	39.72	307.39	24.00	24.00	0.00	0.00
16.10.25	1.93	45.57	312.30	39.38	302.20	24.00	24.00	0.00	0.00
17.10.25	1.99	45.74	312.35	39.34	293.46	24.00	24.00	0.00	0.00
18.10.25	2.03	45.91	312.31	39.38	230.03	24.00	24.00	0.00	0.00
19.10.25	2.09	46.31	312.42	39.61	281.98	24.00	24.00	0.00	0.00
20.10.25	2.09	46.38	312.51	39.68	155.21	24.00	24.00	0.00	0.00
Итого	55.65	---	7224.56	---	6796.65	708.41	720.00	0.00	0.00
Среднее	---	43.890	---	36.689	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	164.55	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, 21 мкр., 12
Потребитель: АО "Жилуправление"
Прибор: ТВ7-04.1 Заводской номер: 20120949

БД=1, ТВ1, СИ=6, КТЗ=0, ФРТ=0, КСН=0xB7D3

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	16.72	16.47	н/д	0.25	6.12	7.58	н/д	0.010	0.005	н/д	0.010	0.005	н/д	0.005	0	н/д	24	0
20.09.25	16.93	16.71	н/д	0.22	6.12	9.64	н/д	0.000	0.005	н/д	0.000	0.005	н/д	-0.005	0.000	н/д	24	0
21.09.25	16.93	16.70	н/д	0.23	6.12	9.64	н/д	0.000	0.005	н/д	0.000	0.005	н/д	-0.005	0.000	н/д	24	0
22.09.25	16.94	16.70	н/д	0.24	6.12	9.64	н/д	0.000	0.010	н/д	0.000	0.010	н/д	-0.010	0.000	н/д	24	0
23.09.25	17.01	16.76	н/д	0.26	6.12	9.64	н/д	0.000	0.005	н/д	0.000	0.005	н/д	-0.005	0.000	н/д	24	0
24.09.25	17.13	16.85	н/д	0.27	6.12	9.64	н/д	0.000	0.005	н/д	0.000	0.005	н/д	-0.005	0.000	н/д	24	0
25.09.25	64.54	51.66	н/д	12.88	6.12	9.65	н/д	133.415	131.625	н/д	131.523	129.368	н/д	2.155	1.683	н/д	24	0
26.09.25	66.58	49.01	н/д	17.57	6.12	9.65	н/д	178.030	179.515	н/д	176.060	175.947	н/д	0.114	3.077	н/д	24	0
27.09.25	64.21	45.19	н/д	19.02	6.12	9.66	н/д	155.540	157.215	н/д	154.196	154.196	н/д	0.000	2.918	н/д	24	0
28.09.25	66.65	45.90	н/д	20.74	6.12	9.66	н/д	153.050	154.550	н/д	151.530	151.530	н/д	0.000	3.129	н/д	24	0
29.09.25	51.88	40.89	н/д	10.99	6.12	9.65	н/д	212.435	214.685	н/д	211.428	211.413	н/д	0.014	2.302	н/д	24	0
30.09.25	50.50	40.65	н/д	9.85	6.12	9.65	н/д	248.485	249.955	н/д	246.847	246.824	н/д	0.023	2.406	н/д	24	0
01.10.25	49.41	40.54	н/д	8.87	6.12	9.65	н/д	264.610	267.415	н/д	263.532	263.532	н/д	0.000	2.313	н/д	24	0
02.10.25	43.27	37.89	н/д	5.37	6.12	9.65	н/д	343.680	346.930	н/д	342.771	342.771	н/д	0.000	1.807	н/д	24	0
03.10.25	48.21	41.18	н/д	7.03	6.12	9.66	н/д	315.185	318.050	н/д	313.737	313.737	н/д	0.000	2.175	н/д	24	0
04.10.25	48.14	40.94	н/д	7.20	6.12	9.66	н/д	305.760	308.890	н/д	304.552	304.552	н/д	0.000	2.161	н/д	24	0
05.10.25	48.42	41.19	н/д	7.23	6.12	9.66	н/д	302.320	305.270	н/д	301.029	301.029	н/д	0.000	2.148	н/д	24	0
06.10.25	48.49	41.25	н/д	7.25	6.12	9.66	н/д	298.020	301.015	н/д	296.776	296.776	н/д	0.000	2.120	н/д	24	0
07.10.25	47.75	40.82	н/д	6.93	6.12	9.66	н/д	294.145	297.160	н/д	293.024	293.024	н/д	0.000	2.001	н/д	24	0
08.10.25	46.10	39.77	н/д	6.34	6.12	9.66	н/д	295.765	298.220	н/д	294.528	294.528	н/д	0.000	1.837	н/д	24	0
09.10.25	46.02	39.74	н/д	6.29	6.12	9.66	н/д	297.610	300.340	н/д	296.496	296.496	н/д	0.000	1.835	н/д	24	0
10.10.25	46.19	39.93	н/д	6.26	6.12	9.66	н/д	296.830	299.485	н/д	295.662	295.662	н/д	0.000	1.820	н/д	24	0
11.10.25	46.20	39.86	н/д	6.34	6.12	9.66	н/д	296.075	298.260	н/д	294.684	294.684	н/д	0.000	1.838	н/д	24	0
12.10.25	45.94	39.44	н/д	6.50	6.12	9.66	н/д	294.730	296.870	н/д	293.371	293.371	н/д	0.000	1.878	н/д	24	0
13.10.25	45.86	39.35	н/д	6.51	6.12	9.66	н/д	293.645	295.830	н/д	292.322	292.322	н/д	0.000	1.874	н/д	24	0
14.10.25	45.86	39.37	н/д	6.49	6.12	9.66	н/д	292.170	294.580	н/д	290.968	290.968	н/д	0.000	1.858	н/д	24	0
15.10.25	45.55	39.11	н/д	6.44	6.12	9.66	н/д	291.685	294.425	н/д	290.696	290.696	н/д	0.000	1.841	н/д	24	0
16.10.25	45.72	39.04	н/д	6.68	6.12	9.66	н/д	291.210	293.905	н/д	290.204	290.204	н/д	0.000	1.908	н/д	24	0
17.10.25	45.88	39.06	н/д	6.82	6.12	9.66	н/д	291.100	293.580	н/д	289.960	289.960	н/д	0.000	1.948	н/д	24	0
18.10.25	46.29	39.28	н/д	7.01	6.12	9.66	н/д	291.130	293.235	н/д	289.772	289.772	н/д	0.000	2.001	н/д	24	0
19.10.25	46.36	39.40	н/д	6.96	6.12	9.66	н/д	291.065	293.460	н/д	289.841	289.841	н/д	0.000	1.986	н/д	24	0
20.10.25	47.53	40.76	н/д	6.77	6.12	9.66	н/д	300.690	302.740	н/д	298.996	299.094	н/д	-0.098	1.993	н/д	24	0
Итого	---	---	---	---	---	---	---	7028.390	7087.240	---	6994.515	6992.332	---	2.183	54.857	---	768	0
Среднее	48.59	40.64	---	7.94	6.12	9.59	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	72502.260	72970.865	0.000	71827.111	71825.759	0.000	1.352	670.919	0.000	7983	2806
20.10.25 24:00	79530.650	80058.105	0.000	78821.627	78818.093	0.000	3.534	725.777	0.000	8751	2806
Итого за период	7028.390	7087.240	0.000	6994.516	6992.334	0.000	---	54.858	0.000	768	0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ИМ2300, Суточный с 19.09.25 по 20.10.25

Объект: г. Октябрьский, 21 мкр., 13
 Потребитель: АО "Жилуправление"
 Прибор: ИМ2300 Заводской номер: ВВ521

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	0.00	15.38	0.00	15.08	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	15.34	0.00	15.04	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	15.51	0.00	15.21	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	15.66	0.00	15.34	0.00	0.00	24.00	0.00	0.00
25.09.25	0.27	15.89	401.96	15.42	200.12	7.95	24.00	0.00	0.00
26.09.25	1.59	33.52	773.32	28.84	411.10	24.00	24.00	0.00	0.00
27.09.25	3.64	65.37	261.90	51.40	253.68	24.00	24.00	0.00	0.00
28.09.25	3.91	63.34	244.04	47.27	237.18	24.00	24.00	0.00	0.00
29.09.25	4.30	65.74	243.15	48.04	235.88	24.00	24.00	0.00	0.00
30.09.25	3.26	55.42	355.30	42.99	345.82	23.80	24.00	0.00	0.00
01.10.25	3.33	51.66	406.26	41.71	395.80	23.81	24.00	0.00	0.00
02.10.25	3.25	52.55	418.01	42.08	407.21	23.70	24.00	0.00	0.00
03.10.25	2.52	42.77	580.99	38.39	566.02	24.00	24.00	0.00	0.00
04.10.25	3.06	47.53	550.52	41.96	536.11	24.00	24.00	0.00	0.00
05.10.25	3.05	47.46	545.27	41.85	531.17	24.00	24.00	0.00	0.00
06.10.25	3.05	47.74	545.47	42.14	531.24	24.00	24.00	0.00	0.00
07.10.25	3.03	47.81	542.95	42.21	528.83	24.00	24.00	0.00	0.00
08.10.25	2.85	47.09	542.15	41.81	527.97	24.00	24.00	0.00	0.00
09.10.25	2.63	45.46	543.75	40.62	529.64	24.00	24.00	0.00	0.00
10.10.25	2.63	45.38	545.06	40.53	530.72	24.00	24.00	0.00	0.00
11.10.25	2.65	45.54	545.60	40.67	531.40	24.00	24.00	0.00	0.00
12.10.25	2.64	45.55	545.79	40.69	531.45	24.00	24.00	0.00	0.00
13.10.25	2.67	45.30	546.53	40.40	532.18	24.00	24.00	0.00	0.00
14.10.25	2.70	45.22	546.94	40.27	532.58	24.00	24.00	0.00	0.00
15.10.25	2.68	45.20	546.24	40.28	532.07	24.00	24.00	0.00	0.00
16.10.25	2.68	44.91	545.88	39.99	531.71	24.00	24.00	0.00	0.00
17.10.25	2.77	45.07	546.72	39.99	532.47	24.00	24.00	0.00	0.00
18.10.25	2.83	45.23	547.19	40.04	533.00	24.00	24.00	0.00	0.00
19.10.25	2.87	45.63	547.05	40.37	532.80	24.00	24.00	0.00	0.00
20.10.25	2.85	45.71	547.00	40.48	532.76	24.00	24.00	0.00	0.00
Итого	73.71	---	12965.04	---	12090.91	607.26	720.00	0.00	0.00
Среднее	---	42.999	---	37.037	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	6607.68	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, 21 мкр., 14
Потребитель: АО "Жилуправление"
Прибор ТЭМ-106 Заводской номер: 3060472
Формула $Q = M1(h1 - h2)$
Тип системы Подача + расходомер

Система: 1
ТВ1

	ДУ, мм	Gmin, м3/ч	Gmax, м3/ч	Kv, л/имп	Fmax, КГц
1	80	9.6	160	10	---
2	80	9.42	157	10	---

Дата	Q, (Гкал)	M1, (т)	M2, (т)	dM, (т)	T1, (°C)	T2, (°C)	P1, (МПа)	P2, (МПа)	Время наработки, (ч)
19.09.25	н/д	н/д	н/д	н/д	16.13	16.01	0.0	0.0	н/д
20.09.25	0.000	0.00	0.02	-0.0	16.20	16.19	0.0	0.0	24.00
21.09.25	0.000	0.00	0.02	-0.0	16.17	16.19	0.0	0.0	24.00
22.09.25	0.000	0.00	0.93	-0.9	16.31	16.35	0.0	0.0	24.00
23.09.25	0.000	0.00	0.03	-0.0	16.38	16.42	0.0	0.0	24.00
24.09.25	0.000	0.00	0.04	-0.0	16.62	16.70	0.0	0.0	24.00
25.09.25	0	0.00	0.04	-0.0	16.34	16.35	0	0.0	24.00
26.09.25	0	0.16	0.05	0.1	16.41	20.47	0.2	0.2	24.00
27.09.25	0.000	0.00	0.04	-0.0	42.06	24.05	0.5	0.5	24.00
28.09.25	0.000	0.00	0.04	-0.0	47.40	19.81	0.5	0.5	24.00
29.09.25	0.000	0.00	0.08	-0.1	45.79	20.11	0.5	0.5	24.00
30.09.25	0.423	32.33	18.73	13.6	51.24	38.15	0.5	0.5	23.99
01.10.25	1.976	125.70	72.34	53.4	56.84	41.12	0.5	0.5	24.00
02.10.25	1.266	218.71	126.46	92.2	41.50	35.71	0.5	0.5	24.00
03.10.25	1.618	202.87	117.52	85.3	47.26	39.28	0.5	0.5	24.00
04.10.25	1.588	199.51	115.66	83.8	47.53	39.57	0.5	0.5	24.00
05.10.25	1.589	199.57	115.74	83.8	47.72	39.75	0.5	0.5	24.00
06.10.25	1.567	195.11	112.89	82.2	47.97	39.93	0.5	0.5	24.00
07.10.25	1.570	199.46	115.59	83.9	47.92	40.04	0.5	0.5	24.00
08.10.25	1.391	199.73	115.88	83.8	45.67	38.70	0.5	0.5	24.00
09.10.25	1.382	200.55	116.41	84.1	45.54	38.64	0.5	0.5	24.00
10.10.25	1.377	200.26	116.23	84.0	45.66	38.78	0.5	0.5	24.00
11.10.25	1.374	200.20	116.23	84.0	45.71	38.84	0.5	0.5	24.00
12.10.25	1.371	200.11	116.23	83.9	45.56	38.70	0.5	0.5	24.00
13.10.25	1.366	199.95	115.96	84.0	45.36	38.52	0.5	0.5	24.00
14.10.25	1.352	199.76	116.04	83.7	45.34	38.57	0.5	0.5	24.00
15.10.25	1.334	199.54	115.85	83.7	45.10	38.41	0.5	0.5	24.00
16.10.25	1.368	199.58	115.97	83.6	45.23	38.36	0.5	0.5	24.00
17.10.25	1.375	199.58	116.01	83.6	45.19	38.29	0.5	0.5	24.00
18.10.25	1.430	199.49	115.76	83.7	45.76	38.58	0.5	0.5	24.00
19.10.25	1.431	199.49	115.91	83.6	45.80	38.62	0.5	0.5	24.00
20.10.25	1.322	177.97	103.53	74.4	45.79	38.35	0.5	0.5	24.00
Итого	29.47	3949.6	2292.2	1657.4	---	---	---	---	743.99
Среднее	---	---	---	---	38.92	31.67	0.4	0.4	---

Показания интеграторов

Дата	Q, (Гкал)	M1, (т)	M2, (т)	Время наработки, (ч)	Общее время раб. (ч)	Время неработы, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д	н/д	н/д
20.10.25 24:00	7065.15	606822.9	602984.0	71987.4	71812.24	175.166
Итого за период	н/д	н/д	н/д	н/д	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, 21 мкр., 1
Потребитель: АО "Жилуправление"
Прибор: ТВ7-04.1 Заводской номер: 20121035

БД=1, ТВ1, СИ=6, КТЗ=0, ФРТ=0, КСН=0х2С8D

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	15.80	15.63	н/д	0.17	6.12	3.85	н/д	2.645	4.260	н/д	0.000	0.000	н/д	0.000	0.000	н/д	15	9
20.09.25	15.95	15.81	н/д	0.13	6.12	0.08	н/д	2.095	19.800	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
21.09.25	15.93	15.78	н/д	0.15	6.12	0.08	н/д	0.005	23.210	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
22.09.25	16.03	15.83	н/д	0.20	6.12	0.08	н/д	0.000	24.070	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
23.09.25	16.22	15.97	н/д	0.25	6.12	0.08	н/д	0.000	22.405	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
24.09.25	16.38	16.07	н/д	0.30	6.12	0.08	н/д	0.000	19.800	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
25.09.25	64.71	51.34	н/д	13.37	6.12	1.62	н/д	89.740	93.410	н/д	88.025	83.417	н/д	4.607	1.179	н/д	9	15
26.09.25	66.14	52.59	н/д	13.55	6.12	4.24	н/д	223.390	218.750	н/д	218.958	215.938	н/д	3.020	2.971	н/д	24	0
27.09.25	63.91	49.39	н/д	14.52	6.12	4.16	н/д	206.245	202.060	н/д	202.414	199.777	н/д	2.637	2.942	н/д	24	0
28.09.25	66.33	49.97	н/д	16.37	6.12	4.13	н/д	206.260	202.400	н/д	202.148	200.056	н/д	2.092	3.313	н/д	24	0
29.09.25	51.38	42.93	н/д	8.45	4.08	4.35	н/д	304.245	301.220	н/д	300.429	298.671	н/д	1.758	2.530	н/д	24	0
30.09.25	49.90	42.22	н/д	7.67	0.01	4.36	н/д	340.930	338.185	н/д	336.888	335.426	н/д	1.462	2.554	н/д	24	0
01.10.25	49.28	41.80	н/д	7.49	0.00	4.77	н/д	348.325	345.495	н/д	324.949	323.484	н/д	1.466	2.400	н/д	23	1
02.10.25	43.26	39.13	н/д	4.13	0.00	5.00	н/д	468.310	465.860	н/д	464.211	462.680	н/д	1.530	1.869	н/д	24	0
03.10.25	48.12	42.81	н/д	5.31	0.00	5.05	н/д	444.520	441.870	н/д	439.656	438.190	н/д	1.466	2.288	н/д	24	0
04.10.25	48.05	42.70	н/д	5.36	0.00	5.05	н/д	440.370	437.715	н/д	435.569	434.078	н/д	1.491	2.288	н/д	24	0
05.10.25	48.34	42.99	н/д	5.35	0.00	5.05	н/д	440.460	437.825	н/д	435.602	434.139	н/д	1.463	2.285	н/д	24	0
06.10.25	48.41	43.07	н/д	5.33	0.00	4.97	н/д	438.600	435.960	н/д	433.723	432.277	н/д	1.446	2.268	н/д	24	0
07.10.25	47.66	42.62	н/д	5.04	0.00	4.79	н/д	438.375	435.830	н/д	433.675	432.226	н/д	1.449	2.141	н/д	24	0
08.10.25	46.03	41.40	н/д	4.63	0.00	4.55	н/д	439.625	437.180	н/д	435.235	433.778	н/д	1.457	1.972	н/д	24	0
09.10.25	45.95	41.36	н/д	4.59	2.81	4.55	н/д	444.610	442.145	н/д	440.231	438.704	н/д	1.527	1.999	н/д	24	0
10.10.25	46.12	41.59	н/д	4.53	6.12	4.61	н/д	447.630	445.110	н/д	443.234	441.613	н/д	1.621	2.010	н/д	24	0
11.10.25	46.13	41.56	н/д	4.57	6.12	4.62	н/д	447.675	445.170	н/д	443.297	441.683	н/д	1.614	2.027	н/д	24	0
12.10.25	45.87	41.23	н/д	4.64	6.12	4.55	н/д	447.580	445.050	н/д	443.261	441.617	н/д	1.644	2.059	н/д	24	0
13.10.25	45.79	41.16	н/д	4.63	6.12	4.52	н/д	448.445	445.805	н/д	444.151	442.386	н/д	1.765	2.061	н/д	24	0
14.10.25	45.79	41.15	н/д	4.63	6.12	4.51	н/д	449.200	446.675	н/д	444.874	443.243	н/д	1.631	2.065	н/д	24	0
15.10.25	45.47	40.86	н/д	4.61	6.12	4.40	н/д	448.810	446.270	н/д	444.555	442.896	н/д	1.660	2.054	н/д	24	0
16.10.25	45.64	40.90	н/д	4.74	6.12	4.49	н/д	448.895	446.350	н/д	444.581	442.959	н/д	1.622	2.110	н/д	24	0
17.10.25	45.80	40.99	н/д	4.82	6.12	4.53	н/д	448.935	446.365	н/д	444.591	442.951	н/д	1.640	2.145	н/д	24	0
18.10.25	46.21	41.24	н/д	4.96	6.12	4.31	н/д	448.870	446.225	н/д	444.466	442.795	н/д	1.671	2.211	н/д	24	0
19.10.25	46.28	41.33	н/д	4.95	6.12	4.48	н/д	449.005	446.410	н/д	444.576	442.969	н/д	1.607	2.206	н/д	24	0
20.10.25	47.31	41.92	н/д	5.39	6.12	4.58	н/д	400.590	398.170	н/д	396.449	394.991	н/д	1.458	2.139	н/д	24	0
Итого	---	---	---	---	---	---	---	10164.385	10207.050	---	10029.748	9982.944	---	46.804	58.086	---	623	145
Среднее	46.85	40.57	---	6.27	4.23	3.77	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	84986.550	84508.440	0.000	83765.212	83282.719	0.000	482.494	670.571	0.000	7649	3140
20.10.25 24:00	95150.935	94715.490	0.000	93794.959	93265.664	0.000	529.294	728.657	0.000	8272	3285
Итого за период	10164.385	10207.050	0.000	10029.747	9982.945	0.000	---	58.086	0.000	623	145

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 21 мкр., 2
 Потребитель: АО "Жилуправление"
 Прибор: Взлёт ТСРВ-024М Заводской номер: 1900916
 Тип системы: А42-00 Система: 1

ТБ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	16.64	16.33	0.31	0.00	0.00	-0.00	0.1	0.1	0.00	0.00	-0.00	0.000	8.58
20.09.25	16.72	16.41	0.31	0.00	0.00	0.00	0.1	0.1	0.00	0.00	0.00	0.000	24.00
21.09.25	16.72	16.41	0.31	0.00	0.00	0.00	0.1	0.1	0.00	0.00	0.00	0.000	24.00
22.09.25	16.74	16.45	0.29	0.00	0.00	0.00	0.1	0.1	0.00	0.00	0.00	0.000	24.00
23.09.25	16.79	16.50	0.29	0.00	0.00	0.00	0.1	0.1	0.00	0.00	0.00	0.000	24.00
24.09.25	16.96	16.72	0.24	0.00	0.00	0.00	0.1	0.1	0.00	0.00	0.00	0.000	24.00
25.09.25	33.45	27.24	6.21	55.88	53.76	2.12	0.2	0.2	56.95	54.36	2.60	0.970	24.00
26.09.25	65.74	47.73	18.01	154.32	155.40	-1.08	0.5	0.5	157.43	157.11	0.32	2.771	24.00
27.09.25	63.60	43.86	19.74	142.82	144.19	-1.37	0.5	0.4	145.51	145.52	-0.01	2.813	24.00
28.09.25	66.03	44.71	21.32	140.35	141.99	-1.64	0.5	0.4	143.19	143.35	-0.16	2.988	24.00
29.09.25	55.59	41.02	14.57	203.73	205.85	-2.12	0.5	0.5	206.35	207.47	-1.12	2.204	24.00
30.09.25	51.76	40.08	11.68	233.75	236.26	-2.51	0.5	0.5	236.52	238.06	-1.54	2.271	24.00
01.10.25	52.97	40.37	12.60	237.11	240.96	-3.84	0.5	0.5	239.91	242.80	-2.89	2.238	24.00
02.10.25	43.21	37.59	5.62	324.61	328.57	-3.96	0.5	0.5	327.50	330.77	-3.28	1.811	24.00
03.10.25	48.04	40.92	7.12	307.84	312.61	-4.77	0.5	0.5	311.22	315.12	-3.90	2.188	24.00
04.10.25	47.97	40.77	7.20	304.85	309.29	-4.44	0.5	0.5	308.19	311.74	-3.56	2.190	24.00
05.10.25	48.25	41.10	7.15	304.90	309.97	-5.06	0.5	0.5	308.28	312.47	-4.20	2.176	24.00
06.10.25	48.32	41.16	7.16	303.63	308.28	-4.65	0.5	0.5	307.00	310.77	-3.77	2.161	24.00
07.10.25	47.60	40.70	6.90	297.50	302.35	-4.86	0.5	0.5	300.71	304.76	-4.05	2.050	24.00
08.10.25	45.94	39.47	6.47	293.87	298.56	-4.69	0.5	0.5	296.83	300.78	-3.95	1.897	24.00
09.10.25	45.86	39.42	6.44	294.92	299.82	-4.90	0.5	0.5	297.88	302.05	-4.17	1.897	24.00
10.10.25	46.02	39.59	6.43	294.60	299.36	-4.76	0.5	0.5	297.58	301.61	-4.03	1.891	24.00
11.10.25	46.03	39.64	6.39	294.65	299.40	-4.75	0.5	0.5	297.63	301.64	-4.02	1.882	24.00
12.10.25	45.78	39.38	6.40	294.64	299.41	-4.77	0.5	0.5	297.59	301.63	-4.04	1.883	24.00
13.10.25	45.70	39.34	6.36	294.57	299.94	-5.38	0.5	0.5	297.50	302.17	-4.67	1.872	24.00
14.10.25	45.69	39.36	6.33	294.20	299.37	-5.17	0.5	0.5	297.13	301.59	-4.46	1.861	24.00
15.10.25	45.39	39.03	6.36	294.05	299.17	-5.12	0.5	0.5	296.95	301.36	-4.41	1.867	24.00
16.10.25	45.55	38.97	6.58	294.16	298.85	-4.69	0.5	0.5	297.07	301.02	-3.95	1.932	24.00
17.10.25	45.71	39.11	6.60	294.12	299.39	-5.27	0.5	0.5	297.05	301.59	-4.54	1.937	24.00
18.10.25	46.12	39.28	6.84	294.07	299.33	-5.26	0.5	0.5	297.06	301.55	-4.49	2.009	24.00
19.10.25	46.19	39.32	6.87	294.09	299.17	-5.08	0.5	0.5	297.08	301.39	-4.31	2.018	24.00
20.10.25	46.67	39.00	7.67	262.89	267.76	-4.87	0.5	0.5	265.68	269.80	-4.11	1.952	24.00
Итого	---	---	---	6806.11	6909.02	-102.91	---	---	6881.80	6962.49	-80.69	53.729	752.58
Среднее	42.80	35.53	7.27	---	---	---	0.4	0.4	---	---	---	---	---

Показания интеграторов

Дата	Мтс	Q, (Гкал)
18.09.25 24:00	0.00	0.000
20.10.25 24:00	-1307.88	713.161
Итого за период	---	713.161

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 21 мкр., 3
 Потребитель: АО "Жилуправление"
 Прибор: ТЭМ-106 Заводской номер: 3060273
 Формула: $Q = M1(h1 - h2)$
 Тип системы: Подача + расходомер

Система: 1

ТВ1

	ДУ, мм	Gmin, м3/ч	Gmax, м3/ч	Kv, л/имп	Fmax, КГц
1	80	0	160	10	---
2	80	0	160	10	---

Дата	Q, (Гкал)	M1, (т)	M2, (т)	dM, (т)	T1, (°C)	T2, (°C)	P1, (МПа)	P2, (МПа)	Время наработки, (ч)
19.09.25	н/д	н/д	н/д	н/д	15.382	15.069	0.6	0.5	н/д
20.09.25	0.000	0.00	0.67	-0.7	14.957	14.735	0.6	0.5	24.00
21.09.25	0.000	0.00	0.67	-0.7	14.872	14.649	0.6	0.5	24.00
22.09.25	0.000	0.00	0.67	-0.7	15.033	14.858	0.6	0.5	24.00
23.09.25	0.000	0.00	0.66	-0.7	15.269	15.070	0.6	0.5	24.00
24.09.25	0.000	0.00	0.66	-0.7	15.575	15.319	0.6	0.5	24.00
25.09.25	0.898	58.77	57.83	0.9	61.528	46.305	0.6	0.5	24.00
26.09.25	3.205	195.87	196.48	-0.6	65.650	49.310	0.6	0.5	24.00
27.09.25	3.208	181.53	182.99	-1.5	62.926	45.274	0.6	0.5	24.00
28.09.25	3.520	181.43	182.85	-1.4	65.543	46.161	0.6	0.5	24.00
29.09.25	2.655	253.81	254.80	-1.0	51.658	41.376	0.6	0.5	24.00
30.09.25	2.697	323.84	325.07	-1.2	48.685	40.419	0.6	0.5	24.00
01.10.25	2.774	296.76	298.57	-1.8	49.879	40.699	0.6	0.5	24.00
02.10.25	2.038	427.03	429.49	-2.5	42.628	37.871	0.6	0.5	24.00
03.10.25	2.519	403.02	404.82	-1.8	47.868	41.633	0.6	0.5	24.00
04.10.25	2.522	400.40	402.20	-1.8	47.816	41.531	0.6	0.5	24.00
05.10.25	2.521	400.58	402.46	-1.9	48.076	41.798	0.6	0.5	24.00
06.10.25	2.506	399.06	401.06	-2.0	48.187	41.922	0.6	0.5	24.00
07.10.25	2.382	398.42	400.37	-1.9	47.608	41.645	0.6	0.5	24.00
08.10.25	2.179	399.98	401.93	-2.0	45.807	40.374	0.6	0.5	24.00
09.10.25	2.183	401.53	403.49	-2.0	45.722	40.301	0.6	0.5	24.00
10.10.25	2.162	401.16	403.16	-2.0	45.890	40.516	0.6	0.5	24.00
11.10.25	2.159	401.32	403.27	-1.9	45.908	40.544	0.6	0.5	24.00
12.10.25	2.167	401.34	403.29	-2.0	45.670	40.287	0.6	0.5	24.00
13.10.25	2.178	401.25	403.26	-2.0	45.567	40.154	0.6	0.5	24.00
14.10.25	2.163	400.84	402.84	-2.0	45.551	40.171	0.6	0.5	24.00
15.10.25	2.167	400.51	402.55	-2.0	45.256	39.860	0.6	0.5	24.00
16.10.25	2.236	400.53	402.62	-2.1	45.425	39.856	0.6	0.5	24.00
17.10.25	2.270	400.43	402.54	-2.1	45.538	39.885	0.6	0.5	24.00
18.10.25	2.334	400.26	402.49	-2.2	45.985	40.168	0.6	0.5	24.00
19.10.25	2.329	400.35	402.51	-2.2	46.045	40.244	0.6	0.5	24.00
20.10.25	2.243	354.41	356.54	-2.1	46.856	40.575	0.6	0.5	24.00
Итого	62.22	9084.4	9132.8	-48.6	---	---	---	---	744.00
Среднее	---	---	---	---	42.95	36.52	0.6	0.5	---

Показания интеграторов

Дата	Q, (Гкал)	M1, (т)	M2, (т)	Время наработки, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д
20.10.25 24:00	11091.6	927931.4	929949.5	86654.5
Итого за период	н/д	н/д	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 21 мкр., 4/5
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00168976

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0x2983

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	17.95	15.10	2.85	4.650	4.650	4.650	4.650	0.000	6.90	6.70	0.0130	0.0	24.0
20.09.25	15.31	14.86	0.45	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
21.09.25	15.10	14.78	0.32	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
22.09.25	15.32	15.02	0.30	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
23.09.25	15.66	15.35	0.31	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
24.09.25	15.97	15.59	0.38	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
25.09.25	65.13	50.90	14.23	84.250	84.250	82.630	83.220	-0.590	6.90	6.70	1.1760	0.0	24.0
26.09.25	66.10	51.80	14.30	218.010	218.010	213.690	215.290	-1.600	6.90	6.70	3.0530	0.0	24.0
27.09.25	63.97	48.81	15.16	194.040	194.040	190.470	191.880	-1.410	6.90	6.70	2.8820	0.0	24.0
28.09.25	66.32	49.84	16.48	192.040	192.040	188.220	189.880	-1.660	6.90	6.70	3.1000	0.0	24.0
29.09.25	61.92	46.08	15.84	87.760	87.760	86.220	86.880	-0.660	6.90	6.70	1.3700	0.0	24.0
30.09.25	53.77	37.86	15.91	40.710	40.710	40.130	40.410	-0.280	6.90	6.70	0.6310	0.0	24.0
01.10.25	48.86	40.66	8.20	242.490	242.490	239.720	240.600	-0.880	6.90	6.70	1.9610	0.0	24.0
02.10.25	43.03	37.79	5.24	316.510	316.510	313.780	314.410	-0.630	6.90	6.70	1.6410	0.0	24.0
03.10.25	47.84	41.10	6.74	288.370	288.370	285.250	286.080	-0.830	6.90	6.70	1.9200	0.0	24.0
04.10.25	47.78	41.00	6.78	285.560	285.560	282.440	283.370	-0.930	6.90	6.70	1.9090	0.0	24.0
05.10.25	48.06	41.31	6.75	285.490	285.490	282.370	283.230	-0.860	6.90	6.70	1.9010	0.0	24.0
06.10.25	48.12	41.44	6.68	284.370	284.370	281.260	282.040	-0.780	6.90	6.70	1.8730	0.0	24.0
07.10.25	47.35	41.03	6.32	284.000	284.000	281.000	281.720	-0.720	6.90	6.70	1.7730	0.0	24.0
08.10.25	45.77	39.96	5.81	285.080	285.080	282.210	282.920	-0.710	6.90	6.70	1.6420	0.0	24.0
09.10.25	45.69	39.90	5.79	286.190	286.190	283.310	284.030	-0.720	6.90	6.70	1.6390	0.0	24.0
10.10.25	45.85	40.13	5.72	286.360	286.360	283.480	284.200	-0.720	6.90	6.70	1.6190	0.0	24.0
11.10.25	45.85	40.15	5.70	286.180	286.180	283.300	284.020	-0.720	6.90	6.70	1.6130	0.0	24.0
12.10.25	45.60	39.81	5.79	286.180	286.180	283.300	284.020	-0.720	6.90	6.70	1.6370	0.0	24.0
13.10.25	45.53	39.73	5.80	286.270	286.270	283.390	284.110	-0.720	6.90	6.70	1.6430	0.0	24.0
14.10.25	45.52	39.79	5.73	286.020	286.020	283.190	283.860	-0.670	6.90	6.70	1.6250	0.0	24.0
15.10.25	45.21	39.46	5.75	285.920	285.920	283.110	283.790	-0.680	6.90	6.70	1.6290	0.0	24.0
16.10.25	45.38	39.45	5.93	286.650	286.650	283.850	284.490	-0.640	6.90	6.70	1.6810	0.0	24.0
17.10.25	45.54	39.50	6.04	286.610	286.610	283.810	284.450	-0.640	6.90	6.70	1.7100	0.0	24.0
18.10.25	45.93	39.76	6.17	286.650	286.650	283.770	284.490	-0.720	6.90	6.70	1.7510	0.0	24.0
19.10.25	46.01	39.83	6.18	286.680	286.680	283.800	284.520	-0.720	6.90	6.70	1.7510	0.0	24.0
20.10.25	46.92	40.47	6.45	264.010	264.010	261.300	261.940	-0.640	6.90	6.70	1.6880	0.0	24.0
Итого	---	---	---	6507.0	6507.0	6433.65	6454.50	-20.850	---	---	46.8310	0.0	768.0
Среднее	43.69	36.82	6.87	---	---	---	---	---	6.90	6.70	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	109654.739	109654.739	108053.719	108587.409	1110.3480	-533.690	2323.0	17750.0
20.10.25 24:00	116161.789	116161.789	114487.370	115041.910	1157.1790	-554.540	2323.0	18518.0
Итого за период	6507.050	6507.050	6433.650	6454.501	46.8310	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, 21 мкр., 6
Потребитель: АО "Жилуправление"
Прибор ТВ7-04.1 Заводской номер: 20121046

БД=1, ТВ1, СИ=6, КТЗ=0, ФРТ=0, КСН=0хЕ5F6

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	14.64	14.51	н/д	0.13	4.67	4.66	н/д	0.010	0.005	н/д	0.010	0.005	н/д	0.005	0	н/д	24	0
20.09.25	14.91	14.74	н/д	0.17	0.00	0.27	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
21.09.25	14.91	14.73	н/д	0.18	0.00	0.27	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
22.09.25	15.04	14.86	н/д	0.18	0.00	0.28	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
23.09.25	15.21	15.00	н/д	0.21	0.00	0.28	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
24.09.25	15.45	15.20	н/д	0.25	0.00	0.29	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
25.09.25	62.18	50.84	н/д	11.34	0.08	2.77	н/д	154.275	152.240	н/д	151.951	149.895	н/д	2.056	1.710	н/д	24	0
26.09.25	66.25	47.22	н/д	19.03	0.08	4.96	н/д	151.795	154.645	н/д	150.948	150.836	н/д	0.112	2.859	н/д	24	0
27.09.25	63.83	42.78	н/д	21.05	0.07	4.91	н/д	134.150	136.910	н/д	133.699	133.699	н/д	0.000	2.802	н/д	24	0
28.09.25	66.28	43.23	н/д	23.05	0.10	4.89	н/д	131.435	133.890	н/д	130.765	130.765	н/д	0.000	3.001	н/д	24	0
29.09.25	50.70	39.81	н/д	10.89	0.05	5.08	н/д	207.910	212.350	н/д	207.628	207.655	н/д	-0.026	2.238	н/д	23	1
30.09.25	49.86	39.95	н/д	9.91	0.03	5.08	н/д	250.705	254.165	н/д	250.038	250.038	н/д	0.000	2.450	н/д	24	0
01.10.25	49.13	39.79	н/д	9.33	0.05	5.51	н/д	263.085	264.380	н/д	261.263	261.263	н/д	0.000	2.408	н/д	24	0
02.10.25	43.25	37.78	н/д	5.47	0.01	5.70	н/д	362.320	363.740	н/д	360.298	360.298	н/д	0.000	1.925	н/д	24	0
03.10.25	48.16	41.22	н/д	6.93	0.04	5.77	н/д	345.005	345.920	н/д	342.250	342.216	н/д	0.034	2.331	н/д	24	0
04.10.25	48.09	41.06	н/д	7.03	0.05	5.77	н/д	341.900	343.160	н/д	339.373	339.373	н/д	0.000	2.345	н/д	24	0
05.10.25	48.37	41.37	н/д	7.00	0.07	5.77	н/д	342.075	343.355	н/д	339.502	339.502	н/д	0.000	2.336	н/д	24	0
06.10.25	48.44	41.46	н/д	6.98	0.08	5.70	н/д	340.535	341.925	н/д	338.018	338.018	н/д	0.000	2.320	н/д	24	0
07.10.25	47.70	41.06	н/д	6.64	0.08	5.51	н/д	340.245	341.760	н/д	337.892	337.892	н/д	0.000	2.204	н/д	24	0
08.10.25	46.06	39.93	н/д	6.13	0.08	5.26	н/д	341.820	343.440	н/д	339.693	339.693	н/д	0.000	2.043	н/д	24	0
09.10.25	45.97	39.84	н/д	6.13	0.10	5.27	н/д	342.935	344.625	н/д	340.844	340.844	н/д	0.000	2.052	н/д	24	0
10.10.25	46.14	40.05	н/д	6.09	0.10	5.34	н/д	342.660	344.340	н/д	340.545	340.545	н/д	0.000	2.034	н/д	24	0
11.10.25	46.15	40.07	н/д	6.08	0.11	5.35	н/д	342.765	344.440	н/д	340.645	340.645	н/д	0.000	2.031	н/д	24	0
12.10.25	45.90	39.72	н/д	6.18	0.12	5.27	н/д	342.750	344.395	н/д	340.665	340.665	н/д	0.000	2.067	н/д	24	0
13.10.25	45.82	39.62	н/д	6.19	0.10	5.25	н/д	342.655	344.320	н/д	340.585	340.585	н/д	0.000	2.071	н/д	24	0
14.10.25	45.81	39.65	н/д	6.16	0.06	5.23	н/д	342.275	343.935	н/д	340.208	340.208	н/д	0.000	2.056	н/д	24	0
15.10.25	45.50	39.37	н/д	6.13	0.07	5.12	н/д	342.080	343.685	н/д	340.022	340.022	н/д	0.000	2.046	н/д	24	0
16.10.25	45.67	39.32	н/д	6.35	0.08	5.21	н/д	342.185	343.755	н/д	340.105	340.105	н/д	0.000	2.121	н/д	24	0
17.10.25	45.83	39.38	н/д	6.45	0.09	5.26	н/д	342.145	343.685	н/д	340.035	340.035	н/д	0.000	2.155	н/д	24	0
18.10.25	46.24	39.64	н/д	6.60	0.06	5.03	н/д	342.095	343.615	н/д	339.928	339.928	н/д	0.000	2.206	н/д	24	0
19.10.25	46.31	39.77	н/д	6.54	0.04	5.22	н/д	342.160	343.630	н/д	339.950	339.950	н/д	0.000	2.185	н/д	24	0
20.10.25	47.31	40.19	н/д	7.12	0.05	5.33	н/д	303.910	305.035	н/д	301.221	301.190	н/д	0.031	2.110	н/д	22	2
Итого	---	---	---	---	---	---	---	7777.880	7821.345	---	7728.081	7725.870	---	2.212	58.106	---	765	3
Среднее	48.09	40.46	---	7.63	0.20	4.43	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	71632.890	71834.800	0.000	70810.291	70801.339	0.000	8.952	681.845	0.000	7638	3151
20.10.25 24:00	79410.770	79656.145	0.000	78538.371	78527.208	0.000	11.163	739.952	0.000	8403	3154
Итого за период	7777.880	7821.345	0.000	7728.080	7725.869	0.000	---	58.107	0.000	765	3

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 21 мкр., 7
 Потребитель: АО "Жилуправление"
 Прибор: Вzlёт ТСРВ-024 Заводской номер: 801121
 Тип системы: А42-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	15.46	15.42	0.04	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	4.900
20.09.25	15.51	15.41	0.10	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
21.09.25	15.51	15.39	0.12	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
22.09.25	15.92	15.84	0.08	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
23.09.25	16.18	16.08	0.10	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
24.09.25	16.49	16.36	0.13	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
25.09.25	24.88	22.78	2.10	44.73	44.88	-0.15	0.000	0.000	45.62	45.52	0.10	0.512	24.000
26.09.25	67.21	57.15	10.06	241.23	242.56	-1.33	0.000	0.000	246.35	246.38	-0.03	2.426	24.000
27.09.25	64.31	53.77	10.54	211.52	213.10	-1.57	0.000	0.000	215.63	216.06	-0.43	2.226	24.000
28.09.25	67.10	55.70	11.40	206.86	208.34	-1.47	0.000	0.000	211.22	211.44	-0.23	2.356	24.000
29.09.25	56.65	49.43	7.22	205.81	203.27	2.54	0.000	0.000	209.10	205.68	3.42	1.665	24.000
30.09.25	51.70	44.92	6.78	246.99	249.51	-2.51	0.000	0.000	250.14	251.95	-1.81	1.585	24.000
01.10.25	57.08	48.57	8.51	238.36	240.97	-2.61	0.000	0.000	241.88	243.64	-1.76	1.777	24.000
02.10.25	42.80	39.29	3.51	311.08	314.65	-3.56	0.000	0.000	313.87	317.03	-3.16	1.082	24.000
03.10.25	48.20	43.50	4.70	294.07	297.35	-3.28	0.000	0.000	297.39	300.11	-2.72	1.381	24.000
04.10.25	48.21	43.42	4.79	290.42	293.62	-3.20	0.000	0.000	293.70	296.33	-2.63	1.389	24.000
05.10.25	48.42	43.61	4.81	290.54	293.73	-3.18	0.000	0.000	293.86	296.46	-2.61	1.396	24.000
06.10.25	48.56	43.77	4.79	289.66	292.86	-3.20	0.000	0.000	292.98	295.61	-2.63	1.386	24.000
07.10.25	48.19	43.56	4.63	288.81	292.03	-3.22	0.000	0.000	292.07	294.74	-2.67	1.336	24.000
08.10.25	46.22	42.05	4.17	289.73	293.02	-3.28	0.000	0.000	292.75	295.56	-2.81	1.204	24.000
09.10.25	46.12	41.93	4.19	291.22	294.57	-3.35	0.000	0.000	294.24	297.11	-2.87	1.218	24.000
10.10.25	46.29	42.14	4.15	291.04	294.38	-3.34	0.000	0.000	294.08	296.94	-2.86	1.206	24.000
11.10.25	46.30	42.14	4.16	291.09	294.51	-3.41	0.000	0.000	294.14	297.08	-2.94	1.209	24.000
12.10.25	46.08	41.91	4.17	291.05	294.55	-3.50	0.000	0.000	294.07	297.09	-3.02	1.212	24.000
13.10.25	45.94	41.74	4.20	290.99	294.48	-3.48	0.000	0.000	293.99	296.99	-3.01	1.220	24.000
14.10.25	45.93	41.79	4.14	290.74	294.21	-3.46	0.000	0.000	293.73	296.73	-3.00	1.201	24.000
15.10.25	45.66	41.49	4.17	290.42	293.91	-3.48	0.000	0.000	293.38	296.39	-3.02	1.207	24.000
16.10.25	45.83	41.53	4.30	290.43	293.94	-3.50	0.000	0.000	293.40	296.42	-3.02	1.248	24.000
17.10.25	45.88	41.50	4.38	290.43	293.93	-3.50	0.000	0.000	293.41	296.42	-3.00	1.269	24.000
18.10.25	46.36	41.85	4.51	290.27	293.78	-3.51	0.000	0.000	293.31	296.30	-2.99	1.306	24.000
19.10.25	46.41	41.90	4.51	290.34	293.62	-3.28	0.000	0.000	293.39	296.16	-2.77	1.300	24.000
20.10.25	45.35	41.84	3.51	259.06	259.79	-0.72	0.000	0.000	261.84	262.06	-0.22	1.209	24.000
Итого	---	---	---	6906.87	6975.57	-68.69	---	---	6989.52	7042.20	-52.68	36.525	748.900
Среднее	42.71	38.37	4.34	---	---	---	0.000	0.000	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 21 мкр., 8
 Потребитель: АО "Жилуправление"
 Прибор: Вzlёт ТСРВ-024 Заводской номер: 801985
 Тип системы: А32-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	0.00	0.00	0.00	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	0.000
20.09.25	15.05	14.88	0.17	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	24.000
21.09.25	15.07	14.88	0.19	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	24.000
22.09.25	15.36	15.19	0.17	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	24.000
23.09.25	15.52	15.40	0.12	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	24.000
24.09.25	15.97	15.71	0.26	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	24.000
25.09.25	15.95	15.74	0.21	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	24.000
26.09.25	65.96	58.56	7.40	168.94	177.02	-8.08	0.590	0.549	172.38	181.44	-9.06	-0.276	24.000
27.09.25	63.76	57.32	6.44	152.83	168.03	-15.20	0.590	0.549	155.60	172.58	-16.98	-1.554	24.000
28.09.25	66.71	52.96	13.75	151.86	153.87	-2.00	0.590	0.549	154.85	156.30	-1.45	1.745	24.000
29.09.25	61.03	51.51	9.52	140.58	147.59	-7.00	0.590	0.549	143.07	150.04	-6.97	0.762	24.000
30.09.25	48.12	41.46	6.66	200.18	201.74	-1.55	0.590	0.549	201.94	203.90	-1.96	1.095	24.000
01.10.25	61.12	47.68	13.44	154.95	154.95	0.00	0.590	0.549	157.18	157.00	0.18	1.907	24.000
02.10.25	42.12	38.09	4.03	254.54	255.23	-0.68	0.590	0.549	255.94	257.76	-1.83	0.959	24.000
03.10.25	47.74	42.01	5.73	236.83	237.48	-0.65	0.590	0.549	238.77	240.12	-1.34	1.300	24.000
04.10.25	48.12	42.11	6.01	233.21	233.21	0	0.590	0.549	235.21	235.74	-0.53	1.400	24.000
05.10.25	48.28	42.31	5.97	233.32	233.64	-0.31	0.590	0.549	235.37	236.18	-0.82	1.365	24.000
06.10.25	48.53	42.49	6.04	233.02	233.02	0	0.590	0.549	235.12	235.54	-0.43	1.408	24.000
07.10.25	48.50	42.53	5.97	231.81	231.81	0.00	0.590	0.549	233.91	234.30	-0.39	1.382	24.000
08.10.25	46.27	41.34	4.93	232.42	234.09	-1.66	0.590	0.549	234.33	236.56	-2.23	0.955	24.000
09.10.25	46.09	40.88	5.21	233.98	233.98	0	0.590	0.549	235.90	236.28	-0.38	1.218	24.000
10.10.25	46.21	41.55	4.66	233.85	236.54	-2.68	0.590	0.549	235.84	238.95	-3.12	0.868	24.000
11.10.25	46.26	41.25	5.01	233.91	234.68	-0.77	0.590	0.549	235.89	237.01	-1.13	1.094	24.000
12.10.25	46.10	40.89	5.21	234.05	234.05	0	0.590	0.549	236.02	236.32	-0.30	1.219	24.000
13.10.25	45.89	41.06	4.83	233.95	236.30	-2.34	0.590	0.549	235.89	238.68	-2.78	0.915	24.000
14.10.25	45.88	41.02	4.86	233.79	235.68	-1.88	0.590	0.549	235.75	238.01	-2.26	0.971	24.000
15.10.25	45.65	40.57	5.08	233.53	234.00	-0.47	0.590	0.549	235.45	236.24	-0.79	1.147	24.000
16.10.25	45.75	40.42	5.33	233.57	233.73	-0.15	0.590	0.549	235.52	235.93	-0.41	1.231	24.000
17.10.25	45.73	41.18	4.55	233.48	238.35	-4.87	0.590	0.549	235.44	240.78	-5.33	0.644	24.000
18.10.25	46.28	40.79	5.49	233.37	234.00	-0.63	0.590	0.549	235.36	236.25	-0.89	1.230	24.000
19.10.25	46.33	41.07	5.26	233.37	235.10	-1.73	0.590	0.549	235.37	237.41	-2.04	1.087	24.000
20.10.25	44.80	40.42	4.38	205.71	208.29	-2.58	0.590	0.549	207.47	210.31	-2.84	1.010	24.000
Итого	---	---	---	5401.06	5456.39	-55.33	---	---	5453.56	5519.63	-66.07	25.081	744.000
Среднее	41.88	36.98	4.90	---	---	---	0.572	0.532	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, 21 мкр., 9
Потребитель: АО "Жилуправление"
Прибор ТЭМ-104 Заводской номер: 1641706
Формула $Q = M1(hп - hо)$
Тип системы Р-Подача

Система: 1
ТВ1

	ДУ, мм	Gmin, м3/ч	Gmax, м3/ч	Kv, л/имп	Fmax, КГц
1	80	3.9250000000000003	157	---	---
2	80	4	160	---	---

Дата	Q, (Гкал)	M1, (т)	M2, (т)	dM, (т)	T1, (°C)	T2, (°C)	P1, (МПа)	P2, (МПа)	Время наработки, (ч)
19.09.25	0.000	0.00	0.00	0.0	15.11	14.71	0.6	0.5	24.00
20.09.25	0.000	0.00	0.00	0.0	15.22	14.78	0.6	0.5	24.00
21.09.25	0.000	0.00	0	0	15.29	14.84	0.6	0.5	24.00
22.09.25	0.000	0.00	0	0	15.50	15.04	0.6	0.5	24.00
23.09.25	0.000	0.00	0	0	15.70	15.23	0.6	0.5	24.00
24.09.25	0.000	0.00	0.00	-0.0	15.91	15.39	0.6	0.5	24.00
25.09.25	0.466	19.40	17.82	1.6	60.78	36.75	0.6	0.5	24.00
26.09.25	0.672	23.79	23.72	0.1	64.24	36.02	0.6	0.5	24.00
27.09.25	0.530	21.02	21.61	-0.6	61.62	36.41	0.6	0.5	24.00
28.09.25	0.546	20.52	21.25	-0.7	64.06	37.46	0.6	0.5	24.00
29.09.25	0.575	26.48	26.88	-0.4	50.68	29.14	0.6	0.5	24.00
30.09.25	0.660	31.81	32.34	-0.5	48.67	27.91	0.6	0.5	24.00
01.10.25	0.606	28.87	28.50	0.4	49.78	28.80	0.6	0.5	22.33
02.10.25	1.294	137.33	136.85	0.5	44.95	35.54	0.6	0.5	24.00
03.10.25	2.485	345.18	344.35	0.8	47.45	40.27	0.6	0.5	24.00
04.10.25	2.403	338.64	337.80	0.8	47.39	40.31	0.6	0.5	24.00
05.10.25	2.365	338.75	337.81	0.9	47.65	40.68	0.6	0.5	24.00
06.10.25	2.323	337.48	336.58	0.9	47.73	40.87	0.6	0.5	24.00
07.10.25	2.197	337.04	336.23	0.8	47.10	40.60	0.6	0.5	24.00
08.10.25	1.955	319.50	318.69	0.8	45.38	39.28	0.6	0.5	24.00
09.10.25	1.901	280.83	279.96	0.9	45.31	38.55	0.6	0.5	24.00
10.10.25	1.883	280.63	279.79	0.8	45.48	38.78	0.6	0.5	24.00
11.10.25	1.881	280.67	279.83	0.8	45.49	38.80	0.6	0.5	24.00
12.10.25	1.884	280.64	279.81	0.8	45.25	38.55	0.6	0.5	24.00
13.10.25	1.892	280.59	279.78	0.8	45.16	38.43	0.6	0.5	24.00
14.10.25	1.861	280.26	279.43	0.8	45.15	38.52	0.6	0.5	24.00
15.10.25	1.860	280.15	279.32	0.8	44.85	38.23	0.6	0.5	24.00
16.10.25	1.921	280.24	279.40	0.8	45.01	38.17	0.6	0.5	24.00
17.10.25	1.956	280.15	279.33	0.8	45.15	38.18	0.6	0.5	24.00
18.10.25	2.013	280.09	279.26	0.8	45.57	38.40	0.6	0.5	24.00
19.10.25	2.011	280.11	279.27	0.8	45.64	38.47	0.6	0.5	24.00
20.10.25	1.957	263.47	262.72	0.8	46.59	39.20	0.6	0.5	24.00
Итого	42.10	5673.6	5658.3	15.1	---	---	---	---	766.33
Среднее	---	---	---	---	42.65	33.20	0.6	0.5	---

Показания интеграторов

Дата	Q, (Гкал)	M1, (т)	M2, (т)	Время наработки, (ч)	Общее время раб. (ч)	Время неработы, (ч)
18.09.25 24:00	9179.46	771346.7	736000.8	69096.4	68915.35	181.048
20.10.25 24:00	9221.55	777020.4	741659.1	69862.7	69681.68	181.049
Итого за период	42.09	5673.7	5658.3	766.3	766.33	0.001

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 24 мкр., 10
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00173725

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0x8170

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Мг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
28.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
29.09.25	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
30.09.25	59.93	43.77	16.16	132.390	136.610	130.220	135.360	-5.140	7.94	7.83	2.1000	0.0	24.0
01.10.25	55.32	41.65	13.67	143.910	147.920	141.890	146.730	-4.840	8.42	8.28	1.9390	0.0	24.0
02.10.25	53.65	40.97	12.68	150.880	155.420	148.900	154.200	-5.300	8.58	8.43	1.8830	0.0	24.0
03.10.25	54.80	42.01	12.79	152.180	156.420	150.020	155.090	-5.070	8.60	8.44	1.9150	0.0	24.0
04.10.25	52.54	40.08	12.46	141.860	146.170	140.060	145.070	-5.010	8.62	8.49	1.7410	0.0	24.0
05.10.25	51.89	39.93	11.96	142.460	146.200	140.760	145.160	-4.400	8.62	8.49	1.6800	0.0	24.0
06.10.25	57.10	44.86	12.24	180.680	184.870	177.950	183.120	-5.170	8.42	8.18	2.1790	0.0	24.0
07.10.25	56.68	45.10	11.58	165.470	170.170	163.020	168.580	-5.560	8.22	8.01	1.8800	0.0	24.0
08.10.25	45.44	35.69	9.75	118.210	122.460	117.050	121.790	-4.740	8.08	8.00	1.1390	0.0	24.0
09.10.25	46.67	36.27	10.40	120.470	124.320	119.270	123.600	-4.330	8.09	8.00	1.2360	0.0	24.0
10.10.25	46.94	36.53	10.41	121.440	125.190	120.240	124.470	-4.230	8.14	8.06	1.2470	0.0	24.0
11.10.25	46.65	36.31	10.34	121.100	124.950	119.900	124.230	-4.330	8.15	8.07	1.2370	0.0	24.0
12.10.25	47.44	36.40	11.04	125.130	129.030	123.830	128.260	-4.430	8.06	7.97	1.3650	0.0	24.0
13.10.25	51.48	39.18	12.30	136.900	140.620	135.220	139.660	-4.440	8.01	7.90	1.6580	0.0	24.0
14.10.25	50.35	38.65	11.70	134.430	137.830	132.840	136.870	-4.030	8.00	7.89	1.5540	0.0	24.0
15.10.25	50.26	38.46	11.80	132.890	136.840	131.340	135.880	-4.540	7.90	7.79	1.5470	0.0	24.0
16.10.25	50.66	39.50	11.16	152.950	156.720	151.130	155.580	-4.450	7.98	7.82	1.6830	0.0	24.0
17.10.25	53.37	42.17	11.20	180.040	183.440	177.640	181.930	-4.290	7.97	7.74	1.9890	0.0	24.0
18.10.25	55.03	43.56	11.47	187.460	191.390	184.820	189.710	-4.890	7.74	7.48	2.1130	0.0	24.0
19.10.25	55.40	43.99	11.41	186.800	189.390	184.160	187.710	-3.550	7.91	7.65	2.0970	0.0	24.0
20.10.25	54.99	43.14	11.85	170.580	174.070	168.230	172.560	-4.330	7.97	7.77	1.9920	0.0	24.0
Итого	---	---	---	3098.2	3180.0	3058.49	3155.56	-97.070	---	---	36.1740	0.0	504.0
Среднее	52.21	40.39	11.82	---	---	---	---	---	8.16	8.01	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Мг, (т)	ВОС, (ч)	ВНР, (ч)
28.09.25 24:00	0	0	0	0	0	0	0	0
20.10.25 24:00	3618.560	3811.580	3570.860	3782.029	42.7790	-211.170	0.0	2269.0
Итого за период	3618.560	3811.580	3570.860	3782.029	42.7790	---	0.0	2269.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ИМ2300, Суточный с 19.09.25 по 20.10.25

Объект: г. Октябрьский, 24 мкр., 11
 Потребитель: АО "Жилуправление"
 Прибор: ИМ2300 Заводской номер: ВВ854

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	0.00	18.38	0.00	18.72	18.45	0.00	24.00	0.00	0.00
22.09.25	0.00	18.34	0.00	18.64	0.56	0.00	24.00	0.00	0.00
23.09.25	0.00	18.61	0.00	18.81	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	18.69	0.00	18.83	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	18.79	0.00	18.90	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	18.38	0.00	18.66	0.00	0.00	24.00	0.00	0.00
27.09.25	0.53	38.21	100.39	35.70	100.98	12.77	24.00	0.00	0.00
28.09.25	1.20	56.59	193.27	50.34	196.38	24.00	24.00	0.00	0.00
29.09.25	1.43	58.19	191.84	50.72	194.69	24.00	24.00	0.00	0.00
30.09.25	1.56	58.55	177.51	49.49	178.22	23.84	24.00	0.00	0.00
01.10.25	1.45	58.46	129.04	47.19	128.17	24.00	24.00	0.00	0.00
02.10.25	1.46	54.15	168.75	45.24	167.79	24.00	24.00	0.00	0.00
03.10.25	1.57	52.32	200.30	44.48	200.11	24.00	24.00	0.00	0.00
04.10.25	1.61	53.59	201.69	45.62	201.25	24.00	24.00	0.00	0.00
05.10.25	1.44	51.40	187.13	43.68	186.55	24.00	24.00	0.00	0.00
06.10.25	1.40	50.78	188.08	43.33	187.52	24.00	24.00	0.00	0.00
07.10.25	1.83	55.27	236.95	47.58	236.68	24.00	24.00	0.00	0.00
08.10.25	1.57	53.74	214.73	46.73	213.93	24.00	24.00	0.00	0.00
09.10.25	0.94	44.32	152.05	38.13	150.99	24.00	24.00	0.00	0.00
10.10.25	1.02	45.68	154.19	39.06	153.16	24.00	24.00	0.00	0.00
11.10.25	1.02	45.94	155.04	39.37	154.03	24.00	24.00	0.00	0.00
12.10.25	1.01	45.66	154.94	39.16	153.90	24.00	24.00	0.00	0.00
13.10.25	1.09	46.28	160.32	39.51	159.39	24.00	24.00	0.00	0.00
14.10.25	1.32	50.40	175.29	42.85	174.34	24.00	24.00	0.00	0.00
15.10.25	1.25	49.31	173.99	42.11	172.93	24.00	24.00	0.00	0.00
16.10.25	1.26	49.23	175.09	42.00	174.29	24.00	24.00	0.00	0.00
17.10.25	1.38	49.60	203.35	42.77	202.95	24.00	24.00	0.00	0.00
18.10.25	1.63	52.22	241.42	45.46	241.53	24.00	24.00	0.00	0.00
19.10.25	1.75	53.96	251.03	46.96	251.46	24.00	24.00	0.00	0.00
20.10.25	1.76	54.32	251.17	47.29	251.96	24.00	24.00	0.00	0.00
Итого	32.48	---	4437.56	---	4452.21	564.61	720.00	0.00	0.00
Среднее	---	44.645	---	38.911	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	360.37	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 24 мкр., 12
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00231827

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0x67F3

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	21.55	21.91	-0.36	0.240	0.240	0.240	0.240	0.000	3.62	3.54	0.0000	0.0	24.0
20.09.25	21.58	21.97	-0.39	0.000	0.000	0.000	0.000	0.000	1.03	1.03	0.0000	0.0	24.0
21.09.25	21.52	21.91	-0.39	0.000	0.000	0.000	0.000	0.000	1.03	1.03	0.0000	0.0	24.0
22.09.25	21.58	22.02	-0.44	0.000	0.000	0.000	0.000	0.000	1.03	1.03	0.0000	0.0	24.0
23.09.25	21.76	22.19	-0.43	0.000	0.000	0.000	0.000	0.000	1.03	1.03	0.0000	0.0	24.0
24.09.25	21.92	22.33	-0.41	0.000	0.000	0.000	0.000	0.000	1.03	1.03	0.0000	0.0	24.0
25.09.25	21.98	22.34	-0.36	0.000	0.000	0.000	0.000	0.000	1.02	1.03	0.0000	0.0	24.0
26.09.25	57.75	45.32	12.43	64.810	64.080	63.800	63.470	0.330	4.70	4.58	0.7730	0.0	24.0
27.09.25	57.96	46.73	11.23	120.250	117.380	118.340	116.180	2.160	7.74	7.58	1.3260	0.0	24.0
28.09.25	59.58	47.22	12.36	121.450	118.870	119.510	117.660	1.850	7.71	7.56	1.4750	0.0	24.0
29.09.25	59.94	46.98	12.96	125.830	123.190	123.770	121.930	1.840	7.82	7.68	1.6000	0.0	24.0
30.09.25	59.98	45.65	14.33	118.010	115.270	116.060	114.170	1.890	8.14	8.03	1.6620	0.0	24.0
01.10.25	55.50	43.45	12.05	122.980	120.140	121.240	119.080	2.160	8.60	8.49	1.4570	0.0	24.0
02.10.25	53.76	42.42	11.34	125.470	122.260	123.760	121.230	2.530	8.76	8.64	1.4020	0.0	24.0
03.10.25	54.94	43.43	11.51	126.060	123.020	124.350	121.930	2.420	8.78	8.66	1.4290	0.0	24.0
04.10.25	52.66	41.39	11.27	117.250	114.490	115.810	113.530	2.280	8.80	8.70	1.3040	0.0	24.0
05.10.25	52.02	41.14	10.88	117.800	115.140	116.360	114.180	2.180	8.81	8.70	1.2640	0.0	24.0
06.10.25	57.20	46.08	11.12	148.120	145.050	145.930	143.590	2.340	8.58	8.41	1.6210	0.0	24.0
07.10.25	56.85	46.33	10.52	134.800	131.740	132.770	130.390	2.380	8.39	8.24	1.3960	0.0	24.0
08.10.25	45.60	36.31	9.29	97.440	95.070	96.520	94.450	2.070	8.27	8.20	0.8940	0.0	24.0
09.10.25	46.83	36.87	9.96	100.310	97.930	99.350	97.280	2.070	8.28	8.21	0.9890	0.0	24.0
10.10.25	47.10	37.19	9.91	100.880	98.540	99.920	97.820	2.100	8.34	8.27	0.9900	0.0	24.0
11.10.25	46.81	36.99	9.82	100.800	98.470	99.840	97.750	2.090	8.35	8.27	0.9790	0.0	24.0
12.10.25	47.59	37.40	10.19	104.270	101.900	103.210	101.140	2.070	8.25	8.18	1.0490	0.0	24.0
13.10.25	51.62	40.39	11.23	113.600	111.080	112.160	110.240	1.920	8.20	8.11	1.2560	0.0	24.0
14.10.25	50.51	39.81	10.70	111.320	108.870	110.010	108.150	1.860	8.18	8.10	1.1760	0.0	24.0
15.10.25	50.42	39.46	10.96	110.090	107.620	108.820	106.900	1.920	8.09	8.00	1.1900	0.0	24.0
16.10.25	50.83	40.61	10.22	127.350	124.710	125.870	123.730	2.140	8.16	8.04	1.2810	0.0	24.0
17.10.25	53.55	43.46	10.09	150.510	147.610	148.520	146.260	2.260	8.13	7.96	1.4960	0.0	24.0
18.10.25	55.22	44.86	10.36	156.250	153.260	154.090	151.820	2.270	7.90	7.72	1.5940	0.0	24.0
19.10.25	55.58	45.23	10.35	156.370	153.380	154.210	151.940	2.270	8.07	7.89	1.5970	0.0	24.0
20.10.25	55.18	44.34	10.84	140.070	137.240	138.120	135.970	2.150	8.15	8.00	1.4960	0.0	24.0
Итого	---	---	---	3012.3	2946.5	2972.58	2921.03	51.550	---	---	32.6960	0.0	768.0
Среднее	46.46	37.92	8.53	---	---	---	---	---	6.66	6.56	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	30034.530	28571.420	29580.000	28297.830	368.2470	1282.170	313.0	8630.0
20.10.25 24:00	33046.860	31517.970	32552.579	31218.860	400.9430	1333.720	313.0	9398.0
Итого за период	3012.330	2946.550	2972.579	2921.029	32.6960	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ИМ2300, Суточный с 19.09.25 по 20.10.25

Объект: г. Октябрьский, 24 мкр., 13
 Потребитель: АО "Жилуправление"
 Прибор: ИМ2300 Заводской номер: BA770

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	23.92	0.00	24.44	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	23.95	0.00	24.45	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	23.90	0.00	24.43	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	23.91	0.00	24.45	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	24.05	0.00	24.55	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	24.23	0.00	24.74	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	24.36	0.00	24.79	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	24.25	0.00	24.61	0.00	0.00	24.00	0.00	0.00
27.09.25	0.98	41.37	77.10	34.98	75.13	12.31	24.00	0.00	0.00
28.09.25	1.84	57.61	144.39	44.82	141.13	24.00	24.00	0.00	0.00
29.09.25	1.92	58.97	133.49	44.66	126.93	24.00	24.00	0.00	0.00
30.09.25	2.12	59.62	140.19	44.46	136.87	23.87	24.00	0.00	0.00
01.10.25	2.17	59.62	126.23	42.38	123.45	24.00	24.00	0.00	0.00
02.10.25	1.93	55.13	131.43	40.38	128.91	24.00	24.00	0.00	0.00
03.10.25	1.85	53.24	134.10	39.41	131.52	24.00	24.00	0.00	0.00
04.10.25	1.89	54.50	135.19	40.49	132.44	24.00	24.00	0.00	0.00
05.10.25	1.71	52.30	125.05	38.60	122.80	24.00	24.00	0.00	0.00
06.10.25	1.64	51.67	125.38	38.53	123.40	24.00	24.00	0.00	0.00
07.10.25	2.17	56.22	158.60	42.59	156.27	24.00	24.00	0.00	0.00
08.10.25	1.88	54.57	144.94	42.20	139.65	24.00	24.00	0.00	0.00
09.10.25	1.13	45.11	102.28	34.13	99.93	24.00	24.00	0.00	0.00
10.10.25	1.21	46.47	103.83	34.78	101.58	24.00	24.00	0.00	0.00
11.10.25	1.22	46.73	104.50	35.07	102.17	24.00	24.00	0.00	0.00
12.10.25	1.21	46.46	104.46	34.87	102.01	24.00	24.00	0.00	0.00
13.10.25	1.31	47.10	108.03	34.99	105.72	24.00	24.00	0.00	0.00
14.10.25	1.59	51.25	118.44	37.76	115.72	24.00	24.00	0.00	0.00
15.10.25	1.49	50.14	115.62	37.26	113.38	24.00	24.00	0.00	0.00
16.10.25	1.50	50.05	114.28	36.87	112.12	24.00	24.00	0.00	0.00
17.10.25	1.64	50.42	132.00	37.90	128.92	24.00	24.00	0.00	0.00
18.10.25	1.96	53.09	158.34	40.68	156.47	24.00	24.00	0.00	0.00
19.10.25	2.10	54.85	164.75	42.07	162.41	24.00	24.00	0.00	0.00
20.10.25	2.10	55.21	164.75	42.45	162.05	24.00	24.00	0.00	0.00
Итого	40.56	---	3067.37	---	3000.98	564.18	768.00	0.00	0.00
Среднее	---	45.133	---	35.587	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	6842.72	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 24 мкр., 14/15
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00182441

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0xE4B2

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	19.29	20.10	-0.81	0.000	0.960	0.000	0.960	-0.960	3.72	6.70	0.0000	0.0	24.0
20.09.25	19.36	20.15	-0.79	0.000	3.360	0.000	3.360	-3.360	1.02	6.70	0.0000	0.0	24.0
21.09.25	19.51	20.14	-0.63	0.000	2.880	0.000	2.880	-2.880	1.02	6.70	0.0000	0.0	24.0
22.09.25	20.11	20.83	-0.72	0.000	0.000	0.000	0.000	0.000	1.03	6.70	0.0000	0.0	24.0
23.09.25	20.55	21.27	-0.72	0.000	0.000	0.000	0.000	0.000	1.03	6.70	0.0000	0.0	24.0
24.09.25	21.07	21.89	-0.82	0.000	2.160	0.000	2.160	-2.160	1.03	6.70	0.0000	0.0	24.0
25.09.25	20.09	20.87	-0.78	0.000	5.760	0.000	5.760	-5.760	1.02	6.70	0.0000	0.0	24.0
26.09.25	58.38	42.99	15.39	28.550	32.670	28.120	32.400	-4.280	4.57	7.01	0.3690	0.0	24.0
27.09.25	57.76	45.03	12.73	52.720	53.930	51.980	53.450	-1.470	7.74	7.39	0.6600	0.0	24.0
28.09.25	59.40	44.89	14.51	53.880	55.190	52.950	54.710	-1.760	7.70	7.39	0.7690	0.0	24.0
29.09.25	59.97	45.03	14.94	69.980	70.310	68.770	69.670	-0.900	7.82	7.51	1.0300	0.0	24.0
30.09.25	59.93	44.10	15.83	76.830	77.570	75.530	76.850	-1.320	8.13	7.87	1.1950	0.0	24.0
01.10.25	55.33	41.28	14.05	83.450	83.570	82.290	82.910	-0.620	8.59	8.32	1.1550	0.0	24.0
02.10.25	53.67	40.10	13.57	88.320	88.490	87.160	87.870	-0.710	8.75	8.48	1.1800	0.0	24.0
03.10.25	54.83	41.29	13.54	87.570	89.170	86.370	88.450	-2.080	8.77	8.50	1.1660	0.0	24.0
04.10.25	52.55	39.32	13.23	80.690	83.050	79.730	82.520	-2.790	8.79	8.55	1.0510	0.0	24.0
05.10.25	51.90	39.18	12.72	80.920	83.480	79.960	82.940	-2.980	8.80	8.54	1.0160	0.0	24.0
06.10.25	57.13	44.20	12.93	102.590	105.350	101.060	104.360	-3.300	8.58	8.24	1.3040	0.0	24.0
07.10.25	56.72	44.59	12.13	93.360	96.020	91.990	95.160	-3.170	8.38	8.08	1.1100	0.0	24.0
08.10.25	45.46	34.90	10.56	66.120	68.620	65.480	68.230	-2.750	8.26	8.04	0.6940	0.0	24.0
09.10.25	46.69	35.42	11.27	67.020	69.610	66.300	69.130	-2.830	8.27	8.05	0.7470	0.0	24.0
10.10.25	46.96	35.78	11.18	67.390	70.020	66.670	69.540	-2.870	8.33	8.10	0.7440	0.0	24.0
11.10.25	46.67	35.59	11.08	67.330	69.970	66.610	69.490	-2.880	8.33	8.10	0.7350	0.0	24.0
12.10.25	47.47	35.84	11.63	69.740	72.390	68.970	71.910	-2.940	8.24	8.01	0.8020	0.0	24.0
13.10.25	51.50	38.63	12.87	76.190	78.870	75.230	78.390	-3.160	8.19	7.93	0.9680	0.0	24.0
14.10.25	50.37	38.15	12.22	74.630	77.350	73.670	76.870	-3.200	8.17	7.93	0.9010	0.0	24.0
15.10.25	50.28	38.00	12.28	72.960	74.850	72.090	74.380	-2.290	8.07	7.83	0.8810	0.0	24.0
16.10.25	50.69	39.05	11.64	85.050	87.390	83.960	86.780	-2.820	8.15	7.87	0.9760	0.0	24.0
17.10.25	53.41	41.64	11.77	101.980	104.780	100.630	103.910	-3.280	8.13	7.80	1.1860	0.0	24.0
18.10.25	55.06	43.04	12.02	105.960	108.960	104.520	108.000	-3.480	7.89	7.55	1.2530	0.0	24.0
19.10.25	55.43	43.47	11.96	105.930	109.200	104.490	108.240	-3.750	8.06	7.72	1.2460	0.0	24.0
20.10.25	55.02	42.53	12.49	95.990	99.220	94.700	98.400	-3.700	8.13	7.83	1.1820	0.0	24.0
Итого	---	---	---	1955.1	2025.1	1929.23	2009.68	-80.450	---	---	24.3200	0.0	768.0
Среднее	46.01	36.22	9.78	---	---	---	---	---	6.65	7.67	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	23222.380	23439.840	22857.060	23210.420	295.3020	-353.360	1935.0	8296.0
20.10.25 24:00	25177.530	25464.989	24786.290	25220.100	319.6220	-433.810	1935.0	9064.0
Итого за период	1955.149	2025.149	1929.229	2009.680	24.3200	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 24 мкр., 14/15
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00182895

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0х3DD3

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Мг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	21.20	22.25	-1.05	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
20.09.25	21.24	22.26	-1.02	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
21.09.25	21.26	22.26	-1.00	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
22.09.25	21.70	22.58	-0.88	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
23.09.25	21.92	22.82	-0.90	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
24.09.25	22.22	23.02	-0.80	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
25.09.25	21.81	22.66	-0.85	2.640	0.000	2.640	0.000	2.640	6.90	6.70	0.0000	0.0	24.0
26.09.25	58.15	50.48	7.67	54.310	53.880	53.430	53.260	0.170	6.90	6.70	0.3890	0.0	24.0
27.09.25	58.09	48.54	9.55	144.190	141.250	141.970	139.700	2.270	6.90	6.70	1.3510	0.0	24.0
28.09.25	59.62	48.81	10.81	171.450	168.340	168.630	166.420	2.210	6.90	6.70	1.8210	0.0	24.0
29.09.25	60.00	48.33	11.67	180.210	177.160	177.230	175.200	2.030	6.90	6.70	2.0680	0.0	24.0
30.09.25	60.05	47.15	12.90	164.970	161.400	162.250	159.690	2.560	6.90	6.70	2.0870	0.0	24.0
01.10.25	55.43	44.65	10.78	175.370	171.090	172.870	169.470	3.400	6.90	6.70	1.8610	0.0	24.0
02.10.25	53.75	43.65	10.10	181.220	177.910	178.860	176.320	2.540	6.90	6.70	1.8010	0.0	24.0
03.10.25	54.89	44.67	10.22	182.920	179.000	180.390	177.300	3.090	6.90	6.70	1.8430	0.0	24.0
04.10.25	52.67	42.56	10.11	136.220	132.650	134.490	131.500	2.990	6.90	6.70	1.3560	0.0	24.0
05.10.25	51.97	42.25	9.72	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
06.10.25	56.60	46.74	9.86	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
07.10.25	52.80	44.37	8.43	97.820	95.070	96.520	94.190	2.330	6.90	6.70	0.8160	0.0	24.0
08.10.25	45.50	37.45	8.05	141.290	137.030	139.880	136.150	3.730	6.90	6.70	1.1230	0.0	24.0
09.10.25	46.74	38.19	8.55	143.460	139.060	142.020	138.100	3.920	6.90	6.70	1.2110	0.0	24.0
10.10.25	47.00	38.50	8.50	144.320	139.840	142.880	138.880	4.000	6.90	6.70	1.2130	0.0	24.0
11.10.25	46.71	38.31	8.40	144.160	139.680	142.720	138.720	4.000	6.90	6.70	1.1970	0.0	24.0
12.10.25	47.53	38.72	8.81	149.270	144.830	147.710	143.810	3.900	6.90	6.70	1.2970	0.0	24.0
13.10.25	51.56	41.74	9.82	162.980	158.380	160.990	157.120	3.870	6.90	6.70	1.5780	0.0	24.0
14.10.25	50.43	41.06	9.37	159.850	155.360	157.930	154.160	3.770	6.90	6.70	1.4780	0.0	24.0
15.10.25	50.34	40.80	9.54	158.360	153.890	156.440	152.690	3.750	6.90	6.70	1.4920	0.0	24.0
16.10.25	50.73	41.74	8.99	183.640	179.040	181.450	177.570	3.880	6.90	6.70	1.6270	0.0	24.0
17.10.25	53.45	44.54	8.91	217.760	212.910	214.900	210.920	3.980	6.90	6.70	1.9140	0.0	24.0
18.10.25	55.10	46.00	9.10	226.300	221.350	223.180	219.190	3.990	6.90	6.70	2.0270	0.0	24.0
19.10.25	55.47	46.35	9.12	226.420	221.450	223.250	219.290	3.960	6.90	6.70	2.0330	0.0	24.0
20.10.25	55.06	45.46	9.60	205.970	202.510	203.080	200.620	2.460	6.90	6.70	1.9450	0.0	24.0
Итого	---	---	---	3755.1	3663.0	3705.71	3630.27	75.440	---	---	35.5280	0.0	768.0
Среднее	46.28	39.02	7.25	---	---	---	---	---	6.90	6.70	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Мг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	49450.360	49258.720	48668.450	48719.880	493.9740	-51.430	1873.0	8295.0
20.10.25 24:00	53064.170	52784.770	52234.280	52214.000	528.3790	20.280	1873.0	9039.0
Итого за период	3613.809	3526.049	3565.830	3494.120	34.4050	---	0.0	744.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 24 мкр., 27
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00178846

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0х8D39

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	18.95	20.31	-1.36	189.260	14.030	188.990	14.030	174.960	5.60	5.40	0.0000	0.0	24.0
20.09.25	18.94	20.60	-1.66	375.770	0.000	375.250	0.000	375.250	5.60	5.40	0.0000	0.0	24.0
21.09.25	18.86	20.58	-1.72	421.250	0.000	420.740	0.000	420.740	5.60	5.40	0.0000	0.0	24.0
22.09.25	19.70	21.22	-1.52	338.630	0.000	338.150	0.000	338.150	5.60	5.40	0.0000	0.0	24.0
23.09.25	19.92	21.46	-1.54	325.990	0.000	325.510	0.000	325.510	5.60	5.40	0.0000	0.0	24.0
24.09.25	20.49	21.89	-1.40	299.650	0.000	299.170	0.000	299.170	5.60	5.40	0.0000	0.0	24.0
25.09.25	19.17	20.74	-1.57	260.180	0.000	259.790	0.000	259.790	5.60	5.40	0.0000	0.0	24.0
26.09.25	54.56	55.74	-1.18	414.670	352.980	408.350	347.880	60.470	5.60	5.40	2.7710	0.0	24.0
27.09.25	64.89	55.13	9.76	542.780	578.300	532.370	570.170	-37.800	5.60	5.40	5.1990	0.0	24.0
28.09.25	67.24	56.80	10.44	533.710	570.700	522.800	562.160	-39.360	5.60	5.40	5.4570	0.0	24.0
29.09.25	64.96	53.83	11.13	480.670	516.190	471.440	509.210	-37.770	5.60	5.40	5.2400	0.0	24.0
30.09.25	63.08	49.97	13.11	385.500	416.730	378.470	411.820	-33.350	5.60	5.40	4.9580	0.0	24.0
01.10.25	55.87	45.81	10.06	406.800	441.300	400.900	436.900	-36.000	5.60	5.40	4.0240	0.0	24.0
02.10.25	53.18	44.15	9.03	429.770	462.760	424.040	458.490	-34.450	5.60	5.40	3.8180	0.0	24.0
03.10.25	54.26	45.15	9.11	434.320	464.970	428.370	460.520	-32.150	5.60	5.40	3.8920	0.0	24.0
04.10.25	51.95	43.04	8.91	408.070	437.100	402.940	433.260	-30.320	5.60	5.40	3.5840	0.0	24.0
05.10.25	51.32	42.68	8.64	407.270	436.200	402.230	432.400	-30.170	5.60	5.40	3.4680	0.0	24.0
06.10.25	56.39	47.54	8.85	507.260	540.680	499.760	534.910	-35.150	5.60	5.40	4.4090	0.0	24.0
07.10.25	55.83	47.53	8.30	468.530	501.200	461.690	495.800	-34.110	5.60	5.40	3.8000	0.0	24.0
08.10.25	44.79	37.80	6.99	343.980	371.890	340.720	369.360	-28.640	5.60	5.40	2.3750	0.0	24.0
09.10.25	45.93	38.55	7.38	351.530	379.250	348.040	376.610	-28.570	5.60	5.40	2.5660	0.0	24.0
10.10.25	46.20	38.81	7.39	353.780	381.320	350.180	378.680	-28.500	5.60	5.40	2.5780	0.0	24.0
11.10.25	45.92	38.60	7.32	354.150	381.660	350.650	379.020	-28.370	5.60	5.40	2.5600	0.0	24.0
12.10.25	46.73	38.97	7.76	365.330	393.060	361.560	390.230	-28.670	5.60	5.40	2.7980	0.0	24.0
13.10.25	50.85	42.17	8.68	395.930	424.440	391.120	420.850	-29.730	5.60	5.40	3.3940	0.0	24.0
14.10.25	49.74	41.42	8.32	390.740	419.160	386.220	415.740	-29.520	5.60	5.40	3.2090	0.0	24.0
15.10.25	49.61	41.13	8.48	388.700	417.700	384.260	414.340	-30.080	5.60	5.40	3.2550	0.0	24.0
16.10.25	61.25	51.44	9.81	548.170	586.780	538.610	579.390	-40.780	5.60	5.40	5.2690	0.0	24.0
17.10.25	66.80	55.70	11.10	575.640	616.440	564.030	607.560	-43.530	5.60	5.40	6.2580	0.0	24.0
18.10.25	67.12	55.88	11.24	567.900	608.110	556.320	599.280	-42.960	5.60	5.40	6.2560	0.0	24.0
19.10.25	67.48	56.29	11.19	568.290	608.760	556.590	599.800	-43.210	5.60	5.40	6.2220	0.0	24.0
20.10.25	62.12	51.16	10.96	426.090	459.820	418.480	454.150	-35.670	5.60	5.40	4.5530	0.0	24.0
Итого	---	---	---	13260.3	11781.5	13087.74	11652.56	1435.180	---	---	101.9130	0.0	768.0
Среднее	47.94	41.31	6.62	---	---	---	---	---	5.60	5.40	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	111567.600	118310.520	109514.850	116796.980	1216.6810	-7282.130	1875.0	8291.0
20.10.25 24:00	124827.909	130092.050	122602.589	128449.540	1318.5940	-5846.950	1875.0	9059.0
Итого за период	13260.308	11781.529	13087.739	11652.559	101.9130	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 24 мкр., 28
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00168975

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0хFC7D

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
28.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
29.09.25	60.27	50.64	9.63	148.820	174.570	146.340	172.470	-26.130	7.67	7.53	1.4550	0.0	24.0
30.09.25	60.22	48.64	11.58	145.220	146.150	142.830	144.590	-1.760	7.97	7.90	1.6510	0.0	24.0
01.10.25	55.53	45.93	9.60	156.490	158.090	154.280	156.550	-2.270	8.44	8.35	1.4800	0.0	24.0
02.10.25	53.92	45.02	8.90	163.390	165.540	161.190	164.050	-2.860	8.60	8.50	1.4310	0.0	24.0
03.10.25	55.02	46.11	8.91	164.200	167.130	161.940	165.450	-3.510	8.62	8.51	1.4380	0.0	24.0
04.10.25	52.75	44.04	8.71	152.960	156.330	151.040	154.890	-3.850	8.64	8.56	1.3130	0.0	24.0
05.10.25	52.14	43.64	8.50	119.710	122.440	118.200	121.310	-3.110	6.99	6.93	1.0000	0.0	24.0
06.10.25	59.84	51.45	8.39	102.560	104.510	100.850	103.240	-2.390	4.55	4.45	0.8430	0.0	24.0
07.10.25	56.64	49.00	7.64	175.390	176.460	172.790	174.460	-1.670	8.25	8.09	1.3180	0.0	24.0
08.10.25	45.64	38.41	7.23	128.350	129.460	127.120	128.590	-1.470	8.10	8.06	0.9170	0.0	24.0
09.10.25	46.86	39.23	7.63	130.510	132.470	129.170	131.510	-2.340	8.11	8.07	0.9820	0.0	24.0
10.10.25	47.13	39.55	7.58	131.290	133.800	129.850	132.840	-2.990	8.17	8.13	0.9810	0.0	24.0
11.10.25	46.83	39.34	7.49	131.120	133.880	129.760	132.920	-3.160	8.18	8.13	0.9700	0.0	24.0
12.10.25	47.69	39.83	7.86	135.620	138.630	134.140	137.600	-3.460	8.09	8.04	1.0540	0.0	24.0
13.10.25	51.71	43.11	8.60	147.840	151.020	145.980	149.740	-3.760	8.04	7.97	1.2500	0.0	24.0
14.10.25	50.56	42.35	8.21	145.160	148.490	143.480	147.290	-3.810	8.03	7.96	1.1800	0.0	24.0
15.10.25	50.48	42.13	8.35	143.820	147.220	142.140	146.020	-3.880	7.93	7.86	1.1820	0.0	24.0
16.10.25	50.87	43.13	7.74	166.120	169.740	164.170	168.270	-4.100	8.01	7.90	1.2700	0.0	24.0
17.10.25	53.61	46.07	7.54	196.750	200.560	194.160	198.570	-4.410	8.00	7.81	1.4630	0.0	24.0
18.10.25	55.24	47.53	7.71	204.470	208.360	201.590	206.200	-4.610	7.77	7.57	1.5540	0.0	24.0
19.10.25	55.62	47.89	7.73	204.560	208.460	201.680	206.300	-4.620	7.94	7.73	1.5550	0.0	24.0
20.10.25	55.23	47.06	8.17	185.990	189.830	183.410	187.930	-4.520	8.00	7.85	1.4940	0.0	24.0
Итого	---	---	---	3380.3	3463.1	3336.11	3430.79	-94.680	---	---	27.7810	0.0	528.0
Среднее	52.90	44.55	8.35	---	---	---	---	---	7.91	7.81	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
27.09.25 24:00	0	0	0	0	0	0	0	0
20.10.25 24:00	49124.610	50394.579	48360.190	49816.009	394.4160	-1455.820	2208.0	8792.0
Итого за период	49124.610	50394.579	48360.190	49816.009	394.4160	---	2208.0	8792.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 24 мкр., 2
 Потребитель: АО "Жилуправление"
 Прибор: ТЭМ-106 Заводской номер: 3060257
 Формула: $Q = M1(h1 - h2)$
 Тип системы: Подача + расходомер

Система: 1

ТВ1

	ДУ, мм	Gmin, м3/ч	Gmax, м3/ч	Kv, л/имп	Fmax, КГц
1	80	8	192	10	---
2	80	8	192	10	---

Дата	Q, (Гкал)	M1, (т)	M2, (т)	dM, (т)	T1, (°C)	T2, (°C)	P1, (МПа)	P2, (МПа)	Время наработки, (ч)
19.09.25	н/д	н/д	н/д	н/д	22.175	23.585	0.0	0.5	н/д
20.09.25	0.000	0.00	82.81	-82.8	22.108	23.502	0.0	0.5	24.00
21.09.25	0.000	0.00	90.21	-90.2	22.187	23.566	0.0	0.5	24.00
22.09.25	0.000	0.00	100.76	-100.8	22.473	23.761	0.0	0.5	24.00
23.09.25	0.000	0.00	82.29	-82.3	22.592	23.936	0.0	0.5	24.00
24.09.25	0.000	0.00	54.35	-54.4	22.813	24.257	0.0	0.5	24.00
25.09.25	0.000	1.25	3.07	-1.8	22.263	23.609	0.0	0.5	24.00
26.09.25	1.599	126.04	124.21	1.8	59.882	47.082	0.0	0.6	24.00
27.09.25	2.392	197.79	196.48	1.3	57.895	45.678	0.0	0.6	24.00
28.09.25	2.494	192.86	191.45	1.4	59.587	46.531	0.0	0.6	24.00
29.09.25	2.542	194.72	193.15	1.6	59.866	46.743	0.0	0.6	24.00
30.09.25	2.440	173.53	171.75	1.8	60.118	45.924	0.0	0.7	24.00
01.10.25	2.103	183.52	181.39	2.1	55.478	43.870	0.0	0.7	24.00
02.10.25	2.006	190.22	188.04	2.2	53.571	42.873	0.0	0.7	24.00
03.10.25	2.050	192.03	190.47	1.6	54.869	44.043	0.0	0.7	24.00
04.10.25	1.879	178.60	177.25	1.3	52.557	41.882	0.0	0.7	24.00
05.10.25	1.817	179.17	177.89	1.3	51.909	41.611	0.0	0.8	24.00
06.10.25	2.281	224.08	222.75	1.3	56.940	46.620	0.0	0.7	24.00
07.10.25	2.020	210.50	209.23	1.3	56.870	47.136	0.0	0.7	24.00
08.10.25	1.252	149.59	148.46	1.1	45.345	36.826	0.0	0.7	24.00
09.10.25	1.356	152.35	151.21	1.1	46.642	37.587	0.0	0.7	24.00
10.10.25	1.358	153.26	152.10	1.2	46.918	37.902	0.0	0.7	24.00
11.10.25	1.351	153.14	151.98	1.2	46.643	37.670	0.0	0.7	24.00
12.10.25	1.456	157.75	156.58	1.2	47.338	37.957	0.0	0.7	24.00
13.10.25	1.764	172.11	165.14	7.0	51.488	41.096	0.0	0.7	24.00
14.10.25	1.652	169.27	1.84	167.4	50.367	40.463	0.0	0.7	24.00
15.10.25	1.659	167.63	7.73	159.9	50.265	40.225	0.0	0.7	24.00
16.10.25	1.772	191.98	2.81	189.2	50.628	41.256	0.0	0.7	24.00
17.10.25	2.055	227.11	15.18	211.9	53.276	44.089	0.0	0.7	24.00
18.10.25	2.204	236.38	36.74	199.6	55.016	45.560	0.0	0.6	24.00
19.10.25	2.212	236.37	110.39	126.0	55.387	45.894	0.0	0.7	24.00
20.10.25	2.115	216.11	214.50	1.6	54.989	45.067	0.0	0.7	24.00
Итого	47.83	4627.4	3952.2	675.1	---	---	---	---	744.00
Среднее	---	---	---	---	46.58	38.68	0.0	0.6	---

Показания интеграторов

Дата	Q, (Гкал)	M1, (т)	M2, (т)	Время наработки, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д
20.10.25 24:00	9127.9	654754.7	651130.0	87228.6
Итого за период	н/д	н/д	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 24 мкр., 3
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00169001

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0x0E76

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Мг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	21.48	21.97	-0.49	0.640	1.600	0.640	1.600	-0.960	1.22	1.51	0.0000	0.0	24.0
20.09.25	21.73	22.00	-0.27	0.640	0.640	0.640	0.640	0.000	1.22	1.47	0.0000	0.0	24.0
21.09.25	21.45	21.90	-0.45	0.960	1.280	0.960	1.280	-0.320	1.22	1.31	0.0000	0.0	24.0
22.09.25	21.80	22.26	-0.46	0.640	0.640	0.640	0.640	0.000	1.23	6.23	0.0000	0.0	24.0
23.09.25	21.91	22.37	-0.46	0.960	0.960	0.960	0.960	0.000	1.22	6.70	0.0000	0.0	24.0
24.09.25	23.21	23.85	-0.64	0.640	1.280	0.640	1.280	-0.640	1.26	6.70	0.0000	0.0	24.0
25.09.25	23.27	24.02	-0.75	0.960	0.960	0.960	0.960	0.000	1.25	6.70	0.0000	0.0	24.0
26.09.25	59.63	51.20	8.43	80.970	80.600	79.650	79.620	0.030	4.85	5.11	0.6750	0.0	24.0
27.09.25	58.31	49.45	8.86	134.870	131.920	132.730	130.480	2.250	7.61	4.46	1.1800	0.0	24.0
28.09.25	59.94	50.36	9.58	132.240	129.120	130.080	127.600	2.480	7.63	4.42	1.2500	0.0	24.0
29.09.25	60.33	49.96	10.37	136.720	132.940	134.470	131.390	3.080	7.77	4.53	1.4000	0.0	24.0
30.09.25	60.38	48.40	11.98	126.690	123.310	124.570	121.990	2.580	8.10	4.89	1.4980	0.0	24.0
01.10.25	55.68	45.66	10.02	135.240	131.850	133.300	130.550	2.750	8.58	5.35	1.3430	0.0	24.0
02.10.25	54.01	44.38	9.63	142.110	139.150	140.160	137.900	2.260	8.75	5.50	1.3580	0.0	24.0
03.10.25	55.16	45.43	9.73	143.390	140.300	141.430	138.950	2.480	8.76	5.51	1.3810	0.0	24.0
04.10.25	52.89	43.34	9.55	133.830	130.560	132.150	129.360	2.790	8.80	5.56	1.2710	0.0	24.0
05.10.25	52.24	43.13	9.11	134.460	131.100	132.780	129.900	2.880	8.81	5.55	1.2180	0.0	24.0
06.10.25	57.48	48.28	9.20	170.120	166.170	167.600	164.290	3.310	8.56	5.20	1.5490	0.0	24.0
07.10.25	56.94	48.37	8.57	156.980	153.290	154.570	151.520	3.050	8.38	5.03	1.3360	0.0	24.0
08.10.25	45.76	38.22	7.54	111.850	109.010	110.740	108.220	2.520	8.30	5.07	0.8400	0.0	24.0
09.10.25	46.99	39.03	7.96	113.690	110.740	112.490	110.020	2.470	8.30	5.07	0.9040	0.0	24.0
10.10.25	47.26	39.33	7.93	114.390	111.430	113.190	110.710	2.480	8.36	5.12	0.9030	0.0	24.0
11.10.25	46.97	38.96	8.01	114.240	111.310	113.040	110.590	2.450	8.36	5.13	0.9110	0.0	24.0
12.10.25	47.79	39.34	8.45	118.040	115.070	116.740	114.270	2.470	8.28	5.03	0.9920	0.0	24.0
13.10.25	51.83	42.58	9.25	128.620	125.320	126.990	124.270	2.720	8.20	4.93	1.1790	0.0	24.0
14.10.25	50.70	41.92	8.78	126.300	123.220	124.830	122.260	2.570	8.20	4.92	1.0990	0.0	24.0
15.10.25	50.61	41.74	8.87	125.250	122.130	123.810	121.170	2.640	8.09	4.82	1.1030	0.0	24.0
16.10.25	50.99	42.74	8.25	144.350	141.010	142.640	139.780	2.860	8.16	4.84	1.1820	0.0	24.0
17.10.25	53.71	45.58	8.13	170.900	167.060	168.660	165.430	3.230	8.11	4.73	1.3790	0.0	24.0
18.10.25	55.36	47.04	8.32	177.550	173.680	175.060	171.820	3.240	7.87	4.46	1.4650	0.0	24.0
19.10.25	55.74	47.40	8.34	177.520	173.650	174.910	171.730	3.180	8.04	4.62	1.4670	0.0	24.0
20.10.25	55.34	46.63	8.71	161.600	158.040	159.280	156.410	2.870	8.13	4.75	1.3960	0.0	24.0
Итого	---	---	---	3417.3	3339.3	3371.31	3307.59	63.720	---	---	30.2790	0.0	768.0
Среднее	46.77	39.90	6.87	---	---	---	---	---	6.61	4.85	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Мг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	38462.630	37688.970	37856.090	37265.650	352.0320	590.440	1316.0	8843.0
20.10.25 24:00	41879.990	41028.310	41227.400	40573.240	382.3110	654.160	1316.0	9611.0
Итого за период	3417.360	3339.339	3371.310	3307.589	30.2790	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 24 мкр., 4
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00177120

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0x8202

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Мг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	24.29	24.98	-0.69	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
20.09.25	24.30	24.98	-0.68	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
21.09.25	24.32	25.04	-0.72	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
22.09.25	24.63	25.28	-0.65	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
23.09.25	25.00	26.01	-1.01	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
24.09.25	26.44	29.03	-2.59	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
25.09.25	26.45	29.07	-2.62	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
26.09.25	59.41	49.04	10.37	154.030	153.570	151.520	151.840	-0.320	6.20	6.00	1.5680	0.0	24.0
27.09.25	58.11	48.09	10.02	254.160	252.910	250.220	250.200	0.020	6.20	6.00	2.5040	0.0	24.0
28.09.25	59.76	49.03	10.73	247.520	246.330	243.480	243.530	-0.050	6.20	6.00	2.6080	0.0	24.0
29.09.25	60.14	49.25	10.89	247.900	246.530	243.780	243.710	0.070	6.20	6.00	2.6530	0.0	24.0
30.09.25	60.23	48.46	11.77	221.060	220.070	217.370	217.650	-0.280	6.20	6.00	2.5550	0.0	24.0
01.10.25	55.56	45.92	9.64	229.240	228.630	225.980	226.380	-0.400	6.20	6.00	2.1750	0.0	24.0
02.10.25	53.82	45.01	8.81	244.070	242.690	240.810	240.360	0.450	6.20	6.00	2.1160	0.0	24.0
03.10.25	55.00	46.09	8.91	245.630	243.330	242.130	240.910	1.220	6.20	6.00	2.1510	0.0	24.0
04.10.25	52.71	44.00	8.71	229.790	227.860	226.830	225.700	1.130	6.20	6.00	1.9710	0.0	24.0
05.10.25	52.06	43.64	8.42	230.930	229.270	228.040	227.220	0.820	6.20	6.00	1.9170	0.0	24.0
06.10.25	57.24	48.79	8.45	291.620	289.490	287.170	286.230	0.940	6.20	6.00	2.4250	0.0	24.0
07.10.25	57.15	49.11	8.04	262.080	260.300	258.090	257.350	0.740	6.20	6.00	2.0770	0.0	24.0
08.10.25	45.56	37.96	7.60	170.430	168.580	168.740	167.430	1.310	6.20	6.00	1.2800	0.0	24.0
09.10.25	46.82	39.25	7.57	191.410	189.950	189.450	188.550	0.900	6.20	6.00	1.4320	0.0	24.0
10.10.25	47.07	39.66	7.41	196.230	194.520	194.180	193.080	1.100	6.20	6.00	1.4350	0.0	24.0
11.10.25	46.79	39.38	7.41	195.790	194.190	193.760	192.750	1.010	6.20	6.00	1.4360	0.0	24.0
12.10.25	47.58	39.83	7.75	202.650	201.130	200.560	199.600	0.960	6.20	6.00	1.5560	0.0	24.0
13.10.25	51.65	43.15	8.50	221.230	219.430	218.500	217.500	1.000	6.20	6.00	1.8540	0.0	24.0
14.10.25	50.52	42.36	8.16	217.490	216.060	214.900	214.230	0.670	6.20	6.00	1.7510	0.0	24.0
15.10.25	50.43	42.16	8.27	215.510	213.750	212.940	212.000	0.940	6.20	6.00	1.7580	0.0	24.0
16.10.25	50.80	43.13	7.67	248.090	246.640	245.050	244.560	0.490	6.20	6.00	1.8770	0.0	24.0
17.10.25	53.50	46.00	7.50	294.080	292.250	290.160	289.390	0.770	6.20	6.00	2.1750	0.0	24.0
18.10.25	55.17	47.50	7.67	305.810	304.220	301.490	301.030	0.460	6.20	6.00	2.3120	0.0	24.0
19.10.25	55.54	47.88	7.66	305.870	304.150	301.550	300.820	0.730	6.20	6.00	2.3050	0.0	24.0
20.10.25	55.16	47.06	8.10	276.550	274.810	272.650	271.930	0.720	6.20	6.00	2.2070	0.0	24.0
Итого	---	---	---	5899.1	5860.6	5819.35	5803.95	15.400	---	---	50.0980	0.0	768.0
Среднее	47.28	40.81	6.47	---	---	---	---	---	6.20	6.00	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Мг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	66338.810	65654.260	65272.600	64888.910	563.9970	383.690	1960.0	8272.0
20.10.25 24:00	72237.979	71514.920	71091.949	70692.860	614.0950	399.090	1960.0	9040.0
Итого за период	5899.169	5860.660	5819.348	5803.949	50.0980	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 24 мкр., 5
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00129521

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0x26FA

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	20.99	21.70	-0.71	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
20.09.25	21.02	21.74	-0.72	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
21.09.25	21.14	21.82	-0.68	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
22.09.25	21.17	21.81	-0.64	0.320	0.320	0.320	0.320	0.000	3.45	3.40	0.0000	0.0	24.0
23.09.25	21.55	22.96	-1.41	2.240	0.000	2.240	0.000	2.240	1.00	1.05	0.0000	0.0	24.0
24.09.25	22.51	23.51	-1.00	5.120	0.000	5.120	0.000	5.120	1.00	1.05	0.0000	0.0	24.0
25.09.25	20.93	21.70	-0.77	8.010	0.000	8.010	0.000	8.010	1.00	1.04	0.0000	0.0	24.0
26.09.25	54.98	49.02	5.96	68.380	65.910	67.390	65.150	2.240	4.64	4.52	0.4940	0.0	24.0
27.09.25	58.00	50.12	7.88	141.700	142.370	139.540	140.690	-1.150	7.75	7.54	1.0950	0.0	24.0
28.09.25	59.64	50.38	9.26	142.520	143.120	140.170	141.440	-1.270	7.77	7.54	1.2970	0.0	24.0
29.09.25	59.68	49.62	10.06	144.180	144.470	141.870	142.830	-0.960	7.92	7.67	1.4250	0.0	24.0
30.09.25	60.12	48.16	11.96	127.610	127.900	125.500	126.570	-1.070	8.27	8.07	1.5000	0.0	24.0
01.10.25	55.49	45.52	9.97	137.340	137.840	135.400	136.500	-1.100	8.77	8.53	1.3480	0.0	24.0
02.10.25	53.87	44.53	9.34	145.290	145.520	143.330	144.210	-0.880	8.95	8.69	1.3380	0.0	24.0
03.10.25	55.02	45.59	9.43	146.680	147.270	144.710	145.830	-1.120	8.95	8.69	1.3620	0.0	24.0
04.10.25	52.73	43.45	9.28	135.390	136.260	133.710	135.060	-1.350	9.01	8.77	1.2400	0.0	24.0
05.10.25	52.09	43.17	8.92	136.090	137.030	134.410	135.830	-1.420	9.00	8.76	1.1970	0.0	24.0
06.10.25	57.37	48.52	8.85	176.600	177.400	173.940	175.510	-1.570	8.80	8.44	1.5360	0.0	24.0
07.10.25	57.06	48.72	8.34	160.850	161.860	158.410	159.990	-1.580	8.62	8.28	1.3150	0.0	24.0
08.10.25	45.68	38.32	7.36	109.410	110.570	108.370	109.840	-1.470	8.52	8.31	0.7950	0.0	24.0
09.10.25	46.88	39.08	7.80	111.600	112.660	110.400	111.940	-1.540	8.52	8.31	0.8600	0.0	24.0
10.10.25	47.15	39.19	7.96	113.530	114.590	112.330	113.870	-1.540	8.56	8.35	0.8950	0.0	24.0
11.10.25	46.86	38.97	7.89	113.250	114.320	112.050	113.600	-1.550	8.59	8.38	0.8840	0.0	24.0
12.10.25	47.69	39.43	8.26	117.880	118.880	116.580	118.070	-1.490	8.49	8.27	0.9630	0.0	24.0
13.10.25	51.69	42.63	9.06	130.440	131.370	128.790	130.190	-1.400	8.43	8.19	1.1630	0.0	24.0
14.10.25	50.57	41.87	8.70	127.720	128.710	126.230	127.690	-1.460	8.41	8.17	1.0970	0.0	24.0
15.10.25	50.47	41.66	8.81	126.510	127.530	125.070	126.570	-1.500	8.31	8.08	1.0990	0.0	24.0
16.10.25	50.87	42.76	8.11	148.840	149.880	147.130	148.650	-1.520	8.40	8.11	1.1930	0.0	24.0
17.10.25	53.58	45.70	7.88	179.270	180.110	176.890	178.360	-1.470	8.40	8.02	1.3930	0.0	24.0
18.10.25	55.23	47.19	8.04	186.970	187.740	184.330	185.820	-1.490	8.15	7.76	1.4830	0.0	24.0
19.10.25	55.60	47.54	8.06	187.090	187.780	184.450	185.860	-1.410	8.33	7.94	1.4840	0.0	24.0
20.10.25	55.20	46.66	8.54	166.250	167.120	163.950	165.470	-1.520	8.40	8.05	1.3990	0.0	24.0
Итого	---	---	---	3497.0	3498.5	3450.64	3465.86	-15.220	---	---	29.8550	0.0	768.0
Среднее	46.33	39.78	6.55	---	---	---	---	---	7.35	7.13	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	40631.080	40460.530	39987.330	39991.680	357.1950	-4.350	2104.0	8128.0
20.10.25 24:00	44128.159	43959.060	43437.970	43457.540	387.0500	-19.570	2104.0	8896.0
Итого за период	3497.078	3498.529	3450.639	3465.860	29.8550	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 24 мкр., 7
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00166015

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0x5FF4

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	18.63	18.11	0.52	8.660	0.000	8.660	0.000	8.660	2.24	6.70	0.0000	0.0	24.0
20.09.25	18.54	18.09	0.45	4.160	0.000	4.160	0.000	4.160	4.47	6.70	0.0000	0.0	24.0
21.09.25	18.62	18.17	0.45	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
22.09.25	18.61	18.33	0.28	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
23.09.25	19.29	18.86	0.43	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
24.09.25	19.63	19.32	0.31	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
25.09.25	64.06	57.73	6.33	130.540	130.450	128.090	128.430	-0.340	6.90	6.70	0.7820	0.0	24.0
26.09.25	64.63	58.25	6.38	319.330	318.350	313.270	313.350	-0.080	6.90	6.70	1.9790	0.0	24.0
27.09.25	57.57	49.48	8.09	192.360	195.120	189.470	192.930	-3.460	6.90	6.70	1.5330	0.0	24.0
28.09.25	59.18	50.44	8.74	187.140	189.980	184.120	187.730	-3.610	6.90	6.70	1.6090	0.0	24.0
29.09.25	59.50	50.55	8.95	188.570	191.460	185.500	189.190	-3.690	6.90	6.70	1.6580	0.0	24.0
30.09.25	59.60	49.79	9.81	165.180	168.580	162.510	166.600	-4.090	6.90	6.70	1.5920	0.0	24.0
01.10.25	55.02	47.05	7.97	177.740	180.860	175.260	178.970	-3.710	6.90	6.70	1.3960	0.0	24.0
02.10.25	53.34	45.89	7.45	188.880	191.310	186.320	189.450	-3.130	6.90	6.70	1.3860	0.0	24.0
03.10.25	54.51	47.00	7.51	190.880	192.440	188.210	190.480	-2.270	6.90	6.70	1.4130	0.0	24.0
04.10.25	52.22	44.81	7.41	176.880	178.640	174.690	176.960	-2.270	6.90	6.70	1.2910	0.0	24.0
05.10.25	51.58	44.45	7.13	177.820	179.480	175.660	177.800	-2.140	6.90	6.70	1.2510	0.0	24.0
06.10.25	56.81	49.65	7.16	228.540	228.430	225.090	225.790	-0.700	6.90	6.70	1.6060	0.0	24.0
07.10.25	56.61	49.76	6.85	208.800	209.450	205.670	207.000	-1.330	6.90	6.70	1.3910	0.0	24.0
08.10.25	45.13	39.01	6.12	143.590	146.730	142.220	145.660	-3.440	6.90	6.70	0.8700	0.0	24.0
09.10.25	46.35	39.94	6.41	147.940	150.910	146.500	149.710	-3.210	6.90	6.70	0.9410	0.0	24.0
10.10.25	46.63	40.27	6.36	149.380	152.330	147.940	151.130	-3.190	6.90	6.70	0.9420	0.0	24.0
11.10.25	46.35	40.03	6.32	149.160	152.180	147.720	150.980	-3.260	6.90	6.70	0.9340	0.0	24.0
12.10.25	47.12	40.52	6.60	154.660	157.500	153.080	156.220	-3.140	6.90	6.70	1.0080	0.0	24.0
13.10.25	51.16	43.98	7.18	169.860	172.080	167.780	170.540	-2.760	6.90	6.70	1.2060	0.0	24.0
14.10.25	50.04	43.21	6.83	166.540	168.950	164.620	167.510	-2.890	6.90	6.70	1.1230	0.0	24.0
15.10.25	49.95	42.96	6.99	164.910	167.350	162.990	165.910	-2.920	6.90	6.70	1.1380	0.0	24.0
16.10.25	50.37	43.84	6.53	192.340	193.880	190.030	192.170	-2.140	6.90	6.70	1.2380	0.0	24.0
17.10.25	53.09	46.73	6.36	230.140	230.360	227.090	228.020	-0.930	6.90	6.70	1.4400	0.0	24.0
18.10.25	54.76	48.23	6.53	239.740	239.600	236.380	236.960	-0.580	6.90	6.70	1.5390	0.0	24.0
19.10.25	55.13	48.60	6.53	239.880	239.720	236.520	237.080	-0.560	6.90	6.70	1.5420	0.0	24.0
20.10.25	54.71	47.82	6.89	214.140	214.650	211.160	212.360	-1.200	6.90	7.00	1.4530	0.0	24.0
Итого	---	---	---	4907.7	4940.7	4840.71	4888.93	-48.220	---	---	34.2610	0.0	768.0
Среднее	47.14	41.27	5.87	---	---	---	---	---	6.68	6.71	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	39640.060	39760.680	38969.200	39277.750	382.8210	-308.550	1438.0	7505.0
20.10.25 24:00	44547.819	44701.470	43809.910	44166.680	417.0820	-356.770	1438.0	8273.0
Итого за период	4907.759	4940.790	4840.710	4888.930	34.2610	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 24 мкр., 8
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00234689

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0xВ0FD

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
28.09.25	59.41	48.85	10.56	135.850	138.950	133.690	137.420	-3.730	6.90	6.70	1.4070	0.0	24.0
29.09.25	59.75	48.67	11.08	138.170	141.920	135.910	140.360	-4.450	6.90	6.70	1.5070	0.0	24.0
30.09.25	59.79	47.75	12.04	123.330	127.270	121.300	125.950	-4.650	6.90	6.70	1.4560	0.0	24.0
01.10.25	55.25	45.38	9.87	130.150	134.610	128.290	133.310	-5.020	6.90	6.70	1.2630	0.0	24.0
02.10.25	53.57	44.30	9.27	134.750	139.350	133.020	138.100	-5.080	6.90	6.70	1.2310	0.0	24.0
03.10.25	54.72	45.21	9.51	136.280	140.710	134.360	139.380	-5.020	6.90	6.70	1.2770	0.0	24.0
04.10.25	52.45	43.00	9.45	128.130	132.380	126.450	131.180	-4.730	6.90	6.70	1.1940	0.0	24.0
05.10.25	51.81	42.69	9.12	128.740	132.960	127.060	131.760	-4.700	6.90	6.70	1.1590	0.0	24.0
06.10.25	57.04	47.78	9.26	162.840	167.740	160.360	165.950	-5.590	6.90	6.70	1.4820	0.0	24.0
07.10.25	56.60	47.88	8.72	149.860	154.490	147.580	152.760	-5.180	6.90	6.70	1.2820	0.0	24.0
08.10.25	45.37	37.64	7.73	107.790	111.520	106.770	110.770	-4.000	6.90	6.70	0.8230	0.0	24.0
09.10.25	46.59	38.46	8.13	109.280	113.010	108.100	112.290	-4.190	6.90	6.70	0.8750	0.0	24.0
10.10.25	46.86	38.79	8.07	109.900	113.600	108.700	112.880	-4.180	6.90	6.70	0.8750	0.0	24.0
11.10.25	46.57	38.62	7.95	109.790	113.520	108.610	112.800	-4.190	6.90	6.70	0.8630	0.0	24.0
12.10.25	47.36	39.01	8.35	113.540	117.330	112.280	116.540	-4.260	6.90	6.70	0.9340	0.0	24.0
13.10.25	51.38	42.24	9.14	123.690	127.610	122.200	126.570	-4.370	6.90	6.70	1.1150	0.0	24.0
14.10.25	50.27	41.49	8.78	121.450	125.360	120.010	124.400	-4.390	6.90	6.70	1.0510	0.0	24.0
15.10.25	50.18	41.28	8.90	120.360	124.230	118.920	123.270	-4.350	6.90	6.70	1.0560	0.0	24.0
16.10.25	50.61	42.30	8.31	138.870	143.200	137.160	141.970	-4.810	6.90	6.70	1.1360	0.0	24.0
17.10.25	53.34	45.15	8.19	164.250	169.290	162.040	167.700	-5.660	6.90	6.70	1.3270	0.0	24.0
18.10.25	55.00	46.60	8.40	170.700	175.930	168.300	174.190	-5.890	6.90	6.70	1.4130	0.0	24.0
19.10.25	55.37	46.96	8.41	170.790	176.030	168.390	174.140	-5.750	6.90	6.70	1.4140	0.0	24.0
20.10.25	54.95	46.16	8.79	153.280	158.000	151.150	156.410	-5.260	6.90	6.70	1.3250	0.0	24.0
Итого	---	---	---	3081.7	3179.0	3040.65	3150.10	-109.450	---	---	27.4650	0.0	552.0
Среднее	52.79	43.74	9.04	---	---	---	---	---	6.90	6.70	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
26.09.25 24:00	0	0	0	0	0	0	0	0
20.10.25 24:00	3344.560	3390.450	3300.170	3359.240	29.3170	-59.070	1171.0	2270.0
Итого за период	3344.560	3390.450	3300.170	3359.240	29.3170	---	1171.0	2270.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ИМ2300, Суточный с 19.09.25 по 20.10.25

Объект: г. Октябрьский, 25 мкр., 11
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ508

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	0.00	22.36	133.35	22.72	126.65	0.00	24.00	0.00	0.00
21.09.25	0.00	22.34	80.86	22.71	76.90	0.00	24.00	0.00	0.00
22.09.25	0.00	22.29	46.76	22.68	48.28	0.00	24.00	0.00	0.00
23.09.25	0.00	22.52	36.76	22.84	37.68	0.00	24.00	0.00	0.00
24.09.25	0.00	22.94	31.78	23.27	35.95	0.00	24.00	0.00	0.00
25.09.25	0.00	23.15	34.67	23.46	34.96	0.00	24.00	0.00	0.00
26.09.25	0.00	22.77	30.82	23.12	31.82	0.00	24.00	0.00	0.00
27.09.25	0.65	33.76	175.78	32.02	174.77	11.66	24.00	0.00	0.00
28.09.25	1.37	47.07	349.48	43.14	349.90	24.00	24.00	0.00	0.00
29.09.25	1.52	47.46	354.43	43.18	354.63	24.00	24.00	0.00	0.00
30.09.25	1.56	45.66	347.88	41.16	347.64	24.00	24.00	0.00	0.00
01.10.25	1.65	45.98	331.24	40.98	330.76	24.00	24.00	0.00	0.00
02.10.25	1.74	46.39	351.28	41.42	350.84	24.00	24.00	0.00	0.00
03.10.25	1.73	46.35	345.88	41.33	344.87	23.98	23.98	0.00	0.00
04.10.25	1.80	47.65	326.54	42.17	325.37	23.99	23.99	0.00	0.00
05.10.25	1.98	50.30	319.94	44.10	318.93	24.00	24.00	0.00	0.00
06.10.25	1.90	49.70	319.23	43.72	318.15	24.00	24.00	0.00	0.00
07.10.25	1.69	47.48	308.41	42.00	307.38	24.00	24.00	0.00	0.00
08.10.25	1.52	45.56	301.96	40.52	301.02	24.00	24.00	0.00	0.00
09.10.25	1.44	44.63	299.77	39.80	299.03	24.00	24.00	0.00	0.00
10.10.25	1.52	45.52	300.10	40.44	299.61	24.00	24.00	0.00	0.00
11.10.25	1.51	45.71	299.90	40.65	299.52	24.00	24.00	0.00	0.00
12.10.25	1.54	46.57	275.50	40.74	275.06	24.00	24.00	0.00	0.00
13.10.25	1.49	45.07	299.24	40.08	298.08	24.00	24.00	0.00	0.00
14.10.25	1.53	45.27	298.03	40.13	296.73	24.00	24.00	0.00	0.00
15.10.25	1.62	46.44	301.61	41.07	300.41	24.00	24.00	0.00	0.00
16.10.25	1.86	49.83	289.21	43.36	288.29	24.00	24.00	0.00	0.00
17.10.25	1.93	50.39	291.84	43.73	290.71	23.99	24.00	0.00	0.00
18.10.25	1.96	50.45	309.08	44.08	308.30	24.00	24.00	0.00	0.00
19.10.25	1.95	50.13	306.53	43.76	305.76	24.00	24.00	0.00	0.00
20.10.25	1.97	50.44	306.01	44.00	305.22	24.00	24.00	0.00	0.00
Итого	39.43	---	7803.87	---	7783.22	563.62	743.97	0.00	0.00
Среднее	---	41.361	---	37.367	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	3553.53	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 25 мкр., 12
 Потребитель: АО "Жилуправление"
 Прибор: ТЭМ-106 Заводской номер: 3060249
 Формула: $Q = M1(h1 - h2)$
 Тип системы: Подача + расходомер

Система: 1

ТВ1

	ДУ, мм	Gmin, м3/ч	Gmax, м3/ч	Kv, л/имп	Fmax, КГц
1	80	9.6	160	10	---
2	80	9.42	157	10	---

Дата	Q, (Гкал)	M1, (т)	M2, (т)	dM, (т)	T1, (°C)	T2, (°C)	P1, (МПа)	P2, (МПа)	Время наработки, (ч)
19.09.25	0.000	0.00	0.00	0.0	16.489	15.853	0.5	0.5	24.00
20.09.25	0.000	0.00	0.00	0.0	16.579	15.985	0.5	0.5	24.00
21.09.25	0.000	0.00	0.00	0.0	16.658	16.043	0.5	0.5	24.00
22.09.25	0.000	0.00	0.00	0.0	17.593	17.091	0.5	0.5	24.00
23.09.25	0.000	0.00	0.00	0.0	18.279	17.703	0.5	0.5	24.00
24.09.25	0.000	0.00	0.00	0.0	19.444	18.699	0.5	0.5	24.00
25.09.25	0.411	144.72	145.10	-0.4	38.251	35.408	0.5	0.5	24.00
26.09.25	1.349	363.57	368.20	-4.6	42.518	38.803	0.5	0.5	24.00
27.09.25	1.802	341.27	344.53	-3.3	49.307	44.025	0.5	0.5	24.00
28.09.25	1.894	337.02	340.02	-3.0	50.495	44.871	0.5	0.5	24.00
29.09.25	1.918	333.80	336.46	-2.7	49.909	44.158	0.5	0.5	24.00
30.09.25	1.890	316.42	318.66	-2.2	48.828	42.849	0.5	0.5	24.00
01.10.25	1.704	271.36	272.93	-1.6	47.451	41.167	0.5	0.5	24.00
02.10.25	1.462	211.24	212.49	-1.2	45.837	38.909	0.5	0.5	24.00
03.10.25	1.533	268.12	272.54	-4.4	45.633	39.912	0.5	0.5	24.00
04.10.25	1.482	337.71	341.33	-3.6	43.508	39.114	0.5	0.5	24.00
05.10.25	1.465	334.36	337.56	-3.2	43.158	38.771	0.5	0.5	24.00
06.10.25	1.502	278.13	280.84	-2.7	44.509	39.101	0.5	0.5	24.00
07.10.25	1.530	293.89	296.83	-2.9	45.136	39.926	0.5	0.5	24.00
08.10.25	1.441	328.37	332.68	-4.3	43.962	39.569	0.5	0.5	24.00
09.10.25	1.481	327.02	331.42	-4.4	44.246	39.714	0.5	0.5	24.00
10.10.25	1.459	324.15	328.27	-4.1	44.388	39.882	0.5	0.5	24.00
11.10.25	1.433	322.97	326.78	-3.8	44.138	39.695	0.5	0.5	24.00
12.10.25	1.437	320.99	325.33	-4.3	43.662	39.180	0.5	0.5	24.00
13.10.25	1.490	319.80	324.63	-4.8	43.984	39.319	0.5	0.5	24.00
14.10.25	1.583	323.41	328.27	-4.9	45.264	40.363	0.5	0.5	24.00
15.10.25	1.794	325.38	330.09	-4.7	48.589	43.070	0.5	0.5	24.00
16.10.25	1.662	317.98	322.98	-5.0	46.243	41.012	0.5	0.5	24.00
17.10.25	1.786	320.68	325.20	-4.5	47.849	42.276	0.5	0.5	24.00
18.10.25	1.775	316.45	320.31	-3.9	47.391	41.778	0.5	0.5	24.00
19.10.25	1.781	315.56	319.35	-3.8	47.684	42.034	0.5	0.5	24.00
20.10.25	1.756	315.27	318.64	-3.4	47.484	41.909	0.5	0.5	24.00
Итого	40.82	8009.6	8101.4	-91.7	---	---	---	---	768.00
Среднее	---	---	---	---	40.45	36.19	0.5	0.5	---

Показания интеграторов

Дата	Q, (Гкал)	M1, (т)	M2, (т)	Время наработки, (ч)
18.09.25 24:00	8076.6	774438.5	783182.2	81865.8
20.10.25 24:00	8117.4	782448.1	791283.6	82633.8
Итого за период	40.8	8009.6	8101.4	768.0

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 25 мкр., 13
 Потребитель: АО "Жилуправление"
 Прибор: ТЭМ-106 Заводской номер: 3060256
 Формула: $Q = M1(h1 - h2)$
 Тип системы: Подача + расходомер

Система: 1

ТВ1

	ДУ, мм	Gmin, м3/ч	Gmax, м3/ч	Kv, л/имп	Fmax, КГц
1	80	8	160	10	---
2	80	8.55	171	10	---

Дата	Q, (Гкал)	M1, (т)	M2, (т)	dM, (т)	T1, (°C)	T2, (°C)	P1, (МПа)	P2, (МПа)	Время наработки, (ч)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-
28.09.25	-	-	-	-	-	-	-	-	-
29.09.25	-	-	-	-	-	-	-	-	-
30.09.25	-	-	-	-	-	-	-	-	-
01.10.25	-	-	-	-	-	-	-	-	-
02.10.25	-	-	-	-	-	-	-	-	-
03.10.25	-	-	-	-	-	-	-	-	-
04.10.25	-	-	-	-	-	-	-	-	-
05.10.25	-	-	-	-	-	-	-	-	-
06.10.25	н/д	н/д	н/д	н/д	13.932	12.256	0.0	0.0	н/д
07.10.25	1.548	336.84	336.03	0.8	45.087	40.491	0.5	0.5	8788.77
08.10.25	1.452	385.30	384.36	0.9	43.908	40.143	0.5	0.5	24.00
09.10.25	1.473	385.77	384.83	0.9	44.198	40.384	0.5	0.5	24.00
10.10.25	1.465	383.74	382.78	1.0	44.334	40.521	0.5	0.5	24.00
11.10.25	1.435	382.18	381.24	0.9	44.086	40.335	0.5	0.5	24.00
12.10.25	1.437	381.28	380.31	1.0	43.617	39.851	0.5	0.5	24.00
13.10.25	1.484	381.63	380.68	0.9	43.945	40.060	0.5	0.5	24.00
14.10.25	1.582	387.53	386.66	0.9	45.231	41.154	0.5	0.5	24.00
15.10.25	1.820	395.76	394.97	0.8	48.527	43.934	0.5	0.4	24.00
16.10.25	1.678	389.71	388.84	0.9	46.197	41.894	0.5	0.5	24.00
17.10.25	1.811	395.24	394.41	0.8	47.798	43.221	0.5	0.5	24.00
18.10.25	1.787	393.07	392.41	0.7	47.345	42.804	0.5	0.4	24.00
19.10.25	1.812	393.47	392.89	0.6	47.635	43.035	0.5	0.5	24.00
20.10.25	1.782	393.68	393.11	0.6	47.437	42.916	0.5	0.5	24.00
Итого	22.57	5385.2	5373.5	11.7	---	---	---	---	9100.77
Среднее	---	---	---	---	43.55	39.53	0.5	0.5	---

Показания интеграторов

Дата	Q, (Гкал)	M1, (т)	M2, (т)	Время наработки, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д
20.10.25 24:00	1114.4	147534.0	147008.9	14389.8
Итого за период	н/д	н/д	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 25 мкр., 13а
 Потребитель: АО "Жилуправление"
 Прибор: ТЭМ-106 Заводской номер: 3060232
 Формула: $Q = M1(h1 - h2)$
 Тип системы: Подача + расходомер

Система: 1
 ТВ1

	ДУ, мм	Gmin, м3/ч	Gmax, м3/ч	Kv, л/имп	Fmax, КГц
1	50	3.599999999	60	10	---
2	50	3.54	59	10	---

Дата	Q, (Гкал)	M1, (т)	M2, (т)	dM, (т)	T1, (°C)	T2, (°C)	P1, (МПа)	P2, (МПа)	Время наработки, (ч)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-
28.09.25	-	-	-	-	-	-	-	-	-
29.09.25	-	-	-	-	-	-	-	-	-
30.09.25	-	-	-	-	-	-	-	-	-
01.10.25	-	-	-	-	-	-	-	-	-
02.10.25	-	-	-	-	-	-	-	-	-
03.10.25	-	-	-	-	-	-	-	-	-
04.10.25	-	-	-	-	-	-	-	-	-
05.10.25	-	-	-	-	-	-	-	-	-
06.10.25	н/д	н/д	н/д	н/д	44.263	39.651	0.5	0.5	н/д
07.10.25	1.126	280.73	286.88	-6.2	44.158	40.142	0.5	0.5	24.00
08.10.25	1.057	322.33	329.25	-6.9	42.996	39.714	0.5	0.5	24.00
09.10.25	1.077	322.73	329.56	-6.8	43.277	39.936	0.5	0.5	24.00
10.10.25	1.073	321.29	328.14	-6.8	43.413	40.072	0.5	0.5	24.00
11.10.25	1.062	320.45	327.33	-6.9	43.168	39.851	0.5	0.5	24.00
12.10.25	1.067	319.90	326.67	-6.8	42.705	39.365	0.5	0.5	24.00
13.10.25	1.093	320.30	327.04	-6.7	43.022	39.607	0.5	0.5	24.00
14.10.25	1.166	325.39	332.22	-6.8	44.287	40.699	0.5	0.5	24.00
15.10.25	1.357	333.90	340.81	-6.9	47.585	43.518	0.5	0.5	24.00
16.10.25	1.256	329.03	335.89	-6.9	45.252	41.432	0.5	0.5	24.00
17.10.25	1.353	333.28	340.23	-6.9	46.855	42.791	0.5	0.5	24.00
18.10.25	1.334	332.71	339.71	-7.0	46.407	42.395	0.5	0.5	24.00
19.10.25	1.346	332.75	339.79	-7.0	46.695	42.648	0.5	0.5	24.00
20.10.25	1.330	333.04	340.13	-7.1	46.497	42.501	0.5	0.5	24.00
Итого	16.70	4527.8	4623.7	-95.7	---	---	---	---	336.00
Среднее	---	---	---	---	44.71	40.95	0.5	0.5	---

Показания интеграторов

Дата	Q, (Гкал)	M1, (т)	M2, (т)	Время наработки, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д
20.10.25 24:00	4674.9	527672.8	529547.0	54200.2
Итого за период	н/д	н/д	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, 25 мкр., 146
Потребитель: АО "Жилуправление"
Прибор ТВ7-04.1 Заводской номер: 22179475

БД=1, ТВ1, СИ=6, КТЗ=0, ФРТ=0, КСН=0х71FC

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	21.80	24.81	н/д	-3.02	0.00	0.02	н/д	80.660	3.780	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
20.09.25	21.83	24.82	н/д	-2.99	0.00	0.02	н/д	109.410	0.000	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
21.09.25	21.76	24.80	н/д	-3.04	0.00	0.02	н/д	167.800	0.000	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
22.09.25	22.21	25.26	н/д	-3.04	0.00	0.02	н/д	231.140	0.000	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
23.09.25	22.83	26.04	н/д	-3.21	0.00	0.02	н/д	224.460	0.000	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
24.09.25	23.34	26.41	н/д	-3.08	0.00	0.02	н/д	230.120	0.000	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
25.09.25	22.46	25.67	н/д	-3.21	0.00	0.02	н/д	187.710	0.000	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
26.09.25	44.56	39.80	н/д	4.76	2.84	2.42	н/д	377.710	290.220	н/д	288.873	287.371	н/д	1.502	1.379	н/д	13	11
27.09.25	49.37	43.77	н/д	5.60	5.16	4.39	н/д	570.470	565.080	н/д	564.047	560.123	н/д	3.925	3.166	н/д	24	0
28.09.25	50.57	44.41	н/д	6.15	5.12	4.37	н/д	577.090	577.580	н/д	571.315	571.306	н/д	0.009	3.523	н/д	24	0
29.09.25	49.98	43.82	н/д	6.16	5.15	4.42	н/д	581.930	584.860	н/д	577.540	577.368	н/д	0.172	3.564	н/д	24	0
30.09.25	48.92	42.77	н/д	6.15	5.27	4.60	н/д	567.580	569.640	н/д	563.104	563.104	н/д	0.000	3.468	н/д	24	0
01.10.25	47.55	41.17	н/д	6.38	5.77	5.25	н/д	494.750	494.070	н/д	489.988	489.917	н/д	0.071	3.128	н/д	24	0
02.10.25	45.92	38.26	н/д	7.66	6.06	5.80	н/д	358.590	356.360	н/д	355.135	354.061	н/д	1.075	2.720	н/д	24	0
03.10.25	45.71	38.92	н/д	6.79	6.08	5.72	н/д	410.730	407.340	н/д	406.805	404.599	н/д	2.206	2.763	н/д	24	0
04.10.25	43.57	38.52	н/д	5.05	5.99	5.43	н/д	524.780	521.690	н/д	520.264	518.245	н/д	2.019	2.631	н/д	24	0
05.10.25	43.22	38.30	н/д	4.92	6.00	5.44	н/д	521.970	518.980	н/д	517.552	515.612	н/д	1.939	2.548	н/д	24	0
06.10.25	44.54	38.40	н/д	6.14	6.02	5.64	н/д	429.420	426.720	н/д	425.518	423.942	н/д	1.575	2.613	н/д	24	0
07.10.25	45.19	39.28	н/д	5.91	5.86	5.43	н/д	458.970	456.120	н/д	454.674	452.968	н/д	1.706	2.689	н/д	24	0
08.10.25	44.01	39.12	н/д	4.89	5.61	5.05	н/д	524.590	521.640	н/д	519.944	518.068	н/д	1.876	2.545	н/д	24	0
09.10.25	44.29	39.28	н/д	5.01	5.69	5.13	н/д	525.200	522.260	н/д	520.505	518.685	н/д	1.820	2.610	н/д	24	0
10.10.25	44.43	39.45	н/д	4.98	5.78	5.23	н/д	523.230	520.350	н/д	518.537	516.728	н/д	1.810	2.585	н/д	24	0
11.10.25	44.18	39.26	н/д	4.92	5.79	5.23	н/д	522.210	519.350	н/д	517.544	515.805	н/д	1.739	2.551	н/д	24	0
12.10.25	43.72	38.81	н/д	4.91	5.69	5.14	н/д	521.240	518.420	н/д	516.697	514.952	н/д	1.745	2.538	н/д	24	0
13.10.25	44.03	38.95	н/д	5.08	5.68	5.12	н/д	521.380	518.540	н/д	516.789	515.011	н/д	1.778	2.628	н/д	24	0
14.10.25	45.29	39.96	н/д	5.33	5.62	5.05	н/д	529.530	526.620	н/д	524.568	522.872	н/д	1.696	2.800	н/д	24	0
15.10.25	48.66	42.60	н/д	6.06	5.43	4.83	н/д	541.940	538.700	н/д	536.019	534.266	н/д	1.753	3.251	н/д	24	0
16.10.25	46.28	40.58	н/д	5.70	5.64	5.07	н/д	532.920	529.890	н/д	527.678	525.980	н/д	1.698	3.008	н/д	24	0
17.10.25	47.90	41.85	н/д	6.05	5.73	5.13	н/д	540.510	537.340	н/д	534.807	533.080	н/д	1.727	3.239	н/д	24	0
18.10.25	47.45	41.45	н/д	6.00	5.45	4.87	н/д	537.850	534.720	н/д	532.264	530.574	н/д	1.690	3.196	н/д	24	0
19.10.25	47.73	41.71	н/д	6.03	5.63	5.04	н/д	538.150	534.980	н/д	532.520	530.762	н/д	1.758	3.213	н/д	24	0
20.10.25	47.53	41.62	н/д	5.91	5.67	5.08	н/д	538.550	535.380	н/д	532.957	531.198	н/д	1.759	3.153	н/д	24	0
Итого	---	---	---	---	---	---	---	14002.590	12630.630	---	12565.644	12526.597	---	39.048	71.509	---	589	179
Среднее	39.36	36.09	---	3.27	4.34	3.91	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	105317.470	104540.140	0.000	103578.751	103131.145	0.000	447.606	864.196	0.000	4627	3284
20.10.25 24:00	119320.060	117170.770	0.000	116144.397	115657.743	0.000	486.654	935.705	0.000	5216	3463
Итого за период	14002.590	12630.630	0.000	12565.646	12526.598	0.000	---	71.509	0.000	589	179

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ИМ2300, Суточный с 19.09.25 по 20.10.25

Объект: г. Октябрьский, 25 мкр., 16
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ380

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	0.00	19.51	0.00	19.28	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	19.58	0.00	19.34	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	19.67	0.00	19.42	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	20.14	0.00	20.07	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	21.21	0.00	21.40	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	22.26	0.00	22.39	0.00	0.00	24.00	0.00	0.00
26.09.25	0.81	31.52	244.17	29.61	239.01	13.98	24.00	0.00	0.00
27.09.25	1.65	42.13	378.98	37.77	373.35	24.00	24.00	0.00	0.00
28.09.25	2.16	48.60	376.17	42.84	370.77	24.00	24.00	0.00	0.00
29.09.25	2.26	49.74	370.89	43.64	365.76	24.00	24.00	0.00	0.00
30.09.25	2.22	49.18	364.93	43.09	360.02	24.00	24.00	0.00	0.00
01.10.25	2.10	48.06	344.31	41.94	340.99	24.00	24.00	0.00	0.00
02.10.25	1.85	46.64	293.33	40.16	291.49	24.00	24.00	0.00	0.00
03.10.25	1.58	45.17	211.24	37.66	211.02	24.00	24.00	0.00	0.00
04.10.25	1.62	45.11	245.82	38.27	244.94	24.00	24.00	0.00	0.00
05.10.25	1.56	42.86	311.11	37.85	309.59	24.00	24.00	0.00	0.00
06.10.25	1.50	42.52	307.71	37.63	306.38	24.00	24.00	0.00	0.00
07.10.25	1.52	44.03	249.63	37.73	249.23	24.00	24.00	0.00	0.00
08.10.25	1.56	44.45	270.60	38.63	270.38	24.00	24.00	0.00	0.00
09.10.25	1.49	43.30	309.71	38.49	308.59	24.00	24.00	0.00	0.00
10.10.25	1.52	43.60	309.68	38.68	308.56	24.00	24.00	0.00	0.00
11.10.25	1.50	43.73	307.05	38.83	306.09	24.00	24.00	0.00	0.00
12.10.25	1.48	43.47	306.17	38.62	305.39	24.00	24.00	0.00	0.00
13.10.25	1.49	43.00	305.52	38.12	304.90	24.00	24.00	0.00	0.00
14.10.25	1.56	43.36	306.73	38.26	305.95	24.00	24.00	0.00	0.00
15.10.25	1.66	44.63	311.92	39.30	310.73	24.00	24.00	0.00	0.00
16.10.25	1.92	47.76	318.96	41.72	317.09	24.00	24.00	0.00	0.00
17.10.25	1.80	45.57	313.65	39.81	312.24	24.00	24.00	0.00	0.00
18.10.25	1.93	47.11	318.05	41.02	316.31	24.00	24.00	0.00	0.00
19.10.25	1.92	46.68	316.66	40.62	315.02	24.00	24.00	0.00	0.00
20.10.25	1.92	46.98	316.81	40.91	315.17	24.00	24.00	0.00	0.00
Итого	42.58	---	7709.80	---	7658.97	589.98	744.00	0.00	0.00
Среднее	---	40.051	---	35.584	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	5550.07	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 25 мкр., 18
 Потребитель: АО "Жилуправление"
 Прибор: Взлёт ТСРВ-024 Заводской номер: 801982
 Тип системы: А32-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	16.27	16.12	0.15	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
20.09.25	16.42	16.27	0.15	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
21.09.25	16.47	16.31	0.16	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
22.09.25	16.52	16.36	0.16	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
23.09.25	16.64	16.47	0.17	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
24.09.25	16.83	16.63	0.20	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
25.09.25	18.28	17.76	0.52	20.45	19.31	1.13	0.000	0.000	20.58	19.46	1.12	0.128	24.000
26.09.25	39.28	36.80	2.48	312.00	312.29	-0.28	0.000	0.000	313.92	314.84	-0.91	0.742	24.000
27.09.25	48.23	43.55	4.68	340.71	341.25	-0.54	0.000	0.000	343.63	345.46	-1.82	1.555	24.000
28.09.25	50.24	45.11	5.13	342.86	343.31	-0.45	0.000	0.000	345.95	347.84	-1.88	1.713	24.000
29.09.25	49.99	44.75	5.24	344.94	345.64	-0.70	0.000	0.000	347.99	350.17	-2.17	1.740	24.000
30.09.25	49.59	44.11	5.48	327.22	327.67	-0.44	0.000	0.000	330.05	331.88	-1.83	1.753	24.000
01.10.25	47.78	42.51	5.27	316.21	316.21	0.00	0.000	0.000	318.68	320.06	-1.38	1.665	24.000
02.10.25	45.92	39.07	6.85	203.32	203.32	0.00	0.000	0.000	204.52	205.74	-1.21	1.384	24.000
03.10.25	46.15	39.11	7.04	199.10	199.10	0.00	0.000	0.000	200.30	201.46	-1.15	1.400	24.000
04.10.25	43.95	39.27	4.68	289.07	289.07	0	0.000	0.000	290.81	292.24	-1.43	1.340	24.000
05.10.25	43.22	38.76	4.46	288.23	288.23	0	0.000	0.000	289.88	291.34	-1.46	1.283	24.000
06.10.25	43.99	38.73	5.26	256.94	256.94	0	0.000	0.000	258.43	259.75	-1.32	1.292	24.000
07.10.25	44.85	39.20	5.65	232.97	232.97	0.00	0.000	0.000	234.39	235.59	-1.20	1.312	24.000
08.10.25	44.52	39.97	4.55	289.20	289.41	-0.20	0.000	0.000	291.03	292.65	-1.62	1.297	24.000
09.10.25	43.90	39.53	4.37	290.83	290.83	0.00	0.000	0.000	292.59	294.04	-1.45	1.270	24.000
10.10.25	44.36	39.95	4.41	289.24	289.24	0	0.000	0.000	291.05	292.48	-1.43	1.273	24.000
11.10.25	44.44	40.03	4.41	288.82	288.82	0.00	0.000	0.000	290.64	292.06	-1.42	1.274	24.000
12.10.25	43.83	39.51	4.32	289.12	289.48	-0.36	0.000	0.000	290.90	292.65	-1.75	1.217	24.000
13.10.25	43.51	39.06	4.45	288.78	288.78	0	0.000	0.000	290.51	291.89	-1.37	1.284	24.000
14.10.25	44.01	39.55	4.46	289.40	289.40	0.00	0.000	0.000	291.19	292.56	-1.37	1.286	24.000
15.10.25	48.84	43.25	5.59	302.17	302.17	0.00	0.000	0.000	304.72	305.89	-1.18	1.685	24.000
16.10.25	45.82	40.89	4.93	293.32	293.32	0.00	0.000	0.000	295.39	296.67	-1.28	1.446	24.000
17.10.25	47.90	42.45	5.45	299.34	299.34	0	0.000	0.000	301.74	302.93	-1.20	1.628	24.000
18.10.25	47.37	41.99	5.38	297.86	297.86	0.00	0.000	0.000	300.17	301.38	-1.22	1.600	24.000
19.10.25	47.48	42.08	5.40	298.08	298.08	0.00	0.000	0.000	300.41	301.62	-1.21	1.605	24.000
20.10.25	47.48	42.18	5.30	298.17	298.17	0	0.000	0.000	300.50	301.72	-1.22	1.578	24.000
Итого	---	---	---	7288.36	7290.23	-1.86	---	---	7339.98	7374.38	-34.40	35.749	768.000
Среднее	39.50	35.54	3.96	---	---	---	0.000	0.000	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 25 мкр., 19
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ584

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-
28.09.25	-	-	-	-	-	-	-	-	-
29.09.25	1.83	50.33	301.86	44.27	299.33	24.00	24.00	0.00	0.00
30.09.25	1.80	49.78	295.84	43.69	293.18	24.00	24.00	0.00	0.00
01.10.25	1.69	48.58	279.20	42.50	277.24	24.00	24.00	0.00	0.00
02.10.25	1.50	47.16	235.15	40.60	234.49	24.00	24.00	0.00	0.00
03.10.25	1.30	45.67	171.65	38.09	172.16	24.00	24.00	0.00	0.00
04.10.25	1.33	45.59	201.39	38.73	201.83	24.00	24.00	0.00	0.00
05.10.25	1.28	43.38	253.50	38.31	252.59	24.00	24.00	0.00	0.00
06.10.25	1.24	43.03	251.59	38.08	250.26	24.00	24.00	0.00	0.00
07.10.25	1.26	44.55	202.19	38.13	201.53	24.00	24.00	0.00	0.00
08.10.25	1.30	44.96	219.50	38.96	218.65	24.00	24.00	0.00	0.00
09.10.25	1.24	43.81	249.94	38.85	248.63	24.00	24.00	0.00	0.00
10.10.25	1.27	44.13	249.84	39.05	248.51	24.00	24.00	0.00	0.00
11.10.25	1.25	44.26	247.87	39.20	246.46	24.00	24.00	0.00	0.00
12.10.25	1.23	43.99	247.53	38.99	246.13	24.00	24.00	0.00	0.00
13.10.25	1.23	43.50	247.82	38.54	246.32	24.00	24.00	0.00	0.00
14.10.25	1.26	43.90	248.02	38.79	246.59	24.00	24.00	0.00	0.00
15.10.25	1.35	45.24	250.90	39.86	249.61	24.00	24.00	0.00	0.00
16.10.25	1.54	48.25	253.33	42.18	252.02	24.00	24.00	0.00	0.00
17.10.25	1.45	46.16	251.39	40.40	250.32	24.00	24.00	0.00	0.00
18.10.25	1.53	47.66	253.52	41.59	252.46	24.00	24.00	0.00	0.00
19.10.25	1.52	47.24	253.07	41.22	251.98	24.00	24.00	0.00	0.00
20.10.25	1.53	47.54	253.09	41.48	252.11	24.00	24.00	0.00	0.00
Итого	30.93	---	5418.19	---	5392.40	528.00	528.00	0.00	0.00
Среднее	---	45.850	---	40.069	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	3233.86	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 25 мкр., 21
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00182281

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0хD22D

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Мг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	16.65	17.54	-0.89	0.000	0.000	0.000	0.000	0.000	1.03	1.03	0.0000	0.0	24.0
20.09.25	16.63	17.52	-0.89	0.000	0.000	0.000	0.000	0.000	1.03	1.03	0.0000	0.0	24.0
21.09.25	16.64	17.54	-0.90	0.000	0.000	0.000	0.000	0.000	1.03	1.03	0.0000	0.0	24.0
22.09.25	16.86	17.73	-0.87	0.000	0.000	0.000	0.000	0.000	1.04	1.03	0.0000	0.0	24.0
23.09.25	17.09	18.00	-0.91	0.000	0.000	0.000	0.000	0.000	1.04	1.03	0.0000	0.0	24.0
24.09.25	17.44	18.28	-0.84	0.000	0.000	0.000	0.000	0.000	1.04	1.03	0.0000	0.0	24.0
25.09.25	39.03	36.16	2.87	214.310	210.560	212.770	209.270	3.500	4.22	3.99	0.6120	0.0	24.0
26.09.25	43.19	39.03	4.16	322.230	319.420	319.410	317.120	2.290	6.11	5.87	1.3350	0.0	24.0
27.09.25	49.20	44.02	5.18	373.600	372.160	369.350	368.800	0.550	6.22	5.96	1.9110	0.0	24.0
28.09.25	50.39	44.91	5.48	368.200	365.890	363.830	362.390	1.440	6.18	5.94	1.9870	0.0	24.0
29.09.25	49.82	44.33	5.49	359.630	357.800	355.470	354.510	0.960	6.22	5.99	1.9450	0.0	24.0
30.09.25	48.73	43.18	5.55	338.240	336.500	334.460	333.540	0.920	6.36	6.15	1.8520	0.0	24.0
01.10.25	47.38	41.56	5.82	288.580	287.040	285.520	284.730	0.790	6.88	6.73	1.6580	0.0	24.0
02.10.25	45.72	38.69	7.03	208.310	206.980	206.300	205.540	0.760	7.20	7.15	1.4450	0.0	24.0
03.10.25	45.51	39.35	6.16	241.230	239.470	238.870	237.760	1.110	7.21	7.11	1.4700	0.0	24.0
04.10.25	43.43	38.77	4.66	305.140	302.800	302.480	300.640	1.840	7.09	6.92	1.4080	0.0	24.0
05.10.25	43.07	38.54	4.53	302.260	299.860	299.620	297.700	1.920	7.10	6.93	1.3580	0.0	24.0
06.10.25	44.37	38.63	5.74	245.220	243.200	242.990	241.470	1.520	7.15	7.05	1.3930	0.0	24.0
07.10.25	45.02	39.55	5.47	262.400	259.980	259.930	258.100	1.830	6.98	6.86	1.4180	0.0	24.0
08.10.25	43.87	39.32	4.55	300.530	297.920	297.860	295.760	2.100	6.71	6.55	1.3520	0.0	24.0
09.10.25	44.15	39.52	4.63	301.050	298.370	298.310	296.210	2.100	6.80	6.64	1.3810	0.0	24.0
10.10.25	44.28	39.69	4.59	298.820	296.080	296.100	293.920	2.180	6.89	6.73	1.3570	0.0	24.0
11.10.25	44.03	39.51	4.52	298.490	295.710	295.800	293.550	2.250	6.89	6.73	1.3360	0.0	24.0
12.10.25	43.57	39.05	4.52	297.720	294.870	295.100	292.750	2.350	6.79	6.64	1.3320	0.0	24.0
13.10.25	43.89	39.23	4.66	297.790	294.910	295.100	292.780	2.320	6.79	6.63	1.3720	0.0	24.0
14.10.25	45.17	40.26	4.91	302.420	299.590	299.540	297.300	2.240	6.72	6.56	1.4700	0.0	24.0
15.10.25	48.44	42.89	5.55	309.280	306.550	305.880	303.900	1.980	6.53	6.36	1.6950	0.0	24.0
16.10.25	46.14	40.93	5.21	303.890	300.810	300.850	298.490	2.360	6.75	6.59	1.5670	0.0	24.0
17.10.25	47.73	42.25	5.48	308.190	305.160	304.900	302.590	2.310	6.81	6.65	1.6650	0.0	24.0
18.10.25	47.28	41.87	5.41	306.990	303.830	303.810	301.380	2.430	6.56	6.39	1.6420	0.0	24.0
19.10.25	47.57	42.13	5.44	307.100	303.920	303.780	301.320	2.460	6.73	6.57	1.6520	0.0	24.0
20.10.25	47.38	41.98	5.40	307.390	304.090	304.110	301.520	2.590	6.77	6.61	1.6410	0.0	24.0
Итого	---	---	---	7769.0	7703.4	7692.14	7643.04	49.100	---	---	39.2540	0.0	768.0
Среднее	40.30	36.31	3.99	---	---	---	---	---	5.59	5.45	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Мг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	52637.020	52018.250	51924.320	51528.380	459.2020	395.940	2783.0	8027.0
20.10.25 24:00	60406.030	59721.720	59616.460	59171.420	498.4560	445.040	2783.0	8795.0
Итого за период	7769.010	7703.470	7692.139	7643.040	39.2540	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 25 мкр., 22
 Потребитель: АО "Жилуправление"
 Прибор: ТЭМ-106 Заводской номер: 3060254
 Формула: $Q = M1(h1 - h2)$
 Тип системы: Подача + расходомер

Система: 1

ТВ1

	ДУ, мм	Gmin, м3/ч	Gmax, м3/ч	Kv, л/имп	Fmax, КГц
1	80	9.6	160	10	---
2	80	10.92	182	10	---

Дата	Q, (Гкал)	M1, (т)	M2, (т)	dM, (т)	T1, (°C)	T2, (°C)	P1, (МПа)	P2, (МПа)	Время наработки, (ч)
19.09.25	0.000	0.00	0.00	0.0	22.371	24.382	0.0	0.0	24.00
20.09.25	0.000	0.00	0.00	0.0	22.492	24.442	0.0	0.0	24.00
21.09.25	0.000	0.00	0.00	0.0	22.624	24.536	0.0	0.0	24.00
22.09.25	0.000	0.00	0.00	0.0	22.879	26.085	0.0	0.0	24.00
23.09.25	0.000	0.00	0.00	0.0	23.408	27.531	0.0	0.0	24.00
24.09.25	0.000	0.00	0.00	0.0	23.682	26.802	0.0	0.0	24.00
25.09.25	0.596	154.37	151.28	3.1	38.759	34.913	0.3	0.1	24.00
26.09.25	1.403	270.32	268.99	1.3	42.222	37.052	0.5	0.2	24.00
27.09.25	1.914	272.89	271.53	1.4	49.040	42.040	0.5	0.2	24.00
28.09.25	2.059	270.39	268.00	2.4	50.264	42.665	0.5	0.2	24.00
29.09.25	2.426	318.27	316.36	1.9	49.643	42.035	0.5	0.2	24.00
30.09.25	2.489	335.23	333.18	2.1	48.686	41.278	0.5	0.2	24.00
01.10.25	2.228	289.00	287.61	1.4	47.305	39.614	0.5	0.2	24.00
02.10.25	1.897	205.37	204.98	0.4	45.636	36.423	0.6	0.2	24.00
03.10.25	1.946	235.71	234.81	0.9	45.467	37.233	0.6	0.2	24.00
04.10.25	1.872	301.96	300.05	1.9	43.346	37.167	0.6	0.2	24.00
05.10.25	1.810	299.08	297.14	1.9	42.987	36.957	0.6	0.2	24.00
06.10.25	1.825	244.91	243.57	1.3	44.236	36.807	0.6	0.2	24.00
07.10.25	1.886	260.97	259.49	1.5	44.931	37.728	0.6	0.2	24.00
08.10.25	1.813	300.97	299.09	1.9	43.788	37.784	0.5	0.2	24.00
09.10.25	1.851	301.50	299.67	1.8	44.042	37.924	0.5	0.2	24.00
10.10.25	1.824	299.15	297.36	1.8	44.187	38.111	0.5	0.2	24.00
11.10.25	1.799	298.84	297.03	1.8	43.953	37.955	0.5	0.2	24.00
12.10.25	1.798	298.24	296.42	1.8	43.498	37.491	0.5	0.2	24.00
13.10.25	1.832	298.21	296.49	1.7	43.768	37.644	0.5	0.2	24.00
14.10.25	1.943	302.51	300.70	1.8	44.953	38.550	0.5	0.2	24.00
15.10.25	2.272	309.67	307.77	1.9	48.428	41.111	0.5	0.2	24.00
16.10.25	2.076	303.51	301.71	1.8	45.983	39.163	0.5	0.2	24.00
17.10.25	2.246	307.81	305.94	1.9	47.639	40.362	0.5	0.2	24.00
18.10.25	2.209	306.79	304.94	1.8	47.182	39.998	0.5	0.2	24.00
19.10.25	2.221	307.09	305.24	1.8	47.466	40.252	0.5	0.2	24.00
20.10.25	2.194	307.48	305.62	1.9	47.266	40.150	0.5	0.2	24.00
Итого	50.43	7400.2	7355.0	45.2	---	---	---	---	768.00
Среднее	---	---	---	---	41.32	36.32	0.4	0.2	---

Показания интеграторов

Дата	Q, (Гкал)	M1, (т)	M2, (т)	Время наработки, (ч)
18.09.25 24:00	9590.7	659457.7	658240.0	68896.3
20.10.25 24:00	9641.2	666857.9	665594.9	69664.3
Итого за период	50.5	7400.2	7354.9	768.0

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 25 мкр., 23
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00179084

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0x2CE2

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	16.67	16.41	0.26	0.640	0.000	0.640	0.000	0.640	1.04	1.01	0.0000	0.0	24.0
20.09.25	16.46	16.39	0.07	0.000	0.000	0.000	0.000	0.000	1.04	1.01	0.0000	0.0	24.0
21.09.25	16.45	16.38	0.07	0.000	0.000	0.000	0.000	0.000	1.04	1.01	0.0000	0.0	24.0
22.09.25	16.67	16.56	0.11	0.000	0.000	0.000	0.000	0.000	1.04	1.01	0.0000	0.0	24.0
23.09.25	17.03	16.83	0.20	0.000	0.000	0.000	0.000	0.000	1.04	1.01	0.0000	0.0	24.0
24.09.25	17.27	17.03	0.24	0.000	0.000	0.000	0.000	0.000	1.04	1.01	0.0000	0.0	24.0
25.09.25	38.40	35.88	2.52	61.000	62.320	60.580	61.950	-1.370	3.35	3.17	0.1520	0.0	24.0
26.09.25	42.52	39.38	3.14	155.980	159.700	154.660	158.550	-3.890	6.33	5.97	0.4850	0.0	24.0
27.09.25	49.15	44.77	4.38	155.520	159.510	153.820	158.070	-4.250	5.95	5.61	0.6740	0.0	24.0
28.09.25	50.34	45.63	4.71	153.140	157.260	151.290	155.760	-4.470	5.92	5.59	0.7110	0.0	24.0
29.09.25	49.78	44.98	4.80	148.000	152.080	146.260	150.640	-4.380	5.95	5.64	0.7020	0.0	24.0
30.09.25	48.72	43.74	4.98	136.310	140.300	134.760	139.000	-4.240	6.08	5.81	0.6700	0.0	24.0
01.10.25	47.33	41.95	5.38	111.980	115.880	110.810	114.860	-4.050	6.59	6.40	0.5950	0.0	24.0
02.10.25	45.65	39.08	6.57	79.830	83.390	79.110	82.890	-3.780	6.91	6.83	0.5160	0.0	24.0
03.10.25	45.45	39.67	5.78	92.980	96.500	92.080	95.770	-3.690	6.91	6.79	0.5330	0.0	24.0
04.10.25	43.39	38.99	4.40	118.490	122.000	117.530	121.040	-3.510	6.80	6.59	0.5160	0.0	24.0
05.10.25	43.04	38.79	4.25	117.450	120.790	116.490	119.860	-3.370	6.81	6.60	0.4940	0.0	24.0
06.10.25	44.31	38.93	5.38	95.750	98.770	94.880	98.060	-3.180	6.86	6.72	0.5110	0.0	24.0
07.10.25	44.97	39.87	5.10	103.100	106.140	102.060	105.340	-3.280	6.69	6.53	0.5180	0.0	24.0
08.10.25	43.83	39.58	4.25	118.460	121.550	117.430	120.590	-3.160	6.43	6.22	0.4950	0.0	24.0
09.10.25	44.11	39.80	4.31	118.720	121.790	117.640	120.830	-3.190	6.51	6.30	0.5060	0.0	24.0
10.10.25	44.25	39.95	4.30	118.110	121.120	117.010	120.160	-3.150	6.60	6.39	0.5040	0.0	24.0
11.10.25	44.00	39.66	4.34	117.960	120.950	116.860	119.990	-3.130	6.60	6.39	0.5060	0.0	24.0
12.10.25	43.54	39.12	4.42	117.630	120.660	116.670	119.740	-3.070	6.51	6.30	0.5120	0.0	24.0
13.10.25	43.85	39.44	4.41	117.800	120.770	116.740	119.830	-3.090	6.50	6.29	0.5130	0.0	24.0
14.10.25	45.12	40.46	4.66	119.800	122.750	118.700	121.740	-3.040	6.43	6.22	0.5500	0.0	24.0
15.10.25	48.41	43.21	5.20	122.360	125.280	120.990	124.140	-3.150	6.24	6.02	0.6240	0.0	24.0
16.10.25	46.09	41.17	4.92	119.910	122.860	118.710	121.900	-3.190	6.46	6.25	0.5830	0.0	24.0
17.10.25	47.68	42.54	5.14	121.640	124.600	120.390	123.590	-3.200	6.52	6.31	0.6180	0.0	24.0
18.10.25	47.24	42.15	5.09	121.310	124.240	120.110	123.280	-3.170	6.27	6.05	0.6110	0.0	24.0
19.10.25	47.53	42.41	5.12	121.400	124.320	120.200	123.360	-3.160	6.44	6.22	0.6180	0.0	24.0
20.10.25	47.33	42.23	5.10	121.580	124.500	120.370	123.540	-3.170	6.48	6.26	0.6120	0.0	24.0
Итого	---	---	---	3086.8	3170.0	3056.79	3144.48	-87.690	---	---	14.3290	0.0	768.0
Среднее	40.20	36.34	3.86	---	---	---	---	---	5.36	5.17	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	23417.510	24285.070	23104.170	24045.350	174.6120	-941.180	2468.0	7762.0
20.10.25 24:00	26504.360	27455.100	26160.960	27189.830	188.9410	-1028.870	2468.0	8530.0
Итого за период	3086.850	3170.029	3056.790	3144.480	14.3290	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ТС1, Суточный с 19.09.25 по 20.10.25

Объект: г. Октябрьский, 25 мкр., 23
 Потребитель: АО "Жилуправление"
 Прибор: ТЭМ-106 Заводской номер: 3060468
 Формула: $Q = M1(h1 - h2)$
 Тип системы: Подача + расходомер

Система: 1

ТВ1

	ДУ, мм	Gmin, м3/ч	Gmax, м3/ч	Kv, л/имп	Fmax, КГц
1	50	3.719999999	62	10	---
2	50	3.999999999	60	10	---

Дата	Q, (Гкал)	M1, (т)	M2, (т)	dM, (т)	T1, (°C)	T2, (°C)	P1, (МПа)	P2, (МПа)	Время наработки, (ч)
19.09.25	0.000	0.00	0.00	0.0	18.448	18.016	0.5	0.5	24.00
20.09.25	0.000	0.00	0.00	0.0	18.422	18.009	0.5	0.5	24.00
21.09.25	0.000	0.00	0.00	0.0	18.409	17.964	0.5	0.5	24.00
22.09.25	0.000	0.00	0.00	0.0	18.353	17.754	0.5	0.5	24.00
23.09.25	0.000	0.00	0.00	0.0	18.538	18.025	0.5	0.5	24.00
24.09.25	0.000	0.00	0.00	-0.0	18.746	18.000	0.4	0.5	24.00
25.09.25	0.018	3.73	4.38	-0.6	39.251	34.547	0.4	0.5	24.00
26.09.25	0.312	115.27	111.46	3.8	39.369	36.671	0.6	0.5	24.00
27.09.25	0.518	118.28	114.55	3.7	48.531	44.161	0.5	0.5	24.00
28.09.25	0.539	114.60	109.92	4.7	50.074	45.377	0.5	0.5	24.00
29.09.25	0.674	125.80	121.22	4.6	49.672	44.318	0.5	0.5	24.00
30.09.25	0.679	116.27	112.76	3.5	49.291	43.455	0.5	0.5	24.00
01.10.25	0.617	109.57	106.52	3.0	47.449	41.818	0.6	0.5	24.00
02.10.25	0.525	76.96	74.76	2.2	45.828	39.004	0.6	0.6	24.00
03.10.25	0.529	76.75	74.88	1.9	46.059	39.160	0.6	0.6	24.00
04.10.25	0.502	105.81	102.11	3.7	43.620	38.872	0.6	0.6	24.00
05.10.25	0.485	101.69	98.03	3.7	43.090	38.321	0.6	0.6	24.00
06.10.25	0.489	90.42	87.24	3.2	43.809	38.397	0.6	0.6	24.00
07.10.25	0.507	88.37	85.57	2.8	44.862	39.125	0.6	0.6	24.00
08.10.25	0.491	104.36	101.34	3.0	44.171	39.467	0.6	0.5	24.00
09.10.25	0.487	102.98	99.84	3.1	43.845	39.118	0.6	0.5	24.00
10.10.25	0.485	101.05	98.09	3.0	44.214	39.414	0.6	0.5	24.00
11.10.25	0.486	99.91	96.87	3.0	44.246	39.378	0.6	0.6	24.00
12.10.25	0.484	99.18	96.39	2.8	43.712	38.830	0.6	0.5	24.00
13.10.25	0.474	98.29	95.42	2.9	43.440	38.615	0.6	0.5	24.00
14.10.25	0.475	97.93	95.31	2.6	43.805	38.956	0.6	0.5	24.00
15.10.25	0.621	101.27	98.85	2.4	48.988	42.861	0.5	0.5	24.00
16.10.25	0.528	102.45	99.38	3.1	45.577	40.424	0.6	0.5	24.00
17.10.25	0.602	108.41	105.03	3.4	47.782	42.234	0.6	0.6	24.00
18.10.25	0.576	104.81	101.54	3.3	47.183	41.685	0.5	0.5	24.00
19.10.25	0.580	103.08	99.76	3.3	47.355	41.734	0.6	0.5	24.00
20.10.25	0.570	102.02	98.49	3.5	47.268	41.677	0.6	0.5	24.00
Итого	13.25	2569.3	2489.7	79.6	---	---	---	---	768.00
Среднее	---	---	---	---	40.42	36.11	0.6	0.5	---

Показания интеграторов

Дата	Q, (Гкал)	M1, (т)	M2, (т)	Время наработки, (ч)
18.09.25 24:00	2450.1	244302.7	244211.7	74639.7
20.10.25 24:00	2463.3	246872.0	246701.5	75407.7
Итого за период	13.2	2569.3	2489.8	768.0

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 25 мкр., 23а
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00179018

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0х98ВЕ

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	21.04	21.22	-0.18	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
20.09.25	21.01	21.20	-0.19	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
21.09.25	20.99	21.22	-0.23	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
22.09.25	21.22	21.68	-0.46	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
23.09.25	22.51	22.87	-0.36	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
24.09.25	22.45	23.22	-0.77	0.320	0.000	0.320	0.000	0.320	3.51	3.85	0.0000	0.0	24.0
25.09.25	38.62	36.32	2.30	74.160	74.180	73.670	73.640	0.030	3.51	1.82	0.1770	0.0	24.0
26.09.25	42.67	39.85	2.82	181.390	181.760	180.100	180.100	0.000	6.90	1.82	0.5290	0.0	24.0
27.09.25	49.35	45.54	3.81	180.420	181.050	178.750	178.750	0.000	6.90	1.83	0.6940	0.0	24.0
28.09.25	50.55	46.51	4.04	178.150	178.940	176.460	176.460	0.000	6.90	1.83	0.7270	0.0	24.0
29.09.25	49.98	45.93	4.05	173.320	174.230	171.810	171.810	0.000	6.90	1.83	0.7100	0.0	24.0
30.09.25	48.91	44.84	4.07	162.710	163.650	161.430	161.430	0.000	6.90	1.83	0.6710	0.0	24.0
01.10.25	47.54	43.25	4.29	138.860	139.580	137.850	137.850	0.000	6.90	1.83	0.6040	0.0	24.0
02.10.25	45.87	40.58	5.29	н/д	н/д	н/д	н/д	н/д	6.90	1.83	н/д	н/д	н/д
03.10.25	45.68	41.02	4.66	114.770	115.180	113.890	113.880	0.010	6.90	1.83	0.5390	0.0	24.0
04.10.25	43.59	40.09	3.50	145.850	146.810	145.040	145.040	0.000	6.90	1.83	0.5180	0.0	24.0
05.10.25	43.23	39.82	3.41	144.950	145.570	143.980	143.980	0.000	6.90	1.82	0.5040	0.0	24.0
06.10.25	44.51	40.21	4.30	119.000	118.790	117.910	117.780	0.130	6.90	1.83	0.5160	0.0	24.0
07.10.25	45.17	41.10	4.07	128.090	127.600	126.800	126.550	0.250	6.90	1.83	0.5300	0.0	24.0
08.10.25	44.03	40.67	3.36	147.340	146.740	145.950	145.540	0.410	6.90	1.83	0.5070	0.0	24.0
09.10.25	44.30	40.86	3.44	147.780	146.990	146.370	145.790	0.580	6.90	1.83	0.5210	0.0	24.0
10.10.25	44.44	41.01	3.43	146.790	145.860	145.350	144.660	0.690	6.90	1.83	0.5090	0.0	24.0
11.10.25	44.20	40.80	3.40	146.730	145.640	145.340	144.440	0.900	6.90	1.83	0.5050	0.0	24.0
12.10.25	43.73	40.29	3.44	146.480	145.280	145.150	144.080	1.070	6.90	1.83	0.5120	0.0	24.0
13.10.25	44.04	40.54	3.50	146.600	145.310	145.250	144.110	1.140	6.90	1.83	0.5220	0.0	24.0
14.10.25	45.30	41.57	3.73	148.990	147.610	147.550	146.340	1.210	6.90	1.83	0.5670	0.0	24.0
15.10.25	48.62	44.44	4.18	152.650	151.180	150.990	149.800	1.190	6.90	1.83	0.6450	0.0	24.0
16.10.25	46.28	42.33	3.95	149.660	148.230	148.140	146.950	1.190	6.90	1.83	0.5990	0.0	24.0
17.10.25	47.88	43.68	4.20	151.880	150.400	150.200	148.960	1.240	6.90	1.83	0.6420	0.0	24.0
18.10.25	47.43	43.25	4.18	151.330	149.870	149.650	148.430	1.220	6.90	1.83	0.6390	0.0	24.0
19.10.25	47.72	43.49	4.23	151.490	150.020	149.810	148.580	1.230	6.90	1.83	0.6460	0.0	24.0
20.10.25	47.52	43.37	4.15	151.670	150.170	150.040	148.770	1.270	6.90	1.83	0.6360	0.0	24.0
Итого	---	---	---	3681.3	3670.6	3647.80	3633.72	14.080	---	---	14.1690	0.0	744.0
Среднее	41.26	38.21	3.05	---	---	---	---	---	6.69	2.65	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
20.10.25 24:00	3618.120	3606.580	3585.009	3570.930	14.0280	14.080	1323.0	1403.0
Итого за период	н/д	н/д	н/д	н/д	н/д	---	н/д	н/д

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, 25 мкр., 23а
Потребитель: АО "Жилуправление"
Прибор: ТВ7-04.1 Заводской номер: 22179188

БД=1, ТВ1, СИ=6, КТЗ=0, ФРТ=0, КСН=0х0DDC

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
28.09.25	50.52	45.97	н/д	4.54	4.83	4.45	н/д	134.105	127.818	н/д	132.522	126.572	н/д	5.950	0.603	н/д	24	0
29.09.25	49.95	45.29	н/д	4.66	4.86	4.51	н/д	130.628	124.015	н/д	129.117	122.847	н/д	6.271	0.603	н/д	24	0
30.09.25	48.86	44.04	н/д	4.82	4.99	4.68	н/д	129.005	122.557	н/д	127.583	121.468	н/д	6.115	0.615	н/д	24	0
01.10.25	47.52	42.44	н/д	5.08	5.51	5.28	н/д	113.188	107.970	н/д	112.013	107.086	н/д	4.927	0.569	н/д	24	0
02.10.25	45.84	39.56	н/д	6.28	5.84	5.72	н/д	81.503	77.670	н/д	80.721	77.129	н/д	3.593	0.507	н/д	24	0
03.10.25	45.66	40.12	н/д	5.54	5.85	5.68	н/д	93.575	89.433	н/д	92.683	88.786	н/д	3.896	0.514	н/д	24	0
04.10.25	43.58	39.45	н/д	4.13	5.73	5.48	н/д	118.235	113.292	н/д	117.212	112.509	н/д	4.703	0.484	н/д	24	0
05.10.25	43.23	39.18	н/д	4.05	5.74	5.49	н/д	117.060	112.173	н/д	116.065	111.410	н/д	4.655	0.470	н/д	24	0
06.10.25	44.49	39.37	н/д	5.12	5.79	5.62	н/д	95.997	91.810	н/д	95.131	91.179	н/д	3.952	0.487	н/д	24	0
07.10.25	45.16	40.26	н/д	4.90	5.62	5.43	н/д	102.815	98.385	н/д	101.854	97.670	н/д	4.184	0.499	н/д	24	0
08.10.25	44.02	39.93	н/д	4.09	5.35	5.10	н/д	117.805	112.893	н/д	116.766	112.086	н/д	4.680	0.478	н/д	24	0
09.10.25	44.29	40.14	н/д	4.15	5.43	5.18	н/д	117.973	113.068	н/д	116.917	112.252	н/д	4.665	0.485	н/д	24	0
10.10.25	44.43	40.23	н/д	4.20	5.53	5.28	н/д	117.327	112.505	н/д	116.268	111.685	н/д	4.583	0.489	н/д	24	0
11.10.25	44.19	40.07	н/д	4.12	5.53	5.28	н/д	117.152	112.342	н/д	116.106	111.540	н/д	4.567	0.478	н/д	24	0
12.10.25	43.72	39.61	н/д	4.12	5.43	5.19	н/д	116.865	112.048	н/д	115.844	111.257	н/д	4.587	0.477	н/д	24	0
13.10.25	44.03	39.84	н/д	4.19	5.42	5.18	н/д	116.878	112.067	н/д	115.840	111.265	н/д	4.575	0.485	н/д	24	0
14.10.25	45.27	40.79	н/д	4.48	5.36	5.11	н/д	118.680	113.795	н/д	117.562	112.936	н/д	4.626	0.526	н/д	24	0
15.10.25	48.61	43.58	н/д	5.03	5.16	4.90	н/д	121.533	116.500	н/д	120.202	115.488	н/д	4.714	0.605	н/д	24	0
16.10.25	46.26	41.57	н/д	4.69	5.38	5.13	н/д	119.118	114.180	н/д	117.944	113.287	н/д	4.657	0.553	н/д	24	0
17.10.25	47.87	42.91	н/д	4.96	5.46	5.20	н/д	120.823	115.780	н/д	119.546	114.811	н/д	4.735	0.593	н/д	24	0
18.10.25	47.42	42.54	н/д	4.88	5.19	4.94	н/д	120.402	115.387	н/д	119.150	114.439	н/д	4.711	0.582	н/д	24	0
19.10.25	47.71	42.78	н/д	4.93	5.37	5.11	н/д	120.533	115.522	н/д	119.270	114.557	н/д	4.713	0.588	н/д	24	0
20.10.25	47.51	42.67	н/д	4.85	5.41	5.15	н/д	120.640	115.658	н/д	119.386	114.701	н/д	4.684	0.579	н/д	24	0
Итого	---	---	---	---	---	---	---	2661.840	2546.868	---	2635.702	2526.960	---	108.743	12.269	---	552	0
Среднее	46.18	41.53	---	4.65	5.43	5.18	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
20.10.25 24:00	2971.837	2843.432	0.000	2926.459	2805.525	0.000	120.934	13.287	0.000	604	4
Итого за период	н/д	н/д	н/д	н/д	н/д	н/д	---	н/д	н/д	н/д	н/д

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 25 мкр., 7
 Потребитель: АО "Жилуправление"
 Прибор: Вzlёт ТСРВ-024 Заводской номер: 801126
 Тип системы: А42-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	17.67	17.80	-0.13	0.00	0.00	0.00	0.003	0.015	0.00	0.00	0.00	0.000	24.000
21.09.25	17.71	17.80	-0.09	0.00	0.00	0.00	0.003	0.015	0.00	0.00	0.00	0.000	24.000
22.09.25	18.12	18.12	0.00	0.00	0.00	0.00	0.003	0.015	0.00	0.00	0.00	0.000	24.000
23.09.25	18.64	18.60	0.04	0.00	0.00	0.00	0.002	0.014	0.00	0.00	0.00	0.000	24.000
24.09.25	19.44	19.36	0.08	0.00	0.00	0.00	0.002	0.014	0.00	0.00	0.00	0.000	24.000
25.09.25	26.40	24.85	1.55	146.05	143.69	2.36	0.167	0.228	146.61	144.19	2.42	0.133	23.983
26.09.25	39.40	35.62	3.78	430.36	424.85	5.51	0.304	0.394	433.64	427.44	6.20	1.551	23.967
27.09.25	47.83	42.23	5.60	384.15	381.27	2.88	0.317	0.387	388.37	384.53	3.84	2.140	24.000
28.09.25	48.27	41.75	6.52	409.40	406.88	2.52	0.318	0.382	413.98	410.29	3.69	2.660	24.000
29.09.25	46.52	39.77	6.75	409.01	407.34	1.66	0.318	0.376	413.27	410.44	2.83	2.747	23.983
30.09.25	46.72	39.16	7.56	388.40	386.81	1.58	0.339	0.390	392.48	389.67	2.82	2.916	23.983
01.10.25	47.23	40.54	6.69	498.87	498.14	0.72	0.363	0.411	504.21	502.09	2.12	3.280	23.983
02.10.25	47.07	41.14	5.93	557.89	556.65	1.24	0.358	0.399	563.83	561.18	2.65	3.292	24.000
03.10.25	48.42	42.17	6.25	541.74	540.40	1.34	0.346	0.382	547.87	545.04	2.83	3.383	23.983
04.10.25	51.30	44.33	6.97	531.47	530.33	1.13	0.342	0.376	538.11	535.31	2.80	3.672	23.933
05.10.25	50.67	44.01	6.66	532.31	531.37	0.94	0.343	0.376	538.82	536.29	2.53	3.520	23.950
06.10.25	48.41	42.24	6.17	513.69	512.71	0.98	0.343	0.370	519.48	517.12	2.36	3.163	24.000
07.10.25	46.42	40.80	5.62	491.00	490.34	0.66	0.322	0.345	496.10	494.28	1.82	2.752	24.000
08.10.25	45.45	40.32	5.13	471.81	471.25	0.56	0.292	0.319	476.50	474.94	1.56	2.407	23.983
09.10.25	46.33	40.85	5.48	473.53	472.70	0.82	0.290	0.317	478.42	476.50	1.92	2.584	23.983
10.10.25	46.50	41.08	5.42	475.77	475.10	0.67	0.290	0.316	480.73	478.96	1.76	2.573	24.000
11.10.25	47.41	41.60	5.81	459.72	459.42	0.29	0.287	0.308	464.67	463.24	1.42	2.642	23.983
12.10.25	45.92	40.34	5.58	481.93	480.98	0.94	0.294	0.319	486.82	484.75	2.07	2.678	24.000
13.10.25	46.03	40.35	5.68	484.75	483.68	1.07	0.293	0.316	489.70	487.48	2.22	2.746	24.000
14.10.25	47.17	41.21	5.96	494.44	493.61	0.82	0.298	0.322	499.74	497.65	2.08	2.938	23.983
15.10.25	50.64	43.53	7.11	491.11	490.24	0.86	0.303	0.322	497.13	494.71	2.42	3.478	24.000
16.10.25	51.24	43.75	7.49	490.87	489.77	1.09	0.324	0.342	497.03	494.28	2.75	3.665	24.000
17.10.25	51.32	43.86	7.46	503.19	502.26	0.92	0.345	0.366	509.52	506.91	2.61	3.746	24.000
18.10.25	50.98	43.58	7.40	501.45	500.35	1.10	0.330	0.350	507.69	504.92	2.77	3.704	24.000
19.10.25	51.29	43.85	7.44	501.21	500.09	1.11	0.346	0.366	507.51	504.71	2.79	3.720	24.000
20.10.25	50.96	43.63	7.33	501.46	500.83	0.62	0.351	0.371	507.68	505.42	2.26	3.670	24.000
Итого	---	---	---	12165.59	12131.07	34.51	---	---	12299.91	12232.35	67.55	75.758	743.700
Среднее	42.50	37.36	5.14	---	---	---	0.266	0.298	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 25 мкр., 8
 Потребитель: АО "Жилуправление"
 Прибор: Взлёт ТСРВ-024 Заводской номер: 900470
 Тип системы: А32-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	25.84	25.33	0.51	0.00	0.00	0.00	0.016	0.164	0.00	0.00	0.00	0.000	24.000
21.09.25	25.84	25.33	0.51	0.00	0.00	0.00	0.016	0.164	0.00	0.00	0.00	0.000	24.000
22.09.25	25.79	25.30	0.49	0.00	0.00	0.00	0.017	0.164	0.00	0.00	0.00	0.000	24.000
23.09.25	26.12	25.83	0.29	0.00	0.00	0.00	0.016	0.165	0.00	0.00	0.00	0.000	24.000
24.09.25	26.59	26.37	0.22	0.00	0.00	0.00	0.013	0.166	0.00	0.00	0.00	0.000	24.000
25.09.25	28.65	27.99	0.66	0.00	0.00	0.00	0.059	0.167	0.00	0.00	0.00	0.000	24.000
26.09.25	31.74	30.31	1.43	481.78	481.62	0.15	0.382	0.168	484.04	483.92	0.13	0.727	24.000
27.09.25	47.54	42.29	5.25	474.68	474.60	0.08	0.375	0.176	479.32	479.23	0.09	2.510	24.000
28.09.25	47.81	42.42	5.39	463.95	463.71	0.24	0.371	0.177	468.52	468.27	0.25	2.524	24.000
29.09.25	46.99	41.45	5.54	453.93	453.58	0.35	0.364	0.176	458.26	457.85	0.40	2.549	24.000
30.09.25	45.82	39.85	5.97	391.44	391.34	0.10	0.355	0.174	394.95	394.82	0.12	2.349	24.000
01.10.25	46.60	40.62	5.98	455.42	455.43	-0.00	0.407	0.175	459.26	459.97	-0.71	2.741	24.000
02.10.25	45.99	40.15	5.84	430.84	430.82	0.02	0.390	0.176	434.40	435.02	-0.62	2.531	24.000
03.10.25	47.48	41.18	6.30	422.09	422.07	0.01	0.383	0.178	426.07	426.20	-0.13	2.708	23.950
04.10.25	50.39	42.82	7.57	389.89	389.89	-0.00	0.369	0.179	393.72	394.27	-0.55	2.962	23.967
05.10.25	50.32	42.93	7.39	398.99	398.99	0	0.369	0.180	402.78	403.59	-0.80	2.959	24.000
06.10.25	49.27	42.01	7.26	391.81	391.81	0	0.367	0.179	395.60	395.95	-0.36	2.859	24.000
07.10.25	46.69	39.88	6.81	359.20	359.20	0.00	0.355	0.178	362.23	362.71	-0.48	2.455	24.000
08.10.25	44.75	38.98	5.77	327.06	327.04	0.02	0.308	0.177	329.59	330.07	-0.47	1.895	24.000
09.10.25	45.54	39.56	5.98	324.95	324.95	0	0.307	0.178	327.62	328.00	-0.38	1.945	24.000
10.10.25	46.06	39.97	6.09	328.00	327.99	0.01	0.306	0.178	330.69	331.20	-0.51	2.003	24.000
11.10.25	46.23	39.91	6.32	331.77	331.70	0.06	0.306	0.179	334.41	335.03	-0.62	2.103	24.000
12.10.25	46.76	40.05	6.71	297.07	297.05	0.02	0.299	0.180	299.65	299.85	-0.20	1.943	24.000
13.10.25	45.17	38.62	6.55	349.18	349.18	0	0.307	0.177	351.85	352.47	-0.63	2.294	24.000
14.10.25	45.73	39.01	6.72	352.63	352.62	0.01	0.305	0.177	355.42	355.99	-0.57	2.376	24.000
15.10.25	49.58	41.43	8.15	358.07	358.00	0.07	0.319	0.180	361.45	361.81	-0.35	2.921	24.000
16.10.25	50.63	41.98	8.65	354.35	354.35	0	0.316	0.181	357.76	358.32	-0.55	3.049	24.000
17.10.25	51.00	43.82	7.18	460.32	460.32	0	0.361	0.182	464.76	465.88	-1.12	3.317	24.000
18.10.25	50.57	43.49	7.08	458.84	458.84	0	0.338	0.181	463.31	464.19	-0.88	3.257	24.000
19.10.25	50.67	43.53	7.14	457.92	457.92	0.00	0.359	0.180	462.30	463.36	-1.06	3.278	24.000
20.10.25	50.69	43.67	7.02	457.44	457.44	0	0.364	0.181	462.13	462.59	-0.47	3.223	24.000
Итого	---	---	---	9971.62	9970.44	1.17	---	---	10060.10	10070.58	-10.48	63.481	743.917
Среднее	43.19	37.94	5.25	---	---	---	0.284	0.175	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, 34 микрорайон, 10
Потребитель: АО "Жилуправление"
Прибор: ТВ7-04.1 Заводской номер: 20127892

БД=1, ТВ1, СИ=6, КТЗ=0, ФРТ=0, КСН=0х21ДЗ

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	24.57	23.49	н/д	1.08	6.12	6.12	н/д	н/д	0.000	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
20.09.25	24.38	23.48	н/д	0.90	6.12	6.12	н/д	н/д	0.000	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
21.09.25	24.49	23.55	н/д	0.95	6.12	6.12	н/д	н/д	0.000	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
22.09.25	24.60	24.01	н/д	0.59	2.39	3.91	н/д	0.030	2.190	н/д	0.000	0.000	н/д	0.000	0.000	н/д	13	11
23.09.25	24.88	24.36	н/д	0.52	0.10	2.57	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
24.09.25	24.89	24.34	н/д	0.56	0.08	2.55	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
25.09.25	40.92	24.27	н/д	16.65	1.69	3.37	н/д	4.430	0.010	н/д	4.396	0.010	н/д	4.386	0.073	н/д	24	0
26.09.25	44.75	34.87	н/д	9.88	5.36	5.09	н/д	63.930	61.910	н/д	63.339	61.584	н/д	1.756	0.625	н/д	24	0
27.09.25	44.87	35.73	н/д	9.14	4.97	4.95	н/д	207.570	205.270	н/д	205.650	204.140	н/д	1.509	1.878	н/д	24	0
28.09.25	44.67	35.13	н/д	9.54	4.98	4.95	н/д	198.800	197.800	н/д	197.078	196.656	н/д	0.421	1.878	н/д	24	0
29.09.25	46.45	34.80	н/д	11.65	4.94	4.90	н/д	182.230	181.880	н/д	180.768	180.575	н/д	0.192	2.103	н/д	24	0
30.09.25	56.17	38.25	н/д	17.91	5.40	5.35	н/д	169.040	166.130	н/д	166.819	164.808	н/д	2.011	2.986	н/д	24	0
01.10.25	50.77	34.75	н/д	16.02	5.47	5.41	н/д	154.090	153.050	н/д	152.626	151.887	н/д	0.739	2.442	н/д	24	0
02.10.25	47.20	29.08	н/д	18.12	5.56	5.48	н/д	99.430	97.190	н/д	98.603	96.678	н/д	1.925	1.784	н/д	24	0
03.10.25	49.37	35.49	н/д	13.88	5.61	5.56	н/д	184.720	184.740	н/д	183.456	182.914	н/д	0.541	2.544	н/д	24	0
04.10.25	50.98	39.21	н/д	11.77	5.61	5.60	н/д	291.600	292.550	н/д	289.517	289.131	н/д	0.386	3.404	н/д	24	0
05.10.25	51.52	39.78	н/д	11.74	5.67	5.66	н/д	294.620	296.380	н/д	292.656	292.656	н/д	0.000	3.433	н/д	24	0
06.10.25	48.07	37.70	н/д	10.37	5.55	5.52	н/д	269.030	268.010	н/д	267.359	265.135	н/д	2.224	2.769	н/д	24	0
07.10.25	43.51	34.53	н/д	8.98	5.47	5.44	н/д	247.540	248.680	н/д	246.681	246.144	н/д	0.537	2.212	н/д	24	0
08.10.25	43.84	34.70	н/д	9.13	5.43	5.40	н/д	247.100	249.000	н/д	246.332	246.332	н/д	0.000	2.247	н/д	24	0
09.10.25	43.41	34.44	н/д	8.98	5.43	5.39	н/д	247.000	248.910	н/д	246.260	246.260	н/д	0.000	2.208	н/д	24	0
10.10.25	43.53	34.60	н/д	8.93	5.36	5.33	н/д	247.070	249.020	н/д	246.348	246.348	н/д	0.000	2.198	н/д	24	0
11.10.25	43.51	34.50	н/д	9.01	5.43	5.40	н/д	246.960	248.870	н/д	246.225	246.225	н/д	0.000	2.216	н/д	24	0
12.10.25	43.14	34.20	н/д	8.94	5.42	5.39	н/д	246.520	248.400	н/д	245.802	245.802	н/д	0.000	2.195	н/д	24	0
13.10.25	42.77	33.95	н/д	8.82	5.41	5.38	н/д	246.020	247.970	н/д	245.364	245.364	н/д	0.000	2.162	н/д	24	0
14.10.25	44.77	35.14	н/д	9.63	5.47	5.44	н/д	258.210	256.460	н/д	256.613	254.343	н/д	2.271	2.468	н/д	24	0
15.10.25	47.72	37.14	н/д	10.58	5.56	5.54	н/д	270.270	271.280	н/д	268.775	268.284	н/д	0.491	2.840	н/д	24	0
16.10.25	46.85	36.41	н/д	10.44	5.72	5.69	н/д	266.880	265.670	н/д	265.149	263.176	н/д	1.974	2.765	н/д	24	0
17.10.25	47.20	36.52	н/д	10.68	5.70	5.68	н/д	269.880	268.870	н/д	267.846	266.581	н/д	1.265	2.857	н/д	24	0
18.10.25	46.29	35.86	н/д	10.44	5.46	5.43	н/д	265.530	266.040	н/д	263.899	263.578	н/д	0.321	2.751	н/д	24	0
19.10.25	45.55	35.40	н/д	10.15	5.45	5.42	н/д	261.290	262.260	н/д	259.823	259.823	н/д	0.000	2.634	н/д	24	0
20.10.25	46.15	35.77	н/д	10.39	5.48	5.46	н/д	264.170	265.120	н/д	262.617	262.617	н/д	0.000	2.725	н/д	24	0
Итого	---	---	---	---	---	---	---	5703.960	5703.660	---	5670.001	5647.051	---	22.949	60.397	---	685	83
Среднее	45.34	34.50	---	10.84	4.95	5.18	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0	592
20.10.25 24:00	5703.960	5703.660	0.000	5670.000	5647.050	0.000	22.950	60.398	0.000	685	675
Итого за период	5703.960	5703.660	0.000	5670.000	5647.050	0.000	---	60.398	0.000	685	83

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 34 микрорайон, 10а
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ391

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	19.12	0.00	19.96	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	19.10	0.00	20.00	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	19.27	0.00	20.01	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	19.23	0.00	19.97	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	19.24	0.00	19.95	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	19.57	0.00	20.26	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	19.78	0.00	20.44	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	19.50	0.00	20.14	0.00	0.00	24.00	0.00	0.00
27.09.25	0.00	18.84	0.00	19.59	0.00	0.00	24.00	0.00	0.00
28.09.25	0.00	18.42	0.00	19.23	0.00	0.00	24.00	0.00	0.00
29.09.25	0.00	18.16	0.00	19.15	0.00	0.00	24.00	0.00	0.00
30.09.25	0.00	17.80	0.00	18.81	0.00	0.00	24.00	0.00	0.00
01.10.25	0.24	28.75	16.24	23.00	0.00	10.20	24.00	0.00	0.00
02.10.25	0.79	46.13	96.31	34.87	0.00	23.94	24.00	0.00	0.00
03.10.25	1.24	46.27	256.33	41.41	0.00	23.94	24.00	0.00	0.00
04.10.25	1.32	47.78	269.02	42.87	0.00	23.94	24.00	0.00	0.00
05.10.25	1.41	49.90	277.95	44.82	0.00	24.00	24.00	0.00	0.00
06.10.25	1.40	50.43	278.14	45.40	0.00	24.00	24.00	0.00	0.00
07.10.25	1.12	46.37	275.59	42.31	0.00	24.00	24.00	0.00	0.00
08.10.25	0.94	42.70	273.98	39.26	0.00	24.00	24.00	0.00	0.00
09.10.25	0.94	42.91	273.68	39.47	0.00	24.00	24.00	0.00	0.00
10.10.25	0.91	42.51	272.87	39.15	0.00	23.94	24.00	0.00	0.00
11.10.25	0.92	42.66	273.93	39.30	0.00	24.00	24.00	0.00	0.00
12.10.25	0.93	42.66	273.84	39.26	0.00	24.00	24.00	0.00	0.00
13.10.25	0.92	42.19	272.72	38.82	0.00	24.00	24.00	0.00	0.00
14.10.25	0.90	41.89	269.63	38.55	0.00	24.00	24.00	0.00	0.00
15.10.25	1.03	44.03	271.24	40.24	0.00	24.00	24.00	0.00	0.00
16.10.25	1.14	46.57	272.04	42.37	0.00	24.00	24.00	0.00	0.00
17.10.25	1.13	45.89	272.07	41.72	0.00	24.00	24.00	0.00	0.00
18.10.25	1.14	46.15	272.44	41.94	0.00	24.00	24.00	0.00	0.00
19.10.25	1.11	45.34	272.05	41.25	0.00	24.00	24.00	0.00	0.00
20.10.25	1.06	44.58	272.35	40.67	0.00	24.00	24.00	0.00	0.00
Итого	20.59	---	5012.42	---	0.00	465.96	768.00	0.00	0.00
Среднее	---	34.804	---	32.318	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	4987.02	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 34 микрорайон, 12/2
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВА774

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	0.00	20.00	0.00	21.34	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	20.19	0.00	21.57	1207.71	0.00	24.00	0.00	0.00
23.09.25	0.00	20.64	0.00	21.99	327.16	0.00	24.00	0.00	0.00
24.09.25	0.00	21.25	0.00	22.76	33.13	0.00	24.00	0.00	0.00
25.09.25	0.00	22.13	0.00	23.37	951.22	0.00	24.00	0.00	0.00
26.09.25	0.18	26.05	46.98	25.31	535.13	8.26	24.00	0.00	0.00
27.09.25	0.68	42.10	127.56	36.69	129.31	24.00	24.00	0.00	0.00
28.09.25	0.87	44.86	131.00	38.24	133.02	23.79	23.79	0.00	0.00
29.09.25	0.91	44.67	135.20	37.94	136.89	24.00	24.00	0.00	0.00
30.09.25	1.02	46.68	124.86	38.36	125.87	24.00	24.00	0.00	0.00
01.10.25	1.42	56.47	116.39	44.24	117.90	24.00	24.00	0.00	0.00
02.10.25	1.13	50.61	126.31	41.51	128.19	24.00	24.00	0.00	0.00
03.10.25	1.01	47.32	136.37	39.90	138.54	24.00	24.00	0.00	0.00
04.10.25	1.07	48.66	139.35	40.97	141.77	24.00	24.00	0.00	0.00
05.10.25	1.18	50.80	142.90	42.53	144.98	24.00	24.00	0.00	0.00
06.10.25	1.19	51.35	143.51	43.07	145.78	24.00	24.00	0.00	0.00
07.10.25	0.97	47.72	134.44	40.57	136.77	24.00	24.00	0.00	0.00
08.10.25	0.78	43.31	126.45	37.16	128.90	24.00	24.00	0.00	0.00
09.10.25	0.78	43.66	125.32	37.41	127.78	24.00	24.00	0.00	0.00
10.10.25	0.77	43.23	125.22	37.11	127.70	24.00	24.00	0.00	0.00
11.10.25	0.76	43.34	124.64	37.23	127.17	24.00	24.00	0.00	0.00
12.10.25	0.77	43.32	123.41	37.07	125.78	24.00	24.00	0.00	0.00
13.10.25	0.78	42.97	124.04	36.63	125.47	24.00	24.00	0.00	0.00
14.10.25	0.78	42.57	123.37	36.20	125.10	24.00	24.00	0.00	0.00
15.10.25	0.87	44.45	127.13	37.60	129.12	24.00	24.00	0.00	0.00
16.10.25	1.01	47.51	131.67	39.83	134.17	24.00	24.00	0.00	0.00
17.10.25	0.99	46.67	130.13	39.09	132.90	24.00	24.00	0.00	0.00
18.10.25	1.01	47.03	130.51	39.28	133.27	24.00	24.00	0.00	0.00
19.10.25	0.98	46.10	128.70	38.46	131.59	24.00	24.00	0.00	0.00
20.10.25	0.93	45.38	127.70	38.06	130.59	24.00	24.00	0.00	0.00
Итого	22.84	---	3153.16	---	6212.91	584.05	719.79	0.00	0.00
Среднее	---	41.368	---	35.716	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	3778.69	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 34 микрорайон, 13
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00182302

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0x093В

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	23.20	23.83	-0.63	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
21.09.25	23.24	23.77	-0.53	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
22.09.25	23.18	23.72	-0.54	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
23.09.25	23.82	24.18	-0.36	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
24.09.25	23.84	24.06	-0.22	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
25.09.25	36.09	34.05	2.04	72.880	72.880	72.440	72.500	-0.060	6.90	6.70	0.1490	0.0	24.0
26.09.25	42.19	38.72	3.47	193.310	193.310	191.720	191.980	-0.260	6.90	6.70	0.6650	0.0	24.0
27.09.25	44.87	40.25	4.62	190.500	190.500	188.730	189.060	-0.330	6.90	6.70	0.8710	0.0	24.0
28.09.25	44.67	39.76	4.91	191.220	191.220	189.460	189.780	-0.320	6.90	6.70	0.9270	0.0	24.0
29.09.25	46.78	40.58	6.20	176.330	176.330	174.480	174.940	-0.460	6.90	6.70	1.0810	0.0	24.0
30.09.25	56.48	47.03	9.45	167.360	167.360	164.930	165.670	-0.740	6.90	6.70	1.5540	0.0	24.0
01.10.25	50.14	43.38	6.76	183.500	183.500	181.350	181.890	-0.540	6.90	6.70	1.2220	0.0	24.0
02.10.25	47.35	41.65	5.70	196.070	196.070	193.980	194.430	-0.450	6.90	6.70	1.1020	0.0	24.0
03.10.25	48.74	42.80	5.94	199.430	199.430	197.200	197.660	-0.460	6.90	6.70	1.1700	0.0	24.0
04.10.25	50.83	44.45	6.38	203.490	203.490	201.040	201.600	-0.560	6.90	6.70	1.2790	0.0	24.0
05.10.25	51.36	44.96	6.40	204.700	204.700	202.190	202.760	-0.570	6.90	6.70	1.2930	0.0	24.0
06.10.25	47.77	42.21	5.56	191.250	191.250	189.210	189.620	-0.410	6.90	6.70	1.0530	0.0	24.0
07.10.25	43.35	38.58	4.77	180.390	180.390	178.740	179.190	-0.450	6.90	6.70	0.8520	0.0	24.0
08.10.25	43.66	38.83	4.83	178.660	178.660	177.060	177.460	-0.400	6.90	6.70	0.8550	0.0	24.0
09.10.25	43.24	38.52	4.72	178.640	178.640	177.070	177.440	-0.370	6.90	6.70	0.8360	0.0	24.0
10.10.25	43.36	38.64	4.72	178.260	178.260	176.670	177.060	-0.390	6.90	6.70	0.8310	0.0	24.0
11.10.25	43.35	38.54	4.81	177.610	177.610	176.030	176.410	-0.380	6.90	6.70	0.8450	0.0	24.0
12.10.25	42.96	38.09	4.87	177.240	177.240	175.700	176.040	-0.340	6.90	6.70	0.8570	0.0	24.0
13.10.25	42.59	37.77	4.82	176.720	176.720	175.240	175.520	-0.280	6.90	6.70	0.8440	0.0	24.0
14.10.25	44.62	39.36	5.26	182.460	182.460	180.790	181.150	-0.360	6.90	6.70	0.9500	0.0	24.0
15.10.25	47.54	41.74	5.80	189.010	189.010	186.980	187.470	-0.490	6.90	6.70	1.0850	0.0	24.0
16.10.25	46.70	41.00	5.70	187.200	187.200	185.270	185.750	-0.480	6.90	6.70	1.0560	0.0	24.0
17.10.25	47.04	41.28	5.76	187.700	187.700	185.770	186.210	-0.440	6.90	6.70	1.0680	0.0	24.0
18.10.25	46.13	40.51	5.62	185.090	185.090	183.200	183.650	-0.450	6.90	6.70	1.0260	0.0	24.0
19.10.25	45.38	40.00	5.38	183.670	183.670	181.900	182.250	-0.350	6.90	6.70	0.9790	0.0	24.0
20.10.25	45.99	40.42	5.57	185.000	185.000	183.120	183.560	-0.440	6.90	6.70	1.0210	0.0	24.0
Итого	---	---	---	4717.6	4717.6	4670.27	4681.05	-10.780	---	---	25.4710	0.0	744.0
Среднее	42.27	37.82	4.44	---	---	---	---	---	6.90	6.70	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	0	0	0	0	0	0	0	0
20.10.25 24:00	44217.289	45905.749	43634.959	45456.050	317.1370	-1821.090	2463.0	8536.0
Итого за период	44217.289	45905.749	43634.959	45456.050	317.1370	---	2463.0	8536.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 34 микрорайон, 13а
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00166313

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0хАСОС

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	20.62	20.12	0.50	0.000	0.000	0.000	0.000	0.000	1.34	1.48	0.0000	0.0	24.0
21.09.25	20.63	20.18	0.45	0.000	0.000	0.000	0.000	0.000	1.34	1.48	0.0000	0.0	24.0
22.09.25	20.79	20.39	0.40	0.000	0.000	0.000	0.000	0.000	1.34	1.48	0.0000	0.0	24.0
23.09.25	21.01	20.61	0.40	0.000	0.000	0.000	0.000	0.000	1.34	1.48	0.0000	0.0	24.0
24.09.25	21.27	20.90	0.37	0.000	0.000	0.000	0.000	0.000	1.35	1.49	0.0000	0.0	24.0
25.09.25	36.17	34.35	1.82	128.080	127.900	127.300	127.210	0.090	3.09	3.06	0.2340	0.0	24.0
26.09.25	42.14	39.46	2.68	328.080	328.600	325.330	326.190	-0.860	5.88	5.65	0.8700	0.0	24.0
27.09.25	44.89	41.65	3.24	300.480	300.340	297.620	297.890	-0.270	5.87	5.70	0.9640	0.0	24.0
28.09.25	44.70	41.42	3.28	294.900	294.400	292.150	292.030	0.120	5.87	5.71	0.9550	0.0	24.0
29.09.25	46.84	42.68	4.16	273.510	272.640	270.670	270.300	0.370	5.80	5.69	1.1230	0.0	24.0
30.09.25	56.51	49.94	6.57	266.950	265.900	263.000	262.770	0.230	6.22	6.15	1.7240	0.0	24.0
01.10.25	50.14	45.29	4.85	301.300	301.670	297.740	298.780	-1.040	6.31	6.20	1.4410	0.0	24.0
02.10.25	47.38	43.32	4.06	321.630	323.200	318.280	320.350	-2.070	6.41	6.26	1.2950	0.0	24.0
03.10.25	48.78	44.58	4.20	327.380	329.810	323.740	326.740	-3.000	6.47	6.32	1.3590	0.0	24.0
04.10.25	50.87	46.36	4.51	334.060	337.370	330.030	333.990	-3.960	6.50	6.34	1.4860	0.0	24.0
05.10.25	51.40	46.89	4.51	336.020	339.860	331.920	336.350	-4.430	6.55	6.39	1.4960	0.0	24.0
06.10.25	47.77	43.85	3.92	313.980	317.590	310.600	314.730	-4.130	6.41	6.28	1.2130	0.0	24.0
07.10.25	43.37	40.00	3.37	296.510	299.920	293.880	297.700	-3.820	6.31	6.21	0.9910	0.0	24.0
08.10.25	43.68	40.29	3.39	293.750	297.090	291.140	294.810	-3.670	6.27	6.18	0.9870	0.0	24.0
09.10.25	43.26	39.92	3.34	293.560	296.920	290.990	294.750	-3.760	6.27	6.17	0.9690	0.0	24.0
10.10.25	43.38	40.07	3.31	292.960	296.310	290.330	294.150	-3.820	6.20	6.11	0.9600	0.0	24.0
11.10.25	43.37	40.03	3.34	291.720	295.030	289.110	292.870	-3.760	6.27	6.18	0.9620	0.0	24.0
12.10.25	42.98	39.60	3.38	291.120	294.400	288.610	292.220	-3.610	6.26	6.17	0.9750	0.0	24.0
13.10.25	42.61	39.24	3.37	290.250	293.490	287.770	291.350	-3.580	6.25	6.16	0.9700	0.0	24.0
14.10.25	44.67	40.99	3.68	299.720	303.100	296.910	300.700	-3.790	6.32	6.21	1.0900	0.0	24.0
15.10.25	47.56	43.49	4.07	310.200	313.720	306.910	310.900	-3.990	6.42	6.30	1.2480	0.0	24.0
16.10.25	46.72	42.70	4.02	307.330	310.780	304.160	308.120	-3.960	6.57	6.45	1.2210	0.0	24.0
17.10.25	47.06	42.99	4.07	308.120	311.560	304.960	308.880	-3.920	6.55	6.43	1.2390	0.0	24.0
18.10.25	46.16	42.17	3.99	303.950	307.320	300.890	304.730	-3.840	6.31	6.20	1.2000	0.0	24.0
19.10.25	45.40	41.56	3.84	301.640	305.020	298.680	302.530	-3.850	6.29	6.19	1.1450	0.0	24.0
20.10.25	46.02	42.08	3.94	303.830	307.230	300.780	304.640	-3.860	6.33	6.22	1.1820	0.0	24.0
Итого	---	---	---	7711.0	7771.1	7633.50	7705.68	-72.180	---	---	29.2990	0.0	744.0
Среднее	41.87	38.61	3.25	---	---	---	---	---	5.38	5.30	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	0	0	0	0	0	0	0	0
20.10.25 24:00	67566.189	68243.730	66654.049	67503.949	378.0490	-849.900	2229.0	8771.0
Итого за период	67566.189	68243.730	66654.049	67503.949	378.0490	---	2229.0	8771.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 34 микрорайон, 16а
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00178920

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0х764А

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Мг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	23.13	23.86	-0.73	0.000	0.000	0.000	0.000	0.000	2.01	5.38	0.0000	0.0	24.0
21.09.25	22.98	23.71	-0.73	0.000	0.000	0.000	0.000	0.000	2.01	6.14	0.0000	0.0	24.0
22.09.25	22.89	23.62	-0.73	0.000	0.000	0.000	0.000	0.000	2.01	4.77	0.0000	0.0	24.0
23.09.25	23.25	23.93	-0.68	0.000	0.000	0.000	0.000	0.000	2.01	4.00	0.0000	0.0	24.0
24.09.25	23.55	24.04	-0.49	0.000	0.000	0.000	0.000	0.000	2.01	3.79	0.0000	0.0	24.0
25.09.25	22.40	22.84	-0.44	0.000	0.000	0.000	0.000	0.000	2.01	3.04	0.0000	0.0	24.0
26.09.25	44.73	41.37	3.36	159.650	155.250	158.110	153.980	4.130	2.01	3.75	0.5190	0.0	24.0
27.09.25	45.03	41.84	3.19	323.080	315.360	319.950	312.750	7.200	2.01	4.16	1.0030	0.0	24.0
28.09.25	44.85	41.55	3.30	322.940	316.110	319.830	313.510	6.320	2.01	4.19	1.0400	0.0	24.0
29.09.25	47.28	42.98	4.30	304.090	298.380	300.830	295.760	5.070	2.01	4.27	1.2750	0.0	24.0
30.09.25	56.74	50.33	6.41	297.610	292.660	293.110	289.190	3.920	2.01	4.43	1.8620	0.0	24.0
01.10.25	50.17	45.71	4.46	331.410	326.910	327.430	323.650	3.780	2.01	4.16	1.4420	0.0	24.0
02.10.25	47.57	43.74	3.83	354.540	351.270	350.720	348.070	2.650	2.01	4.15	1.3230	0.0	24.0
03.10.25	49.00	45.00	4.00	360.830	358.180	356.710	354.730	1.980	2.01	4.35	1.4090	0.0	24.0
04.10.25	51.07	46.78	4.29	368.020	365.870	363.490	362.090	1.400	2.01	4.29	1.5350	0.0	24.0
05.10.25	51.60	47.31	4.29	370.200	368.230	365.510	364.340	1.170	2.01	4.00	1.5510	0.0	24.0
06.10.25	47.81	44.16	3.65	344.890	343.460	341.110	340.290	0.820	2.01	3.91	1.2300	0.0	24.0
07.10.25	43.56	40.41	3.15	326.710	325.510	323.750	322.980	0.770	2.01	3.85	1.0090	0.0	24.0
08.10.25	43.84	40.67	3.17	325.150	323.840	322.150	321.300	0.850	2.01	3.65	1.0080	0.0	24.0
09.10.25	43.42	40.30	3.12	324.890	323.580	321.940	321.060	0.880	2.02	2.83	1.0000	0.0	24.0
10.10.25	43.56	40.44	3.12	324.800	323.770	321.860	321.220	0.640	2.01	2.66	1.0000	0.0	24.0
11.10.25	43.55	40.38	3.17	324.410	323.330	321.500	320.770	0.730	2.01	2.35	1.0170	0.0	24.0
12.10.25	43.13	39.91	3.22	324.210	322.960	321.290	320.470	0.820	2.02	2.19	1.0280	0.0	24.0
13.10.25	42.79	39.58	3.21	323.380	322.140	320.540	319.700	0.840	2.02	2.17	1.0260	0.0	24.0
14.10.25	44.96	41.46	3.50	333.870	332.670	330.660	329.940	0.720	2.01	1.93	1.1570	0.0	24.0
15.10.25	47.74	43.87	3.87	345.190	343.890	341.450	340.730	0.720	2.01	1.91	1.3200	0.0	24.0
16.10.25	46.93	43.09	3.84	342.580	341.110	338.960	338.070	0.890	2.01	1.58	1.3040	0.0	24.0
17.10.25	47.25	43.34	3.91	343.210	341.840	339.590	338.730	0.860	2.01	1.55	1.3280	0.0	24.0
18.10.25	46.36	42.54	3.82	338.410	337.230	334.960	334.300	0.660	2.01	1.81	1.2770	0.0	24.0
19.10.25	45.59	41.92	3.67	336.240	334.850	332.880	332.060	0.820	2.01	1.65	1.2180	0.0	24.0
20.10.25	46.21	42.45	3.76	338.550	337.260	335.120	334.350	0.770	2.01	1.37	1.2630	0.0	24.0
Итого	---	---	---	8188.8	8125.6	8103.45	8054.04	49.410	---	---	30.1440	0.0	744.0
Среднее	42.03	39.13	2.89	---	---	---	---	---	2.01	3.36	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Мг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	0	0	0	0	0	0	0	0
20.10.25 24:00	129981.700	128881.660	128070.340	127416.749	788.0300	653.590	523.0	19093.0
Итого за период	129981.700	128881.660	128070.340	127416.749	788.0300	---	523.0	19093.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 34 микрорайон, 166
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00182774

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0хD783

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	20.51	19.73	0.78	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
21.09.25	20.60	19.84	0.76	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
22.09.25	20.99	20.32	0.67	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
23.09.25	21.46	20.86	0.60	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
24.09.25	21.96	21.47	0.49	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
25.09.25	20.83	19.99	0.84	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
26.09.25	44.46	40.95	3.51	174.930	173.830	173.280	172.460	0.820	6.90	6.70	0.6170	0.0	24.0
27.09.25	45.04	41.29	3.75	297.370	297.360	294.550	295.000	-0.450	6.90	6.70	1.0990	0.0	24.0
28.09.25	44.83	40.99	3.84	295.290	295.720	292.540	293.370	-0.830	6.90	6.70	1.1240	0.0	24.0
29.09.25	47.06	42.29	4.77	274.980	276.800	272.090	274.460	-2.370	6.90	6.70	1.2950	0.0	24.0
30.09.25	56.79	49.73	7.06	264.060	265.800	260.150	262.700	-2.550	6.90	6.70	1.8320	0.0	24.0
01.10.25	50.31	45.32	4.99	292.990	295.610	289.510	292.740	-3.230	6.90	6.70	1.4400	0.0	24.0
02.10.25	47.52	43.28	4.24	313.840	316.750	310.510	313.940	-3.430	6.90	6.70	1.3160	0.0	24.0
03.10.25	48.93	44.41	4.52	319.980	322.710	316.420	319.700	-3.280	6.90	6.70	1.4280	0.0	24.0
04.10.25	51.03	46.20	4.83	327.060	329.150	323.060	325.860	-2.800	6.90	6.70	1.5550	0.0	24.0
05.10.25	51.56	46.73	4.83	329.410	331.190	325.340	327.800	-2.460	6.66	6.70	1.5690	0.0	24.0
06.10.25	47.91	43.77	4.14	307.580	309.290	304.260	306.490	-2.230	6.90	6.70	1.2540	0.0	24.0
07.10.25	43.49	39.96	3.53	290.370	292.100	287.750	289.940	-2.190	6.90	6.70	1.0160	0.0	24.0
08.10.25	43.80	40.24	3.56	288.940	290.620	286.370	288.410	-2.040	6.90	6.70	1.0210	0.0	24.0
09.10.25	43.38	39.85	3.53	288.720	290.430	286.160	288.270	-2.110	6.20	6.70	1.0010	0.0	24.0
10.10.25	43.50	40.02	3.48	288.740	290.450	286.160	288.290	-2.130	6.90	6.70	0.9950	0.0	24.0
11.10.25	43.49	39.95	3.54	288.380	290.050	285.770	287.890	-2.120	6.00	6.70	1.0070	0.0	24.0
12.10.25	43.10	39.50	3.60	287.950	289.620	285.450	287.510	-2.060	6.65	6.70	1.0230	0.0	24.0
13.10.25	42.73	39.17	3.56	287.160	288.780	284.700	286.690	-1.990	6.89	6.70	1.0120	0.0	24.0
14.10.25	44.81	40.93	3.88	296.280	297.930	293.500	295.590	-2.090	6.90	6.70	1.1380	0.0	24.0
15.10.25	47.71	43.36	4.35	307.100	308.670	303.840	305.940	-2.100	6.90	6.70	1.3230	0.0	24.0
16.10.25	46.86	42.55	4.31	304.380	305.950	301.240	303.320	-2.080	6.41	6.70	1.2970	0.0	24.0
17.10.25	47.20	42.82	4.38	305.390	306.980	302.250	304.340	-2.090	6.90	6.70	1.3210	0.0	24.0
18.10.25	46.30	42.01	4.29	301.130	302.690	298.090	300.210	-2.120	6.55	6.70	1.2780	0.0	24.0
19.10.25	45.53	41.44	4.09	298.810	300.330	295.870	297.890	-2.020	6.90	6.70	1.2120	0.0	24.0
20.10.25	46.16	41.97	4.19	300.890	302.480	297.900	300.010	-2.110	6.90	6.70	1.2450	0.0	24.0
Итого	---	---	---	7331.7	7371.2	7256.76	7308.82	-52.060	---	---	30.4180	0.0	744.0
Среднее	41.60	38.09	3.51	---	---	---	---	---	6.81	6.70	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	0	0	0	0	0	0	0	0
20.10.25 24:00	70924.440	71231.849	69952.719	70451.710	410.7880	-498.990	2116.0	8818.0
Итого за период	70924.440	71231.849	69952.719	70451.710	410.7880	---	2116.0	8818.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 34 микрорайон, 19
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ704

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	0.00	20.35	0.00	20.97	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	20.42	0.00	21.04	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	20.76	0.00	21.35	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	21.12	0.00	21.68	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	21.48	0.00	21.99	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	20.95	0.00	21.48	0.00	0.00	24.00	0.00	0.00
27.09.25	0.79	33.82	159.39	31.15	159.10	14.03	24.00	0.00	0.00
28.09.25	1.74	44.26	322.08	38.85	328.38	24.00	24.00	0.00	0.00
29.09.25	1.95	44.07	336.80	38.26	342.17	24.00	24.00	0.00	0.00
30.09.25	2.58	46.55	327.31	38.54	332.01	24.00	24.00	0.00	0.00
01.10.25	3.87	55.91	327.14	44.05	331.72	24.00	24.00	0.00	0.00
02.10.25	3.25	49.70	371.16	40.77	376.30	24.00	24.00	0.00	0.00
03.10.25	3.01	46.73	400.94	39.20	406.03	24.00	24.00	0.00	0.00
04.10.25	3.18	48.11	408.31	40.32	412.79	24.00	24.00	0.00	0.00
05.10.25	3.47	50.19	416.76	41.85	420.63	24.00	24.00	0.00	0.00
06.10.25	3.48	50.71	419.24	42.39	422.39	24.00	24.00	0.00	0.00
07.10.25	2.81	46.79	391.56	39.67	394.56	24.00	24.00	0.00	0.00
08.10.25	2.28	42.75	370.32	36.58	373.63	24.00	24.00	0.00	0.00
09.10.25	2.28	43.03	368.91	36.84	372.26	24.00	24.00	0.00	0.00
10.10.25	2.23	42.62	368.61	36.55	371.72	24.00	24.00	0.00	0.00
11.10.25	2.22	42.75	368.81	36.73	371.71	24.00	24.00	0.00	0.00
12.10.25	2.24	42.74	368.54	36.64	371.53	24.00	24.00	0.00	0.00
13.10.25	2.26	42.34	367.97	36.17	371.07	24.00	24.00	0.00	0.00
14.10.25	2.28	41.99	367.07	35.78	369.93	24.00	24.00	0.00	0.00
15.10.25	2.57	44.06	379.12	37.27	381.86	24.00	24.00	0.00	0.00
16.10.25	2.94	46.85	392.41	39.35	395.03	24.00	24.00	0.00	0.00
17.10.25	2.89	46.08	389.05	38.62	391.44	24.00	24.00	0.00	0.00
18.10.25	2.94	46.40	390.13	38.86	392.38	24.00	24.00	0.00	0.00
19.10.25	2.84	45.52	384.77	38.12	387.13	24.00	24.00	0.00	0.00
20.10.25	2.70	44.75	381.91	37.68	384.00	24.00	24.00	0.00	0.00
Итого	62.80	---	8778.31	---	8859.77	566.03	720.00	0.00	0.00
Среднее	---	40.460	---	34.958	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	3824.86	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 34 микрорайон, 1
 Потребитель: АО "Жилуправление"
 Прибор: ТЭМ-106 Заводской номер: 3060280
 Формула: $Q = M1(h1 - h2)$
 Тип системы: Подача + расходомер

Система: 1

ТВ1

	ДУ, мм	Gmin, м3/ч	Gmax, м3/ч	Kv, л/имп	Fmax, КГц
1	80	7.5	180	10	---
2	80	8	192	10	---

Дата	Q, (Гкал)	M1, (т)	M2, (т)	dM, (т)	T1, (°C)	T2, (°C)	P1, (МПа)	P2, (МПа)	Время наработки, (ч)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	0	0.00	0.08	-0.1	24.037	24.510	0.2	0.2	24.00
22.09.25	0	0.00	0.09	-0.1	25.121	25.032	0.2	0.2	24.00
23.09.25	0.000	0.00	0.11	-0.1	29.692	27.922	0.2	0.2	24.00
24.09.25	0.000	0.00	0.11	-0.1	29.349	27.653	0.2	0.2	24.00
25.09.25	0.000	0.00	0.11	-0.1	28.639	27.299	0.2	0.2	24.00
26.09.25	0.942	327.56	325.83	1.7	44.144	41.278	0.4	0.4	24.00
27.09.25	1.549	502.03	502.81	-0.8	44.938	41.861	0.5	0.5	24.00
28.09.25	1.638	499.42	500.23	-0.8	44.753	41.480	0.5	0.5	24.00
29.09.25	2.074	467.90	468.08	-0.2	47.375	42.949	0.5	0.5	24.00
30.09.25	2.924	452.51	453.10	-0.6	56.734	50.280	0.6	0.5	24.00
01.10.25	2.230	501.94	502.07	-0.1	49.963	45.529	0.6	0.5	24.00
02.10.25	2.045	530.08	529.97	0.1	47.466	43.616	0.6	0.5	24.00
03.10.25	2.166	530.82	530.60	0.2	48.926	44.853	0.6	0.5	24.00
04.10.25	2.335	531.24	531.23	0.0	50.979	46.593	0.6	0.5	24.00
05.10.25	2.319	533.73	534.05	-0.3	51.512	47.176	0.6	0.5	24.00
06.10.25	1.821	495.66	496.08	-0.4	47.515	43.848	0.6	0.5	24.00
07.10.25	1.519	471.45	471.96	-0.5	43.454	40.238	0.6	0.5	24.00
08.10.25	1.520	469.93	470.51	-0.6	43.690	40.462	0.6	0.5	24.00
09.10.25	1.492	469.14	469.75	-0.6	43.276	40.102	0.6	0.5	24.00
10.10.25	1.482	469.81	470.44	-0.6	43.434	40.286	0.6	0.5	24.00
11.10.25	1.493	469.48	470.15	-0.7	43.430	40.256	0.6	0.5	24.00
12.10.25	1.497	468.33	469.04	-0.7	42.960	39.769	0.6	0.5	24.00
13.10.25	1.471	466.97	467.67	-0.7	42.649	39.505	0.6	0.5	24.00
14.10.25	1.713	482.92	483.72	-0.8	44.931	41.391	0.6	0.5	24.00
15.10.25	1.919	497.31	498.15	-0.8	47.576	43.725	0.6	0.5	24.00
16.10.25	1.912	494.12	494.94	-0.8	46.810	42.948	0.6	0.6	24.00
17.10.25	1.932	495.72	496.55	-0.8	47.087	43.197	0.6	0.6	24.00
18.10.25	1.873	489.80	490.64	-0.8	46.229	42.411	0.6	0.5	24.00
19.10.25	1.778	486.00	486.81	-0.8	45.443	41.792	0.6	0.5	24.00
20.10.25	1.831	489.03	489.87	-0.8	46.080	42.342	0.6	0.5	24.00
Итого	45.47	12092.9	12104.7	-11.7	---	---	---	---	720.00
Среднее	---	---	---	---	43.27	40.01	0.5	0.5	---

Показания интеграторов

Дата	Q, (Гкал)	M1, (т)	M2, (т)	Время наработки, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д
20.10.25 24:00	9604.7	1082995.6	1083114.6	87602.9
Итого за период	н/д	н/д	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 34 микрорайон, 20
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВА776

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-
28.09.25	0.33	44.24	65.83	39.29	65.96	24.00	24.00	0.00	0.00
29.09.25	0.50	44.31	92.37	38.85	92.57	24.00	24.00	0.00	0.00
30.09.25	0.56	46.12	84.95	39.35	85.18	24.00	24.00	0.00	0.00
01.10.25	0.82	55.84	80.99	45.70	81.36	24.00	24.00	0.00	0.00
02.10.25	0.66	50.28	89.65	42.77	89.93	24.00	24.00	0.00	0.00
03.10.25	0.58	46.99	95.41	40.85	95.65	24.00	24.00	0.00	0.00
04.10.25	0.61	48.29	97.04	41.96	97.29	24.00	24.00	0.00	0.00
05.10.25	0.67	50.42	98.98	43.64	99.26	24.00	24.00	0.00	0.00
06.10.25	0.68	50.97	99.65	44.18	99.95	24.00	24.00	0.00	0.00
07.10.25	0.55	47.47	93.57	41.60	93.80	24.00	24.00	0.00	0.00
08.10.25	0.44	43.04	88.33	38.02	88.50	24.00	24.00	0.00	0.00
09.10.25	0.44	43.40	87.55	38.30	87.72	24.00	24.00	0.00	0.00
10.10.25	0.43	42.97	87.63	37.85	82.50	24.00	24.00	0.00	0.00
11.10.25	0.43	43.05	82.33	37.19	71.76	24.00	24.00	0.00	0.00
12.10.25	0.42	42.68	71.30	36.77	71.46	24.00	24.00	0.00	0.00
13.10.25	0.42	42.28	71.01	36.35	71.17	24.00	24.00	0.00	0.00
14.10.25	0.42	42.28	71.01	36.35	71.17	24.00	24.00	0.00	0.00
15.10.25	0.47	44.08	73.78	37.66	73.96	24.00	24.00	0.00	0.00
16.10.25	0.55	47.16	77.41	40.11	77.63	24.00	24.00	0.00	0.00
17.10.25	0.53	46.30	76.35	39.33	76.56	24.00	24.00	0.00	0.00
18.10.25	0.54	46.67	76.54	39.55	76.75	24.00	24.00	0.00	0.00
19.10.25	0.52	45.76	75.61	38.85	75.82	24.00	24.00	0.00	0.00
20.10.25	0.50	45.06	74.35	38.34	74.55	24.00	24.00	0.00	0.00
Итого	12.07	---	1912.23	---	1917.12	552.00	552.00	0.00	0.00
Среднее	---	46.103	---	39.763	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	1788.36	0.01
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 34 микрорайон, 21
 Потребитель: АО "Жилуправление"
 Прибор: Вzlёт ТСРВ-024 Заводской номер: 801135
 Тип системы: А32-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	0.00	0.00	0.00	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	0.000
20.09.25	20.53	20.16	0.37	0.00	0.00	0.00	0.021	0.127	0.00	0.00	0.00	0.000	22.883
21.09.25	20.62	20.26	0.36	0.00	0.00	0.00	0.019	0.127	0.00	0.00	0.00	0.000	24.000
22.09.25	20.72	20.42	0.30	0.00	0.00	0.00	0.022	0.113	0.00	0.00	0.00	0.000	24.000
23.09.25	20.96	20.66	0.30	0.00	0.00	0.00	0.003	0.011	0.00	0.00	0.00	0.000	24.000
24.09.25	21.39	21.07	0.32	0.00	0.00	0.00	0.004	0.012	0.00	0.00	0.00	0.000	24.000
25.09.25	21.45	21.08	0.37	0.00	0.00	0.00	0.004	0.012	0.00	0.00	0.00	0.000	24.000
26.09.25	37.05	33.22	3.83	144.97	140.42	4.55	0.444	0.414	145.95	141.26	4.69	0.727	23.917
27.09.25	45.14	37.69	7.45	163.76	161.31	2.45	0.480	0.462	165.34	162.42	2.92	1.320	24.000
28.09.25	44.80	36.68	8.12	162.22	160.10	2.12	0.479	0.467	163.78	161.12	2.66	1.394	24.000
29.09.25	44.41	36.21	8.20	160.74	158.65	2.09	0.467	0.457	162.26	159.64	2.63	1.391	23.833
30.09.25	53.62	39.69	13.93	137.58	135.81	1.76	0.505	0.502	139.47	136.84	2.63	1.989	24.000
01.10.25	55.00	41.33	13.67	135.66	133.97	1.69	0.516	0.511	137.59	135.06	2.53	1.906	24.000
02.10.25	46.97	37.72	9.25	162.62	160.30	2.32	0.537	0.529	164.33	161.38	2.95	1.591	24.000
03.10.25	47.47	38.24	9.23	165.51	163.50	2.00	0.531	0.524	167.28	164.64	2.65	1.602	24.000
04.10.25	50.45	40.18	10.27	170.97	169.06	1.91	0.541	0.533	173.04	170.36	2.68	1.829	24.000
05.10.25	51.11	40.68	10.43	171.69	169.87	1.81	0.544	0.536	173.81	171.21	2.61	1.862	24.000
06.10.25	51.01	40.88	10.13	169.77	168.00	1.77	0.541	0.535	171.87	169.34	2.54	1.795	24.000
07.10.25	43.51	35.93	7.58	152.61	150.81	1.80	0.524	0.522	153.99	151.73	2.26	1.219	24.000
08.10.25	43.75	35.99	7.76	151.37	149.65	1.71	0.520	0.519	152.75	150.57	2.18	1.235	24.000
09.10.25	43.48	35.86	7.62	150.69	149.00	1.68	0.518	0.518	152.05	149.91	2.14	1.206	24.000
10.10.25	43.26	35.92	7.34	150.47	147.75	2.72	0.514	0.514	151.82	148.65	3.17	1.200	24.000
11.10.25	43.46	38.33	5.13	260.55	257.92	2.63	0.511	0.520	262.90	259.73	3.17	1.404	24.000
12.10.25	43.61	38.72	4.89	273.01	270.76	2.25	0.514	0.524	275.49	272.69	2.80	1.420	24.000
13.10.25	42.75	37.94	4.81	273.72	271.35	2.36	0.512	0.523	276.11	273.21	2.90	1.402	24.000
14.10.25	43.24	38.26	4.98	274.98	271.90	3.08	0.512	0.524	277.44	273.79	3.65	1.484	24.000
15.10.25	47.29	41.24	6.05	279.36	276.72	2.63	0.524	0.534	282.34	278.96	3.38	1.796	24.000
16.10.25	46.42	40.52	5.90	277.81	275.00	2.80	0.531	0.541	280.66	277.15	3.51	1.751	24.000
17.10.25	47.39	41.23	6.16	280.53	277.78	2.75	0.552	0.563	283.53	280.03	3.50	1.847	23.917
18.10.25	46.43	40.47	5.96	278.35	275.32	3.03	0.521	0.532	281.22	277.47	3.75	1.778	24.000
19.10.25	45.98	40.17	5.81	278.14	275.11	3.03	0.517	0.528	280.95	277.22	3.72	1.734	24.000
20.10.25	45.66	39.98	5.68	279.33	276.39	2.94	0.516	0.527	282.11	278.49	3.62	1.703	24.000
Итого	---	---	---	5106.41	5046.41	60.00	---	---	5158.09	5082.86	75.23	38.585	742.550
Среднее	39.97	33.96	6.01	---	---	---	0.405	0.414	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 34 микрорайон, 22
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00176982

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0xE736

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	18.54	18.76	-0.22	0.320	0.320	0.320	0.320	0.000	4.48	4.33	0.0000	0.0	24.0
20.09.25	18.80	19.08	-0.28	0.000	0.000	0.000	0.000	0.000	1.10	1.02	0.0000	0.0	24.0
21.09.25	19.07	19.31	-0.24	0.000	0.000	0.000	0.000	0.000	1.10	1.02	0.0000	0.0	24.0
22.09.25	19.14	19.44	-0.30	0.000	0.000	0.000	0.000	0.000	1.10	1.02	0.0000	0.0	24.0
23.09.25	20.45	20.71	-0.26	0.000	0.000	0.000	0.000	0.000	1.10	1.02	0.0000	0.0	24.0
24.09.25	21.56	21.78	-0.22	0.000	0.000	0.000	0.000	0.000	1.10	1.02	0.0000	0.0	24.0
25.09.25	36.35	34.19	2.16	102.660	103.300	102.020	102.740	-0.720	2.88	2.66	0.2220	0.0	24.0
26.09.25	42.22	38.66	3.56	282.980	285.350	280.580	283.320	-2.740	5.89	5.55	0.9950	0.0	24.0
27.09.25	45.00	40.09	4.91	266.270	268.220	263.740	266.190	-2.450	5.87	5.63	1.2920	0.0	24.0
28.09.25	44.80	39.55	5.25	262.590	263.860	260.130	261.940	-1.810	5.87	5.65	1.3610	0.0	24.0
29.09.25	46.88	40.29	6.59	244.830	245.160	242.270	243.300	-1.030	5.81	5.62	1.5930	0.0	24.0
30.09.25	56.62	46.91	9.71	230.060	229.570	226.670	227.170	-0.500	6.24	6.07	2.1940	0.0	24.0
01.10.25	50.27	43.25	7.02	254.660	253.970	251.650	251.720	-0.070	6.32	6.13	1.7610	0.0	24.0
02.10.25	47.47	41.46	6.01	270.830	270.040	267.980	267.880	0.100	6.41	6.20	1.6080	0.0	24.0
03.10.25	48.87	42.63	6.24	275.600	274.400	272.530	272.060	0.470	6.48	6.26	1.6990	0.0	24.0
04.10.25	50.96	44.30	6.66	281.450	279.830	278.050	277.250	0.800	6.51	6.28	1.8500	0.0	24.0
05.10.25	51.49	44.85	6.64	282.760	281.010	279.250	278.340	0.910	6.56	6.33	1.8500	0.0	24.0
06.10.25	47.89	42.20	5.69	264.300	262.790	261.440	260.550	0.890	6.42	6.21	1.4840	0.0	24.0
07.10.25	43.46	38.57	4.89	249.830	248.490	247.670	246.810	0.860	6.32	6.14	1.2050	0.0	24.0
08.10.25	43.77	38.85	4.92	247.630	246.270	245.390	244.530	0.860	6.29	6.10	1.2070	0.0	24.0
09.10.25	43.35	38.51	4.84	247.710	246.350	245.540	244.670	0.870	6.28	6.10	1.1840	0.0	24.0
10.10.25	43.46	38.46	5.00	236.960	235.680	234.880	234.080	0.800	6.21	6.03	1.1720	0.0	24.0
11.10.25	43.46	38.00	5.46	216.810	215.610	214.890	214.170	0.720	6.27	6.12	1.1730	0.0	24.0
12.10.25	43.07	37.50	5.57	215.870	214.610	214.000	213.170	0.830	6.26	6.11	1.1900	0.0	24.0
13.10.25	42.70	37.08	5.62	215.280	214.030	213.410	212.590	0.820	6.25	6.10	1.1980	0.0	24.0
14.10.25	44.75	38.68	6.07	224.220	222.860	222.120	221.290	0.830	6.32	6.16	1.3490	0.0	24.0
15.10.25	47.67	41.02	6.65	233.560	232.170	231.070	230.340	0.730	6.42	6.25	1.5370	0.0	24.0
16.10.25	46.81	40.19	6.62	230.460	229.100	228.070	227.400	0.670	6.57	6.40	1.5050	0.0	24.0
17.10.25	47.15	40.42	6.73	231.300	229.810	228.900	228.060	0.840	6.55	6.38	1.5380	0.0	24.0
18.10.25	46.25	39.66	6.59	228.150	226.610	225.870	224.930	0.940	6.31	6.15	1.4840	0.0	24.0
19.10.25	45.50	39.16	6.34	225.130	223.660	222.910	222.030	0.880	6.29	6.14	1.4080	0.0	24.0
20.10.25	46.11	39.66	6.45	226.400	225.030	224.170	223.350	0.820	6.33	6.17	1.4450	0.0	24.0
Итого	---	---	---	6248.6	6228.0	6185.52	6180.20	5.320	---	---	36.5040	0.0	768.0
Среднее	41.05	36.35	4.70	---	---	---	---	---	5.31	5.14	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	49104.190	48646.060	48428.430	48180.720	447.2630	247.710	1843.0	7644.0
20.10.25 24:00	55352.810	54874.160	54613.950	54360.919	483.7670	253.030	1843.0	8412.0
Итого за период	6248.619	6228.100	6185.519	6180.199	36.5040	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 34 микрорайон, 26
 Потребитель: АО "Жилуправление"
 Прибор: ТЭМ-106 Заводской номер: 3060240
 Формула: $Q = M1(h1 - h2)$
 Тип системы: Подача + расходомер

Система: 1

ТВ1

	ДУ, мм	Gmin, м3/ч	Gmax, м3/ч	Kv, л/имп	Fmax, КГц
1	80	9.6	160	10	---
2	80	10.02	167	10	---

Дата	Q, (Гкал)	M1, (т)	M2, (т)	dM, (т)	T1, (°C)	T2, (°C)	P1, (МПа)	P2, (МПа)	Время наработки, (ч)
19.09.25	н/д	н/д	н/д	н/д	24.014	22.295	0.5	0.5	н/д
20.09.25	0.000	0.00	0.00	0.0	24.137	22.449	0.5	0.5	24.00
21.09.25	0.000	0.00	0.00	0.0	24.089	22.393	0.5	0.5	24.00
22.09.25	0.000	0.00	0.00	0.0	25.279	22.872	0.5	0.5	24.00
23.09.25	0.000	0.00	0.00	0.0	27.637	23.700	0.5	0.5	24.00
24.09.25	0.000	0.00	0.00	0.0	27.488	23.890	0.5	0.5	24.00
25.09.25	0.000	0.00	0.00	0.0	26.129	23.277	0.5	0.5	24.00
26.09.25	1.003	226.45	225.61	0.8	44.445	40.012	0.5	0.5	24.00
27.09.25	1.633	387.75	388.02	-0.3	44.864	40.649	0.5	0.5	24.00
28.09.25	1.618	383.77	384.08	-0.3	44.682	40.461	0.5	0.5	24.00
29.09.25	1.981	367.62	367.13	0.5	47.448	42.056	0.5	0.5	24.00
30.09.25	2.743	364.87	365.31	-0.4	56.680	49.162	0.5	0.5	24.00
01.10.25	2.248	417.60	417.64	-0.0	49.799	44.413	0.5	0.5	24.00
02.10.25	2.088	444.28	444.26	0.0	47.392	42.690	0.5	0.5	24.00
03.10.25	2.212	449.71	449.66	0.1	48.885	43.963	0.5	0.5	24.00
04.10.25	2.374	455.27	455.10	0.2	50.907	45.691	0.5	0.5	24.00
05.10.25	2.380	457.29	456.96	0.3	51.439	46.232	0.5	0.5	24.00
06.10.25	1.905	424.86	424.55	0.3	47.369	42.883	0.5	0.5	24.00
07.10.25	1.622	404.84	404.60	0.2	43.388	39.378	0.5	0.5	24.00
08.10.25	1.626	404.51	404.33	0.2	43.606	39.583	0.5	0.5	24.00
09.10.25	1.606	404.53	404.37	0.2	43.193	39.218	0.5	0.5	24.00
10.10.25	1.598	404.69	404.56	0.1	43.360	39.407	0.5	0.5	24.00
11.10.25	1.605	404.34	404.29	0.1	43.360	39.387	0.5	0.5	24.00
12.10.25	1.592	403.53	403.55	-0.0	42.875	38.925	0.5	0.5	24.00
13.10.25	1.587	402.98	403.05	-0.1	42.569	38.626	0.5	0.5	24.00
14.10.25	1.819	417.24	417.34	-0.1	44.896	40.531	0.5	0.5	24.00
15.10.25	2.002	429.31	429.44	-0.1	47.482	42.815	0.5	0.5	24.00
16.10.25	1.976	426.27	426.47	-0.2	46.739	42.098	0.5	0.5	24.00
17.10.25	1.999	426.78	427.01	-0.2	46.999	42.311	0.5	0.5	24.00
18.10.25	1.950	422.02	422.28	-0.3	46.152	41.527	0.5	0.5	24.00
19.10.25	1.863	418.92	419.20	-0.3	45.362	40.910	0.5	0.5	24.00
20.10.25	1.921	422.18	422.47	-0.3	46.000	41.445	0.5	0.5	24.00
Итого	46.95	10171.6	10171.3	0.4	---	---	---	---	744.00
Среднее	---	---	---	---	41.83	37.66	0.5	0.5	---

Показания интеграторов

Дата	Q, (Гкал)	M1, (т)	M2, (т)	Время наработки, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д
20.10.25 24:00	6294.4	668346.3	666562.1	83414.1
Итого за период	н/д	н/д	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

ВКТ-7 ТС1 + ГВС, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, 34 микрорайон, 28
Потребитель: АО "Жилуправление"
Прибор ВКТ-7 Заводской номер: 00000001

БД=1, ТВ1, СИ=1, КТЗ=1, ФРТ=0, КСН=0х7ВФ7

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	Qг, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	17.87	18.46	-0.59	0.000	0.000	0.000	0.000	0.000	н/д	0.000	7.00	7.00	0.0000	н/д	0.0	24.0
21.09.25	17.81	18.34	-0.53	0.000	0.000	0.000	0.000	0.000	н/д	0.000	7.00	7.00	0.0000	н/д	0.0	24.0
22.09.25	18.35	18.93	-0.58	0.000	0.000	0.000	0.000	0.000	н/д	0.000	7.00	7.00	0.0000	н/д	0.0	24.0
23.09.25	18.71	19.31	-0.60	0.000	0.000	0.000	0.000	0.000	н/д	0.000	7.00	7.00	0.0000	н/д	0.0	24.0
24.09.25	19.19	19.80	-0.61	0.000	0.000	0.000	0.000	0.000	н/д	0.000	7.00	7.00	0.0000	н/д	0.0	24.0
25.09.25	18.26	18.76	-0.50	0.000	0.000	0.000	0.000	0.000	н/д	0.000	3.51	7.00	0.0000	н/д	0.0	24.0
26.09.25	43.70	38.38	5.32	104.920	103.800	0.000	103.960	103.100	н/д	0.860	1.04	7.00	0.5430	н/д	0.0	24.0
27.09.25	44.12	39.07	5.05	183.320	181.910	0.000	181.610	180.640	н/д	0.970	1.06	7.00	0.8920	н/д	0.0	24.0
28.09.25	43.92	38.83	5.09	181.420	179.640	0.000	179.740	178.430	н/д	1.310	1.06	7.00	0.8910	н/д	0.0	24.0
29.09.25	46.24	39.84	6.40	174.560	172.100	0.000	172.760	170.840	н/д	1.920	1.05	5.76	1.0860	н/д	0.0	24.0
30.09.25	55.58	46.37	9.21	172.280	169.860	0.000	169.800	168.140	н/д	1.660	1.06	1.07	1.5630	н/д	0.0	24.0
01.10.25	49.22	42.78	6.44	191.810	188.600	0.000	189.570	186.910	н/д	2.660	1.06	1.06	1.2180	н/д	0.0	24.0
02.10.25	46.60	41.18	5.42	205.120	201.360	0.000	202.980	199.680	н/д	3.300	1.06	1.06	1.0990	н/д	0.0	24.0
03.10.25	48.02	42.36	5.66	207.880	204.200	0.000	205.610	202.430	н/д	3.180	1.06	1.07	1.1610	н/д	0.0	24.0
04.10.25	50.01	43.98	6.03	211.740	207.970	0.000	209.180	206.050	н/д	3.130	1.06	1.07	1.2610	н/д	0.0	24.0
05.10.25	50.66	44.59	6.07	213.750	209.680	0.000	211.130	207.710	н/д	3.420	1.06	1.07	1.2790	н/д	0.0	24.0
06.10.25	47.01	41.77	5.24	199.030	194.530	0.000	196.940	192.860	н/д	4.080	1.06	1.07	1.0320	н/д	0.0	24.0
07.10.25	42.80	38.25	4.55	188.240	183.500	0.000	186.560	182.250	н/д	4.310	1.06	1.07	0.8460	н/д	0.0	24.0
08.10.25	43.08	38.56	4.52	187.860	182.980	0.000	186.180	181.660	н/д	4.520	1.06	1.07	0.8380	н/д	0.0	24.0
09.10.25	42.67	38.24	4.43	187.590	182.390	0.000	185.910	181.160	н/д	4.750	1.06	1.07	0.8270	н/д	0.0	24.0
10.10.25	42.80	38.38	4.42	187.740	182.190	0.000	186.060	180.930	н/д	5.130	1.06	1.07	0.8210	н/д	0.0	24.0
11.10.25	42.79	38.28	4.51	187.920	182.150	0.000	186.240	180.950	н/д	5.290	1.06	1.07	0.8380	н/д	0.0	24.0
12.10.25	42.36	37.86	4.50	187.670	181.630	0.000	186.040	180.390	н/д	5.650	1.06	1.07	0.8350	н/д	0.0	24.0
13.10.25	42.03	37.53	4.50	187.220	180.990	0.000	185.600	179.790	н/д	5.810	1.06	1.07	0.8330	н/д	0.0	24.0
14.10.25	44.11	39.21	4.90	193.580	187.070	0.000	191.740	185.680	н/д	6.060	1.06	1.07	0.9380	н/д	0.0	24.0
15.10.25	46.90	41.51	5.39	200.580	193.680	0.000	198.500	192.090	н/д	6.410	1.06	1.07	1.0670	н/д	0.0	24.0
16.10.25	46.08	40.74	5.34	198.700	191.560	0.000	196.690	190.050	н/д	6.640	1.06	1.07	1.0490	н/д	0.0	24.0
17.10.25	46.32	40.92	5.40	199.230	191.860	0.000	197.150	190.300	н/д	6.850	1.06	1.07	1.0630	н/д	0.0	24.0
18.10.25	45.50	40.20	5.30	196.380	188.820	0.000	194.460	187.380	н/д	7.080	1.06	1.07	1.0270	н/д	0.0	24.0
19.10.25	44.77	39.67	5.10	194.800	187.020	0.000	192.910	185.580	н/д	7.330	1.06	1.07	0.9820	н/д	0.0	24.0
20.10.25	45.34	40.13	5.21	196.350	188.360	0.000	194.430	186.920	н/д	7.510	1.06	1.07	1.0110	н/д	0.0	24.0
Итого	---	---	---	4739.6	4617.8	0.00	4691.75	4581.92	---	109.829	---	---	25.0000	---	0.0	744.0
Среднее	40.41	36.20	4.21	---	---	---	---	---	---	---	2.10	2.94	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	Mг, (т)	Qo, (Гкал)	Qг, (Гкал)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	0	0	0	0	0	0	0	0	0	0	0
20.10.25 24:00	48384.659	65600.379	0.000	47757.730	65131.400	н/д	-17373.669	341.9350	н/д	1920.0	11534.0
Итого за период	48384.659	65600.379	0.000	47757.730	65131.400	н/д	---	341.9350	н/д	1920.0	11534.0

Представитель абонента _____/_____ Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 34 микрорайон, 28
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00175254

БД=1, ТВ1, СИ=1, КТЗ=1, ФРТ=0, КСН=0x7BF7

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	17.87	18.46	-0.59	0.000	0.000	0.000	0.000	0.000	7.00	7.00	0.0000	0.0	24.0
21.09.25	17.81	18.34	-0.53	0.000	0.000	0.000	0.000	0.000	7.00	7.00	0.0000	0.0	24.0
22.09.25	18.35	18.93	-0.58	0.000	0.000	0.000	0.000	0.000	7.00	7.00	0.0000	0.0	24.0
23.09.25	18.71	19.31	-0.60	0.000	0.000	0.000	0.000	0.000	7.00	7.00	0.0000	0.0	24.0
24.09.25	19.19	19.80	-0.61	0.000	0.000	0.000	0.000	0.000	7.00	7.00	0.0000	0.0	24.0
25.09.25	18.26	18.76	-0.50	0.000	0.000	0.000	0.000	0.000	3.51	7.00	0.0000	0.0	24.0
26.09.25	43.70	38.38	5.32	104.920	103.800	103.960	103.100	0.860	1.04	7.00	0.5430	0.0	24.0
27.09.25	44.12	39.07	5.05	183.320	181.910	181.610	180.640	0.970	1.06	7.00	0.8920	0.0	24.0
28.09.25	43.92	38.83	5.09	181.420	179.640	179.740	178.430	1.310	1.06	7.00	0.8910	0.0	24.0
29.09.25	46.24	39.84	6.40	174.560	172.100	172.760	170.840	1.920	1.05	5.76	1.0860	0.0	24.0
30.09.25	55.58	46.37	9.21	172.280	169.860	169.800	168.140	1.660	1.06	1.07	1.5630	0.0	24.0
01.10.25	49.22	42.78	6.44	191.810	188.600	189.570	186.910	2.660	1.06	1.06	1.2180	0.0	24.0
02.10.25	46.60	41.18	5.42	205.120	201.360	202.980	199.680	3.300	1.06	1.06	1.0990	0.0	24.0
03.10.25	48.02	42.36	5.66	207.880	204.200	205.610	202.430	3.180	1.06	1.07	1.1610	0.0	24.0
04.10.25	50.01	43.98	6.03	211.740	207.970	209.180	206.050	3.130	1.06	1.07	1.2610	0.0	24.0
05.10.25	50.66	44.59	6.07	213.750	209.680	211.130	207.710	3.420	1.06	1.07	1.2790	0.0	24.0
06.10.25	47.01	41.77	5.24	199.030	194.530	196.940	192.860	4.080	1.06	1.07	1.0320	0.0	24.0
07.10.25	42.80	38.25	4.55	188.240	183.500	186.560	182.250	4.310	1.06	1.07	0.8460	0.0	24.0
08.10.25	43.08	38.56	4.52	187.860	182.980	186.180	181.660	4.520	1.06	1.07	0.8380	0.0	24.0
09.10.25	42.67	38.24	4.43	187.590	182.390	185.910	181.160	4.750	1.06	1.07	0.8270	0.0	24.0
10.10.25	42.80	38.38	4.42	187.740	182.190	186.060	180.930	5.130	1.06	1.07	0.8210	0.0	24.0
11.10.25	42.79	38.28	4.51	187.920	182.150	186.240	180.950	5.290	1.06	1.07	0.8380	0.0	24.0
12.10.25	42.36	37.86	4.50	187.670	181.630	186.040	180.390	5.650	1.06	1.07	0.8350	0.0	24.0
13.10.25	42.03	37.53	4.50	187.220	180.990	185.600	179.790	5.810	1.06	1.07	0.8330	0.0	24.0
14.10.25	44.11	39.21	4.90	193.580	187.070	191.740	185.680	6.060	1.06	1.07	0.9380	0.0	24.0
15.10.25	46.90	41.51	5.39	200.580	193.680	198.500	192.090	6.410	1.06	1.07	1.0670	0.0	24.0
16.10.25	46.08	40.74	5.34	198.700	191.560	196.690	190.050	6.640	1.06	1.07	1.0490	0.0	24.0
17.10.25	46.32	40.92	5.40	199.230	191.860	197.150	190.300	6.850	1.06	1.07	1.0630	0.0	24.0
18.10.25	45.50	40.20	5.30	196.380	188.820	194.460	187.380	7.080	1.06	1.07	1.0270	0.0	24.0
19.10.25	44.77	39.67	5.10	194.800	187.020	192.910	185.580	7.330	1.06	1.07	0.9820	0.0	24.0
20.10.25	45.34	40.13	5.21	196.350	188.360	194.430	186.920	7.510	1.06	1.07	1.0110	0.0	24.0
Итого	---	---	---	4739.6	4617.8	4691.75	4581.92	109.830	---	---	25.0000	0.0	744.0
Среднее	40.41	36.20	4.21	---	---	---	---	---	2.10	2.94	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	0	0	0	0	0	0	0	0
20.10.25 24:00	48384.659	65600.379	47757.730	65131.400	341.9350	-17373.670	1920.0	11534.0
Итого за период	48384.659	65600.379	47757.730	65131.400	341.9350	---	1920.0	11534.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 34 микрорайон, 3
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ632

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	0.00	23.98	0.00	23.33	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	23.97	0.00	23.32	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	23.92	0.00	23.29	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	24.13	0.00	23.46	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	24.13	0.00	23.52	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	24.15	0.00	23.57	0.00	0.00	24.00	0.00	0.00
27.09.25	0.72	36.20	184.39	33.50	187.41	15.15	24.00	0.00	0.00
28.09.25	1.16	44.18	277.71	40.01	284.11	24.00	24.00	0.00	0.00
29.09.25	1.20	43.99	274.76	39.63	281.29	24.00	24.00	0.00	0.00
30.09.25	1.49	46.29	262.96	40.51	268.30	24.00	24.00	0.00	0.00
01.10.25	2.20	55.72	254.46	47.06	258.98	24.00	24.00	0.00	0.00
02.10.25	1.81	49.69	280.71	43.15	285.67	24.00	24.00	0.00	0.00
03.10.25	1.64	46.64	296.15	41.08	301.56	24.00	24.00	0.00	0.00
04.10.25	1.75	48.00	298.25	42.13	303.07	24.00	24.00	0.00	0.00
05.10.25	1.91	50.08	298.90	43.69	304.60	24.00	24.00	0.00	0.00
06.10.25	1.91	50.61	301.45	44.26	306.24	24.00	24.00	0.00	0.00
07.10.25	1.55	46.81	283.43	41.37	286.59	24.00	24.00	0.00	0.00
08.10.25	1.28	42.68	270.73	37.95	271.73	24.00	24.00	0.00	0.00
09.10.25	1.28	42.98	269.52	38.24	270.68	24.00	24.00	0.00	0.00
10.10.25	1.26	42.57	269.37	37.89	270.51	24.00	24.00	0.00	0.00
11.10.25	1.25	42.69	269.32	38.03	270.74	24.00	24.00	0.00	0.00
12.10.25	1.27	42.67	268.85	37.95	270.63	24.00	24.00	0.00	0.00
13.10.25	1.28	42.29	269.13	37.51	270.23	24.00	24.00	0.00	0.00
14.10.25	1.26	41.93	268.72	37.21	269.58	24.00	24.00	0.00	0.00
15.10.25	1.44	43.92	276.12	38.72	277.76	24.00	24.00	0.00	0.00
16.10.25	1.62	46.78	283.71	41.06	287.17	24.00	24.00	0.00	0.00
17.10.25	1.59	45.98	281.71	40.33	284.67	24.00	24.00	0.00	0.00
18.10.25	1.61	46.32	282.64	40.62	285.48	24.00	24.00	0.00	0.00
19.10.25	1.56	45.43	279.45	39.84	281.87	24.00	24.00	0.00	0.00
20.10.25	1.49	44.68	277.82	39.31	279.73	24.00	24.00	0.00	0.00
Итого	35.53	---	6580.26	---	6658.60	567.15	720.00	0.00	0.00
Среднее	---	41.114	---	36.718	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	2712.68	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 34 микрорайон, 4
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BA857

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	0.00	26.25	0.00	24.63	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	26.27	0.00	24.67	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	26.29	0.00	24.72	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	27.41	0.00	25.12	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	27.94	0.00	25.42	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	27.45	0.00	25.05	0.00	0.00	24.00	0.00	0.00
27.09.25	0.77	37.46	170.59	33.90	168.50	14.68	24.00	0.00	0.00
28.09.25	1.27	44.99	267.70	40.23	266.82	24.00	24.00	0.00	0.00
29.09.25	1.37	44.79	272.18	39.73	271.62	24.00	24.00	0.00	0.00
30.09.25	1.60	47.26	251.18	40.75	251.94	24.00	24.00	0.00	0.00
01.10.25	2.32	56.74	238.83	46.99	241.00	24.00	24.00	0.00	0.00
02.10.25	1.87	50.50	263.34	43.28	264.82	24.00	24.00	0.00	0.00
03.10.25	1.70	47.48	277.17	41.32	278.46	24.00	24.00	0.00	0.00
04.10.25	1.84	48.89	281.31	42.34	283.51	24.00	24.00	0.00	0.00
05.10.25	2.01	50.99	284.63	43.92	286.86	24.00	24.00	0.00	0.00
06.10.25	2.02	51.52	286.57	44.46	288.93	24.00	24.00	0.00	0.00
07.10.25	1.60	47.57	266.98	41.61	269.26	24.00	24.00	0.00	0.00
08.10.25	1.30	43.47	252.86	38.33	253.70	24.00	24.00	0.00	0.00
09.10.25	1.30	43.75	251.70	38.59	253.05	24.00	24.00	0.00	0.00
10.10.25	1.28	43.34	251.31	38.24	252.63	24.00	24.00	0.00	0.00
11.10.25	1.28	43.47	251.83	38.39	253.32	24.00	24.00	0.00	0.00
12.10.25	1.29	43.46	251.55	38.32	252.78	24.00	24.00	0.00	0.00
13.10.25	1.30	43.04	252.16	37.86	252.73	24.00	24.00	0.00	0.00
14.10.25	1.29	42.69	251.42	37.57	251.94	24.00	24.00	0.00	0.00
15.10.25	1.47	44.78	259.29	39.11	260.03	24.00	24.00	0.00	0.00
16.10.25	1.67	47.61	267.82	41.37	269.86	24.00	24.00	0.00	0.00
17.10.25	1.64	46.82	265.48	40.65	266.43	24.00	24.00	0.00	0.00
18.10.25	1.67	47.15	266.37	40.88	267.17	24.00	24.00	0.00	0.00
19.10.25	1.61	46.26	263.33	40.13	263.65	24.00	24.00	0.00	0.00
20.10.25	1.54	45.49	261.39	39.60	261.51	24.00	24.00	0.00	0.00
Итого	37.01	---	6206.99	---	6230.52	566.68	720.00	0.00	0.00
Среднее	---	42.371	---	37.239	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	4106.50	1.15
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, 34 микрорайон, 4а
Потребитель: АО "Жилуправление"
Прибор: ТЭМ-106 Заводской номер: 3060278
Формула: $Q = M1(h1 - h2)$
Тип системы: Подача + расходомер

Система: 1
ТВ1

	ДУ, мм	Gmin, м3/ч	Gmax, м3/ч	Kv, л/имп	Fmax, КГц
1	50	0	66	0	---
2	50	0	67.10000000 000001	0	---

Дата	Q, (Гкал)	M1, (т)	M2, (т)	dM, (т)	T1, (°C)	T2, (°C)	P1, (МПа)	P2, (МПа)	Время наработки, (ч)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-
28.09.25	-	-	-	-	-	-	-	-	-
29.09.25	-	-	-	-	-	-	-	-	-
30.09.25	н/д	н/д	н/д	н/д	23.095	22.072	0.2	0.1	н/д
01.10.25	0.571	113.41	110.88	2.5	46.508	41.473	0.6	0.4	24.00
02.10.25	1.034	206.23	205.15	1.1	47.305	42.293	0.6	0.6	24.00
03.10.25	1.095	209.25	208.38	0.9	48.709	43.478	0.7	0.6	24.00
04.10.25	1.173	210.49	209.63	0.9	50.810	45.239	0.7	0.6	24.00
05.10.25	1.168	211.79	211.02	0.8	51.348	45.832	0.7	0.6	24.00
06.10.25	0.939	197.73	197.02	0.7	47.673	42.923	0.6	0.6	24.00
07.10.25	0.760	187.21	186.62	0.6	43.294	39.232	0.6	0.6	24.00
08.10.25	0.757	186.61	186.11	0.5	43.597	39.537	0.6	0.6	24.00
09.10.25	0.741	186.44	186.02	0.4	43.176	39.200	0.6	0.6	24.00
10.10.25	0.736	186.57	186.19	0.4	43.308	39.362	0.6	0.6	24.00
11.10.25	0.738	186.45	186.12	0.3	43.294	39.332	0.6	0.6	24.00
12.10.25	0.731	186.12	185.82	0.3	42.889	38.963	0.6	0.6	24.00
13.10.25	0.719	185.56	185.28	0.3	42.529	38.655	0.6	0.6	24.00
14.10.25	0.828	191.54	191.27	0.3	44.618	40.298	0.6	0.6	24.00
15.10.25	0.951	198.26	197.99	0.3	47.494	42.696	0.7	0.6	24.00
16.10.25	0.932	196.43	196.17	0.3	46.652	41.909	0.7	0.6	24.00
17.10.25	0.953	197.01	196.76	0.3	46.986	42.149	0.7	0.6	24.00
18.10.25	0.915	194.36	194.11	0.3	46.083	41.377	0.6	0.6	24.00
19.10.25	0.870	193.05	192.79	0.3	45.327	40.821	0.6	0.6	24.00
20.10.25	0.907	194.66	194.40	0.3	45.947	41.289	0.6	0.6	24.00
Итого	17.52	3819.2	3807.7	11.8	---	---	---	---	480.00
Среднее	---	---	---	---	44.79	40.39	0.6	0.6	---

Показания интеграторов

Дата	Q, (Гкал)	M1, (т)	M2, (т)	Время наработки, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д
20.10.25 24:00	5277.3	595850.5	592924.1	98182.7
Итого за период	н/д	н/д	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 34 микрорайон, 6
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ146

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	0.00	23.11	0.00	23.86	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	23.28	0.00	24.00	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	23.05	0.00	23.78	0.00	0.00	24.00	0.00	0.00
27.09.25	0.81	33.17	146.56	30.93	146.30	11.52	24.00	0.00	0.00
28.09.25	1.78	44.94	291.36	38.83	298.93	24.00	24.00	0.00	0.00
29.09.25	1.91	44.73	286.34	38.05	293.49	24.00	24.00	0.00	0.00
30.09.25	2.13	46.65	261.82	38.32	268.12	24.00	24.00	0.00	0.00
01.10.25	3.06	56.62	241.47	43.93	247.60	24.00	24.00	0.00	0.00
02.10.25	2.45	50.82	252.36	41.01	257.08	24.00	24.00	0.00	0.00
03.10.25	2.25	47.37	257.69	38.62	262.73	24.00	24.00	0.00	0.00
04.10.25	2.45	48.70	278.69	39.90	284.39	24.00	24.00	0.00	0.00
05.10.25	2.73	50.88	307.04	41.96	313.64	24.00	24.00	0.00	0.00
06.10.25	2.75	51.43	308.84	42.50	315.61	24.00	24.00	0.00	0.00
07.10.25	2.24	47.89	287.27	40.17	293.17	24.00	24.00	0.00	0.00
08.10.25	1.77	43.35	267.89	36.72	273.77	24.00	24.00	0.00	0.00
09.10.25	1.81	43.73	269.31	37.00	270.30	24.00	24.00	0.00	0.00
10.10.25	1.79	43.29	270.08	36.67	269.26	24.00	24.00	0.00	0.00
11.10.25	1.76	43.39	267.25	36.78	272.91	24.00	24.00	0.00	0.00
12.10.25	1.77	43.37	267.09	36.72	272.70	24.00	24.00	0.00	0.00
13.10.25	1.76	43.05	266.69	36.42	272.40	24.00	24.00	0.00	0.00
14.10.25	1.75	42.64	265.74	36.06	271.60	24.00	24.00	0.00	0.00
15.10.25	1.98	44.46	274.71	37.26	280.18	24.00	24.00	0.00	0.00
16.10.25	2.29	47.61	286.89	39.62	292.83	24.00	24.00	0.00	0.00
17.10.25	2.25	46.72	283.30	38.78	289.00	24.00	24.00	0.00	0.00
18.10.25	2.29	47.11	284.59	39.05	290.32	24.00	24.00	0.00	0.00
19.10.25	2.21	46.17	281.19	38.28	286.93	24.00	24.00	0.00	0.00
20.10.25	2.11	45.46	277.91	37.85	283.58	24.00	24.00	0.00	0.00
Итого	50.10	---	6482.08	---	6606.84	563.52	648.00	0.00	0.00
Среднее	---	43.444	---	36.780	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	8705.27	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 34 микрорайон, 7
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00169014

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0хD178

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Мг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	20.85	20.68	0.17	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
20.09.25	20.78	20.70	0.08	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
21.09.25	20.80	20.71	0.09	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
22.09.25	20.84	20.74	0.10	0.320	0.320	0.320	0.320	0.000	3.92	6.00	0.0000	0.0	24.0
23.09.25	21.46	21.35	0.11	0.000	0.000	0.000	0.000	0.000	2.55	6.00	0.0000	0.0	24.0
24.09.25	21.69	21.58	0.11	0.000	0.000	0.000	0.000	0.000	2.55	6.00	0.0000	0.0	24.0
25.09.25	21.30	21.19	0.11	0.000	0.000	0.000	0.000	0.000	2.54	6.00	0.0000	0.0	24.0
26.09.25	44.89	38.13	6.76	38.990	37.810	38.610	37.540	1.070	3.82	6.00	0.2620	0.0	24.0
27.09.25	44.66	39.27	5.39	88.140	85.740	87.320	85.120	2.200	5.99	6.00	0.4720	0.0	24.0
28.09.25	44.45	38.83	5.62	82.460	80.320	81.740	79.840	1.900	6.04	6.00	0.4600	0.0	24.0
29.09.25	46.30	38.91	7.39	72.900	70.960	72.170	70.500	1.670	6.01	6.00	0.5330	0.0	24.0
30.09.25	56.08	44.23	11.85	64.710	62.850	63.750	62.370	1.380	6.47	6.00	0.7580	0.0	24.0
01.10.25	50.18	41.06	9.12	64.600	62.950	63.840	62.440	1.400	6.54	6.00	0.5820	0.0	24.0
02.10.25	47.02	38.45	8.57	59.880	58.330	59.190	57.850	1.340	6.61	6.00	0.5070	0.0	24.0
03.10.25	48.62	41.86	6.76	86.630	85.300	85.600	84.530	1.070	6.70	6.00	0.5790	0.0	24.0
04.10.25	50.24	44.62	5.62	119.800	118.580	118.360	117.430	0.930	6.76	6.00	0.6660	0.0	24.0
05.10.25	50.78	45.22	5.56	120.910	119.700	119.470	118.500	0.970	6.81	6.00	0.6640	0.0	24.0
06.10.25	47.46	42.53	4.93	110.180	108.990	109.040	108.070	0.970	6.67	6.00	0.5370	0.0	24.0
07.10.25	42.87	38.59	4.28	101.700	100.580	100.750	99.860	0.890	6.57	6.00	0.4320	0.0	24.0
08.10.25	43.21	38.89	4.32	101.060	99.950	100.110	99.230	0.880	6.54	6.00	0.4310	0.0	24.0
09.10.25	42.79	38.55	4.24	100.830	99.740	99.910	99.020	0.890	6.53	6.00	0.4230	0.0	24.0
10.10.25	42.90	38.63	4.27	100.890	99.780	99.940	99.060	0.880	6.46	6.00	0.4250	0.0	24.0
11.10.25	42.88	38.58	4.30	100.800	99.720	99.840	99.000	0.840	6.53	6.00	0.4270	0.0	24.0
12.10.25	42.52	38.25	4.27	100.590	99.520	99.760	98.800	0.960	6.52	6.00	0.4260	0.0	24.0
13.10.25	42.14	37.90	4.24	100.490	99.460	99.680	98.740	0.940	6.51	6.00	0.4230	0.0	24.0
14.10.25	44.00	39.36	4.64	104.920	103.890	103.940	103.140	0.800	6.57	6.00	0.4820	0.0	24.0
15.10.25	47.02	41.94	5.08	110.180	109.150	109.080	108.300	0.780	6.68	6.00	0.5550	0.0	24.0
16.10.25	46.14	41.10	5.04	108.390	107.370	107.330	106.530	0.800	6.83	6.00	0.5420	0.0	24.0
17.10.25	46.47	41.33	5.14	108.710	107.690	107.580	106.790	0.790	6.82	6.00	0.5540	0.0	24.0
18.10.25	45.59	40.54	5.05	107.560	106.550	106.560	105.770	0.790	6.57	6.00	0.5360	0.0	24.0
19.10.25	44.87	39.99	4.88	105.910	104.930	104.950	104.210	0.740	6.56	6.00	0.5140	0.0	24.0
20.10.25	45.46	40.46	5.00	107.030	106.040	106.070	105.300	0.770	6.60	6.00	0.5300	0.0	24.0
Итого	---	---	---	2368.5	2336.2	2344.91	2318.26	26.650	---	---	12.7200	0.0	768.0
Среднее	40.53	36.06	4.47	---	---	---	---	---	5.96	6.00	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Мг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	20566.400	20372.840	20292.720	20182.130	172.7100	110.590	2221.0	8009.0
20.10.25 24:00	22934.980	22709.060	22637.630	22500.389	185.4300	137.240	2221.0	8777.0
Итого за период	2368.579	2336.220	2344.910	2318.258	12.7200	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 34 микрорайон, 7
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ377

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-
26.09.25	0.00	39.83	0.00	23.68	0.00	0.00	24.00	0.00	0.00
27.09.25	0.19	41.26	25.27	28.43	25.13	9.71	24.00	0.00	0.00
28.09.25	0.46	44.27	71.32	37.78	71.98	24.00	24.00	0.00	0.00
29.09.25	0.47	44.06	70.53	37.41	70.88	24.00	24.00	0.00	0.00
30.09.25	0.57	46.43	65.32	37.56	65.34	24.00	24.00	0.00	0.00
01.10.25	0.81	55.68	62.36	42.73	62.29	24.00	24.00	0.00	0.00
02.10.25	0.64	49.59	63.29	39.35	62.89	24.00	24.00	0.00	0.00
03.10.25	0.61	46.69	61.39	36.69	59.23	24.00	24.00	0.00	0.00
04.10.25	0.71	48.01	72.77	38.04	72.57	24.00	24.00	0.00	0.00
05.10.25	0.83	50.00	89.63	40.77	89.58	24.00	24.00	0.00	0.00
06.10.25	0.84	50.54	90.46	41.27	90.40	24.00	24.00	0.00	0.00
07.10.25	0.66	46.70	83.23	38.80	83.06	24.00	24.00	0.00	0.00
08.10.25	0.54	42.67	78.13	35.77	77.95	24.00	24.00	0.00	0.00
09.10.25	0.54	42.96	77.78	36.03	77.59	24.00	24.00	0.00	0.00
10.10.25	0.53	42.55	77.65	35.71	77.49	24.00	24.00	0.00	0.00
11.10.25	0.53	42.68	77.46	35.86	77.23	24.00	24.00	0.00	0.00
12.10.25	0.53	42.67	76.82	35.81	76.54	24.00	24.00	0.00	0.00
13.10.25	0.53	42.27	76.65	35.34	76.43	24.00	24.00	0.00	0.00
14.10.25	0.52	41.92	76.42	35.04	76.27	24.00	24.00	0.00	0.00
15.10.25	0.60	43.91	79.41	36.35	79.25	24.00	24.00	0.00	0.00
16.10.25	0.68	46.71	82.35	38.42	82.18	24.00	24.00	0.00	0.00
17.10.25	0.67	45.94	81.85	37.74	81.80	24.00	24.00	0.00	0.00
18.10.25	0.68	46.25	82.35	37.94	82.34	24.00	24.00	0.00	0.00
19.10.25	0.66	45.39	80.81	37.25	80.80	24.00	24.00	0.00	0.00
20.10.25	0.62	44.64	79.70	36.84	79.69	24.00	24.00	0.00	0.00
Итого	14.42	---	1782.95	---	1778.91	561.71	600.00	0.00	0.00
Среднее	---	45.345	---	36.664	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	2188.41	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

ИМ2300, Суточный с 19.09.25 по 20.10.25

Объект: г. Октябрьский, 34 микрорайон, 7
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ400

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-
27.09.25	0.09	30.54	20.04	28.63	20.45	9.80	24.00	0.00	0.00
28.09.25	0.22	44.17	50.68	39.74	51.28	24.00	24.00	0.00	0.00
29.09.25	0.25	43.97	49.91	39.02	50.56	24.00	24.00	0.00	0.00
30.09.25	0.32	46.41	45.50	39.16	46.40	24.00	24.00	0.00	0.00
01.10.25	0.47	55.51	41.33	44.24	42.62	24.00	24.00	0.00	0.00
02.10.25	0.36	49.40	41.48	40.71	42.69	24.00	24.00	0.00	0.00
03.10.25	0.33	46.57	39.29	38.16	40.36	23.97	24.00	0.00	0.00
04.10.25	0.45	47.79	62.07	40.06	63.25	24.00	24.00	0.00	0.00
05.10.25	0.57	49.70	88.12	43.18	89.57	24.00	24.00	0.00	0.00
06.10.25	0.57	50.23	88.76	43.74	90.35	24.00	24.00	0.00	0.00
07.10.25	0.45	46.44	80.73	40.85	81.96	24.00	24.00	0.00	0.00
08.10.25	0.37	42.44	75.19	37.55	76.07	24.00	24.00	0.00	0.00
09.10.25	0.37	42.73	74.85	37.82	75.72	24.00	24.00	0.00	0.00
10.10.25	0.36	42.32	74.81	37.51	75.65	24.00	24.00	0.00	0.00
11.10.25	0.36	42.45	74.83	37.66	75.61	24.00	24.00	0.00	0.00
12.10.25	0.36	42.43	74.75	37.64	75.47	24.00	24.00	0.00	0.00
13.10.25	0.36	42.04	74.54	37.24	75.24	24.00	24.00	0.00	0.00
14.10.25	0.35	41.69	74.20	36.98	74.90	24.00	24.00	0.00	0.00
15.10.25	0.40	43.60	77.49	38.47	78.22	24.00	24.00	0.00	0.00
16.10.25	0.46	46.41	80.87	40.73	81.89	24.00	24.00	0.00	0.00
17.10.25	0.45	45.65	79.93	39.98	80.91	24.00	24.00	0.00	0.00
18.10.25	0.46	45.94	80.13	40.15	81.12	24.00	24.00	0.00	0.00
19.10.25	0.45	45.11	79.07	39.44	79.95	24.00	24.00	0.00	0.00
20.10.25	0.43	44.37	77.91	38.91	78.66	24.00	24.00	0.00	0.00
Итого	9.26	---	1606.48	---	1628.90	561.77	576.00	0.00	0.00
Среднее	---	44.913	---	39.065	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	1280.80	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 34 микрорайон, 8а
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ390

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	16.39	0.00	15.32	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	16.69	0.00	15.57	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	16.72	0.00	15.78	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	17.16	0.00	16.22	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	18.11	0.00	17.64	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	18.35	0.00	17.83	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	19.33	0.00	19.01	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	17.54	0.00	16.32	0.00	0.00	24.00	0.00	0.00
27.09.25	0.20	26.37	23.34	21.58	21.08	7.40	24.00	0.00	0.00
28.09.25	0.44	43.55	67.54	37.03	68.73	24.00	24.00	0.00	0.00
29.09.25	0.45	43.28	64.71	36.30	65.49	24.00	24.00	0.00	0.00
30.09.25	0.68	44.51	73.60	35.37	74.12	24.00	24.00	0.00	0.00
01.10.25	1.08	54.80	75.73	40.47	76.93	24.00	24.00	0.00	0.00
02.10.25	0.84	49.76	75.34	38.49	76.32	24.00	24.00	0.00	0.00
03.10.25	0.75	45.93	77.18	36.14	78.03	24.00	24.00	0.00	0.00
04.10.25	0.83	47.20	83.90	37.34	84.21	24.00	24.00	0.00	0.00
05.10.25	0.98	49.49	95.29	39.15	96.06	24.00	24.00	0.00	0.00
06.10.25	0.99	50.05	95.92	39.68	96.64	24.00	24.00	0.00	0.00
07.10.25	0.82	47.05	89.54	37.92	90.25	24.00	24.00	0.00	0.00
08.10.25	0.63	42.16	82.60	34.54	83.20	24.00	24.00	0.00	0.00
09.10.25	0.64	42.60	82.42	34.84	83.03	24.00	24.00	0.00	0.00
10.10.25	0.62	42.16	82.27	34.57	82.87	24.00	24.00	0.00	0.00
11.10.25	0.62	42.23	82.35	34.71	82.92	24.00	24.00	0.00	0.00
12.10.25	0.62	42.21	82.26	34.64	82.87	24.00	24.00	0.00	0.00
13.10.25	0.63	41.98	82.24	34.28	82.77	24.00	24.00	0.00	0.00
14.10.25	0.62	41.50	81.88	33.92	82.38	24.00	24.00	0.00	0.00
15.10.25	0.69	42.95	84.21	34.79	84.77	24.00	24.00	0.00	0.00
16.10.25	0.82	46.41	88.77	37.22	89.31	24.00	24.00	0.00	0.00
17.10.25	0.79	45.44	87.33	36.42	87.80	24.00	24.00	0.00	0.00
18.10.25	0.81	45.87	87.91	36.68	88.35	24.00	24.00	0.00	0.00
19.10.25	0.78	44.88	86.68	35.92	87.12	24.00	24.00	0.00	0.00
20.10.25	0.74	44.29	85.71	35.58	86.17	24.00	24.00	0.00	0.00
Итого	17.07	---	1918.72	---	1931.42	559.40	768.00	0.00	0.00
Среднее	---	37.718	---	30.977	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	2762.48	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 34 микрорайон, 8а
 Потребитель: АО "Жилуправление"
 Прибор: ТЭМ-106 Заводской номер: 3060236
 Формула: $Q = M1(h1 - h2)$
 Тип системы: Подача + расходомер

Система: 1

ТВ1

	ДУ, мм	Gmin, м3/ч	Gmax, м3/ч	Kv, л/имп	Fmax, КГц
1	80	8	160	10	---
2	80	8.65	173	10	---

Дата	Q, (Гкал)	M1, (т)	M2, (т)	dM, (т)	T1, (°C)	T2, (°C)	P1, (МПа)	P2, (МПа)	Время наработки, (ч)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-
25.09.25	0.133	0.00	0.30	-0.3	24.282	25.004	0.5	0.5	24.00
26.09.25	0.582	59.54	57.14	2.4	44.729	36.228	0.5	0.5	24.00
27.09.25	1.540	188.84	193.79	-4.9	44.769	36.606	0.5	0.5	24.00
28.09.25	1.599	188.54	193.75	-5.2	44.580	36.092	0.5	0.5	24.00
29.09.25	1.777	169.10	173.99	-4.9	46.509	35.990	0.5	0.5	24.00
30.09.25	2.568	159.67	164.23	-4.6	56.351	40.261	0.5	0.5	24.00
01.10.25	1.987	153.14	156.28	-3.1	50.741	37.753	0.5	0.5	24.00
02.10.25	1.702	140.37	139.94	0.4	47.214	35.079	0.5	0.5	24.00
03.10.25	1.958	170.95	163.29	7.7	48.808	37.341	0.5	0.5	24.00
04.10.25	2.295	206.40	196.46	9.9	50.734	39.607	0.5	0.5	24.00
05.10.25	2.316	208.29	198.11	10.2	51.276	40.149	0.5	0.5	24.00
06.10.25	1.882	190.99	179.92	11.1	47.890	38.026	0.5	0.5	24.00
07.10.25	1.470	173.39	167.28	6.1	43.241	34.750	0.5	0.5	24.00
08.10.25	1.466	171.24	169.25	2.0	43.585	35.013	0.5	0.5	24.00
09.10.25	1.441	171.00	169.04	2.0	43.155	34.719	0.5	0.5	24.00
10.10.25	1.444	171.18	169.28	1.9	43.268	34.824	0.5	0.5	24.00
11.10.25	1.452	170.91	169.01	1.9	43.249	34.744	0.5	0.5	24.00
12.10.25	1.465	170.20	168.29	1.9	42.888	34.271	0.5	0.5	24.00
13.10.25	1.458	169.14	167.22	1.9	42.497	33.866	0.5	0.5	24.00
14.10.25	1.672	177.66	175.92	1.7	44.469	35.044	0.5	0.5	24.00
15.10.25	1.944	187.90	186.31	1.6	47.486	37.129	0.5	0.5	24.00
16.10.25	1.883	184.69	182.97	1.7	46.585	36.379	0.5	0.5	24.00
17.10.25	1.930	185.63	183.91	1.7	46.943	36.535	0.5	0.5	24.00
18.10.25	1.866	183.96	182.32	1.6	46.021	35.868	0.5	0.5	24.00
19.10.25	1.770	179.92	178.21	1.7	45.289	35.440	0.5	0.5	24.00
20.10.25	1.830	182.14	180.47	1.7	45.885	35.825	0.5	0.5	24.00
Итого	43.43	4314.8	4266.7	48.1	---	---	---	---	624.00
Среднее	---	---	---	---	45.48	35.87	0.5	0.5	---

Показания интеграторов

Дата	Q, (Гкал)	M1, (т)	M2, (т)	Время наработки, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д
20.10.25 24:00	10159.3	744212.7	734576.1	77609.4
Итого за период	н/д	н/д	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 34 микрорайон, 9/3
 Потребитель: АО "Жилуправление"
 Прибор: ТЭМ-106 Заводской номер: 3060251
 Формула: $Q = M1(h1 - h2)$
 Тип системы: Подача + расходомер

Система: 1

ТВ1

	ДУ, мм	Gmin, м3/ч	Gmax, м3/ч	Kv, л/имп	Fmax, КГц
1	80	9.6	160	10	---
2	80	10.32	172	10	---

Дата	Q, (Гкал)	M1, (т)	M2, (т)	dM, (т)	T1, (°C)	T2, (°C)	P1, (МПа)	P2, (МПа)	Время наработки, (ч)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	н/д	н/д	н/д	н/д	21.771	22.728	0.1	0.0	н/д
23.09.25	0.000	0.00	0.00	0.0	22.043	22.947	0.1	0.0	24.00
24.09.25	0.000	0.00	0.00	0.0	22.248	23.051	0.1	0.0	24.00
25.09.25	0.269	89.88	88.38	1.5	36.831	34.104	0.2	0.0	24.00
26.09.25	1.154	310.88	311.69	-0.8	40.720	37.098	0.5	0.0	24.00
27.09.25	1.416	166.57	165.02	1.6	44.858	36.448	0.5	0.0	24.00
28.09.25	1.483	161.14	160.44	0.7	44.620	35.507	0.5	0.0	24.00
29.09.25	1.560	146.77	146.08	0.7	45.714	35.176	0.5	0.0	24.00
30.09.25	2.213	135.97	130.83	5.1	56.295	40.118	0.5	0.0	24.00
01.10.25	1.884	133.22	132.33	0.9	51.165	37.123	0.5	0.0	24.00
02.10.25	1.535	115.98	115.21	0.8	47.114	33.978	0.5	0.0	24.00
03.10.25	1.861	170.70	169.63	1.1	48.962	38.162	0.5	0.0	24.00
04.10.25	2.416	262.93	263.65	-0.7	50.856	41.770	0.5	0.0	24.00
05.10.25	2.411	264.12	265.14	-1.0	51.428	42.406	0.5	0.0	24.00
06.10.25	2.009	246.98	247.69	-0.7	48.511	40.479	0.5	0.0	24.00
07.10.25	1.566	228.51	228.85	-0.3	43.327	36.577	0.5	0.0	24.00
08.10.25	1.583	228.09	228.34	-0.2	43.768	36.927	0.5	0.0	24.00
09.10.25	1.549	227.86	228.01	-0.1	43.314	36.616	0.5	0.0	24.00
10.10.25	1.539	227.93	227.99	-0.1	43.381	36.728	0.5	0.0	24.00
11.10.25	1.552	227.71	227.67	0.0	43.365	36.651	0.5	0.0	24.00
12.10.25	1.576	227.58	227.46	0.1	43.138	36.312	0.5	0.0	24.00
13.10.25	1.572	226.85	226.71	0.1	42.672	35.842	0.5	0.0	24.00
14.10.25	1.716	233.30	233.21	0.1	44.278	37.022	0.5	0.0	24.00
15.10.25	2.028	245.43	245.43	0.0	47.734	39.574	0.5	0.0	24.00
16.10.25	1.973	241.54	241.52	0.0	46.715	38.652	0.5	0.0	24.00
17.10.25	2.027	242.98	242.94	0.0	47.154	38.920	0.5	0.0	24.00
18.10.25	1.952	239.82	239.70	0.1	46.167	38.130	0.5	0.0	24.00
19.10.25	1.860	237.27	237.08	0.2	45.548	37.811	0.5	0.0	24.00
20.10.25	1.906	239.12	238.95	0.2	46.023	38.151	0.5	0.0	24.00
Итого	44.61	5479.1	5469.9	9.3	---	---	---	---	672.00
Среднее	---	---	---	---	43.44	36.03	0.4	0.0	---

Показания интеграторов

Дата	Q, (Гкал)	M1, (т)	M2, (т)	Время наработки, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д
20.10.25 24:00	8977.6	783613.9	810688.8	88630.6
Итого за период	н/д	н/д	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, 34 микрорайон, 9
Потребитель: АО "Жилуправление"
Прибор: ТВ7-04.1 Заводской номер: 22179274

БД=1, ТВ1, СИ=6, КТЗ=0, ФРТ=0, КСН=0х3DCE

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	20.55	21.16	н/д	-0.61	4.78	4.78	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	6	18
20.09.25	20.24	21.00	н/д	-0.76	1.52	1.52	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
21.09.25	20.45	21.20	н/д	-0.74	1.52	1.52	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
22.09.25	20.73	21.43	н/д	-0.70	1.52	1.52	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
23.09.25	20.84	21.58	н/д	-0.73	1.52	1.53	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
24.09.25	20.92	21.62	н/д	-0.70	1.54	1.54	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
25.09.25	36.95	33.56	н/д	3.39	2.68	2.53	н/д	75.827	77.370	н/д	76.066	76.304	н/д	-0.238	0.259	н/д	24	0
26.09.25	41.14	36.22	н/д	4.91	4.97	4.68	н/д	175.298	177.822	н/д	175.379	175.379	н/д	0.000	0.862	н/д	24	0
27.09.25	44.86	35.05	н/д	9.81	4.90	4.83	н/д	82.015	83.180	н/д	81.910	82.090	н/д	-0.180	0.803	н/д	23	1
28.09.25	44.62	34.24	н/д	10.38	4.90	4.84	н/д	81.180	82.333	н/д	81.179	81.179	н/д	0.000	0.842	н/д	24	0
29.09.25	46.36	33.61	н/д	12.75	4.85	4.80	н/д	73.760	74.965	н/д	73.816	73.816	н/д	0.000	0.940	н/д	24	0
30.09.25	56.13	36.73	н/д	19.39	5.30	5.26	н/д	67.522	69.220	н/д	67.429	67.921	н/д	-0.492	1.307	н/д	24	0
01.10.25	50.63	34.31	н/д	16.32	5.36	5.33	н/д	62.763	63.998	н/д	62.847	62.847	н/д	0.000	1.024	н/д	24	0
02.10.25	47.14	30.84	н/д	16.30	5.44	5.42	н/д	49.645	50.627	н/д	49.787	49.787	н/д	0.000	0.811	н/д	24	0
03.10.25	49.06	36.22	н/д	12.84	5.52	5.46	н/д	80.757	82.165	н/д	80.777	80.777	н/д	0.000	1.036	н/д	24	0
04.10.25	50.78	40.05	н/д	10.74	5.57	5.46	н/д	121.202	123.315	н/д	121.092	121.092	н/д	0.000	1.299	н/д	24	0
05.10.25	51.46	40.60	н/д	10.85	5.62	5.51	н/д	122.082	124.495	н/д	122.084	122.084	н/д	0.000	1.324	н/д	24	0
06.10.25	48.05	38.59	н/д	9.46	5.49	5.39	н/д	112.245	114.368	н/д	112.328	112.328	н/д	0.000	1.062	н/д	24	0
07.10.25	43.45	35.30	н/д	8.15	5.40	5.31	н/д	104.185	106.018	н/д	104.366	104.366	н/д	0.000	0.849	н/д	24	0
08.10.25	43.78	35.59	н/д	8.20	5.36	5.28	н/д	103.738	105.628	н/д	103.939	103.939	н/д	0.000	0.851	н/д	24	0
09.10.25	43.36	35.33	н/д	8.03	5.36	5.27	н/д	103.647	105.485	н/д	103.838	103.838	н/д	0.000	0.833	н/д	24	0
10.10.25	43.47	35.43	н/д	8.04	5.28	5.20	н/д	103.698	105.588	н/д	103.910	103.910	н/д	0.000	0.835	н/д	24	0
11.10.25	43.45	35.33	н/д	8.13	5.36	5.28	н/д	103.610	105.577	н/д	103.868	103.868	н/д	0.000	0.843	н/д	24	0
12.10.25	43.10	34.88	н/д	8.22	5.35	5.27	н/д	103.403	105.363	н/д	103.669	103.669	н/д	0.000	0.851	н/д	24	0
13.10.25	42.71	34.40	н/д	8.31	5.34	5.26	н/д	103.088	105.035	н/д	103.372	103.372	н/д	0.000	0.858	н/д	24	0
14.10.25	44.67	35.65	н/д	9.02	5.40	5.31	н/д	107.143	109.225	н/д	107.394	107.394	н/д	0.000	0.968	н/д	24	0
15.10.25	47.66	37.77	н/д	9.89	5.50	5.41	н/д	112.135	114.390	н/д	112.314	112.314	н/д	0.000	1.109	н/д	24	0
16.10.25	46.78	36.94	н/д	9.85	5.65	5.56	н/д	110.588	112.815	н/д	110.811	110.811	н/д	0.000	1.090	н/д	24	0
17.10.25	47.14	37.15	н/д	9.99	5.64	5.55	н/д	110.988	113.243	н/д	111.204	111.204	н/д	0.000	1.109	н/д	24	0
18.10.25	46.23	36.47	н/д	9.76	5.39	5.30	н/д	109.577	111.765	н/д	109.813	109.813	н/д	0.000	1.070	н/д	24	0
19.10.25	45.50	36.02	н/д	9.48	5.38	5.29	н/д	108.092	110.240	н/д	108.345	108.345	н/д	0.000	1.026	н/д	24	0
20.10.25	46.09	36.43	н/д	9.66	5.42	5.33	н/д	109.175	111.345	н/д	109.408	109.408	н/д	0.000	1.056	н/д	24	0
Итого	---	---	---	---	---	---	---	2597.363	2645.575	---	2600.945	2601.855	---	-0.910	24.917	---	749	19
Среднее	45.74	36.15	---	9.59	4.65	4.58	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	77138.972	78625.245	0.000	76913.171	76921.101	0.000	-7.930	759.658	0.000	14384	3101
20.10.25 24:00	79736.335	81270.818	0.000	79514.116	79522.956	0.000	-8.840	784.575	0.000	15133	3120
Итого за период	2597.363	2645.573	0.000	2600.945	2601.855	0.000	---	24.917	0.000	749	19

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 34 микрорайон, 9а
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ858

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	0.00	18.31	0.00	18.74	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	18.40	0.00	18.84	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	18.83	0.00	19.27	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	19.12	0.00	19.55	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	19.44	0.00	19.86	0.00	0.00	24.00	0.00	0.00
26.09.25	0.27	24.65	85.91	23.85	85.51	7.62	24.00	0.00	0.00
27.09.25	0.87	41.19	187.72	35.63	188.03	24.00	24.00	0.00	0.00
28.09.25	0.87	43.85	88.63	34.03	89.31	24.00	24.00	0.00	0.00
29.09.25	0.86	43.64	83.08	33.23	83.77	24.00	24.00	0.00	0.00
30.09.25	0.93	45.46	74.53	32.77	74.96	24.00	24.00	0.00	0.00
01.10.25	1.23	54.75	66.51	36.13	67.11	24.00	24.00	0.00	0.00
02.10.25	0.91	49.20	56.97	32.93	57.36	24.00	24.00	0.00	0.00
03.10.25	0.64	45.94	32.68	26.27	31.66	24.00	24.00	0.00	0.00
04.10.25	0.93	47.50	65.25	31.10	65.48	24.00	24.00	0.00	0.00
05.10.25	1.25	49.90	105.65	38.03	106.60	24.00	24.00	0.00	0.00
06.10.25	1.24	50.43	106.02	38.67	106.94	24.00	24.00	0.00	0.00
07.10.25	1.00	46.75	96.24	36.47	97.30	24.00	24.00	0.00	0.00
08.10.25	0.80	42.59	88.65	33.55	89.50	24.00	24.00	0.00	0.00
09.10.25	0.81	42.91	88.97	33.76	89.54	24.00	24.00	0.00	0.00
10.10.25	0.83	42.50	89.78	33.29	90.94	24.00	24.00	0.00	0.00
11.10.25	0.82	42.61	89.87	33.43	91.07	24.00	24.00	0.00	0.00
12.10.25	0.83	42.59	89.76	33.35	91.04	24.00	24.00	0.00	0.00
13.10.25	0.82	42.23	89.60	33.02	90.78	24.00	24.00	0.00	0.00
14.10.25	0.83	41.86	89.47	32.59	90.54	24.00	24.00	0.00	0.00
15.10.25	0.93	43.77	93.68	33.80	94.83	24.00	24.00	0.00	0.00
16.10.25	1.07	46.63	98.38	35.76	99.37	24.00	24.00	0.00	0.00
17.10.25	1.05	45.84	96.96	34.97	97.98	24.00	24.00	0.00	0.00
18.10.25	1.08	46.18	97.13	35.08	98.24	24.00	24.00	0.00	0.00
19.10.25	1.04	45.30	95.83	34.41	96.86	24.00	24.00	0.00	0.00
20.10.25	0.99	44.57	94.25	34.04	95.39	24.00	24.00	0.00	0.00
Итого	22.90	---	2251.52	---	2270.11	583.62	720.00	0.00	0.00
Среднее	---	40.231	---	31.214	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	321.18	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 34 микрорайон, 96
 Потребитель: АО "Жилуправление"
 Прибор: ТЭМ-106 Заводской номер: 3060235
 Формула: $Q = M1(h1 - h2)$
 Тип системы: Подача + расходомер

Система: 1
 ТВ1

	ДУ, мм	Gmin, м3/ч	Gmax, м3/ч	Kv, л/имп	Fmax, КГц
1	50	3.025600000	60	10	---
2	50	0000004	60.5	10	---

Дата	Q, (Гкал)	M1, (т)	M2, (т)	dM, (т)	T1, (°C)	T2, (°C)	P1, (МПа)	P2, (МПа)	Время наработки, (ч)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	0.000	0.00	0.00	0.0	19.205	19.411	0.5	0.5	24.00
21.09.25	0.000	0.00	0.00	0.0	19.295	19.493	0.5	0.5	24.00
22.09.25	0.000	0.00	0.00	0.0	19.738	19.906	0.5	0.5	24.00
23.09.25	0.000	0.00	0.00	0.0	19.939	20.099	0.5	0.5	24.00
24.09.25	0.000	0.00	0.00	0.0	20.273	20.397	0.5	0.5	24.00
25.09.25	0.000	0.00	0.00	0.0	19.333	19.487	0.5	0.5	24.00
26.09.25	0.372	46.54	45.73	0.8	43.276	35.268	0.5	0.5	24.00
27.09.25	0.750	74.88	74.76	0.1	44.077	34.047	0.5	0.5	24.00
28.09.25	0.836	77.38	76.76	0.6	43.895	33.083	0.5	0.5	24.00
29.09.25	1.024	75.34	75.46	-0.1	45.522	31.908	0.5	0.5	24.00
30.09.25	1.358	67.92	67.95	-0.0	54.938	34.932	0.5	0.5	24.00
01.10.25	1.003	58.19	57.50	0.7	49.868	32.617	0.5	0.5	24.00
02.10.25	0.642	32.86	32.96	-0.1	45.722	26.154	0.5	0.5	24.00
03.10.25	0.980	65.70	65.75	-0.0	48.502	33.564	0.5	0.5	24.00
04.10.25	1.339	106.12	105.91	0.2	50.285	37.653	0.5	0.5	24.00
05.10.25	1.340	106.82	106.48	0.3	50.827	38.276	0.5	0.5	24.00
06.10.25	1.076	96.85	96.43	0.4	47.465	36.341	0.5	0.5	24.00
07.10.25	0.857	89.04	88.57	0.5	42.912	33.271	0.5	0.5	24.00
08.10.25	0.857	88.41	87.83	0.6	43.234	33.532	0.5	0.5	24.00
09.10.25	0.841	88.20	87.58	0.6	42.814	33.261	0.5	0.5	24.00
10.10.25	0.838	88.25	87.58	0.7	42.932	33.421	0.5	0.5	24.00
11.10.25	0.839	88.15	87.54	0.6	42.915	33.380	0.5	0.5	24.00
12.10.25	0.850	88.51	86.80	1.7	42.542	32.931	0.5	0.5	24.00
13.10.25	0.849	87.87	87.29	0.6	42.159	32.479	0.5	0.5	24.00
14.10.25	0.958	92.12	91.54	0.6	44.122	33.706	0.5	0.5	24.00
15.10.25	1.103	96.87	96.24	0.6	47.057	35.655	0.5	0.5	24.00
16.10.25	1.082	95.44	94.85	0.6	46.194	34.843	0.5	0.5	24.00
17.10.25	1.107	95.43	94.82	0.6	46.543	34.925	0.5	0.5	24.00
18.10.25	1.065	93.61	93.00	0.6	45.635	34.247	0.5	0.5	24.00
19.10.25	1.016	92.16	91.59	0.6	44.911	33.876	0.5	0.5	24.00
20.10.25	1.046	93.29	92.70	0.6	45.503	34.277	0.5	0.5	24.00
Итого	24.03	2086.0	2073.6	12.4	---	---	---	---	744.00
Среднее	---	---	---	---	40.70	31.18	0.5	0.5	---

Показания интеграторов

Дата	Q, (Гкал)	M1, (т)	M2, (т)	Время наработки, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д
20.10.25 24:00	3662.1	264312.0	262359.4	50075.2
Итого за период	н/д	н/д	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 10
 Потребитель: АО "Жилуправление"
 Прибор: ТЭМ-104 Заводской номер: 3060471
 Формула: $Q = M1(h_p - h_o)$
 Тип системы: Р-Подача

Система: 1
ТВ1

	ДУ, мм	Gmin, м3/ч	Gmax, м3/ч	Кв, л/имп	Fmax, КГц
1	80	0	46.8	---	---
2	80	0	49.5	---	---

Дата	Q, (Гкал)	M1, (т)	M2, (т)	dM, (т)	T1, (°C)	T2, (°C)	P1, (МПа)	P2, (МПа)	Время наработки, (ч)
19.09.25	0.001	0.00	0.00	0.0	22.230	23.010	0.9	0.5	23.98
20.09.25	0.001	0.00	0.00	0.0	22.310	23.100	0.9	0.5	23.96
21.09.25	0.000	0.00	0.00	0.0	22.370	23.160	0.9	0.5	23.98
22.09.25	0.000	0.00	0.00	0.0	22.430	23.190	0.9	0.5	23.97
23.09.25	0	0.00	0.00	0.0	22.580	23.310	0.9	0.5	23.98
24.09.25	0	0.00	0.00	0.0	22.700	23.390	0.9	0.5	23.97
25.09.25	0.000	0.00	0.00	0.0	22.770	23.420	0.9	0.5	23.97
26.09.25	1.036	198.25	202.10	-3.9	44.600	39.450	0.9	0.5	23.97
27.09.25	1.682	306.38	313.54	-7.2	43.840	38.430	0.9	0.5	23.97
28.09.25	1.768	305.88	313.07	-7.2	44.500	38.800	0.9	0.5	23.97
29.09.25	1.746	295.74	302.28	-6.5	44.040	38.210	0.9	0.5	23.97
30.09.25	1.840	284.47	290.55	-6.1	43.970	37.580	0.9	0.5	23.97
01.10.25	1.967	283.99	290.00	-6.0	45.170	38.330	0.9	0.5	23.98
02.10.25	2.224	287.68	293.81	-6.1	48.460	40.810	0.9	0.5	23.97
03.10.25	2.239	289.88	295.91	-6.0	49.250	41.610	0.9	0.5	23.96
04.10.25	2.278	290.31	296.06	-5.7	49.730	41.950	0.9	0.5	23.97
05.10.25	2.166	286.65	292.02	-5.4	49.220	41.740	0.9	0.5	23.97
06.10.25	1.723	270.17	274.77	-4.6	44.870	38.570	0.9	0.5	23.97
07.10.25	1.545	265.03	269.57	-4.5	42.930	37.180	0.9	0.5	23.96
08.10.25	1.551	264.35	268.94	-4.6	43.140	37.350	0.9	0.5	23.97
09.10.25	1.529	264.07	268.60	-4.5	42.810	37.100	0.9	0.5	23.97
10.10.25	1.513	264.05	268.77	-4.7	42.820	37.170	0.9	0.5	23.97
11.10.25	1.514	264.08	268.87	-4.8	42.870	37.210	0.9	0.5	23.97
12.10.25	1.515	264.39	269.24	-4.9	42.670	37.020	0.9	0.5	23.97
13.10.25	1.509	263.72	268.59	-4.9	42.370	36.730	0.9	0.5	23.97
14.10.25	1.805	275.17	280.60	-5.4	45.520	39.040	0.9	0.5	23.98
15.10.25	1.928	278.66	284.29	-5.6	47.020	40.180	0.9	0.5	23.97
16.10.25	2.065	283.86	289.76	-5.9	48.090	40.890	0.9	0.5	23.97
17.10.25	2.116	285.51	291.50	-6.0	48.720	41.380	0.9	0.5	23.97
18.10.25	2.065	282.90	288.80	-5.9	48.090	40.870	0.9	0.5	23.97
19.10.25	2.015	283.31	289.24	-5.9	47.770	40.730	0.9	0.5	23.97
20.10.25	2.043	284.83	290.82	-6.0	48.090	40.990	0.9	0.5	23.97
Итого	45.38	6923.3	7061.7	-138.3	---	---	---	---	767.06
Среднее	---	---	---	---	40.56	35.68	0.9	0.5	---

Показания интеграторов

Дата	Q, (Гкал)	M1, (т)	M2, (т)	Время наработки, (ч)
18.09.25 24:00	5435.3	522877.2	543744.5	50734.5
20.10.25 24:00	5480.7	529800.5	550806.2	51501.6
Итого за период	45.4	6923.3	7061.7	767.1

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 11
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BA767

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-
26.09.25	0.15	24.23	114.39	24.07	114.42	8.02	24.00	0.00	0.00
27.09.25	0.75	38.96	265.91	35.78	269.72	24.00	24.00	0.00	0.00
28.09.25	0.92	44.68	166.75	39.15	167.23	24.00	24.00	0.00	0.00
29.09.25	0.96	45.36	156.87	39.25	156.94	24.00	24.00	0.00	0.00
30.09.25	0.94	44.86	150.48	38.57	150.30	24.00	24.00	0.00	0.00
01.10.25	0.98	44.83	144.30	38.06	143.96	24.00	24.00	0.00	0.00
02.10.25	1.03	45.91	145.04	38.78	144.62	24.00	24.00	0.00	0.00
03.10.25	1.17	49.34	148.96	41.50	148.37	24.00	24.00	0.00	0.00
04.10.25	1.17	50.18	150.14	42.35	149.23	24.00	24.00	0.00	0.00
05.10.25	1.20	50.65	150.06	42.65	148.87	24.00	24.00	0.00	0.00
06.10.25	1.15	50.21	148.56	42.47	147.05	24.00	24.00	0.00	0.00
07.10.25	0.92	45.80	139.01	39.21	137.68	24.00	24.00	0.00	0.00
08.10.25	0.82	43.76	136.53	37.74	135.19	24.00	24.00	0.00	0.00
09.10.25	0.82	43.98	134.82	37.89	133.46	24.00	24.00	0.00	0.00
10.10.25	0.80	43.65	134.51	37.66	133.08	24.00	24.00	0.00	0.00
11.10.25	0.79	43.65	134.07	37.72	132.57	24.00	24.00	0.00	0.00
12.10.25	0.80	43.69	134.28	37.73	132.66	24.00	24.00	0.00	0.00
13.10.25	0.80	43.53	134.25	37.56	132.67	24.00	24.00	0.00	0.00
14.10.25	0.80	43.19	134.05	37.20	132.50	24.00	24.00	0.00	0.00
15.10.25	0.95	46.21	139.85	39.44	138.02	24.00	24.00	0.00	0.00
16.10.25	1.02	47.89	142.12	40.70	140.11	24.00	24.00	0.00	0.00
17.10.25	1.09	48.96	144.63	41.40	142.70	24.00	24.00	0.00	0.00
18.10.25	1.12	49.64	145.68	41.91	143.71	24.00	24.00	0.00	0.00
19.10.25	1.11	48.98	144.41	41.31	142.39	24.00	24.00	0.00	0.00
20.10.25	1.08	48.69	146.20	41.25	144.23	24.00	24.00	0.00	0.00
Итого	23.34	---	3685.87	---	3661.68	584.02	600.00	0.00	0.00
Среднее	---	45.233	---	38.854	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	374439.00	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 12
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BA753

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	18.85	0.00	17.67	0.00	24.00	24.00	0.00	0.00
20.09.25	0.00	18.78	0.00	17.55	0.00	23.60	24.00	0.00	0.00
21.09.25	0.00	18.97	0.00	17.97	0.00	24.00	24.00	0.00	0.00
22.09.25	0.00	19.00	0.00	17.97	0.00	24.00	24.00	0.00	0.00
23.09.25	0.00	19.87	0.00	19.04	0.00	23.60	24.00	0.00	0.00
24.09.25	0.00	21.65	0.00	21.11	0.00	23.60	24.00	0.00	0.00
25.09.25	0.00	23.02	0.00	22.57	0.00	23.60	24.00	0.00	0.00
26.09.25	0.27	27.69	193.61	26.83	193.76	23.27	24.00	0.00	0.00
27.09.25	0.86	39.14	286.63	35.74	287.26	23.60	24.00	0.00	0.00
28.09.25	1.01	44.47	178.64	38.79	179.96	24.00	24.00	0.00	0.00
29.09.25	1.05	45.13	170.72	38.99	172.18	24.00	24.00	0.00	0.00
30.09.25	1.03	44.64	162.32	38.26	163.69	24.00	24.00	0.00	0.00
01.10.25	1.04	44.58	148.78	37.60	150.09	24.00	24.00	0.00	0.00
02.10.25	1.11	45.79	148.71	38.35	150.08	24.00	24.00	0.00	0.00
03.10.25	1.25	49.12	152.46	40.92	153.96	24.00	24.00	0.00	0.00
04.10.25	1.26	49.90	153.43	41.66	154.95	24.00	24.00	0.00	0.00
05.10.25	1.29	50.39	153.04	41.96	154.48	24.00	24.00	0.00	0.00
06.10.25	1.22	49.83	151.00	41.72	152.39	24.00	24.00	0.00	0.00
07.10.25	0.98	45.46	141.84	38.57	143.24	24.00	24.00	0.00	0.00
08.10.25	0.88	43.51	139.62	37.20	140.93	24.00	24.00	0.00	0.00
09.10.25	0.87	43.70	137.92	37.36	139.25	24.00	24.00	0.00	0.00
10.10.25	0.87	43.39	137.78	37.08	139.06	24.00	24.00	0.00	0.00
11.10.25	0.86	43.39	137.16	37.12	138.42	24.00	24.00	0.00	0.00
12.10.25	0.87	43.41	137.25	37.09	138.61	24.00	24.00	0.00	0.00
13.10.25	0.87	43.24	137.37	36.90	138.69	24.00	24.00	0.00	0.00
14.10.25	0.87	42.93	137.36	36.59	138.60	24.00	24.00	0.00	0.00
15.10.25	1.04	46.08	142.98	38.84	144.35	24.00	24.00	0.00	0.00
16.10.25	1.10	47.76	144.80	40.13	146.19	24.00	24.00	0.00	0.00
17.10.25	1.18	48.84	147.54	40.82	148.90	24.00	24.00	0.00	0.00
18.10.25	1.21	49.48	148.25	41.28	149.62	24.00	24.00	0.00	0.00
19.10.25	1.19	48.86	147.46	40.74	148.88	24.00	24.00	0.00	0.00
20.10.25	1.17	48.54	148.95	40.67	150.30	24.00	24.00	0.00	0.00
Итого	25.35	---	3885.62	---	3917.84	765.27	768.00	0.00	0.00
Среднее	---	39.669	---	34.222	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	850544.19	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 13
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВА768

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	18.59	0.00	18.75	3.85	0.00	24.00	0.00	0.00
20.09.25	0.00	18.51	0.00	18.67	3.76	0.00	24.00	0.00	0.00
21.09.25	0.00	18.47	0.00	18.66	3.72	0.00	24.00	0.00	0.00
22.09.25	0.00	18.44	0.00	18.61	3.66	0.00	24.00	0.00	0.00
23.09.25	0.00	18.48	0.00	18.66	3.60	0.00	24.00	0.00	0.00
24.09.25	0.00	18.66	0.00	18.83	3.55	0.00	24.00	0.00	0.00
25.09.25	0.00	18.83	0.00	18.99	3.49	0.00	24.00	0.00	0.00
26.09.25	0.00	24.71	0.00	24.32	120.62	9.49	24.00	0.00	0.00
27.09.25	0.00	37.59	0.00	35.05	186.75	23.48	24.00	0.00	0.00
28.09.25	0.00	44.50	0.00	39.04	159.08	24.00	24.00	0.00	0.00
29.09.25	0.00	45.17	0.00	39.17	160.65	24.00	24.00	0.00	0.00
30.09.25	0.00	44.67	0.00	38.53	153.83	24.00	24.00	0.00	0.00
01.10.25	0.00	44.63	0.00	37.93	142.53	24.00	24.00	0.00	0.00
02.10.25	0.00	45.71	0.00	38.64	142.46	24.00	24.00	0.00	0.00
03.10.25	0.00	49.12	0.00	41.35	146.33	24.00	24.00	0.00	0.00
04.10.25	0.00	49.95	0.00	42.12	147.26	24.00	24.00	0.00	0.00
05.10.25	0.00	50.42	0.00	42.45	146.96	24.00	24.00	0.00	0.00
06.10.25	0.00	49.97	0.00	42.24	145.04	24.00	24.00	0.00	0.00
07.10.25	0.00	45.58	0.00	38.98	136.06	24.00	24.00	0.00	0.00
08.10.25	0.30	43.56	49.41	37.50	84.18	24.00	24.00	0.00	0.00
09.10.25	0.80	43.77	131.74	37.66	0.00	24.00	24.00	0.00	0.00
10.10.25	0.78	43.45	128.84	37.38	68.05	23.36	23.36	0.00	0.00
11.10.25	0.78	43.44	130.99	37.47	126.22	24.00	24.00	0.00	0.00
12.10.25	0.78	43.49	131.03	37.51	125.96	24.00	24.00	0.00	0.00
13.10.25	0.79	43.32	130.94	37.29	125.71	24.00	24.00	0.00	0.00
14.10.25	0.79	42.99	130.69	36.96	125.28	24.00	24.00	0.00	0.00
15.10.25	0.93	46.00	135.77	39.18	131.27	24.00	24.00	0.00	0.00
16.10.25	0.99	47.66	137.81	40.43	134.07	24.00	24.00	0.00	0.00
17.10.25	1.06	48.74	139.37	41.14	139.67	23.47	23.47	0.00	0.00
18.10.25	1.09	49.40	141.91	41.72	145.54	24.00	24.00	0.00	0.00
19.10.25	1.06	48.75	140.86	41.21	144.40	24.00	24.00	0.00	0.00
20.10.25	1.04	48.46	142.51	41.14	146.11	24.00	24.00	0.00	0.00
Итого	11.19	---	1671.87	---	3309.66	583.80	766.83	0.00	0.00
Среднее	---	39.220	---	34.299	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	5011.36	0.00
20.10.25 24:00	5023.55	0.00
Итого за период	12.19	0.00

Представитель абонента _____/_____

Представитель поставщика _____/_____

ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, 35 мкр. (Шашина), 14
Потребитель: АО "Жилуправление"
Прибор: Вэлёт ТСРВ-043 Заводской номер: 1801771
Тип системы: СО Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT	M1, (т)	M2, (т)	ΔM, (т)	M3, (м3)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	V3, (м3)	Теплота (Гкал) Q	Время раб. (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	20.89	20.54	0.35	0.000	0.014	-0.014	0.000	0.1	0.1	0.000	0.013	-0.013	0.000	0.000	24.00
21.09.25	20.88	20.51	0.37	0.000	0.101	-0.101	0.000	0.1	0.1	0.000	0.102	-0.102	0.000	0.000	24.00
22.09.25	20.98	20.62	0.36	0.000	0.051	-0.051	0.000	0.1	0.1	0.000	0.051	-0.051	0.000	0.000	24.00
23.09.25	21.25	20.89	0.36	0.000	0.036	-0.036	0.000	0.1	0.1	0.000	0.036	-0.036	0.000	0.000	24.00
24.09.25	21.55	21.14	0.41	0.000	0.055	-0.055	0.000	0.1	0.1	0.000	0.055	-0.055	0.000	0.000	24.00
25.09.25	21.50	21.06	0.44	0.000	0.112	-0.112	0.000	0.1	0.1	0.000	0.112	-0.112	0.000	0.000	24.00
26.09.25	36.15	32.25	3.90	177.108	176.442	0.666	0.000	0.4	0.4	178.866	177.743	1.123	0.000	1.119	24.00
27.09.25	44.80	38.08	6.72	290.129	291.113	-0.984	0.000	0.7	0.7	292.902	293.112	-0.210	0.000	1.947	24.00
28.09.25	45.46	38.14	7.32	294.331	293.237	1.094	0.000	0.7	0.7	297.228	295.258	1.970	0.000	2.151	24.00
29.09.25	44.97	37.22	7.75	287.688	284.337	3.351	0.000	0.7	0.7	290.462	286.204	4.258	0.000	2.223	24.00
30.09.25	44.87	36.27	8.60	281.646	280.141	1.505	0.000	0.7	0.7	284.341	281.874	2.467	0.000	2.418	24.00
01.10.25	46.31	36.47	9.84	268.303	269.055	-0.752	0.000	0.7	0.7	271.027	270.737	0.290	0.000	2.608	24.00
02.10.25	49.47	37.75	11.72	243.971	244.314	-0.343	0.000	0.6	0.7	246.808	245.964	0.844	0.000	2.854	24.00
03.10.25	50.23	38.47	11.76	246.079	246.141	-0.062	0.000	0.6	0.6	249.029	247.870	1.159	0.000	2.887	24.00
04.10.25	50.73	38.75	11.98	246.876	246.586	0.290	0.000	0.6	0.6	249.891	248.345	1.546	0.000	2.951	24.00
05.10.25	50.05	38.53	11.52	240.243	239.971	0.272	0.000	0.6	0.6	243.107	241.664	1.443	0.000	2.766	24.00
06.10.25	45.68	35.69	9.99	220.686	220.790	-0.104	0.000	0.6	0.6	222.890	222.121	0.769	0.000	2.205	24.00
07.10.25	43.92	34.61	9.31	214.414	214.886	-0.472	0.000	0.6	0.6	216.387	216.098	0.289	0.000	1.992	24.00
08.10.25	44.08	34.79	9.29	213.555	214.292	-0.737	0.000	0.6	0.6	215.535	215.513	0.022	0.000	1.981	24.00
09.10.25	43.76	34.57	9.19	212.701	213.647	-0.946	0.000	0.6	0.6	214.645	214.849	-0.204	0.000	1.951	24.00
10.10.25	43.80	34.73	9.07	213.467	214.567	-1.100	0.000	0.6	0.6	215.422	215.787	-0.365	0.000	1.930	24.00
11.10.25	43.85	34.61	9.24	213.035	214.235	-1.200	0.000	0.6	0.6	214.990	215.443	-0.453	0.000	1.963	24.00
12.10.25	43.58	34.28	9.30	214.274	215.549	-1.275	0.000	0.6	0.6	216.217	216.740	-0.523	0.000	1.989	24.00
13.10.25	43.33	34.10	9.23	212.524	213.830	-1.306	0.000	0.6	0.6	214.428	214.999	-0.571	0.000	1.958	24.00
14.10.25	46.56	36.32	10.24	228.007	229.530	-1.523	0.000	0.6	0.6	230.379	230.970	-0.591	0.000	2.340	24.00
15.10.25	48.01	37.17	10.84	230.750	232.316	-1.566	0.000	0.6	0.6	233.283	233.838	-0.555	0.000	2.496	24.00
16.10.25	49.09	37.80	11.29	238.411	240.065	-1.654	0.000	0.6	0.6	241.148	241.696	-0.548	0.000	2.686	24.00
17.10.25	49.66	38.18	11.48	238.905	240.586	-1.681	0.000	0.6	0.6	241.712	242.256	-0.544	0.000	2.736	24.00
18.10.25	49.08	37.75	11.33	236.700	238.370	-1.670	0.000	0.6	0.6	239.417	239.987	-0.570	0.000	2.676	24.00
19.10.25	48.70	37.70	11.00	235.358	237.021	-1.663	0.000	0.6	0.6	238.020	238.625	-0.605	0.000	2.583	24.00
20.10.25	49.07	38.03	11.04	239.241	240.956	-1.715	0.000	0.6	0.6	241.987	242.614	-0.627	0.000	2.637	24.00
Итого	---	---	---	5938.402	5952.346	-13.944	0.000	---	---	6000.121	5990.676	9.445	0.000	58.047	744.00
Среднее	41.36	33.45	7.911	---	---	---	---	0.5	0.5	---	---	---	---	---	---

Показания интеграторов

Дата	M1, т	M2, т	V1, м3	V2, м3	Q, Гкал	Время раб., ч
18.09.25 24:00	н/д	н/д	н/д	н/д	н/д	н/д
20.10.25 24:00	193376.213	192794.030	195318.698	193937.729	2511.257	20088.217
Итого за период	н/д	н/д	н/д	н/д	н/д	н/д

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 15
 Потребитель: АО "Жилуправление"
 Прибор: ИМ2300 Заводской номер: DD177

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	23.30	0.00	21.90	7.70	0.00	24.00	0.00	0.00
20.09.25	0.00	23.52	0.00	22.10	6.96	0.00	24.00	0.00	0.00
21.09.25	0.00	23.46	0.00	22.03	7.51	0.00	24.00	0.00	0.00
22.09.25	0.00	23.44	0.00	22.04	6.84	0.00	24.00	0.00	0.00
23.09.25	0.00	23.79	0.00	22.43	7.70	0.00	24.00	0.00	0.00
24.09.25	0.00	23.94	0.00	22.56	8.45	0.00	24.00	0.00	0.00
25.09.25	0.00	24.14	0.00	22.74	9.17	0.00	24.00	0.00	0.00
26.09.25	0.00	24.19	0.00	22.68	7.99	0.00	24.00	0.00	0.00
27.09.25	1.11	37.99	197.32	34.01	195.92	15.26	24.00	0.00	0.00
28.09.25	1.69	44.90	275.01	38.74	269.14	24.00	24.00	0.00	0.00
29.09.25	1.83	45.55	275.87	38.90	270.35	24.00	24.00	0.00	0.00
30.09.25	1.78	45.06	263.61	38.30	257.76	24.00	24.00	0.00	0.00
01.10.25	1.77	44.94	249.42	37.84	243.41	24.00	24.00	0.00	0.00
02.10.25	1.89	46.50	241.50	38.61	235.48	24.00	24.00	0.00	0.00
03.10.25	2.10	49.58	233.09	40.57	226.69	24.00	24.00	0.00	0.00
04.10.25	2.14	50.32	234.93	41.20	228.75	24.00	24.00	0.00	0.00
05.10.25	2.17	50.82	235.35	41.58	229.32	24.00	24.00	0.00	0.00
06.10.25	2.04	50.07	230.53	41.22	224.31	24.00	24.00	0.00	0.00
07.10.25	1.62	45.68	215.10	38.13	208.92	24.00	24.00	0.00	0.00
08.10.25	1.49	44.01	211.10	36.94	204.87	24.00	24.00	0.00	0.00
09.10.25	1.48	44.15	210.24	37.08	203.97	24.00	24.00	0.00	0.00
10.10.25	1.47	43.82	210.11	36.80	203.55	24.00	24.00	0.00	0.00
11.10.25	1.46	43.87	210.23	36.90	203.99	24.00	24.00	0.00	0.00
12.10.25	1.46	43.93	209.98	36.97	203.77	24.00	24.00	0.00	0.00
13.10.25	1.46	43.63	210.64	36.67	204.27	24.00	24.00	0.00	0.00
14.10.25	1.46	43.40	210.29	36.45	203.72	24.00	24.00	0.00	0.00
15.10.25	1.74	46.71	221.93	38.88	215.64	24.00	24.00	0.00	0.00
16.10.25	1.84	48.11	224.20	39.87	217.92	24.00	24.00	0.00	0.00
17.10.25	1.95	49.19	229.62	40.67	223.40	24.00	24.00	0.00	0.00
18.10.25	2.01	49.72	230.26	41.00	224.26	24.00	24.00	0.00	0.00
19.10.25	1.98	49.16	230.34	40.54	224.31	24.00	24.00	0.00	0.00
20.10.25	1.93	48.77	230.27	40.36	224.16	24.00	24.00	0.00	0.00
Итого	41.87	---	5490.94	---	5410.20	567.26	768.00	0.00	0.00
Среднее	---	40.614	---	34.585	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	3116.29	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 15а
 Потребитель: АО "Жилуправление"
 Прибор: Вzlёт ТСРВ-024 Заводской номер: 801184
 Тип системы: А32-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	23.47	22.51	0.96	0.00	0.00	0.00	0.183	0.000	0.00	0.00	0.00	0.000	24.000
20.09.25	23.24	22.33	0.91	0.00	0.00	0.00	0.182	0.000	0.00	0.00	0.00	0.000	24.000
21.09.25	23.61	22.67	0.94	0.00	0.00	0.00	0.182	0.000	0.00	0.00	0.00	0.000	24.000
22.09.25	23.63	22.63	1.00	0.00	0.00	0.00	0.181	0.000	0.00	0.00	0.00	0.000	24.000
23.09.25	23.64	22.64	1.00	0.00	0.00	0.00	0.181	0.000	0.00	0.00	0.00	0.000	24.000
24.09.25	23.78	22.78	1.00	0.00	0.00	0.00	0.181	0.000	0.00	0.00	0.00	0.000	24.000
25.09.25	23.97	22.94	1.03	0.00	0.00	0.00	0.180	0.000	0.00	0.00	0.00	0.000	24.000
26.09.25	30.43	27.67	2.76	74.72	74.22	0.50	0.290	0.159	75.04	75.18	-0.14	0.546	24.000
27.09.25	44.88	37.54	7.34	217.99	217.98	0.00	0.572	0.560	218.37	221.14	-2.77	1.596	24.000
28.09.25	45.27	37.12	8.15	214.53	214.50	0.02	0.566	0.556	215.05	217.47	-2.43	1.746	24.000
29.09.25	45.42	36.96	8.46	212.71	212.71	0.00	0.550	0.540	213.26	215.63	-2.37	1.795	24.000
30.09.25	44.46	35.69	8.77	194.17	194.17	0	0.610	0.602	194.63	196.69	-2.06	1.699	24.000
01.10.25	44.71	35.76	8.95	191.82	191.76	0.05	0.606	0.598	192.24	194.31	-2.08	1.715	24.000
02.10.25	49.22	38.10	11.12	182.54	182.54	0.00	0.553	0.545	183.12	185.31	-2.19	2.026	24.000
03.10.25	49.78	38.60	11.18	183.50	183.50	0	0.544	0.535	184.03	186.42	-2.39	2.047	24.000
04.10.25	50.39	39.10	11.29	184.88	184.88	0.00	0.541	0.533	185.42	187.91	-2.48	2.082	24.000
05.10.25	50.85	39.48	11.37	184.05	184.05	0.00	0.541	0.533	184.51	187.20	-2.70	2.089	24.000
06.10.25	46.82	37.01	9.81	171.47	171.47	0.00	0.529	0.521	171.53	174.31	-2.78	1.681	24.000
07.10.25	43.89	35.07	8.82	164.82	164.82	0	0.524	0.516	164.74	167.38	-2.65	1.451	24.000
08.10.25	43.96	35.17	8.79	164.63	164.63	0.00	0.523	0.515	164.60	167.14	-2.54	1.445	24.000
09.10.25	43.75	35.04	8.71	163.61	163.61	0.00	0.525	0.517	163.52	166.14	-2.61	1.422	24.000
10.10.25	43.62	35.08	8.54	164.11	164.11	0	0.519	0.511	163.93	166.74	-2.81	1.399	24.000
11.10.25	43.70	35.12	8.58	163.30	163.30	0.00	0.521	0.513	162.93	166.10	-3.17	1.398	24.000
12.10.25	43.83	35.12	8.71	164.36	164.36	0	0.522	0.514	163.85	167.34	-3.49	1.429	24.000
13.10.25	43.19	34.51	8.68	163.18	163.18	0.00	0.523	0.515	162.60	166.13	-3.53	1.413	24.000
14.10.25	44.90	35.61	9.29	168.98	168.98	0.00	0.525	0.517	168.47	172.14	-3.68	1.574	24.000
15.10.25	47.72	37.49	10.23	174.07	174.07	0	0.527	0.518	173.58	177.61	-4.04	1.777	24.000
16.10.25	48.53	37.87	10.66	177.34	177.34	0	0.514	0.506	176.88	181.00	-4.12	1.888	24.000
17.10.25	49.67	38.67	11.00	180.59	180.59	0.00	0.491	0.483	180.15	184.43	-4.28	1.982	24.000
18.10.25	48.95	38.12	10.83	177.78	177.78	0	0.482	0.474	177.36	181.45	-4.09	1.920	24.000
19.10.25	48.80	38.11	10.69	178.47	178.47	0	0.482	0.474	178.06	182.14	-4.08	1.904	24.000
20.10.25	48.75	38.09	10.66	178.30	178.30	0	0.482	0.474	177.89	181.95	-4.06	1.897	24.000
Итого	---	---	---	4395.95	4395.36	0.59	---	---	4395.74	4469.28	-73.54	41.922	768.000
Среднее	40.96	33.46	7.51	---	---	---	0.448	0.398	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 16
 Потребитель: АО "Жилуправление"
 Прибор: Взлёт ТСРВ-024 Заводской номер: 902713
 Тип системы: А42-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
27.09.25	44.86	38.47	6.39	506.36	504.68	1.68	0.570	0.540	511.21	508.22	2.99	3.233	24.000
28.09.25	45.52	38.33	7.19	523.13	521.62	1.51	0.565	0.537	528.30	525.26	3.04	3.759	24.000
29.09.25	45.02	37.61	7.41	520.59	518.56	2.03	0.561	0.534	525.62	522.04	3.58	3.854	24.000
30.09.25	44.95	37.18	7.77	512.27	510.80	1.47	0.613	0.588	517.19	514.14	3.05	3.973	24.000
01.10.25	46.42	38.82	7.60	574.14	573.08	1.06	0.584	0.571	580.09	577.26	2.83	4.344	24.000
02.10.25	49.64	41.96	7.68	645.81	643.21	2.59	0.541	0.535	653.38	648.61	4.77	4.955	24.000
03.10.25	50.40	42.72	7.68	647.88	645.04	2.83	0.537	0.530	655.69	650.65	5.04	4.968	24.000
04.10.25	50.91	43.10	7.81	650.98	647.59	3.38	0.535	0.527	658.98	653.33	5.65	5.070	24.000
05.10.25	50.22	42.77	7.45	646.49	642.97	3.51	0.532	0.526	654.24	648.59	5.65	4.810	24.000
06.10.25	45.76	39.60	6.16	626.82	623.97	2.84	0.516	0.515	633.09	628.64	4.46	3.857	24.000
07.10.25	43.97	38.32	5.65	621.66	619.26	2.39	0.513	0.514	627.40	623.59	3.81	3.507	24.000
08.10.25	44.14	38.53	5.61	622.84	620.75	2.09	0.512	0.513	628.64	625.13	3.50	3.488	24.000
09.10.25	43.82	38.28	5.54	620.64	618.76	1.87	0.513	0.514	626.32	623.07	3.25	3.428	24.000
10.10.25	43.85	38.34	5.51	620.64	618.90	1.73	0.505	0.506	626.34	623.23	3.10	3.417	24.000
11.10.25	43.91	38.31	5.60	620.98	619.30	1.68	0.511	0.512	626.70	623.62	3.07	3.466	24.000
12.10.25	43.64	37.97	5.67	620.74	619.15	1.58	0.511	0.511	626.38	623.40	2.99	3.512	24.000
13.10.25	43.39	37.67	5.72	620.36	618.86	1.50	0.511	0.511	625.94	623.03	2.91	3.537	24.000
14.10.25	46.67	40.09	6.58	632.60	630.97	1.62	0.517	0.514	639.19	635.82	3.37	4.161	24.000
15.10.25	48.15	41.16	6.99	636.73	635.08	1.65	0.517	0.513	643.77	640.21	3.55	4.443	24.000
16.10.25	49.25	41.82	7.43	642.72	640.97	1.74	0.496	0.491	650.14	646.33	3.81	4.768	24.000
17.10.25	49.83	42.28	7.55	644.07	642.31	1.75	0.480	0.474	651.69	647.81	3.88	4.853	24.000
18.10.25	49.23	41.81	7.42	642.01	640.26	1.75	0.475	0.470	649.42	645.61	3.82	4.754	24.000
19.10.25	48.85	41.63	7.22	641.59	639.89	1.70	0.476	0.471	648.89	645.19	3.70	4.624	24.000
20.10.25	49.21	41.93	7.28	642.21	640.50	1.70	0.475	0.469	649.62	645.89	3.73	4.666	24.000
Итого	---	---	---	14684.24	14636.49	47.75	---	---	14838.24	14748.68	89.57	99.447	576.000
Среднее	46.73	39.95	6.79	---	---	---	0.524	0.516	---	---	---	---	---

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 17
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВА720

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	0.00	25.91	0.00	26.95	0.01	0.00	24.00	5.05	0.00
22.09.25	0.00	25.88	0.00	26.91	0.00	0.00	24.00	5.00	0.00
23.09.25	0.00	25.76	0.00	26.76	0.00	0.00	24.00	4.82	0.00
24.09.25	0.00	25.79	0.00	26.82	0.01	0.00	24.00	4.95	0.00
25.09.25	0.00	25.83	0.00	26.87	0.13	0.00	24.00	4.93	0.00
26.09.25	0.03	26.49	62.30	27.16	61.60	5.75	24.00	4.90	0.00
27.09.25	0.40	32.75	260.96	31.24	263.60	23.72	24.00	4.86	0.00
28.09.25	0.55	35.96	258.17	33.83	261.45	24.00	24.00	4.81	0.00
29.09.25	1.04	47.65	250.61	43.49	255.00	24.00	24.00	4.99	0.00
30.09.25	0.94	45.52	240.10	41.56	244.10	24.00	24.00	4.95	0.00
01.10.25	1.10	48.87	230.48	44.09	234.88	24.00	24.00	5.08	0.00
02.10.25	1.08	45.30	246.22	40.90	249.91	24.00	24.00	5.05	0.00
03.10.25	1.20	47.93	251.24	43.14	256.22	24.00	24.00	5.00	0.00
04.10.25	1.24	49.02	251.58	44.08	257.03	24.00	24.00	4.90	0.00
05.10.25	1.36	51.06	255.70	45.74	256.17	24.00	24.00	4.83	0.00
06.10.25	1.29	50.64	257.30	45.62	258.30	24.00	24.00	4.84	0.00
07.10.25	1.17	48.49	261.09	44.00	261.09	24.00	24.00	4.77	0.00
08.10.25	1.08	47.50	259.87	43.33	260.59	24.00	24.00	4.79	0.00
09.10.25	1.03	46.54	257.08	42.52	257.74	24.00	24.00	4.77	0.00
10.10.25	1.01	46.06	256.47	42.13	255.58	24.00	24.00	4.78	0.00
11.10.25	1.00	46.10	256.55	42.21	257.48	24.00	24.00	4.76	0.00
12.10.25	1.01	46.11	256.44	42.16	255.55	24.00	24.00	4.84	0.00
13.10.25	1.03	46.03	256.33	42.02	256.48	24.00	24.00	4.82	0.00
14.10.25	1.02	45.48	255.37	41.48	255.73	24.00	24.00	4.85	0.00
15.10.25	1.11	47.60	262.27	43.38	261.23	24.00	24.00	4.80	0.00
16.10.25	1.16	48.80	265.59	44.41	265.44	24.00	24.00	4.78	0.00
17.10.25	1.28	50.31	272.04	45.62	270.52	24.00	24.00	4.74	0.00
18.10.25	1.33	50.70	273.96	45.84	275.05	24.00	24.00	4.77	0.00
19.10.25	1.28	49.71	269.21	44.94	266.73	24.00	24.00	4.81	0.00
20.10.25	1.22	48.95	266.98	44.39	239.87	24.00	24.00	4.84	0.00
Итого	25.96	---	6233.91	---	6237.49	581.47	720.00	146.08	0.00
Среднее	---	42.625	---	39.453	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	2852.34	5660.07
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 18
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00178675

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0х1577

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	16.95	16.73	0.22	0.320	0.320	0.320	0.320	0.000	6.42	5.32	0.0000	0.0	24.0
20.09.25	17.31	17.11	0.20	0.000	0.000	0.000	0.000	0.000	5.18	1.98	0.0000	0.0	24.0
21.09.25	17.26	17.03	0.23	0.000	0.000	0.000	0.000	0.000	5.08	1.93	0.0000	0.0	24.0
22.09.25	17.40	17.20	0.20	0.000	0.000	0.000	0.000	0.000	4.99	1.93	0.0000	0.0	24.0
23.09.25	17.59	17.39	0.20	0.000	0.000	0.000	0.000	0.000	4.92	2.02	0.0000	0.0	24.0
24.09.25	18.10	33.59	-15.49	0.000	2.410	0.000	2.400	-2.400	4.15	2.20	0.0000	0.0	24.0
25.09.25	27.57	26.11	1.46	105.120	107.670	106.190	105.880	0.310	4.23	3.49	0.1580	0.0	24.0
26.09.25	33.25	30.48	2.77	295.920	307.060	296.770	303.150	-6.380	5.67	5.64	0.8100	0.0	24.0
27.09.25	37.02	33.13	3.89	281.940	293.270	282.560	289.250	-6.690	5.73	5.66	1.0950	0.0	24.0
28.09.25	47.53	41.05	6.48	276.900	287.170	276.820	281.980	-5.160	5.69	5.58	1.7920	0.0	24.0
29.09.25	45.74	39.28	6.46	263.670	274.040	262.740	270.310	-7.570	5.72	5.59	1.6940	0.0	24.0
30.09.25	47.67	40.57	7.10	257.610	267.340	256.420	263.620	-7.200	6.17	6.04	1.8170	0.0	24.0
01.10.25	45.62	39.21	6.41	269.380	280.250	268.950	275.970	-7.020	6.18	6.07	1.7220	0.0	24.0
02.10.25	47.83	41.02	6.81	274.780	284.230	274.630	279.130	-4.500	6.21	6.09	1.8690	0.0	24.0
03.10.25	49.03	41.99	7.04	277.190	286.160	277.310	280.470	-3.160	6.22	6.10	1.9480	0.0	24.0
04.10.25	50.91	43.44	7.47	282.480	291.940	282.070	286.230	-4.160	6.20	6.07	2.1010	0.0	24.0
05.10.25	49.94	43.04	6.90	283.950	292.350	284.640	285.630	-0.990	6.24	6.13	1.9620	0.0	24.0
06.10.25	48.42	42.04	6.38	290.210	299.100	291.000	292.480	-1.480	6.21	6.10	1.8530	0.0	24.0
07.10.25	47.15	41.22	5.93	288.090	297.300	288.640	291.240	-2.600	6.20	6.10	1.7080	0.0	24.0
08.10.25	46.26	40.56	5.70	284.860	294.400	285.270	288.830	-3.560	6.17	6.06	1.6230	0.0	24.0
09.10.25	45.85	40.24	5.61	284.370	293.510	285.500	287.280	-1.780	6.17	6.06	1.5950	0.0	24.0
10.10.25	45.99	40.37	5.62	284.610	293.900	285.060	288.260	-3.200	6.10	5.99	1.6010	0.0	24.0
11.10.25	45.98	40.31	5.67	284.290	293.610	285.050	287.730	-2.680	6.17	6.06	1.6090	0.0	24.0
12.10.25	45.64	39.93	5.71	283.560	292.930	284.610	286.760	-2.150	6.17	6.06	1.6240	0.0	24.0
13.10.25	45.24	39.61	5.63	282.250	291.390	283.300	285.370	-2.070	6.16	6.05	1.5940	0.0	24.0
14.10.25	47.70	41.57	6.13	291.670	300.310	292.010	294.330	-2.320	6.19	6.08	1.7850	0.0	24.0
15.10.25	48.85	42.39	6.46	296.370	305.140	296.670	298.840	-2.170	6.25	6.13	1.9150	0.0	24.0
16.10.25	50.18	43.40	6.78	302.790	311.810	302.990	305.250	-2.260	6.41	6.29	2.0480	0.0	24.0
17.10.25	50.43	43.67	6.76	303.380	311.740	303.990	304.610	-0.620	6.39	6.28	2.0520	0.0	24.0
18.10.25	49.58	42.92	6.66	298.640	307.700	299.220	300.890	-1.670	6.17	6.05	1.9880	0.0	24.0
19.10.25	48.56	42.20	6.36	295.280	304.170	295.610	297.940	-2.330	6.17	6.06	1.8780	0.0	24.0
20.10.25	49.36	42.82	6.54	298.210	306.480	299.250	299.250	0.000	6.19	6.08	1.9560	0.0	24.0
Итого	---	---	---	7237.8	7477.7	7247.59	7333.40	-85.810	---	---	43.7970	0.0	768.0
Среднее	40.68	36.30	4.38	---	---	---	---	---	5.88	5.29	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	0.000	0.320	0.000	0.320	0.0000	-0.320	1124.0	1237.0
20.10.25 24:00	7237.840	7478.020	7247.590	7333.719	43.7970	-86.130	1124.0	2005.0
Итого за период	7237.840	7477.700	7247.590	7333.399	43.7970	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ИМ2300, Суточный с 19.09.25 по 20.10.25

Объект: г. Октябрьский, 35 мкр. (Шашина), 1
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BA755

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	22.97	0.00	21.58	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	23.06	0.00	21.65	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	23.09	0.00	21.69	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	23.13	0.00	21.72	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	23.16	0.00	21.76	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	23.17	0.00	21.82	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	23.31	0.00	21.90	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	23.41	0.00	22.00	0.00	0.00	24.00	0.00	0.00
27.09.25	0.75	34.29	132.65	30.98	0.00	11.47	24.00	0.00	0.00
28.09.25	1.56	44.82	268.51	39.01	0.00	24.00	24.00	0.00	0.00
29.09.25	1.67	45.49	268.74	39.28	0.00	24.00	24.00	0.00	0.00
30.09.25	1.65	44.99	264.95	38.74	0.00	24.00	24.00	0.00	0.00
01.10.25	1.75	44.95	255.40	38.09	0.00	23.36	24.00	0.00	0.00
02.10.25	1.91	46.06	262.21	38.78	0.00	24.00	24.00	0.00	0.00
03.10.25	2.16	49.51	269.38	41.46	0.00	24.00	24.00	0.00	0.00
04.10.25	2.18	50.35	271.74	42.31	0.00	24.00	24.00	0.00	0.00
05.10.25	2.22	50.82	272.33	42.65	0.00	24.00	24.00	0.00	0.00
06.10.25	2.13	50.37	268.49	42.42	0.00	24.00	24.00	0.00	0.00
07.10.25	1.70	45.93	253.66	39.23	0.00	24.00	24.00	0.00	0.00
08.10.25	1.52	43.89	249.27	37.78	0.00	24.00	24.00	0.00	0.00
09.10.25	1.54	44.11	246.42	37.84	0.00	24.00	24.00	0.00	0.00
10.10.25	1.52	43.78	246.46	37.59	0.00	24.00	24.00	0.00	0.00
11.10.25	1.51	43.78	246.13	37.64	0.00	24.00	24.00	0.00	0.00
12.10.25	1.51	43.82	246.22	37.66	0.00	24.00	24.00	0.00	0.00
13.10.25	1.53	43.66	246.24	37.43	0.00	24.00	24.00	0.00	0.00
14.10.25	1.51	41.18	246.79	35.04	0.00	24.00	24.00	0.00	0.00
15.10.25	1.80	38.36	256.26	31.35	0.00	24.00	24.00	0.00	0.00
16.10.25	1.93	40.35	260.52	32.93	0.00	24.00	24.00	0.00	0.00
17.10.25	2.05	47.40	265.48	39.67	0.00	24.00	24.00	0.00	0.00
18.10.25	2.13	48.11	265.87	40.08	0.00	24.00	24.00	0.00	0.00
19.10.25	2.08	47.58	263.04	39.64	0.00	24.00	24.00	0.00	0.00
20.10.25	2.04	48.85	263.46	41.09	0.00	24.00	24.00	0.00	0.00
Итого	42.35	---	6090.22	---	0.00	562.83	768.00	0.00	0.00
Среднее	---	39.617	---	34.150	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	8844.38	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 20
 Потребитель: АО "Жилуправление"
 Прибор: Вzlёт ТСРВ-024 Заводской номер: 716218
 Тип системы: А32-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	19.81	19.26	0.55	0.00	0.00	0.00	0.290	0.001	0.00	0.00	0.00	0.000	24.000
20.09.25	19.81	19.16	0.65	0.00	0.00	0.00	0.285	0.001	0.00	0.00	0.00	0.000	24.000
21.09.25	19.87	19.15	0.72	0.00	0.00	0.00	0.276	0.001	0.00	0.00	0.00	0.000	24.000
22.09.25	20.25	19.54	0.71	0.00	0.00	0.00	0.274	0.001	0.00	0.00	0.00	0.000	24.000
23.09.25	20.61	19.84	0.77	0.00	0.00	0.00	0.274	0.001	0.00	0.00	0.00	0.000	24.000
24.09.25	21.14	20.29	0.85	0.00	0.00	0.00	0.275	0.001	0.00	0.00	0.00	0.000	24.000
25.09.25	20.71	19.85	0.86	0.00	0.00	0.00	0.268	0.001	0.00	0.00	0.00	0.000	24.000
26.09.25	35.18	31.32	3.86	104.25	103.46	0.78	0.312	0.003	105.12	104.42	0.69	0.646	24.000
27.09.25	44.58	38.03	6.55	163.71	163.13	0.58	0.346	0.002	165.18	164.38	0.80	1.103	24.000
28.09.25	45.25	37.96	7.29	167.19	167.00	0.18	0.343	0.000	168.74	168.28	0.46	1.235	24.000
29.09.25	44.75	37.19	7.56	161.11	161.01	0.09	0.340	0.000	162.56	162.21	0.35	1.231	24.000
30.09.25	44.66	36.51	8.15	151.58	151.52	0.05	0.373	0.000	152.93	152.62	0.32	1.247	24.000
01.10.25	46.05	38.40	7.65	196.36	196.21	0.14	0.357	0.001	198.25	197.87	0.38	1.466	23.950
02.10.25	49.34	42.99	6.35	282.78	282.74	0.03	0.330	0.001	285.75	285.63	0.12	1.813	24.000
03.10.25	50.11	43.73	6.38	284.74	284.74	0	0.327	0.001	287.78	287.78	0.00	1.832	24.000
04.10.25	50.60	44.11	6.49	284.28	284.28	0	0.326	0.001	287.35	287.41	-0.06	1.861	24.000
05.10.25	49.97	43.83	6.14	286.35	286.35	0.00	0.324	0.001	289.46	289.36	0.10	1.776	24.000
06.10.25	45.63	40.64	4.99	283.47	283.47	0.00	0.316	0.000	286.14	285.94	0.20	1.432	24.000
07.10.25	43.83	39.30	4.53	285.15	285.14	0.01	0.315	0.000	287.64	287.45	0.19	1.309	24.000
08.10.25	44.00	39.45	4.55	284.31	284.30	0.01	0.314	0.000	286.81	286.62	0.20	1.311	24.000
09.10.25	43.68	39.17	4.51	285.53	285.50	0.03	0.315	0.000	288.03	287.78	0.25	1.305	24.000
10.10.25	43.71	39.19	4.52	283.17	283.15	0.01	0.310	0.000	285.66	285.40	0.26	1.295	24.000
11.10.25	43.76	39.25	4.51	285.25	285.23	0.02	0.314	0.001	287.78	287.49	0.29	1.302	24.000
12.10.25	43.51	38.95	4.56	281.92	281.87	0.04	0.314	0.000	284.41	284.06	0.35	1.303	24.000
13.10.25	43.24	38.70	4.54	285.15	285.10	0.04	0.313	0.000	287.65	287.27	0.38	1.311	24.000
14.10.25	46.41	40.98	5.43	282.88	282.85	0.03	0.316	0.000	285.73	285.28	0.45	1.550	24.000
15.10.25	47.89	42.18	5.71	286.18	286.14	0.03	0.316	0.000	289.22	288.75	0.47	1.653	24.000
16.10.25	48.96	42.85	6.11	283.43	283.39	0.03	0.303	0.000	286.58	286.05	0.53	1.749	24.000
17.10.25	49.55	43.38	6.17	286.53	286.51	0.02	0.293	0.000	289.78	289.26	0.52	1.784	24.000
18.10.25	48.96	42.83	6.13	282.88	282.85	0.02	0.289	0.000	286.03	285.49	0.54	1.747	24.000
19.10.25	48.60	42.74	5.86	286.76	286.74	0.01	0.290	0.000	289.90	289.43	0.47	1.697	24.000
20.10.25	48.95	42.93	6.02	282.92	282.90	0.02	0.289	0.000	286.07	285.57	0.50	1.718	24.000
Итого	---	---	---	6347.87	6345.60	2.27	---	---	6410.54	6401.80	8.74	36.676	767.950
Среднее	40.42	35.74	4.68	---	---	---	0.310	0.001	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 20
 Потребитель: АО "Жилуправление"
 Прибор: Вzlёт ТСРВ-024 Заводской номер: 903372
 Тип системы: А32-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	0.00	0.00	0.00	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	0.000
20.09.25	0.00	0.00	0.00	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	0.000
21.09.25	0.00	0.00	0.00	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	0.000
22.09.25	17.89	16.78	1.11	0.00	0.00	0.00	0.031	0.018	0.00	0.00	0.00	0.000	13.750
23.09.25	18.81	17.58	1.23	0.00	0.00	0.00	0.031	0.018	0.00	0.00	0.00	0.000	24.000
24.09.25	19.90	18.64	1.26	0.00	0.00	0.00	0.031	0.018	0.00	0.00	0.00	0.000	24.000
25.09.25	18.54	16.96	1.58	0.00	0.00	0.00	0.031	0.017	0.00	0.00	0.00	0.000	24.000
26.09.25	33.31	29.56	3.75	0.00	0.00	0.00	0.348	0.329	0.00	0.00	0.00	0.000	24.000
27.09.25	44.15	39.69	4.46	0.00	0.00	0.00	0.562	0.544	0.00	0.00	0.00	0.000	24.000
28.09.25	44.88	40.06	4.82	0.00	0.00	0.00	0.557	0.540	0.00	0.00	0.00	0.000	24.000
29.09.25	44.44	39.46	4.98	0.00	0.00	0.00	0.553	0.537	0.00	0.00	0.00	0.000	24.000
30.09.25	44.34	39.16	5.18	0.00	0.00	0.00	0.598	0.584	0.00	0.00	0.00	0.000	24.000
01.10.25	45.49	39.53	5.96	105.37	105.37	0	0.574	0.567	105.40	107.26	-1.87	0.697	24.000
02.10.25	48.64	41.38	7.26	177.20	177.21	-0.00	0.530	0.530	177.31	180.53	-3.22	1.284	24.000
03.10.25	49.43	42.24	7.19	179.54	179.68	-0.13	0.526	0.525	179.68	183.16	-3.48	1.277	24.000
04.10.25	49.93	42.55	7.38	180.37	180.38	-0.00	0.523	0.522	180.50	183.94	-3.45	1.329	24.000
05.10.25	49.33	42.21	7.12	176.87	176.88	-0.00	0.520	0.521	176.96	180.36	-3.40	1.258	24.000
06.10.25	45.02	38.85	6.17	163.18	163.19	-0.00	0.505	0.509	163.05	166.08	-3.03	1.006	24.000
07.10.25	43.23	37.48	5.75	159.66	159.66	0.00	0.504	0.508	159.45	162.37	-2.92	0.915	24.000
08.10.25	43.38	37.64	5.74	158.70	158.70	0	0.503	0.507	158.49	161.40	-2.91	0.910	24.000
09.10.25	43.07	37.42	5.65	158.89	158.89	0	0.504	0.508	158.65	161.58	-2.93	0.895	24.000
10.10.25	43.10	37.49	5.61	158.92	158.92	0.00	0.496	0.500	158.66	161.65	-2.99	0.890	24.000
11.10.25	43.15	37.46	5.69	159.45	159.45	0	0.502	0.506	159.16	162.22	-3.05	0.906	24.000
12.10.25	42.90	37.06	5.84	159.75	159.76	-0.00	0.501	0.505	159.48	162.47	-2.99	0.930	24.000
13.10.25	42.63	36.83	5.80	159.50	159.50	0.00	0.501	0.505	159.24	162.17	-2.93	0.922	24.000
14.10.25	45.68	39.21	6.47	169.24	169.25	-0.00	0.506	0.509	169.05	172.38	-3.32	1.097	24.000
15.10.25	47.24	40.45	6.79	172.15	172.16	-0.00	0.506	0.507	171.98	175.51	-3.53	1.166	24.000
16.10.25	48.32	41.27	7.05	176.45	176.45	0	0.485	0.485	176.31	179.98	-3.67	1.243	24.000
17.10.25	48.93	41.80	7.13	178.03	178.03	0	0.469	0.469	177.89	181.69	-3.79	1.268	24.000
18.10.25	48.36	41.27	7.09	175.42	175.42	0	0.464	0.464	175.22	179.00	-3.78	1.240	24.000
19.10.25	48.02	41.09	6.93	175.24	175.26	-0.02	0.465	0.466	175.01	178.84	-3.82	1.211	24.000
20.10.25	48.36	41.37	6.99	176.02	176.02	0	0.463	0.464	175.78	179.66	-3.88	1.228	24.000
Итого	---	---	---	3319.97	3320.18	-0.20	---	---	3317.28	3382.26	-64.98	21.673	685.750
Среднее	37.83	32.89	4.94	---	---	---	0.400	0.396	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 23
 Потребитель: АО "Жилуправление"
 Прибор: Взлёт ТСРВ-024М Заводской номер: 1302337
 Тип системы: А32-00 Система: 1

ТБ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	28.04	26.10	1.94	0.00	0.00	0.00	0.0	0.0	0.00	0.00	0.00	0.000	24.00
20.09.25	28.35	26.57	1.78	0.00	0.00	0.00	0.0	0.0	0.00	0.00	0.00	0.000	24.00
21.09.25	28.49	26.51	1.98	0.00	0.00	0.00	0.0	0.0	0.00	0.00	0.00	0.000	24.00
22.09.25	28.44	26.81	1.63	0.00	0.00	0.00	0.0	0.0	0.00	0.00	0.00	0.000	24.00
23.09.25	29.11	27.46	1.65	0.00	0.00	0.00	0.0	0.0	0.00	0.00	0.00	0.000	24.00
24.09.25	29.53	27.98	1.55	0.00	0.00	0.00	0.0	0.0	0.00	0.00	0.00	0.000	24.00
25.09.25	29.36	28.11	1.25	79.26	79.26	0	0.0	0.2	79.59	79.59	0.00	0.046	24.00
26.09.25	33.30	31.55	1.75	148.19	148.19	0	0.0	0.4	148.97	148.97	0.00	0.242	24.00
27.09.25	36.98	34.34	2.64	187.64	187.64	0.00	0.0	0.4	188.92	188.92	0.00	0.564	24.00
28.09.25	47.80	43.06	4.74	328.67	328.67	0	0.0	0.4	331.96	331.96	0.00	1.525	24.00
29.09.25	45.90	40.74	5.16	319.52	319.52	0.00	0.0	0.4	322.45	322.45	0.00	1.604	24.00
30.09.25	48.28	42.36	5.92	310.39	310.39	0	0.0	0.5	313.48	313.48	0.00	1.797	24.00
01.10.25	45.72	40.43	5.29	324.01	324.01	0	0.0	0.5	326.89	326.98	-0.09	1.681	24.00
02.10.25	48.10	42.42	5.68	330.76	330.76	0	0.0	0.5	334.04	334.04	0.00	1.840	24.00
03.10.25	49.25	43.40	5.85	332.89	332.89	0	0.0	0.5	336.33	336.37	-0.04	1.909	24.00
04.10.25	51.18	44.90	6.28	335.27	335.27	0	0.0	0.5	339.01	339.01	0.00	2.064	24.00
05.10.25	50.36	44.56	5.80	337.36	337.35	0.02	0.0	0.5	340.96	341.10	-0.14	1.921	24.00
06.10.25	48.66	43.36	5.30	344.23	344.23	0	0.0	0.5	347.71	347.81	-0.10	1.786	24.00
07.10.25	47.45	42.57	4.88	342.32	342.32	0	0.0	0.5	345.68	345.68	0.00	1.632	24.00
08.10.25	46.56	41.89	4.67	339.04	339.04	0.00	0.0	0.5	342.25	342.27	-0.02	1.548	24.00
09.10.25	46.13	41.52	4.61	338.31	338.31	0.00	0.0	0.5	341.39	341.53	-0.14	1.521	24.00
10.10.25	46.24	41.68	4.56	338.47	338.47	0.00	0.0	0.5	341.64	341.64	0.00	1.508	24.00
11.10.25	46.23	41.63	4.60	338.15	338.15	0	0.0	0.5	341.31	341.31	0.00	1.517	24.00
12.10.25	45.96	41.32	4.64	337.42	337.42	0	0.0	0.5	340.53	340.53	0.00	1.528	24.00
13.10.25	45.51	40.89	4.62	335.64	335.64	0.00	0.0	0.5	338.68	338.68	0.00	1.515	24.00
14.10.25	47.88	42.80	5.08	345.15	345.15	0	0.0	0.5	348.59	348.59	0.00	1.717	24.00
15.10.25	49.04	43.69	5.35	344.44	344.44	0	0.0	0.5	348.02	348.02	0.00	1.803	24.00
16.10.25	50.44	44.79	5.65	357.19	357.19	0	0.0	0.5	361.10	361.10	0.00	1.976	24.00
17.10.25	50.73	45.04	5.69	358.13	358.13	0.00	0.0	0.5	362.10	362.10	0.00	1.996	24.00
18.10.25	49.84	44.24	5.60	352.72	352.72	0	0.0	0.5	356.49	356.49	0.00	1.936	24.00
19.10.25	48.87	43.53	5.34	349.24	349.24	0	0.0	0.5	352.85	352.85	0.00	1.826	24.00
20.10.25	49.63	44.11	5.52	352.40	352.40	0.00	0.0	0.5	356.13	356.15	-0.02	1.906	24.00
Итого	---	---	---	8206.82	8206.80	0.02	---	---	8287.09	8287.64	-0.55	40.908	768.00
Среднее	43.04	38.76	4.28	---	---	---	0.0	0.4	---	---	---	---	---

Показания интеграторов

Дата	Мтс	Q, (Гкал)
18.09.25 24:00	72.41	6866.216
20.10.25 24:00	72.42	6907.124
Итого за период	---	40.908

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 25
 Потребитель: АО "Жилуправление"
 Прибор: ТЭМ-106 Заводской номер: 3060287
 Формула: $Q = M1(h1 - h2)$
 Тип системы: Подача + расходомер

Система: 1

ТВ1

	ДУ, мм	Gmin, м3/ч	Gmax, м3/ч	Kv, л/имп	Fmax, КГц
1	80	8	192	10	---
2	80	8	192	10	---

Дата	Q, (Гкал)	M1, (т)	M2, (т)	dM, (т)	T1, (°C)	T2, (°C)	P1, (МПа)	P2, (МПа)	Время наработки, (ч)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-
28.09.25	-	-	-	-	-	-	-	-	-
29.09.25	-	-	-	-	-	-	-	-	-
30.09.25	н/д	н/д	н/д	н/д	45.003	39.577	0.5	0.4	н/д
01.10.25	1.820	314.01	311.38	2.6	45.837	40.056	0.5	0.4	24.00
02.10.25	1.991	319.69	316.73	3.0	48.034	41.822	0.5	0.4	24.00
03.10.25	2.074	320.44	317.21	3.2	49.245	42.789	0.5	0.4	24.00
04.10.25	2.226	325.92	322.19	3.7	51.129	44.315	0.5	0.4	24.00
05.10.25	2.074	327.60	323.78	3.8	50.114	43.799	0.5	0.4	24.00
06.10.25	1.952	335.24	331.27	4.0	48.607	42.801	0.5	0.4	24.00
07.10.25	1.798	332.85	328.92	3.9	47.318	41.934	0.5	0.4	24.00
08.10.25	1.698	329.05	325.20	3.9	46.422	41.279	0.5	0.4	24.00
09.10.25	1.667	328.45	324.62	3.8	46.013	40.954	0.5	0.4	24.00
10.10.25	1.670	328.68	324.84	3.8	46.163	41.099	0.5	0.4	24.00
11.10.25	1.673	328.22	324.38	3.8	46.157	41.075	0.5	0.4	24.00
12.10.25	1.667	327.36	323.53	3.8	45.800	40.724	0.5	0.4	24.00
13.10.25	1.649	325.81	322.06	3.7	45.411	40.365	0.5	0.4	24.00
14.10.25	1.884	337.29	333.28	4.0	47.891	42.322	0.5	0.4	24.00
15.10.25	2.027	343.27	339.18	4.1	49.048	43.159	0.5	0.4	24.00
16.10.25	2.163	350.76	346.48	4.3	50.359	44.211	0.5	0.4	24.00
17.10.25	2.178	351.27	346.96	4.3	50.601	44.417	0.5	0.4	24.00
18.10.25	2.115	345.77	341.56	4.2	49.751	43.650	0.5	0.4	24.00
19.10.25	2.000	341.86	337.72	4.1	48.725	42.891	0.5	0.4	24.00
20.10.25	2.082	345.24	341.05	4.2	49.539	43.525	0.5	0.4	24.00
Итого	38.41	6658.8	6582.3	76.2	---	---	---	---	480.00
Среднее	---	---	---	---	47.96	42.23	0.5	0.4	---

Показания интеграторов

Дата	Q, (Гкал)	M1, (т)	M2, (т)	Время наработки, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д
20.10.25 24:00	8672.6	765061.0	756661.7	87204.7
Итого за период	н/д	н/д	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 28
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00178569

БД=1, ТВ1, СИ=1, КТЗ=1, ФРТ=0, КСН=0x5549

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Мг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	17.93	18.03	-0.10	0.000	0.550	0.000	0.550	-0.550	7.00	7.00	0.0000	0.0	24.0
20.09.25	18.01	18.04	-0.03	0.000	0.420	0.000	0.420	-0.420	7.00	7.00	0.0000	0.0	24.0
21.09.25	17.98	18.05	-0.07	0.000	0.090	0.000	0.090	-0.090	7.00	7.00	0.0000	0.0	24.0
22.09.25	18.42	18.43	-0.01	0.000	0.550	0.000	0.550	-0.550	7.00	7.00	0.0000	0.0	24.0
23.09.25	18.76	18.66	0.10	0.000	0.520	0.000	0.520	-0.520	7.00	7.00	0.0000	0.0	24.0
24.09.25	19.24	19.22	0.02	0.000	1.040	0.000	1.040	-1.040	7.00	7.00	0.0000	0.0	24.0
25.09.25	31.49	30.42	1.07	292.920	295.750	291.590	294.510	-2.920	7.00	7.00	0.2980	0.0	24.0
26.09.25	37.95	34.76	3.19	663.850	675.730	659.280	671.870	-12.590	7.00	7.00	2.0830	0.0	24.0
27.09.25	44.04	38.92	5.12	524.300	531.410	519.510	527.690	-8.180	7.00	7.00	2.6530	0.0	24.0
28.09.25	44.69	39.29	5.40	521.660	528.050	516.810	524.240	-7.430	7.00	7.00	2.7820	0.0	24.0
29.09.25	44.17	38.31	5.86	538.430	541.660	533.520	537.980	-4.460	7.00	7.00	3.1200	0.0	24.0
30.09.25	44.12	37.20	6.92	567.180	571.390	562.010	567.720	-5.710	7.00	7.00	3.8790	0.0	24.0
01.10.25	45.86	39.31	6.55	681.730	687.250	675.020	682.290	-7.270	7.00	7.00	4.4090	0.0	24.0
02.10.25	48.76	42.11	6.65	762.170	767.400	753.730	761.010	-7.280	7.00	7.00	5.0020	0.0	24.0
03.10.25	49.50	42.81	6.69	766.520	771.920	757.740	765.260	-7.520	7.00	7.00	5.0570	0.0	24.0
04.10.25	49.99	43.20	6.79	771.410	775.890	762.420	769.110	-6.690	7.00	7.00	5.1710	0.0	24.0
05.10.25	49.29	42.82	6.47	766.470	770.420	757.780	763.780	-6.000	7.00	7.00	4.8900	0.0	24.0
06.10.25	44.91	39.58	5.33	743.070	746.040	736.050	740.580	-4.530	7.00	7.00	3.9100	0.0	24.0
07.10.25	43.18	38.29	4.89	737.130	740.030	730.700	734.990	-4.290	7.00	7.00	3.5660	0.0	24.0
08.10.25	43.34	38.49	4.85	738.810	741.430	732.280	736.290	-4.010	7.00	7.00	3.5420	0.0	24.0
09.10.25	43.02	38.20	4.82	737.020	739.420	730.630	734.400	-3.770	7.00	7.00	3.5070	0.0	24.0
10.10.25	43.06	38.26	4.80	737.340	739.990	730.940	734.950	-4.010	7.00	7.00	3.4950	0.0	24.0
11.10.25	43.11	38.24	4.87	737.250	739.990	730.840	734.950	-4.110	7.00	7.00	3.5510	0.0	24.0
12.10.25	42.84	37.86	4.98	737.160	739.790	730.840	734.880	-4.040	7.00	7.00	3.6290	0.0	24.0
13.10.25	42.60	37.55	5.05	736.690	739.170	730.390	734.320	-3.930	7.00	7.00	3.6720	0.0	24.0
14.10.25	45.91	40.08	5.83	753.870	755.900	746.400	750.200	-3.800	7.00	7.00	4.3430	0.0	24.0
15.10.25	47.29	41.13	6.16	758.910	761.130	750.990	755.150	-4.160	7.00	7.00	4.6180	0.0	24.0
16.10.25	48.37	41.87	6.50	766.830	768.960	758.470	762.630	-4.160	7.00	7.00	4.9200	0.0	24.0
17.10.25	48.92	42.30	6.62	768.480	770.680	759.910	764.200	-4.290	7.00	7.00	5.0190	0.0	24.0
18.10.25	48.34	41.81	6.53	765.040	767.400	756.700	761.110	-4.410	7.00	7.00	4.9370	0.0	24.0
19.10.25	47.96	41.62	6.34	764.430	766.710	756.200	760.480	-4.280	7.00	7.00	4.7830	0.0	24.0
20.10.25	48.33	41.94	6.39	765.450	767.500	757.100	761.190	-4.090	7.00	7.00	4.8300	0.0	24.0
Итого	---	---	---	18104.1	18204.1	17927.85	18068.95	-141.100	---	---	101.6660	0.0	768.0
Среднее	40.04	35.52	4.51	---	---	---	---	---	7.00	7.00	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Мг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	158311.030	157741.510	156101.910	156179.210	1367.2390	-77.300	1608.0	7883.0
20.10.25 24:00	176415.150	175945.690	174029.760	174248.160	1468.9050	-218.400	1608.0	8651.0
Итого за период	18104.119	18204.179	17927.850	18068.950	101.6660	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 29
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВА762

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.01	24.90	984.50	25.04	0.00	3.84	24.00	0.00	0.00
20.09.25	0	25.10	761.63	25.30	0.00	0.56	24.00	0.00	0.00
21.09.25	0.02	25.77	929.31	25.82	0.00	7.07	24.00	0.00	0.00
22.09.25	0.00	25.44	484.58	25.73	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	25.45	562.54	25.69	0.00	2.64	24.00	0.00	0.00
24.09.25	0.00	24.70	345.97	25.06	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	24.72	412.54	24.94	0.00	2.17	24.00	0.00	0.00
26.09.25	0	24.27	325.68	24.63	0.00	0.28	24.00	0.00	0.00
27.09.25	0.46	26.31	386.02	28.79	208.29	7.22	24.00	0.00	0.00
28.09.25	1.40	36.92	654.33	34.75	653.72	24.00	24.00	0.00	0.00
29.09.25	2.10	47.55	583.45	43.95	583.66	24.00	24.00	0.00	0.00
30.09.25	1.85	45.69	439.55	41.46	440.86	24.00	24.00	0.00	0.00
01.10.25	2.21	47.94	484.84	43.34	480.65	24.00	24.00	0.00	0.00
02.10.25	2.17	45.57	524.03	41.44	515.44	24.00	24.00	0.00	0.00
03.10.25	2.38	47.90	541.62	43.50	532.07	24.00	24.00	0.00	0.00
04.10.25	2.71	49.04	581.75	44.48	574.57	24.00	24.00	0.00	0.00
05.10.25	3.34	50.98	688.94	46.13	687.56	24.00	24.00	0.00	0.00
06.10.25	2.92	50.09	670.36	45.74	669.35	24.00	24.00	0.00	0.00
07.10.25	2.72	48.47	689.13	44.52	687.05	24.00	24.00	0.00	0.00
08.10.25	2.46	47.23	677.76	43.60	676.34	24.00	24.00	0.00	0.00
09.10.25	2.19	46.35	663.17	43.04	661.76	24.00	24.00	0.00	0.00
10.10.25	2.18	45.93	663.80	42.63	662.09	24.00	24.00	0.00	0.00
11.10.25	2.20	46.06	667.24	42.75	665.49	24.00	24.00	0.00	0.00
12.10.25	2.26	46.04	670.85	42.67	669.20	24.00	24.00	0.00	0.00
13.10.25	2.31	45.75	678.04	42.33	676.10	24.00	24.00	0.00	0.00
14.10.25	2.35	45.32	684.51	41.88	682.27	24.00	24.00	0.00	0.00
15.10.25	2.95	47.72	730.82	43.69	727.84	24.00	24.00	0.00	0.00
16.10.25	3.25	48.90	756.36	44.59	754.06	24.00	24.00	0.00	0.00
17.10.25	3.50	50.27	773.67	45.73	771.49	24.00	24.00	0.00	0.00
18.10.25	3.53	50.53	775.88	45.98	773.73	24.00	24.00	0.00	0.00
19.10.25	3.45	49.67	764.14	45.14	761.62	24.00	24.00	0.00	0.00
20.10.25	3.25	48.66	755.66	44.36	753.25	24.00	24.00	0.00	0.00
Итого	60.17	---	20312.67	---	15268.46	575.78	768.00	0.00	0.00
Среднее	---	41.101	---	38.397	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	10122.58	1224.69
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 2
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BA756

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	19.07	0.00	18.88	0.00	24.00	24.00	0.00	0.00
20.09.25	0.00	19.03	0.00	18.83	0.00	24.00	24.00	0.00	0.00
21.09.25	0.00	19.04	0.00	18.84	0.00	24.00	24.00	0.00	0.00
22.09.25	0.00	18.99	0.00	18.80	0.00	23.60	24.00	0.00	0.00
23.09.25	0.00	19.16	0.00	19.08	0.00	22.08	24.00	0.00	0.00
24.09.25	0.00	19.31	0.00	19.17	8.82	23.19	24.00	0.00	0.00
25.09.25	0.00	19.43	0.00	19.34	19.82	21.12	24.00	0.00	0.00
26.09.25	0.00	19.30	0.00	19.10	36.82	22.00	24.00	0.00	0.00
27.09.25	0.51	33.24	137.17	31.05	153.76	23.51	24.00	0.00	0.00
28.09.25	1.05	44.47	259.06	40.42	268.69	24.00	24.00	0.00	0.00
29.09.25	1.14	45.11	264.29	40.79	273.36	24.00	24.00	0.00	0.00
30.09.25	1.21	44.62	265.84	40.06	271.08	24.00	24.00	0.00	0.00
01.10.25	1.27	44.53	261.28	39.67	267.01	23.60	24.00	0.00	0.00
02.10.25	1.42	46.08	266.29	40.76	272.97	24.00	24.00	0.00	0.00
03.10.25	1.60	49.24	275.34	43.40	282.43	24.00	24.00	0.00	0.00
04.10.25	1.62	49.98	278.81	44.15	284.23	24.00	24.00	0.00	0.00
05.10.25	1.66	50.50	279.13	44.54	285.07	24.00	24.00	0.00	0.00
06.10.25	1.56	49.73	274.87	44.05	280.84	24.00	24.00	0.00	0.00
07.10.25	1.23	45.28	256.93	40.49	263.89	24.00	24.00	0.00	0.00
08.10.25	1.11	43.57	251.33	39.12	259.70	24.00	24.00	0.00	0.00
09.10.25	1.11	43.73	250.19	39.29	258.78	24.00	24.00	0.00	0.00
10.10.25	1.09	43.42	249.28	39.04	258.50	24.00	24.00	0.00	0.00
11.10.25	1.08	43.46	249.90	39.11	258.48	24.00	24.00	0.00	0.00
12.10.25	1.10	43.51	250.84	39.12	258.60	24.00	24.00	0.00	0.00
13.10.25	1.14	43.20	255.88	38.73	257.97	24.00	24.00	0.00	0.00
14.10.25	1.13	42.96	254.55	38.53	257.59	24.00	24.00	0.00	0.00
15.10.25	1.35	46.31	264.86	41.21	269.82	24.00	24.00	0.00	0.00
16.10.25	1.43	47.73	267.19	42.37	273.38	24.00	24.00	0.00	0.00
17.10.25	1.53	48.83	272.82	43.21	278.79	24.00	24.00	0.00	0.00
18.10.25	1.56	49.38	274.45	43.67	279.87	24.00	24.00	0.00	0.00
19.10.25	1.53	48.81	272.13	43.19	277.60	24.00	24.00	0.00	0.00
20.10.25	1.49	48.40	272.77	42.93	277.98	24.00	24.00	0.00	0.00
Итого	30.92	---	6205.20	---	6435.85	759.10	768.00	0.00	0.00
Среднее	---	39.044	---	35.342	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	7188.66	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 30а
 Потребитель: АО "Жилуправление"
 Прибор: ИМ2300 Заводской номер: BA853

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	27.33	0.00	28.08	0.00	0.00	24.00	8.96	0.00
20.09.25	0.00	27.29	0.00	28.03	0.00	0.00	24.00	8.85	0.00
21.09.25	0.00	27.40	0	28.15	0.00	0.00	24.00	8.96	0.00
22.09.25	0.00	27.31	0.00	28.05	0.00	0.00	24.00	9.08	0.00
23.09.25	0.00	27.22	0.00	27.93	0.00	0.00	24.00	8.59	0.00
24.09.25	0.00	27.69	0.00	28.41	0.00	0.00	24.00	8.72	0.00
25.09.25	0.00	28.15	0.00	28.89	0.00	0.00	24.00	8.74	0.00
26.09.25	0.00	28.56	0.00	28.23	238.05	11.46	24.00	8.68	0.00
27.09.25	0.00	33.77	0.00	31.42	640.97	23.58	24.00	8.52	0.00
28.09.25	0.00	37.47	0.00	33.98	676.96	24.00	24.00	8.71	0.00
29.09.25	0.00	47.79	0.00	41.75	657.78	24.00	24.00	9.08	0.00
30.09.25	2.59	46.05	332.34	39.45	667.29	24.00	24.00	8.76	0.00
01.10.25	5.01	47.90	679.73	40.50	681.86	24.00	24.00	8.98	0.00
02.10.25	4.71	45.89	704.59	39.20	708.61	24.00	24.00	8.98	0.00
03.10.25	5.14	48.11	732.95	41.08	734.85	24.00	24.00	8.83	0.00
04.10.25	5.37	49.31	744.20	42.08	746.32	24.00	24.00	8.59	0.00
05.10.25	5.77	51.19	747.20	43.44	748.92	24.00	24.00	8.64	0.00
06.10.25	5.36	50.17	745.95	42.96	748.35	24.00	24.00	8.86	0.00
07.10.25	5.03	48.67	749.09	41.93	751.77	24.00	24.00	8.51	0.00
08.10.25	4.65	47.39	748.47	41.17	751.56	24.00	24.00	8.54	0.00
09.10.25	4.39	46.50	746.00	40.60	750.12	24.00	24.00	8.50	0.00
10.10.25	4.32	46.10	745.02	40.29	749.59	24.00	24.00	8.55	0.00
11.10.25	4.32	46.26	745.20	40.45	750.27	24.00	24.00	8.38	0.00
12.10.25	4.37	46.25	747.03	40.39	750.35	24.00	24.00	8.55	0.00
13.10.25	4.41	45.88	747.96	39.97	750.77	24.00	24.00	8.62	0.00
14.10.25	4.34	45.50	746.05	39.67	749.69	24.00	24.00	8.77	0.00
15.10.25	4.86	47.92	748.37	41.41	753.37	24.00	24.00	8.48	0.00
16.10.25	5.17	49.13	752.45	42.25	755.64	24.00	24.00	8.42	0.00
17.10.25	5.52	50.43	756.35	43.11	758.32	24.00	24.00	8.41	0.00
18.10.25	5.57	50.65	756.45	43.28	758.64	24.00	24.00	8.38	0.00
19.10.25	5.40	49.83	752.49	42.63	755.54	24.00	24.00	8.50	0.00
20.10.25	5.11	48.79	749.84	41.97	754.07	24.00	24.00	8.83	0.00
Итого	101.41	---	15177.73	---	17789.66	587.04	768.00	277.97	0.00
Среднее	---	42.122	---	37.523	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	21132.60	26412.41
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 31
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00166110

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0xВ72D

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	22.52	23.06	-0.54	0.000	0.320	0.000	0.320	-0.320	6.83	6.64	0.0000	0.0	24.0
20.09.25	22.80	23.16	-0.36	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
21.09.25	22.85	23.21	-0.36	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
22.09.25	22.94	23.30	-0.36	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
23.09.25	23.16	23.55	-0.39	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
24.09.25	23.50	23.91	-0.41	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
25.09.25	29.53	28.51	1.02	115.760	116.970	115.320	116.550	-1.230	6.90	6.70	0.1160	0.0	24.0
26.09.25	33.03	31.00	2.03	223.390	226.990	222.180	225.930	-3.750	6.90	6.70	0.4520	0.0	24.0
27.09.25	36.64	33.51	3.13	199.530	203.360	198.250	202.310	-4.060	6.90	6.70	0.6190	0.0	24.0
28.09.25	47.43	41.81	5.62	193.300	196.970	191.300	195.310	-4.010	6.90	6.70	1.0720	0.0	24.0
29.09.25	45.53	39.76	5.77	182.780	185.330	180.980	183.940	-2.960	6.90	6.70	1.0470	0.0	24.0
30.09.25	47.99	40.91	7.08	176.140	178.990	174.230	177.580	-3.350	6.90	6.70	1.2310	0.0	24.0
01.10.25	45.41	39.14	6.27	183.590	186.430	181.820	185.090	-3.270	6.90	6.70	1.1370	0.0	24.0
02.10.25	47.75	40.79	6.96	181.500	184.410	179.610	183.010	-3.400	6.90	6.70	1.2480	0.0	24.0
03.10.25	48.90	41.28	7.62	175.070	177.630	173.060	176.190	-3.130	6.90	6.70	1.3180	0.0	24.0
04.10.25	50.80	42.72	8.08	180.170	183.370	178.010	181.790	-3.780	6.90	6.70	1.4350	0.0	24.0
05.10.25	50.06	42.46	7.60	182.170	185.520	180.070	183.900	-3.830	6.90	6.70	1.3640	0.0	24.0
06.10.25	48.35	41.52	6.83	188.600	192.180	186.540	190.640	-4.100	6.90	6.70	1.2750	0.0	24.0
07.10.25	47.19	40.83	6.36	185.850	189.430	183.880	187.920	-4.040	6.90	6.70	1.1680	0.0	24.0
08.10.25	46.29	40.15	6.14	182.870	186.450	181.040	185.010	-3.970	6.90	6.70	1.1110	0.0	24.0
09.10.25	45.86	39.85	6.01	182.350	185.980	180.550	184.550	-4.000	6.90	6.70	1.0840	0.0	24.0
10.10.25	45.96	40.02	5.94	182.190	185.850	180.370	184.420	-4.050	6.90	6.70	1.0690	0.0	24.0
11.10.25	45.94	39.95	5.99	181.650	185.320	179.830	183.880	-4.050	6.90	6.70	1.0730	0.0	24.0
12.10.25	45.71	39.71	6.00	181.080	184.820	179.290	183.490	-4.200	6.90	6.70	1.0740	0.0	24.0
13.10.25	45.26	39.30	5.96	179.950	183.510	178.210	182.210	-4.000	6.90	6.70	1.0580	0.0	24.0
14.10.25	47.59	41.16	6.43	188.440	191.530	186.450	190.010	-3.560	6.90	6.70	1.1970	0.0	24.0
15.10.25	48.70	41.80	6.90	193.040	196.890	190.890	195.240	-4.350	6.90	6.70	1.3120	0.0	24.0
16.10.25	50.09	42.85	7.24	199.060	202.800	196.740	201.050	-4.310	6.90	6.70	1.4230	0.0	24.0
17.10.25	50.40	43.10	7.30	199.520	203.290	197.120	201.540	-4.420	6.90	6.70	1.4390	0.0	24.0
18.10.25	49.50	42.29	7.21	194.920	198.690	192.690	197.010	-4.320	6.90	6.70	1.3890	0.0	24.0
19.10.25	48.58	41.68	6.90	191.840	195.630	189.760	194.080	-4.320	6.90	6.70	1.3080	0.0	24.0
20.10.25	49.30	42.22	7.08	194.490	198.260	192.280	196.610	-4.330	6.90	6.70	1.3590	0.0	24.0
Итого	---	---	---	4819.2	4906.9	4770.47	4869.58	-99.110	---	---	29.3780	0.0	768.0
Среднее	41.73	36.82	4.90	---	---	---	---	---	6.90	6.70	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	52751.180	53446.520	51994.220	52867.610	388.1980	-873.390	3112.0	8367.0
20.10.25 24:00	57570.429	58353.440	56764.690	57737.190	417.5760	-972.500	3112.0	9135.0
Итого за период	4819.248	4906.920	4770.470	4869.580	29.3780	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 31а
 Потребитель: АО "Жилуправление"
 Прибор: ИМ2300 Заводской номер: BA854

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	21.14	0.00	21.24	0.00	0.06	24.00	0.00	0.00
20.09.25	0.00	21.17	0.00	21.31	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	21.34	0.00	21.52	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	21.37	0.00	21.59	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	21.82	0.00	22.04	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	22.17	0.00	22.43	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	22.71	0.00	22.98	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	27.02	0.00	26.67	142.58	12.36	24.00	0.00	0.00
27.09.25	0.00	33.33	0.00	31.25	192.88	24.00	24.00	0.00	0.00
28.09.25	0.00	36.73	0.00	32.83	185.63	24.00	24.00	0.00	0.00
29.09.25	0.00	47.47	0.00	40.43	179.53	24.00	24.00	0.00	0.00
30.09.25	0.00	45.54	0.00	38.70	168.12	24.00	24.00	0.00	0.00
01.10.25	0.00	48.08	0.00	40.12	160.49	24.00	24.00	0.00	0.00
02.10.25	0.00	45.40	0.00	37.97	168.08	24.00	24.00	0.00	0.00
03.10.25	0.00	47.78	0.00	39.34	166.64	24.00	24.00	0.00	0.00
04.10.25	0.00	48.92	0.00	39.98	159.25	24.00	24.00	0.00	0.00
05.10.25	0.00	50.83	0.00	41.36	163.16	24.00	24.00	0.00	0.00
06.10.25	0.00	50.11	0.00	41.23	164.53	24.00	24.00	0.00	0.00
07.10.25	0.00	48.36	0.00	40.29	169.43	24.00	24.00	0.00	0.00
08.10.25	0.00	47.21	0.00	39.70	168.08	24.00	24.00	0.00	0.00
09.10.25	0.03	46.33	4.93	39.09	165.29	24.00	24.00	0.00	0.00
10.10.25	0.00	45.89	0.00	38.76	164.92	24.00	24.00	0.00	0.00
11.10.25	0.41	46.00	57.19	38.92	164.85	24.00	24.00	0.00	0.00
12.10.25	1.18	45.97	165.26	38.82	164.36	24.00	24.00	0.00	0.00
13.10.25	1.20	45.72	166.01	38.46	161.30	24.00	24.00	0.00	0.00
14.10.25	1.19	45.28	163.72	37.99	162.84	24.00	24.00	0.00	0.00
15.10.25	1.34	47.57	171.31	39.77	170.44	24.00	24.00	0.00	0.00
16.10.25	1.43	48.71	175.00	40.54	174.08	24.00	24.00	0.00	0.00
17.10.25	1.55	50.11	180.17	41.51	179.19	24.00	24.00	0.00	0.00
18.10.25	1.57	50.41	180.68	41.72	179.68	24.00	24.00	0.00	0.00
19.10.25	1.52	49.52	176.57	40.89	175.61	24.00	24.00	0.00	0.00
20.10.25	1.44	48.60	173.80	40.32	172.90	24.00	24.00	0.00	0.00
Итого	12.86	---	1614.64	---	4223.86	588.42	768.00	0.00	0.00
Среднее	---	40.582	---	34.993	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	6010.97	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 32
 Потребитель: АО "Жилуправление"
 Прибор: ТЭМ-106 Заводской номер: 3060286
 Формула: $Q = M1(h1 - h2)$
 Тип системы: Подача + расходомер

Система: 1
 ТВ1

	ДУ, мм	Gmin, м3/ч	Gmax, м3/ч	Kv, л/имп	Fmax, КГц
1	50	3.2	64	10	---
2	50	3	60	10	---

Дата	Q, (Гкал)	M1, (т)	M2, (т)	dM, (т)	T1, (°C)	T2, (°C)	P1, (МПа)	P2, (МПа)	Время наработки, (ч)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-
28.09.25	-	-	-	-	-	-	-	-	-
29.09.25	-	-	-	-	-	-	-	-	-
30.09.25	-	-	-	-	-	-	-	-	-
01.10.25	-	-	-	-	-	-	-	-	-
02.10.25	-	-	-	-	-	-	-	-	-
03.10.25	-	-	-	-	-	-	-	-	-
04.10.25	-	-	-	-	-	-	-	-	-
05.10.25	-	-	-	-	-	-	-	-	-
06.10.25	н/д	н/д	н/д	н/д	48.615	41.993	0.6	0.5	н/д
07.10.25	1.197	198.52	202.87	-4.3	46.404	40.377	0.6	0.5	24.00
08.10.25	1.134	195.97	200.15	-4.2	45.539	39.754	0.6	0.5	24.00
09.10.25	1.121	195.55	199.65	-4.1	45.136	39.403	0.6	0.5	24.00
10.10.25	1.122	195.71	199.77	-4.1	45.276	39.543	0.6	0.5	24.00
11.10.25	1.125	194.98	198.99	-4.0	45.257	39.484	0.6	0.5	24.00
12.10.25	1.126	193.88	197.84	-4.0	44.921	39.115	0.6	0.5	24.00
13.10.25	1.120	192.62	196.52	-3.9	44.533	38.718	0.6	0.5	24.00
14.10.25	1.260	201.81	205.96	-4.1	46.882	40.649	0.6	0.5	24.00
15.10.25	1.343	206.18	210.44	-4.3	48.058	41.544	0.6	0.5	24.00
16.10.25	1.440	211.83	216.23	-4.4	49.368	42.575	0.6	0.6	24.00
17.10.25	1.453	212.10	216.49	-4.4	49.608	42.761	0.6	0.6	24.00
18.10.25	1.414	207.74	212.00	-4.3	48.778	41.974	0.6	0.5	24.00
19.10.25	1.330	204.62	208.80	-4.2	47.780	41.281	0.6	0.5	24.00
20.10.25	1.385	207.26	211.53	-4.3	48.571	41.890	0.6	0.5	24.00
Итого	17.57	2818.8	2877.2	-58.6	---	---	---	---	336.00
Среднее	---	---	---	---	46.98	40.74	0.6	0.5	---

Показания интеграторов

Дата	Q, (Гкал)	M1, (т)	M2, (т)	Время наработки, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д
20.10.25 24:00	5397.0	513195.2	517327.8	83358.0
Итого за период	н/д	н/д	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 33
 Потребитель: АО "Жилуправление"
 Прибор: ИМ2300 Заводской номер: BA772

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	21.77	17.27	21.76	0.00	13.09	24.00	0.00	0.00
20.09.25	0.00	21.81	17.27	21.76	0.00	14.11	24.00	0.00	0.00
21.09.25	0.00	21.88	17.27	21.86	0.00	12.56	24.00	0.00	0.00
22.09.25	0.00	21.87	17.27	21.85	0.00	13.51	24.00	0.00	0.00
23.09.25	0.00	21.82	17.27	21.81	0.00	12.47	24.00	0.00	0.00
24.09.25	0	22.23	17.26	22.44	0.00	2.02	24.00	0.00	0.00
25.09.25	0.00	22.62	17.26	22.94	0.00	0.00	24.00	0.00	0.00
26.09.25	0.08	24.41	77.71	24.03	0.00	8.24	24.00	0.00	0.00
27.09.25	0.38	33.27	199.19	31.18	0.00	24.00	24.00	0.00	0.00
28.09.25	0.51	36.89	212.32	34.49	0.00	24.00	24.00	0.00	0.00
29.09.25	0.97	47.46	221.40	43.09	0.00	24.00	24.00	0.00	0.00
30.09.25	1.39	45.66	250.26	40.18	0.00	24.00	24.00	0.00	0.00
01.10.25	1.76	47.86	259.80	41.15	0.00	24.00	24.00	0.00	0.00
02.10.25	1.73	45.51	283.99	39.40	0.00	24.00	24.00	0.00	0.00
03.10.25	1.89	47.82	290.86	41.30	0.00	24.00	24.00	0.00	0.00
04.10.25	1.95	48.98	292.40	42.31	0.00	24.00	24.00	0.00	0.00
05.10.25	2.09	50.90	296.07	43.81	0.00	24.00	24.00	0.00	0.00
06.10.25	1.96	50.03	296.71	43.41	0.00	24.00	24.00	0.00	0.00
07.10.25	1.83	48.41	302.66	42.35	0.00	24.00	24.00	0.00	0.00
08.10.25	1.68	47.18	301.19	41.58	0.00	24.00	24.00	0.00	0.00
09.10.25	1.59	46.31	298.76	40.97	172.74	24.00	24.00	0.00	0.00
10.10.25	1.56	45.89	298.30	40.64	302.10	24.00	24.00	0.00	0.00
11.10.25	1.55	46.02	298.38	40.80	302.33	24.00	24.00	0.00	0.00
12.10.25	1.56	46.00	298.04	40.76	302.04	24.00	24.00	0.00	0.00
13.10.25	1.59	45.71	297.67	40.37	301.53	24.00	24.00	0.00	0.00
14.10.25	1.56	45.29	296.48	40.01	300.13	24.00	24.00	0.00	0.00
15.10.25	1.76	47.65	305.45	41.88	309.23	24.00	24.00	0.00	0.00
16.10.25	1.87	48.81	309.68	42.78	313.75	24.00	24.00	0.00	0.00
17.10.25	2.00	50.16	316.30	43.83	320.50	24.00	24.00	0.00	0.00
18.10.25	2.04	50.43	317.16	44.00	321.44	24.00	24.00	0.00	0.00
19.10.25	1.97	49.57	312.55	43.27	316.52	24.00	24.00	0.00	0.00
20.10.25	1.84	48.59	309.19	42.61	313.07	24.00	24.00	0.00	0.00
Итого	39.11	---	7063.39	---	3575.38	652.00	768.00	0.00	0.00
Среднее	---	40.588	---	36.394	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	7468.70	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 34
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00178845

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0хВ8А8

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
26.09.25	35.87	32.91	2.96	91.620	88.700	91.000	88.220	2.780	6.90	6.70	0.2740	0.0	24.0
27.09.25	37.16	33.44	3.72	122.500	118.100	121.670	117.530	4.140	6.90	6.70	0.4530	0.0	24.0
28.09.25	47.63	41.01	6.62	119.280	115.230	118.080	114.270	3.810	6.90	6.70	0.7820	0.0	24.0
29.09.25	46.03	39.69	6.34	106.100	102.650	105.070	101.880	3.190	6.90	6.70	0.6640	0.0	24.0
30.09.25	47.73	40.96	6.77	103.020	100.090	101.920	99.280	2.640	6.90	6.70	0.6880	0.0	24.0
01.10.25	45.76	39.31	6.45	107.220	104.720	106.150	103.980	2.170	6.85	6.64	0.6820	0.0	24.0
02.10.25	47.94	40.71	7.23	112.040	109.460	110.840	108.560	2.280	6.90	6.70	0.8010	0.0	24.0
03.10.25	49.15	41.63	7.52	113.590	111.000	112.290	110.040	2.250	6.90	6.70	0.8420	0.0	24.0
04.10.25	51.03	42.98	8.05	117.780	113.870	116.340	112.910	3.430	6.90	6.70	0.9390	0.0	24.0
05.10.25	50.06	42.64	7.42	119.130	114.380	117.750	113.420	4.330	6.90	6.70	0.8720	0.0	24.0
06.10.25	48.55	41.55	7.00	122.130	117.210	120.820	116.250	4.570	6.90	6.70	0.8440	0.0	24.0
07.10.25	47.27	40.71	6.56	122.090	116.800	120.820	115.840	4.980	6.90	6.70	0.7920	0.0	24.0
08.10.25	46.39	40.06	6.33	120.790	115.500	119.590	114.610	4.980	6.90	6.70	0.7530	0.0	24.0
09.10.25	45.98	39.74	6.24	120.650	115.270	119.450	114.400	5.050	6.90	6.70	0.7460	0.0	24.0
10.10.25	46.12	39.94	6.18	120.810	115.470	119.610	114.530	5.080	6.90	6.70	0.7380	0.0	24.0
11.10.25	46.10	39.78	6.32	120.820	115.430	119.620	114.520	5.100	6.90	6.70	0.7540	0.0	24.0
12.10.25	45.74	39.32	6.42	120.630	115.160	119.430	114.340	5.090	6.90	6.70	0.7660	0.0	24.0
13.10.25	45.37	39.14	6.23	120.070	114.620	118.880	113.820	5.060	6.90	6.70	0.7380	0.0	24.0
14.10.25	47.81	41.01	6.80	123.790	118.280	122.480	117.340	5.140	6.90	6.70	0.8300	0.0	24.0
15.10.25	48.97	41.87	7.10	125.540	120.000	124.120	119.040	5.080	6.90	6.70	0.8780	0.0	24.0
16.10.25	50.28	42.80	7.48	128.190	122.490	126.720	121.470	5.250	6.90	6.70	0.9490	0.0	24.0
17.10.25	50.54	42.97	7.57	128.380	122.790	126.870	121.760	5.110	6.90	6.70	0.9570	0.0	24.0
18.10.25	49.68	42.20	7.48	126.520	120.930	125.080	119.970	5.110	6.90	6.70	0.9360	0.0	24.0
19.10.25	48.68	41.53	7.15	125.180	119.640	123.770	118.680	5.090	6.90	6.70	0.8840	0.0	24.0
20.10.25	49.47	42.13	7.34	126.380	120.790	124.940	119.830	5.110	6.90	6.70	0.9140	0.0	24.0
Итого	---	---	---	2964.2	2848.5	2933.31	2826.49	106.820	---	---	19.4760	0.0	600.0
Среднее	47.01	40.40	6.61	---	---	---	---	---	6.90	6.70	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
24.09.25 24:00	0	0	0	0	0	0	0	0
20.10.25 24:00	2859.140	2747.400	2829.549	2726.189	18.5540	103.360	0.0	586.0
Итого за период	2859.140	2747.400	2829.549	2726.189	18.5540	---	0.0	586.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 34
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00179082

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0x0D62

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
26.09.25	33.43	31.38	2.05	112.580	112.580	112.000	112.060	-0.060	6.43	5.66	0.2310	0.0	24.0
27.09.25	36.50	33.62	2.88	137.430	137.430	136.590	136.650	-0.060	6.34	5.80	0.3920	0.0	24.0
28.09.25	47.57	42.41	5.16	136.930	136.930	135.490	135.730	-0.240	6.23	5.78	0.6980	0.0	24.0
29.09.25	45.85	40.61	5.24	114.910	114.910	113.780	114.000	-0.220	6.18	5.78	0.5980	0.0	24.0
30.09.25	48.05	41.76	6.29	111.470	111.470	110.250	110.560	-0.310	6.60	6.27	0.6940	0.0	24.0
01.10.25	45.44	39.96	5.48	118.620	118.620	117.520	117.760	-0.240	6.64	6.30	0.6430	0.0	24.0
02.10.25	47.87	41.73	6.14	120.500	120.500	119.250	119.540	-0.290	6.68	6.34	0.7300	0.0	24.0
03.10.25	49.01	42.26	6.75	123.630	123.630	122.230	122.590	-0.360	6.69	6.36	0.8240	0.0	24.0
04.10.25	50.97	43.71	7.26	126.080	126.080	124.580	124.880	-0.300	6.67	6.34	0.9030	0.0	24.0
05.10.25	50.31	43.50	6.81	126.980	126.980	125.470	125.830	-0.360	6.72	6.37	0.8510	0.0	24.0
06.10.25	48.48	42.29	6.19	129.380	129.380	127.950	128.310	-0.360	6.72	6.35	0.7950	0.0	24.0
07.10.25	47.34	41.61	5.73	128.550	128.550	127.250	127.510	-0.260	6.70	6.33	0.7280	0.0	24.0
08.10.25	46.44	40.94	5.50	126.950	126.950	125.670	125.990	-0.320	6.66	6.30	0.6890	0.0	24.0
09.10.25	45.99	40.61	5.38	126.690	126.690	125.490	125.730	-0.240	6.66	6.29	0.6740	0.0	24.0
10.10.25	46.08	40.74	5.34	126.910	126.910	125.710	125.950	-0.240	6.59	6.22	0.6720	0.0	24.0
11.10.25	46.06	40.62	5.44	126.930	126.930	125.730	125.970	-0.240	6.67	6.30	0.6850	0.0	24.0
12.10.25	45.86	40.31	5.55	126.860	126.860	125.620	125.900	-0.280	6.67	6.31	0.6960	0.0	24.0
13.10.25	45.39	39.95	5.44	126.210	126.210	125.010	125.250	-0.240	6.65	6.29	0.6790	0.0	24.0
14.10.25	47.70	41.80	5.90	129.980	129.980	128.610	128.910	-0.300	6.69	6.32	0.7580	0.0	24.0
15.10.25	48.82	42.64	6.18	131.740	131.740	130.310	130.570	-0.260	6.75	6.38	0.8040	0.0	24.0
16.10.25	50.25	43.77	6.48	134.710	134.710	133.130	133.510	-0.380	6.92	6.54	0.8620	0.0	24.0
17.10.25	50.57	44.00	6.57	135.170	135.170	133.550	133.960	-0.410	6.94	6.56	0.8770	0.0	24.0
18.10.25	49.65	43.21	6.44	133.010	133.010	131.490	131.810	-0.320	6.68	6.31	0.8480	0.0	24.0
19.10.25	48.77	42.60	6.17	131.800	131.800	130.320	130.690	-0.370	6.68	6.31	0.8010	0.0	24.0
20.10.25	49.44	43.11	6.33	132.820	132.820	131.330	131.630	-0.300	6.71	6.33	0.8270	0.0	24.0
Итого	---	---	---	3176.8	3176.8	3144.33	3151.29	-6.960	---	---	17.9590	0.0	600.0
Среднее	46.87	41.16	5.70	---	---	---	---	---	6.63	6.25	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
24.09.25 24:00	0	0	0	0	0	0	0	0
20.10.25 24:00	32594.470	32594.470	32136.960	32259.650	258.4360	-122.690	1503.0	10743.0
Итого за период	32594.470	32594.470	32136.960	32259.650	258.4360	---	1503.0	10743.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 37
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00166950

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0хDE0E

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	19.16	20.59	-1.43	0.750	6.000	0.750	6.000	-5.250	5.60	3.98	0.0000	0.0	24.0
20.09.25	19.45	20.51	-1.06	0.000	18.000	0.000	18.000	-18.000	5.60	1.14	0.0000	0.0	24.0
21.09.25	19.46	20.50	-1.04	0.000	18.000	0.000	18.000	-18.000	5.60	1.14	0.0000	0.0	24.0
22.09.25	19.64	20.65	-1.01	0.000	18.000	0.000	18.000	-18.000	5.60	1.15	0.0000	0.0	24.0
23.09.25	20.57	21.51	-0.94	0.000	18.000	0.000	18.000	-18.000	5.60	1.15	0.0000	0.0	24.0
24.09.25	21.59	22.46	-0.87	0.000	18.000	0.000	18.000	-18.000	5.60	1.16	0.0000	0.0	24.0
25.09.25	31.30	29.43	1.87	253.440	264.560	252.280	263.520	-11.240	5.60	3.74	0.4130	0.0	24.0
26.09.25	33.10	30.02	3.08	340.040	343.570	338.230	342.110	-3.880	5.60	5.69	1.0270	0.0	24.0
27.09.25	36.86	31.90	4.96	323.130	327.950	321.060	326.370	-5.310	5.60	5.76	1.5850	0.0	24.0
28.09.25	47.32	38.78	8.54	316.750	322.010	313.410	319.760	-6.350	5.60	5.79	2.6690	0.0	24.0
29.09.25	45.58	37.05	8.53	295.690	300.400	292.790	298.430	-5.640	5.60	5.76	2.4920	0.0	24.0
30.09.25	47.67	37.54	10.13	292.950	298.030	289.810	296.080	-6.270	5.60	6.21	2.9250	0.0	24.0
01.10.25	45.43	36.19	9.24	308.890	313.490	305.890	311.580	-5.690	5.60	6.24	2.8140	0.0	24.0
02.10.25	47.70	38.72	8.98	363.390	368.850	359.530	366.270	-6.740	5.60	6.31	3.2190	0.0	24.0
03.10.25	48.95	40.88	8.07	438.970	446.410	433.990	442.960	-8.970	5.60	6.37	3.4860	0.0	24.0
04.10.25	50.82	42.18	8.64	439.660	448.650	434.370	444.900	-10.530	5.60	6.35	3.7380	0.0	24.0
05.10.25	49.97	41.93	8.04	439.430	451.490	434.260	447.760	-13.500	5.60	6.39	3.4750	0.0	24.0
06.10.25	48.37	40.96	7.41	441.480	455.810	436.620	452.240	-15.620	5.60	6.35	3.2220	0.0	24.0
07.10.25	47.16	40.31	6.85	441.180	456.500	436.560	453.040	-16.480	5.60	6.33	2.9820	0.0	24.0
08.10.25	46.30	39.78	6.52	439.830	455.650	435.390	452.250	-16.860	5.60	6.29	2.8260	0.0	24.0
09.10.25	45.88	39.49	6.39	439.280	455.690	434.910	452.350	-17.440	5.60	6.28	2.7660	0.0	24.0
10.10.25	46.01	39.63	6.38	439.660	456.280	435.280	452.940	-17.660	5.60	6.22	2.7640	0.0	24.0
11.10.25	45.99	39.53	6.46	439.280	456.150	434.910	452.790	-17.880	5.60	6.29	2.7920	0.0	24.0
12.10.25	45.68	39.17	6.51	439.820	456.930	435.470	453.690	-18.220	5.60	6.28	2.8260	0.0	24.0
13.10.25	45.27	38.75	6.52	438.270	455.340	434.050	452.140	-18.090	5.60	6.26	2.8220	0.0	24.0
14.10.25	47.62	40.46	7.16	443.370	460.500	438.640	456.960	-18.320	5.60	6.32	3.1280	0.0	24.0
15.10.25	48.76	41.21	7.55	444.980	461.810	440.000	458.140	-18.140	5.60	6.39	3.3100	0.0	24.0
16.10.25	50.11	42.07	8.04	452.370	468.940	447.040	465.040	-18.000	5.60	6.57	3.5750	0.0	24.0
17.10.25	50.36	42.15	8.21	455.150	472.130	449.760	468.200	-18.440	5.60	6.55	3.6760	0.0	24.0
18.10.25	49.52	41.57	7.95	454.070	471.280	448.830	467.450	-18.620	5.60	6.32	3.5510	0.0	24.0
19.10.25	48.55	41.01	7.54	452.620	469.970	447.620	466.270	-18.650	5.60	6.31	3.3560	0.0	24.0
20.10.25	49.31	41.54	7.77	454.940	472.190	449.750	468.360	-18.610	5.60	6.34	3.4840	0.0	24.0
Итого	---	---	---	10489.3	10906.5	10381.20	10827.60	-446.400	---	---	74.9230	0.0	768.0
Среднее	41.23	35.57	5.65	---	---	---	---	---	5.60	5.29	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	88528.550	91908.270	87259.890	91074.370	983.2530	-3814.480	1057.0	10425.0
20.10.25 24:00	99017.939	102814.849	97641.089	101901.969	1058.1760	-4260.880	1057.0	11193.0
Итого за период	10489.388	10906.578	10381.199	10827.599	74.9230	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 38
 Потребитель: АО "Жилуправление"
 Прибор: ИМ2300 Заводской номер: ВА786

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	19.20	0.00	20.36	0.03	0.00	24.00	0.00	0.00
20.09.25	0.00	19.23	0.00	20.42	0.01	0.00	24.00	0.00	0.00
21.09.25	0.00	19.45	0.00	20.59	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	19.55	0.00	20.86	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	20.12	0.00	21.46	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	21.07	0.00	22.18	0.01	0.00	24.00	0.00	0.00
25.09.25	0.00	21.88	0.00	22.91	0.00	0.00	24.00	0.00	0.00
26.09.25	0.11	24.46	99.54	24.10	93.08	11.26	24.00	0.00	0.00
27.09.25	0.52	32.87	224.17	30.48	215.60	24.00	24.00	0.00	0.00
28.09.25	0.81	36.25	220.39	32.54	213.74	24.00	24.00	0.00	0.00
29.09.25	1.47	47.35	217.03	40.57	210.59	24.00	24.00	0.00	0.00
30.09.25	1.25	45.34	198.13	39.04	191.90	24.00	24.00	0.00	0.00
01.10.25	1.44	48.18	194.70	40.74	188.13	24.00	24.00	0.00	0.00
02.10.25	1.41	45.19	206.36	38.37	200.17	24.00	24.00	0.00	0.00
03.10.25	1.53	47.67	210.60	40.37	204.54	24.00	24.00	0.00	0.00
04.10.25	1.59	48.78	212.77	41.28	206.89	24.00	24.00	0.00	0.00
05.10.25	1.76	50.75	219.46	42.72	213.56	24.00	24.00	0.00	0.00
06.10.25	1.69	50.13	222.07	42.50	216.35	24.00	24.00	0.00	0.00
07.10.25	1.59	48.25	227.81	41.25	222.07	24.00	24.00	0.00	0.00
08.10.25	1.47	47.14	226.74	40.66	221.16	24.00	24.00	0.00	0.00
09.10.25	1.38	46.23	224.55	40.07	218.70	24.00	24.00	0.00	0.00
10.10.25	1.36	45.78	223.81	39.71	218.15	24.00	24.00	0.00	0.00
11.10.25	1.36	45.86	225.93	39.83	220.20	24.00	24.00	0.00	0.00
12.10.25	1.38	45.85	227.47	39.76	221.98	24.00	24.00	0.00	0.00
13.10.25	1.42	45.67	227.34	39.43	221.32	24.00	24.00	0.00	0.00
14.10.25	1.42	45.19	226.27	38.89	220.36	24.00	24.00	0.00	0.00
15.10.25	1.57	47.43	233.00	40.68	227.43	24.00	24.00	0.00	0.00
16.10.25	1.68	48.58	236.23	41.46	230.18	24.00	24.00	0.00	0.00
17.10.25	1.82	50.04	241.57	42.49	235.40	24.00	24.00	0.00	0.00
18.10.25	1.85	50.37	242.50	42.72	236.22	24.00	24.00	0.00	0.00
19.10.25	1.79	49.44	238.69	41.92	232.68	24.00	24.00	0.00	0.00
20.10.25	1.69	48.57	236.34	41.41	230.70	24.00	24.00	0.00	0.00
Итого	35.36	---	5463.47	---	5311.15	587.26	768.00	0.00	0.00
Среднее	---	40.058	---	35.368	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	6486.65	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 39
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВА787

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	19.46	0.00	19.88	361.00	5.26	24.00	0.00	0.00
20.09.25	0.00	19.51	0.00	19.91	358.26	4.36	24.00	0.00	0.00
21.09.25	0.00	19.99	0.00	20.06	331.08	6.02	24.00	0.00	0.00
22.09.25	0.00	20.14	0.00	20.10	326.95	12.38	24.00	0.00	0.00
23.09.25	0.00	20.50	0.00	20.49	324.50	11.40	24.00	0.00	0.00
24.09.25	0.00	21.33	0.00	21.14	328.82	13.39	24.00	0.00	0.00
25.09.25	0.00	22.29	0.00	22.03	334.47	22.16	24.00	0.00	0.00
26.09.25	0.12	25.60	104.02	25.28	155.30	12.32	24.00	0.00	0.00
27.09.25	0.34	33.18	162.40	31.04	0.00	24.00	24.00	0.00	0.00
28.09.25	0.63	36.69	178.52	33.15	0.00	24.00	24.00	0.00	0.00
29.09.25	1.15	47.38	186.03	41.20	0.00	24.00	24.00	0.00	0.00
30.09.25	1.10	45.50	183.44	39.58	0.00	24.00	24.00	0.00	0.00
01.10.25	1.43	47.89	198.40	40.62	82.85	24.00	24.00	0.00	0.00
02.10.25	1.44	45.37	213.00	38.62	209.47	24.00	24.00	0.00	0.00
03.10.25	1.58	47.72	220.73	40.57	218.61	24.00	24.00	0.00	0.00
04.10.25	1.61	48.87	225.03	41.71	222.81	24.00	24.00	0.00	0.00
05.10.25	1.74	50.79	228.87	43.16	225.86	24.00	24.00	0.00	0.00
06.10.25	1.66	49.99	230.48	42.78	227.42	24.00	24.00	0.00	0.00
07.10.25	1.55	48.31	235.38	41.73	232.43	24.00	24.00	0.00	0.00
08.10.25	1.44	47.11	234.08	40.97	231.51	24.00	24.00	0.00	0.00
09.10.25	1.36	46.23	231.67	40.36	228.97	24.00	24.00	0.00	0.00
10.10.25	1.33	45.81	231.24	40.04	228.44	24.00	24.00	0.00	0.00
11.10.25	1.33	45.92	231.09	40.16	228.49	24.00	24.00	0.00	0.00
12.10.25	1.33	45.90	231.00	40.11	228.05	24.00	24.00	0.00	0.00
13.10.25	1.37	45.64	230.92	39.70	226.98	24.00	24.00	0.00	0.00
14.10.25	1.38	45.20	229.41	39.16	226.07	24.00	24.00	0.00	0.00
15.10.25	1.55	47.53	236.73	40.98	233.81	24.00	24.00	0.00	0.00
16.10.25	1.65	48.69	240.21	41.81	237.33	24.00	24.00	0.00	0.00
17.10.25	1.77	50.07	245.53	42.83	242.17	24.00	24.00	0.00	0.00
18.10.25	1.80	50.36	246.29	43.04	242.61	24.00	24.00	0.00	0.00
19.10.25	1.73	49.48	242.11	42.31	238.95	24.00	24.00	0.00	0.00
20.10.25	1.63	48.52	239.60	41.70	236.67	24.00	24.00	0.00	0.00
Итого	34.02	---	5436.18	---	6969.88	663.29	768.00	0.00	0.00
Среднее	---	40.218	---	35.507	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	6216.96	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 4
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВА766

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	0.00	21.79	0.00	20.93	0.00	24.00	24.00	0.00	0.00
25.09.25	0.47	22.26	360.40	21.15	61.54	24.00	24.00	0.00	0.00
26.09.25	0.56	21.39	406.01	19.99	48.76	24.00	24.00	0.00	0.00
27.09.25	1.07	32.46	267.17	29.40	208.38	23.36	24.00	0.00	0.00
28.09.25	1.92	44.71	404.60	39.94	407.15	24.00	24.00	0.00	0.00
29.09.25	2.12	45.38	409.16	40.18	412.27	24.00	24.00	0.00	0.00
30.09.25	2.34	44.88	409.97	39.17	414.09	24.00	24.00	0.00	0.00
01.10.25	2.45	44.86	405.21	38.81	409.25	24.00	24.00	0.00	0.00
02.10.25	2.60	45.99	407.34	39.61	411.90	24.00	24.00	0.00	0.00
03.10.25	2.95	49.41	418.36	42.36	423.70	24.00	24.00	0.00	0.00
04.10.25	2.99	50.24	422.30	43.14	427.52	24.00	24.00	0.00	0.00
05.10.25	3.06	50.72	423.32	43.47	429.36	24.00	24.00	0.00	0.00
06.10.25	2.91	50.23	418.16	43.27	424.08	24.00	24.00	0.00	0.00
07.10.25	2.32	45.80	394.61	39.92	400.04	24.00	24.00	0.00	0.00
08.10.25	2.09	43.78	387.32	38.37	392.55	24.00	24.00	0.00	0.00
09.10.25	2.09	44.00	386.18	38.58	391.48	24.00	24.00	0.00	0.00
10.10.25	2.06	43.67	385.74	38.32	391.07	24.00	24.00	0.00	0.00
11.10.25	2.03	43.67	385.81	38.39	391.11	24.00	24.00	0.00	0.00
12.10.25	2.04	43.72	386.05	38.41	391.46	24.00	24.00	0.00	0.00
13.10.25	2.06	43.54	386.28	38.19	391.66	24.00	24.00	0.00	0.00
14.10.25	2.05	43.21	385.43	37.87	390.80	24.00	24.00	0.00	0.00
15.10.25	2.44	46.28	400.68	40.20	406.21	24.00	24.00	0.00	0.00
16.10.25	2.62	47.94	406.51	41.48	412.45	24.00	24.00	0.00	0.00
17.10.25	2.80	49.02	414.51	42.26	420.89	24.00	24.00	0.00	0.00
18.10.25	2.86	49.69	417.68	42.82	424.28	24.00	24.00	0.00	0.00
19.10.25	2.81	49.04	413.22	42.22	419.54	24.00	24.00	0.00	0.00
20.10.25	2.75	48.73	412.90	42.06	419.30	24.00	24.00	0.00	0.00
Итого	58.46	---	10314.92	---	9720.84	647.36	648.00	0.00	0.00
Среднее	---	43.200	---	37.797	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	11103.98	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 6
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00168974

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0х4901

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	21.70	22.05	-0.35	0.480	0.480	0.480	0.480	0.000	5.07	4.54	0.0000	0.0	24.0
20.09.25	21.76	21.91	-0.15	0.000	0.000	0.000	0.000	0.000	2.03	1.00	0.0000	0.0	24.0
21.09.25	21.86	22.07	-0.21	0.000	0.000	0.000	0.000	0.000	1.74	1.00	0.0000	0.0	24.0
22.09.25	22.00	22.15	-0.15	0.000	0.000	0.000	0.000	0.000	1.57	1.00	0.0000	0.0	24.0
23.09.25	22.17	22.35	-0.18	0.000	0.000	0.000	0.000	0.000	1.48	1.00	0.0000	0.0	24.0
24.09.25	22.42	22.54	-0.12	0.000	0.000	0.000	0.000	0.000	1.45	1.00	0.0000	0.0	24.0
25.09.25	22.25	22.38	-0.13	0.000	0.000	0.000	0.000	0.000	1.43	1.00	0.0000	0.0	24.0
26.09.25	45.46	40.01	5.45	156.760	158.970	155.220	157.790	-2.570	4.66	4.13	0.8400	0.0	24.0
27.09.25	44.82	39.10	5.72	300.730	302.270	297.890	300.110	-2.220	7.36	6.86	1.7020	0.0	24.0
28.09.25	45.48	39.37	6.11	303.540	303.690	300.600	301.500	-0.900	7.22	6.82	1.8370	0.0	24.0
29.09.25	45.02	38.59	6.43	295.860	293.630	293.050	291.600	1.450	7.17	6.80	1.8840	0.0	24.0
30.09.25	44.89	37.86	7.03	284.760	281.280	282.100	279.380	2.720	7.68	7.34	1.9790	0.0	24.0
01.10.25	46.45	38.80	7.65	288.290	284.210	285.350	282.200	3.150	7.40	7.08	2.1770	0.0	24.0
02.10.25	49.58	41.26	8.32	296.200	291.710	292.820	289.350	3.470	6.78	6.68	2.4310	0.0	24.0
03.10.25	50.33	42.03	8.30	299.160	294.580	295.600	292.180	3.420	6.55	6.62	2.4510	0.0	24.0
04.10.25	50.83	42.40	8.43	300.010	295.480	296.400	293.020	3.380	6.61	6.60	2.4910	0.0	24.0
05.10.25	50.12	42.05	8.07	295.090	291.500	291.640	289.060	2.580	6.68	6.59	2.3510	0.0	24.0
06.10.25	45.68	38.86	6.82	276.420	273.920	273.690	271.970	1.720	6.64	6.47	1.8620	0.0	24.0
07.10.25	43.91	37.52	6.39	272.080	269.480	269.680	267.780	1.900	6.67	6.46	1.7210	0.0	24.0
08.10.25	44.07	37.66	6.41	271.130	268.530	268.660	266.750	1.910	6.68	6.45	1.7190	0.0	24.0
09.10.25	43.74	37.41	6.33	270.840	268.560	268.440	266.870	1.570	6.71	6.46	1.6970	0.0	24.0
10.10.25	43.79	37.54	6.25	270.830	268.770	268.430	267.040	1.390	6.64	6.38	1.6750	0.0	24.0
11.10.25	43.84	37.60	6.24	270.900	269.040	268.500	267.300	1.200	6.70	6.44	1.6740	0.0	24.0
12.10.25	43.56	37.24	6.32	270.890	269.110	268.490	267.370	1.120	6.71	6.44	1.6960	0.0	24.0
13.10.25	43.32	37.02	6.30	270.600	268.710	268.200	267.030	1.170	6.72	6.44	1.6850	0.0	24.0
14.10.25	46.73	39.60	7.13	283.310	281.140	280.400	279.100	1.300	6.74	6.47	1.9910	0.0	24.0
15.10.25	48.09	40.58	7.51	286.720	284.410	283.600	282.250	1.350	6.74	6.46	2.1270	0.0	24.0
16.10.25	49.19	41.31	7.88	292.540	289.990	289.260	287.690	1.570	6.52	6.24	2.2760	0.0	24.0
17.10.25	49.74	41.71	8.03	294.260	291.690	290.860	289.310	1.550	6.35	6.07	2.3340	0.0	24.0
18.10.25	49.15	41.24	7.91	291.710	289.270	288.360	286.900	1.460	6.32	6.03	2.2780	0.0	24.0
19.10.25	48.76	41.08	7.68	292.000	289.480	288.770	287.200	1.570	6.34	6.04	2.2140	0.0	24.0
20.10.25	49.14	41.38	7.76	293.990	291.450	290.630	289.050	1.580	6.33	6.02	2.2500	0.0	24.0
Итого	---	---	---	7029.1	6971.3	6957.12	6920.28	36.840	---	---	49.3420	0.0	768.0
Среднее	41.24	35.77	5.47	---	---	---	---	---	5.68	5.34	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	68925.960	68313.300	67933.960	67630.670	633.9640	303.290	644.0	9587.0
20.10.25 24:00	75955.059	75284.650	74891.080	74550.949	683.3060	340.130	644.0	10355.0
Итого за период	7029.098	6971.349	6957.119	6920.278	49.3420	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 7
 Потребитель: АО "Жилуправление"
 Прибор: ТЭМ-106 Заводской номер: 3060306
 Формула: $Q = M1(h1 - h2)$
 Тип системы: Подача + расходомер

Система: 1

ТВ1

	ДУ, мм	Gmin, м3/ч	Gmax, м3/ч	Kv, л/имп	Fmax, КГц
1	80	80	160	10	---
2	80	80	160	10	---

Дата	Q, (Гкал)	M1, (т)	M2, (т)	dM, (т)	T1, (°C)	T2, (°C)	P1, (МПа)	P2, (МПа)	Время наработки, (ч)
19.09.25	0.000	0.00	0.00	0.0	24.958	23.729	0.6	0.6	24.00
20.09.25	0.000	0.00	0.00	0.0	25.103	23.856	0.6	0.6	24.00
21.09.25	0.000	0.00	0.00	0.0	25.232	23.947	0.6	0.6	24.00
22.09.25	0.000	0.00	0.00	0.0	25.539	24.310	0.6	0.6	24.00
23.09.25	0.000	0.00	0.00	0.0	25.787	24.457	0.6	0.6	24.00
24.09.25	0.000	0.00	0.00	0.0	26.236	24.795	0.6	0.6	24.00
25.09.25	0.000	0.00	0.00	0.0	25.750	24.320	0.6	0.6	24.00
26.09.25	1.022	184.17	181.41	2.8	45.550	40.009	0.6	0.6	24.00
27.09.25	1.588	268.11	265.24	2.9	44.786	38.863	0.6	0.6	24.00
28.09.25	1.709	268.49	265.74	2.7	45.452	39.087	0.6	0.6	24.00
29.09.25	1.683	257.90	255.37	2.5	44.984	38.462	0.6	0.6	24.00
30.09.25	1.699	245.46	242.99	2.5	44.859	37.940	0.6	0.6	24.00
01.10.25	1.857	246.69	244.23	2.5	46.379	38.851	0.6	0.6	24.00
02.10.25	2.109	252.02	249.48	2.5	49.538	41.171	0.6	0.6	24.00
03.10.25	2.124	254.04	251.47	2.6	50.292	41.934	0.6	0.6	24.00
04.10.25	2.159	254.49	251.88	2.6	50.797	42.317	0.6	0.6	24.00
05.10.25	2.030	250.42	247.86	2.6	50.112	42.009	0.6	0.6	24.00
06.10.25	1.622	235.63	233.54	2.1	45.671	38.789	0.6	0.6	24.00
07.10.25	1.474	231.68	230.08	1.6	43.882	37.520	0.6	0.6	24.00
08.10.25	1.474	230.90	229.63	1.3	44.048	37.664	0.6	0.6	24.00
09.10.25	1.448	230.64	229.57	1.1	43.721	37.442	0.6	0.6	24.00
10.10.25	1.440	230.51	229.56	1.0	43.763	37.516	0.6	0.6	24.00
11.10.25	1.441	230.61	229.74	0.9	43.820	37.572	0.6	0.6	24.00
12.10.25	1.437	230.55	229.71	0.8	43.541	37.307	0.6	0.6	24.00
13.10.25	1.422	230.23	229.41	0.8	43.290	37.117	0.6	0.6	24.00
14.10.25	1.714	240.94	240.07	0.9	46.676	39.564	0.6	0.6	24.00
15.10.25	1.825	243.91	243.00	0.9	48.050	40.569	0.6	0.6	24.00
16.10.25	1.946	248.72	247.77	1.0	49.154	41.331	0.6	0.6	24.00
17.10.25	1.991	249.98	248.99	1.0	49.711	41.748	0.6	0.6	24.00
18.10.25	1.942	247.83	246.82	1.0	49.121	41.287	0.6	0.6	24.00
19.10.25	1.893	248.06	247.03	1.0	48.737	41.107	0.6	0.6	24.00
20.10.25	1.936	249.80	248.73	1.1	49.112	41.365	0.6	0.6	24.00
Итого	42.98	6061.8	6019.3	42.7	---	---	---	---	768.00
Среднее	---	---	---	---	41.99	36.19	0.6	0.6	---

Показания интеграторов

Дата	Q, (Гкал)	M1, (т)	M2, (т)	Время наработки, (ч)
18.09.25 24:00	8565.9	713551.3	712617.0	76633.1
20.10.25 24:00	8608.9	719613.1	718636.3	77401.1
Итого за период	43.0	6061.8	6019.3	768.0

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 8
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ678

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	0.00	21.39	0.00	20.90	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	21.14	0.00	20.66	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	21.24	0.00	20.86	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	21.67	0.00	21.11	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	22.08	0.00	21.38	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	22.11	0.00	21.43	0.00	0.00	24.00	0.00	0.00
27.09.25	0.50	32.91	87.78	29.83	86.74	11.77	24.00	0.00	0.00
28.09.25	0.95	44.04	175.59	38.62	173.89	24.00	24.00	0.00	0.00
29.09.25	1.06	44.70	176.74	38.71	175.46	24.00	24.00	0.00	0.00
30.09.25	1.08	44.20	171.37	37.89	170.27	24.00	24.00	0.00	0.00
01.10.25	1.13	44.17	163.19	37.21	162.17	24.00	24.00	0.00	0.00
02.10.25	1.22	45.40	163.82	37.97	162.89	24.00	24.00	0.00	0.00
03.10.25	1.41	48.69	168.32	40.32	167.37	24.00	24.00	0.00	0.00
04.10.25	1.43	49.48	169.88	41.06	168.99	24.00	24.00	0.00	0.00
05.10.25	1.45	49.96	170.20	41.41	169.35	24.00	24.00	0.00	0.00
06.10.25	1.37	49.41	166.87	41.18	166.02	24.00	24.00	0.00	0.00
07.10.25	1.10	45.04	156.44	37.98	155.62	24.00	24.00	0.00	0.00
08.10.25	1.00	43.13	153.44	36.60	152.76	24.00	24.00	0.00	0.00
09.10.25	1.01	43.33	152.95	36.69	152.27	24.00	24.00	0.00	0.00
10.10.25	1.00	43.01	152.75	36.46	152.04	24.00	24.00	0.00	0.00
11.10.25	1.00	43.02	152.85	36.46	152.12	24.00	24.00	0.00	0.00
12.10.25	1.01	43.07	153.01	36.46	152.33	24.00	24.00	0.00	0.00
13.10.25	1.03	42.86	153.08	36.15	152.33	24.00	24.00	0.00	0.00
14.10.25	1.02	42.56	152.83	35.87	152.05	24.00	24.00	0.00	0.00
15.10.25	1.20	45.67	159.48	38.17	158.68	24.00	24.00	0.00	0.00
16.10.25	1.29	47.23	161.66	39.23	160.97	24.00	24.00	0.00	0.00
17.10.25	1.39	48.30	164.75	39.85	163.98	24.00	24.00	0.00	0.00
18.10.25	1.42	48.92	165.92	40.37	165.09	24.00	24.00	0.00	0.00
19.10.25	1.38	48.30	164.22	39.87	163.39	24.00	24.00	0.00	0.00
20.10.25	1.35	47.97	164.54	39.73	163.65	24.00	24.00	0.00	0.00
Итого	27.80	---	3821.68	---	3800.43	563.77	720.00	0.00	0.00
Среднее	---	40.500	---	34.681	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	2010.11	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 9
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00178915

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0x4E6C

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
27.09.25	44.77	38.40	6.37	155.800	156.770	154.360	155.690	-1.330	6.90	6.70	0.9810	0.0	24.0
28.09.25	45.44	38.58	6.86	151.890	152.020	150.450	150.990	-0.540	6.90	6.70	1.0300	0.0	24.0
29.09.25	44.97	37.75	7.22	145.910	145.470	144.540	144.540	0.000	6.90	6.70	1.0390	0.0	24.0
30.09.25	44.84	37.20	7.64	138.330	137.940	137.070	136.980	0.090	6.90	6.70	1.0450	0.0	24.0
01.10.25	46.37	38.22	8.15	139.110	139.010	137.700	138.010	-0.310	6.90	6.70	1.1200	0.0	24.0
02.10.25	49.52	40.68	8.84	142.880	143.230	141.220	142.060	-0.840	6.90	6.70	1.2460	0.0	24.0
03.10.25	50.27	41.44	8.83	143.790	144.640	142.110	143.440	-1.330	6.90	6.70	1.2530	0.0	24.0
04.10.25	50.77	41.76	9.01	143.580	144.980	141.900	143.780	-1.880	6.90	6.70	1.2770	0.0	24.0
05.10.25	50.09	41.52	8.57	141.010	142.670	139.400	141.530	-2.130	6.90	6.70	1.1930	0.0	24.0
06.10.25	45.65	38.32	7.33	132.020	133.790	130.730	132.850	-2.120	6.90	6.70	0.9560	0.0	24.0
07.10.25	43.85	37.22	6.63	127.380	129.220	126.180	128.440	-2.260	6.90	6.70	0.8350	0.0	24.0
08.10.25	44.02	37.23	6.79	127.910	129.790	126.710	128.950	-2.240	6.90	6.70	0.8560	0.0	24.0
09.10.25	43.69	37.02	6.67	126.890	128.800	125.690	128.080	-2.390	6.90	6.70	0.8380	0.0	24.0
10.10.25	43.73	37.10	6.63	127.030	128.960	125.830	128.180	-2.350	6.90	6.70	0.8310	0.0	24.0
11.10.25	43.79	37.13	6.66	127.480	129.460	126.280	128.670	-2.390	6.90	6.70	0.8350	0.0	24.0
12.10.25	43.51	36.74	6.77	127.530	129.510	126.330	128.730	-2.400	6.90	6.70	0.8550	0.0	24.0
13.10.25	43.26	36.44	6.82	127.410	129.400	126.210	128.680	-2.470	6.90	6.70	0.8600	0.0	24.0
14.10.25	46.64	38.84	7.80	133.200	135.160	131.820	134.250	-2.430	6.90	6.70	1.0300	0.0	24.0
15.10.25	48.02	39.93	8.09	134.970	136.930	133.530	135.970	-2.440	6.90	6.70	1.0770	0.0	24.0
16.10.25	49.12	40.64	8.48	137.570	139.530	135.990	138.440	-2.450	6.90	6.70	1.1500	0.0	24.0
17.10.25	49.68	41.06	8.62	138.330	140.280	136.710	139.130	-2.420	6.90	6.70	1.1760	0.0	24.0
18.10.25	49.08	40.55	8.53	137.590	139.550	136.070	138.510	-2.440	6.90	6.70	1.1580	0.0	24.0
19.10.25	48.71	40.47	8.24	138.690	140.680	137.160	139.600	-2.440	6.90	6.70	1.1280	0.0	24.0
20.10.25	49.07	40.71	8.36	137.650	139.620	136.140	138.510	-2.370	6.90	6.70	1.1380	0.0	24.0
Итого	---	---	---	3283.9	3317.4	3250.13	3294.01	-43.880	---	---	24.9070	0.0	576.0
Среднее	46.61	38.95	7.66	---	---	---	---	---	6.90	6.70	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
25.09.25 24:00	0	0	0	0	0	0	0	0
20.10.25 24:00	35628.160	36105.210	35131.170	35775.220	366.0510	-644.050	1535.0	7983.0
Итого за период	35628.160	36105.210	35131.170	35775.220	366.0510	---	1535.0	7983.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 9
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00179211

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0x4592

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	17.66	17.11	0.55	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
20.09.25	17.69	17.17	0.52	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
21.09.25	17.76	17.23	0.53	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
22.09.25	18.11	17.67	0.44	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
23.09.25	18.51	18.07	0.44	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
24.09.25	19.16	18.70	0.46	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
25.09.25	31.79	30.33	1.46	119.030	120.170	118.470	119.670	-1.200	6.90	6.70	0.1740	0.0	24.0
26.09.25	38.32	35.00	3.32	256.190	258.700	254.360	257.210	-2.850	6.90	6.70	0.8440	0.0	24.0
27.09.25	44.61	38.78	5.83	167.250	169.260	165.690	168.060	-2.370	6.90	6.70	0.9660	0.0	24.0
28.09.25	45.27	39.01	6.26	161.730	163.610	160.200	162.410	-2.210	6.90	6.70	1.0020	0.0	24.0
29.09.25	44.80	38.31	6.49	154.420	156.040	152.970	154.930	-1.960	6.90	6.70	0.9930	0.0	24.0
30.09.25	44.66	37.74	6.92	146.200	147.760	144.790	146.800	-2.010	6.90	6.70	0.9980	0.0	24.0
01.10.25	46.22	38.86	7.36	147.130	148.600	145.650	147.550	-1.900	6.90	6.70	1.0680	0.0	24.0
02.10.25	49.34	41.34	8.00	151.150	152.730	149.470	151.530	-2.060	6.90	6.70	1.1920	0.0	24.0
03.10.25	50.09	42.10	7.99	152.120	153.840	150.390	152.640	-2.250	6.90	6.70	1.2000	0.0	24.0
04.10.25	50.59	42.45	8.14	151.970	153.840	150.130	152.580	-2.450	6.90	6.70	1.2180	0.0	24.0
05.10.25	49.89	42.11	7.78	149.570	151.540	147.790	150.250	-2.460	6.90	6.70	1.1490	0.0	24.0
06.10.25	45.46	38.81	6.65	139.980	142.010	138.690	140.970	-2.280	6.90	6.70	0.9210	0.0	24.0
07.10.25	43.67	37.39	6.28	127.540	129.140	126.400	128.250	-1.850	6.90	6.70	0.7920	0.0	24.0
08.10.25	43.85	37.82	6.03	132.880	133.350	131.680	132.390	-0.710	6.90	6.70	0.7920	0.0	24.0
09.10.25	43.53	37.43	6.10	137.100	137.570	135.900	136.610	-0.710	6.90	6.70	0.8270	0.0	24.0
10.10.25	43.57	37.55	6.02	137.500	138.110	136.300	137.150	-0.850	6.90	6.70	0.8200	0.0	24.0
11.10.25	43.63	37.56	6.07	137.560	138.310	136.360	137.350	-0.990	6.90	6.70	0.8270	0.0	24.0
12.10.25	43.34	37.14	6.20	137.500	138.390	136.300	137.430	-1.130	6.90	6.70	0.8460	0.0	24.0
13.10.25	43.10	36.85	6.25	137.360	138.330	136.160	137.370	-1.210	6.90	6.70	0.8510	0.0	24.0
14.10.25	46.49	39.31	7.18	143.650	144.690	142.220	143.590	-1.370	6.90	6.70	1.0170	0.0	24.0
15.10.25	47.85	40.36	7.49	145.400	146.460	143.850	145.260	-1.410	6.90	6.70	1.0750	0.0	24.0
16.10.25	48.95	41.11	7.84	148.220	149.320	146.560	148.120	-1.560	6.90	6.70	1.1460	0.0	24.0
17.10.25	49.50	41.53	7.97	148.870	149.970	147.190	148.770	-1.580	6.90	6.70	1.1720	0.0	24.0
18.10.25	48.91	41.09	7.82	148.080	149.230	146.400	148.030	-1.630	6.90	6.70	1.1440	0.0	24.0
19.10.25	48.53	40.97	7.56	149.210	150.380	147.530	149.180	-1.650	6.90	6.70	1.1110	0.0	24.0
20.10.25	48.90	41.23	7.67	148.130	149.260	146.450	148.060	-1.610	6.90	6.70	1.1240	0.0	24.0
Итого	---	---	---	3875.7	3910.6	3837.90	3882.16	-44.260	---	---	25.2690	0.0	768.0
Среднее	40.42	34.94	5.48	---	---	---	---	---	6.90	6.70	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	33953.290	34098.590	33469.220	33765.870	329.5250	-296.650	2111.0	8056.0
20.10.25 24:00	37829.030	38009.200	37307.120	37648.030	354.7940	-340.910	2111.0	8824.0
Итого за период	3875.739	3910.610	3837.900	3882.159	25.2690	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 9а
 Потребитель: АО "Жилуправление"
 Прибор: ИМ2300 Заводской номер: BA849

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	19.55	0.00	19.73	0.11	0.00	24.00	0.00	0.00
20.09.25	0.00	19.64	0.00	19.78	0.21	0.00	24.00	0.00	0.00
21.09.25	0.00	19.66	0.00	19.85	0.32	0.00	24.00	0.00	0.00
22.09.25	0.00	19.79	0.00	19.95	0.19	0.00	24.00	0.00	0.00
23.09.25	0.00	20.15	0.00	20.35	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	20.63	0.00	20.77	0.00	6.33	24.00	0.00	0.00
25.09.25	0.00	21.82	0.00	21.83	0.00	10.19	24.00	0.00	0.00
26.09.25	0.00	20.94	0.00	20.90	0.04	23.54	24.00	0.00	0.00
27.09.25	0.30	27.22	50.56	25.53	50.29	21.05	24.00	0.00	0.00
28.09.25	0.88	44.78	182.12	39.91	182.06	24.00	24.00	0.00	0.00
29.09.25	0.93	45.45	180.43	40.29	180.29	24.00	24.00	0.00	0.00
30.09.25	0.91	44.94	170.75	39.58	170.69	24.00	24.00	0.00	0.00
01.10.25	0.91	44.92	161.76	39.29	161.77	24.00	24.00	0.00	0.00
02.10.25	0.96	46.10	162.12	40.18	162.18	24.00	24.00	0.00	0.00
03.10.25	1.07	49.48	166.37	43.01	166.32	24.00	24.00	0.00	0.00
04.10.25	1.08	50.30	167.27	43.85	167.17	24.00	24.00	0.00	0.00
05.10.25	1.10	50.78	167.07	44.20	166.85	24.00	24.00	0.00	0.00
06.10.25	1.04	50.27	164.88	43.93	164.55	24.00	24.00	0.00	0.00
07.10.25	0.82	45.84	154.77	40.55	154.62	24.00	24.00	0.00	0.00
08.10.25	0.74	43.87	151.67	39.00	151.54	24.00	24.00	0.00	0.00
09.10.25	0.73	44.08	150.29	39.21	150.00	24.00	24.00	0.00	0.00
10.10.25	0.72	43.76	149.92	38.91	149.75	24.00	24.00	0.00	0.00
11.10.25	0.71	43.76	149.61	39.00	149.38	24.00	24.00	0.00	0.00
12.10.25	0.73	43.81	149.64	38.94	149.47	24.00	24.00	0.00	0.00
13.10.25	0.74	43.61	149.63	38.64	149.57	24.00	24.00	0.00	0.00
14.10.25	0.73	43.29	149.41	38.39	149.42	24.00	24.00	0.00	0.00
15.10.25	0.87	46.39	155.61	40.83	155.62	24.00	24.00	0.00	0.00
16.10.25	0.93	48.01	157.87	42.12	157.85	24.00	24.00	0.00	0.00
17.10.25	1.00	49.09	160.71	42.87	160.73	24.00	24.00	0.00	0.00
18.10.25	1.02	49.74	161.78	43.42	161.81	24.00	24.00	0.00	0.00
19.10.25	0.99	49.10	160.54	42.90	160.58	24.00	24.00	0.00	0.00
20.10.25	0.98	48.78	162.57	42.73	162.58	24.00	24.00	0.00	0.00
Итого	20.89	---	3737.35	---	3735.96	613.11	768.00	0.00	0.00
Среднее	---	39.361	---	35.326	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	3854.18	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 9а
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BA850

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	19.60	0.00	19.56	0.00	16.43	24.00	0.00	0.00
20.09.25	0.00	19.67	0.00	19.74	0.00	8.47	24.00	0.00	0.00
21.09.25	0.00	19.67	0.00	19.75	0.00	7.55	24.00	0.00	0.00
22.09.25	0.00	19.80	0.00	19.80	0.00	13.31	24.00	0.00	0.00
23.09.25	0.00	20.21	0.00	20.39	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	21.00	0.00	21.02	0.00	10.21	24.00	0.00	0.00
25.09.25	0.00	22.17	0.00	22.14	0.00	11.15	24.00	0.00	0.00
26.09.25	0.00	20.93	0.00	20.57	0.00	24.00	24.00	0.00	0.00
27.09.25	0.24	27.67	43.40	25.23	45.39	23.52	24.00	0.00	0.00
28.09.25	0.68	44.76	139.82	39.92	145.47	24.00	24.00	0.00	0.00
29.09.25	0.80	45.43	152.60	40.18	158.77	24.00	24.00	0.00	0.00
30.09.25	0.88	44.93	154.70	39.20	160.95	24.00	24.00	0.00	0.00
01.10.25	0.95	44.88	161.02	38.95	167.76	24.00	24.00	0.00	0.00
02.10.25	1.01	46.20	161.72	39.95	168.44	24.00	24.00	0.00	0.00
03.10.25	1.14	49.49	165.70	42.61	172.43	24.00	24.00	0.00	0.00
04.10.25	1.13	50.28	166.33	43.48	172.84	24.00	24.00	0.00	0.00
05.10.25	1.15	50.77	165.83	43.84	172.45	24.00	24.00	0.00	0.00
06.10.25	1.08	50.17	163.31	43.56	169.64	24.00	24.00	0.00	0.00
07.10.25	0.86	45.74	153.67	40.16	159.61	24.00	24.00	0.00	0.00
08.10.25	0.78	43.86	150.78	38.71	156.54	24.00	24.00	0.00	0.00
09.10.25	0.77	44.06	149.36	38.91	155.03	24.00	24.00	0.00	0.00
10.10.25	0.76	43.73	149.09	38.62	154.81	24.00	24.00	0.00	0.00
11.10.25	0.75	43.75	148.78	38.71	154.28	24.00	24.00	0.00	0.00
12.10.25	0.75	43.80	148.88	38.73	154.40	24.00	24.00	0.00	0.00
13.10.25	0.77	43.56	149.13	38.41	154.98	24.00	24.00	0.00	0.00
14.10.25	0.37	43.28	69.88	38.11	154.77	24.00	24.00	0.00	0.00
15.10.25	0.00	46.46	0.00	40.51	161.40	24.00	24.00	0.00	0.00
16.10.25	0.00	48.01	0.00	41.75	163.36	24.00	24.00	0.00	0.00
17.10.25	0.00	49.10	0.00	42.46	166.51	24.00	24.00	0.00	0.00
18.10.25	0.00	49.70	0.00	42.92	167.54	24.00	24.00	0.00	0.00
19.10.25	0.00	49.09	0.13	42.38	166.64	24.00	24.00	0.00	0.00
20.10.25	0.00	48.74	0.00	42.28	168.15	24.00	24.00	0.00	0.00
Итого	14.87	---	2594.13	---	3772.16	666.64	768.00	0.00	0.00
Среднее	---	39.391	---	35.080	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	4406.62	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 9а
 Потребитель: АО "Жилуправление"
 Прибор: ИМ2300 Заводской номер: BA859

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	0.00	20.62	0.00	21.01	0.01	0.00	24.00	0.00	0.00
21.09.25	0.00	20.70	0.00	21.15	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	20.85	0.00	21.19	0.00	3.56	24.00	0.00	0.00
23.09.25	0.00	21.14	0.00	21.49	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	22.03	0.20	22.06	0.00	10.47	24.00	0.00	0.00
25.09.25	0.00	23.08	0.62	22.92	0.00	15.49	24.00	0.00	0.00
26.09.25	0.00	21.59	0.96	21.39	0.00	20.57	24.00	0.00	0.00
27.09.25	0.27	28.57	48.70	26.61	27.48	14.06	24.00	0.00	0.00
28.09.25	0.77	44.87	151.86	39.82	114.58	24.00	24.00	0.00	0.00
29.09.25	0.82	45.54	153.34	40.18	152.10	24.00	24.00	0.00	0.00
30.09.25	1.01	45.04	176.47	39.34	175.45	24.00	24.00	0.00	0.00
01.10.25	1.01	44.99	170.05	39.02	168.79	24.00	24.00	0.00	0.00
02.10.25	1.07	46.29	170.31	40.02	169.33	24.00	24.00	0.00	0.00
03.10.25	1.20	49.60	174.43	42.71	173.64	24.00	24.00	0.00	0.00
04.10.25	1.20	50.39	175.33	43.54	174.69	24.00	24.00	0.00	0.00
05.10.25	1.22	50.88	174.93	43.88	174.40	24.00	24.00	0.00	0.00
06.10.25	1.16	50.29	172.41	43.56	172.03	24.00	24.00	0.00	0.00
07.10.25	0.92	45.86	158.63	40.04	158.33	24.00	24.00	0.00	0.00
08.10.25	0.83	43.98	153.03	38.54	152.72	24.00	24.00	0.00	0.00
09.10.25	0.82	44.18	150.54	38.74	150.27	24.00	24.00	0.00	0.00
10.10.25	0.80	43.85	150.17	38.48	149.93	24.00	24.00	0.00	0.00
11.10.25	0.79	43.87	149.83	38.57	149.58	24.00	24.00	0.00	0.00
12.10.25	0.80	43.92	149.91	38.55	149.69	24.00	24.00	0.00	0.00
13.10.25	0.82	43.69	149.86	38.18	149.71	24.00	24.00	0.00	0.00
14.10.25	0.82	43.40	149.68	37.90	149.58	24.00	24.00	0.00	0.00
15.10.25	0.97	46.58	156.18	40.36	156.11	24.00	24.00	0.00	0.00
16.10.25	1.03	48.14	158.34	41.59	158.15	24.00	24.00	0.00	0.00
17.10.25	1.11	49.22	161.42	42.36	160.92	24.00	24.00	0.00	0.00
18.10.25	1.13	49.84	162.44	42.85	162.14	24.00	24.00	0.00	0.00
19.10.25	1.12	49.21	161.41	42.27	161.27	24.00	24.00	0.00	0.00
20.10.25	1.09	48.87	163.19	42.20	162.95	24.00	24.00	0.00	0.00
Итого	22.78	---	3744.24	---	3673.85	616.15	744.00	0.00	0.00
Среднее	---	40.357	---	35.823	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	4309.97	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 9а
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BA868

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	18.58	0.00	18.39	0.04	22.16	24.00	0.00	0.00
20.09.25	0.00	18.70	0.00	18.43	0.01	24.00	24.00	0.00	0.00
21.09.25	0.00	18.83	0.00	18.63	0.01	22.97	24.00	0.00	0.00
22.09.25	0.00	19.06	0.00	18.77	0.00	23.88	24.00	0.00	0.00
23.09.25	0.00	19.52	0.00	19.43	0.00	19.78	24.00	0.00	0.00
24.09.25	0.00	20.30	0.00	20.09	0.00	21.96	24.00	0.00	0.00
25.09.25	0.00	22.00	0.00	21.69	0.00	24.00	24.00	0.00	0.00
26.09.25	0.00	20.14	0.00	19.39	0.01	24.00	24.00	0.00	0.00
27.09.25	0.36	25.86	56.76	23.04	57.15	23.57	24.00	0.00	0.00
28.09.25	0.97	44.61	181.91	39.27	183.92	24.00	24.00	0.00	0.00
29.09.25	1.01	45.27	179.50	39.64	181.42	24.00	24.00	0.00	0.00
30.09.25	1.01	44.76	173.94	38.97	175.75	24.00	24.00	0.00	0.00
01.10.25	1.01	44.71	166.36	38.64	168.12	24.00	24.00	0.00	0.00
02.10.25	1.07	46.04	166.95	39.65	169.08	24.00	24.00	0.00	0.00
03.10.25	1.20	49.33	171.30	42.32	173.46	24.00	24.00	0.00	0.00
04.10.25	1.19	50.11	168.39	43.03	170.70	24.00	24.00	0.00	0.00
05.10.25	1.19	50.61	161.50	43.20	163.56	24.00	24.00	0.00	0.00
06.10.25	1.13	50.00	158.96	42.90	159.82	24.00	24.00	0.00	0.00
07.10.25	0.89	45.57	149.60	39.61	149.55	24.00	24.00	0.00	0.00
08.10.25	0.80	43.70	146.83	38.21	148.91	24.00	24.00	0.00	0.00
09.10.25	0.80	43.89	145.66	38.41	147.41	24.00	24.00	0.00	0.00
10.10.25	0.79	43.56	145.64	38.15	147.77	24.00	24.00	0.00	0.00
11.10.25	0.77	43.59	145.31	38.25	147.50	24.00	24.00	0.00	0.00
12.10.25	0.78	43.63	145.47	38.25	147.58	24.00	24.00	0.00	0.00
13.10.25	0.81	43.40	145.69	37.83	147.37	24.00	24.00	0.00	0.00
14.10.25	0.81	43.11	145.62	37.51	147.22	24.00	24.00	0.00	0.00
15.10.25	0.98	46.31	151.65	39.89	153.47	24.00	24.00	0.00	0.00
16.10.25	1.03	47.85	153.36	41.14	155.22	24.00	24.00	0.00	0.00
17.10.25	1.10	48.93	156.09	41.89	157.93	24.00	24.00	0.00	0.00
18.10.25	1.12	49.54	157.26	42.39	159.18	24.00	24.00	0.00	0.00
19.10.25	1.11	48.92	156.36	41.79	157.87	24.00	24.00	0.00	0.00
20.10.25	1.09	48.57	157.89	41.64	159.50	24.00	24.00	0.00	0.00
Итого	23.02	---	3688.00	---	3729.53	758.32	768.00	0.00	0.00
Среднее	---	39.031	---	34.389	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	4217.29	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, 35 мкр. (Шашина), 9а
 Потребитель: АО "Жилуправление"
 Прибор: ИМ2300 Заводской номер: BA869

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	20.90	0.00	21.72	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	21.44	0.00	22.30	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	21.26	0.00	22.06	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	21.19	0.00	21.98	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	21.69	0.00	22.64	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	22.31	0.00	23.19	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	23.51	0.00	24.37	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	22.24	0.00	22.83	0.00	0.00	24.00	0.00	0.00
27.09.25	0.29	25.33	48.68	24.62	49.22	6.27	24.00	0.00	0.00
28.09.25	0.97	44.86	206.94	40.15	209.74	24.00	24.00	0.00	0.00
29.09.25	1.02	45.53	205.78	40.55	208.38	24.00	24.00	0.00	0.00
30.09.25	1.02	45.05	199.76	39.96	202.11	24.00	24.00	0.00	0.00
01.10.25	1.04	45.00	190.38	39.55	192.49	24.00	24.00	0.00	0.00
02.10.25	1.10	45.94	191.09	40.20	193.05	24.00	24.00	0.00	0.00
03.10.25	1.24	49.48	196.56	43.16	198.52	24.00	24.00	0.00	0.00
04.10.25	1.26	50.38	198.33	44.03	200.07	24.00	24.00	0.00	0.00
05.10.25	1.28	50.82	198.10	44.36	199.78	24.00	24.00	0.00	0.00
06.10.25	1.22	50.50	196.26	44.27	197.72	24.00	24.00	0.00	0.00
07.10.25	0.97	46.09	184.26	40.82	185.70	24.00	24.00	0.00	0.00
08.10.25	0.85	43.93	179.16	39.15	180.57	24.00	24.00	0.00	0.00
09.10.25	0.85	44.17	174.84	39.32	176.17	24.00	24.00	0.00	0.00
10.10.25	0.83	43.85	174.22	39.06	175.48	24.00	24.00	0.00	0.00
11.10.25	0.82	43.83	173.12	39.07	174.24	24.00	24.00	0.00	0.00
12.10.25	0.82	43.87	173.31	39.11	174.30	24.00	24.00	0.00	0.00
13.10.25	0.84	43.75	173.14	38.86	174.40	24.00	24.00	0.00	0.00
14.10.25	0.85	43.37	172.73	38.46	174.14	24.00	24.00	0.00	0.00
15.10.25	0.99	46.26	179.66	40.76	180.93	24.00	24.00	0.00	0.00
16.10.25	1.05	48.06	182.46	42.28	183.65	24.00	24.00	0.00	0.00
17.10.25	1.13	49.11	185.65	43.02	186.91	24.00	24.00	0.00	0.00
18.10.25	1.17	49.85	187.33	43.60	188.59	24.00	24.00	0.00	0.00
19.10.25	1.15	49.16	185.44	42.96	186.70	24.00	24.00	0.00	0.00
20.10.25	1.12	48.91	188.28	42.96	189.54	24.00	24.00	0.00	0.00
Итого	23.88	---	4345.48	---	4382.40	558.27	768.00	0.00	0.00
Среднее	---	39.739	---	35.980	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	4539.08	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Академика Королева, 10а
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00166936

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0x4FB5

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
28.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
29.09.25	49.11	39.79	9.32	106.550	105.200	105.380	104.410	0.970	5.55	1.13	0.9900	0.0	24.0
30.09.25	48.17	37.69	10.48	89.590	88.300	88.630	87.710	0.920	5.76	1.10	0.9350	0.0	24.0
01.10.25	46.74	36.06	10.68	77.440	76.400	76.660	76.000	0.660	6.35	1.10	0.8230	0.0	24.0
02.10.25	44.89	32.56	12.33	56.180	54.760	55.700	54.520	1.180	6.79	1.06	0.6890	0.0	24.0
03.10.25	44.83	33.50	11.33	65.370	63.440	64.810	63.130	1.680	6.75	1.12	0.7400	0.0	24.0
04.10.25	42.92	33.68	9.24	81.900	80.730	81.180	80.250	0.930	6.57	1.13	0.7540	0.0	24.0
05.10.25	42.56	33.44	9.12	80.040	78.920	79.320	78.440	0.880	6.58	1.13	0.7330	0.0	24.0
06.10.25	43.68	32.87	10.81	65.630	64.580	65.070	64.270	0.800	6.70	1.13	0.7090	0.0	24.0
07.10.25	44.41	34.02	10.39	72.500	71.410	71.870	71.080	0.790	6.51	1.22	0.7510	0.0	24.0
08.10.25	43.38	34.75	8.63	87.060	85.750	86.340	85.270	1.070	6.19	1.21	0.7520	0.0	24.0
09.10.25	43.64	34.90	8.74	86.690	85.470	85.970	84.990	0.980	6.27	1.22	0.7580	0.0	24.0
10.10.25	43.77	34.78	8.99	81.850	80.660	81.130	80.180	0.950	6.38	1.22	0.7360	0.0	24.0
11.10.25	43.53	34.67	8.86	81.640	80.460	80.920	79.980	0.940	6.38	1.21	0.7270	0.0	24.0
12.10.25	43.08	34.23	8.85	81.480	80.300	80.760	79.820	0.940	6.29	1.19	0.7220	0.0	24.0
13.10.25	43.36	34.30	9.06	81.520	80.320	80.800	79.840	0.960	6.28	1.77	0.7370	0.0	24.0
14.10.25	44.38	34.99	9.39	82.860	81.640	82.080	81.160	0.920	6.21	3.42	0.7730	0.0	24.0
15.10.25	47.82	37.05	10.77	84.970	83.660	84.070	83.180	0.890	6.00	5.75	0.9020	0.0	24.0
16.10.25	45.53	35.44	10.09	83.510	82.210	82.710	81.730	0.980	6.23	3.39	0.8380	0.0	24.0
17.10.25	47.09	36.37	10.72	84.750	83.380	83.790	82.900	0.890	6.30	5.30	0.8930	0.0	24.0
18.10.25	46.68	36.03	10.65	84.420	83.090	83.460	82.610	0.850	6.04	4.79	0.8910	0.0	24.0
19.10.25	46.97	36.21	10.76	84.490	83.140	83.530	82.660	0.870	6.21	5.80	0.9010	0.0	24.0
20.10.25	46.77	36.18	10.59	84.560	83.190	83.640	82.710	0.930	6.26	5.36	0.8860	0.0	24.0
Итого	---	---	---	1785.0	1757.0	1767.82	1746.84	20.980	---	---	17.6400	0.0	528.0
Среднее	45.15	35.15	9.99	---	---	---	---	---	6.30	2.35	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
27.09.25 24:00	0	0	0	0	0	0	0	0
20.10.25 24:00	44488.750	44109.460	43900.939	43682.700	338.3550	218.240	1364.0	10213.0
Итого за период	44488.750	44109.460	43900.939	43682.700	338.3550	---	1364.0	10213.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Академика Королева, 17
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00178584

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0х45В7

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	22.31	24.74	-2.43	12.880	0.000	12.880	0.000	12.880	1.00	1.05	0.0000	0.0	24.0
20.09.25	22.32	24.70	-2.38	13.570	0.000	13.570	0.000	13.570	1.00	1.05	0.0000	0.0	24.0
21.09.25	22.30	24.64	-2.34	17.590	0.000	17.590	0.000	17.590	1.00	1.06	0.0000	0.0	24.0
22.09.25	22.90	25.24	-2.34	21.050	0.000	21.050	0.000	21.050	1.00	1.06	0.0000	0.0	24.0
23.09.25	23.53	25.81	-2.28	23.870	0.000	23.870	0.000	23.870	1.00	1.06	0.0000	0.0	24.0
24.09.25	23.60	25.93	-2.33	31.960	0.000	31.960	0.000	31.960	1.00	1.07	0.0000	0.0	24.0
25.09.25	28.27	27.83	0.44	176.680	165.320	176.050	164.710	11.340	1.00	1.06	0.1490	0.0	24.0
26.09.25	39.21	36.08	3.13	380.330	436.500	377.340	433.620	-56.280	1.00	1.09	1.3600	0.0	24.0
27.09.25	47.87	42.46	5.41	364.810	452.160	360.820	448.240	-87.420	1.00	1.14	1.9490	0.0	24.0
28.09.25	48.25	42.56	5.69	391.210	495.130	386.860	490.830	-103.970	1.01	1.15	2.1960	0.0	24.0
29.09.25	46.45	40.85	5.60	395.200	501.900	391.090	497.860	-106.770	1.04	1.14	2.1850	0.0	24.0
30.09.25	57.37	49.55	7.82	474.580	595.560	467.140	588.480	-121.340	1.05	1.20	3.6450	0.0	24.0
01.10.25	65.96	57.47	8.49	639.680	770.360	626.940	758.440	-131.500	1.06	1.29	5.2860	0.0	24.0
02.10.25	66.60	58.57	8.03	690.730	802.270	676.720	789.420	-112.700	1.08	1.31	5.4290	0.0	24.0
03.10.25	58.80	52.01	6.79	556.370	630.780	547.230	622.560	-75.330	1.09	1.25	3.7720	0.0	24.0
04.10.25	51.15	44.26	6.89	459.280	509.020	453.540	504.220	-50.680	1.09	1.21	3.1180	0.0	24.0
05.10.25	50.54	43.86	6.68	461.860	506.960	456.260	502.250	-45.990	1.09	1.21	3.0400	0.0	24.0
06.10.25	48.28	42.20	6.08	439.840	493.590	434.970	489.370	-54.400	1.09	1.21	2.6410	0.0	24.0
07.10.25	46.34	40.78	5.56	434.610	482.680	430.140	478.800	-48.660	1.09	1.20	2.3850	0.0	24.0
08.10.25	45.39	40.04	5.35	422.610	474.900	418.450	471.220	-52.770	1.08	1.20	2.2370	0.0	24.0
09.10.25	46.29	40.60	5.69	416.960	476.510	412.660	472.730	-60.070	1.08	1.20	2.3440	0.0	24.0
10.10.25	46.49	40.85	5.64	420.810	478.230	416.440	474.390	-57.950	1.08	1.21	2.3440	0.0	24.0
11.10.25	47.11	40.85	6.26	387.610	436.710	383.520	433.200	-49.680	1.08	1.22	2.3940	0.0	24.0
12.10.25	45.83	40.20	5.63	434.690	478.560	430.290	474.800	-44.510	1.08	1.22	2.4110	0.0	24.0
13.10.25	46.06	40.27	5.79	427.660	477.670	423.320	473.920	-50.600	1.07	1.21	2.4430	0.0	24.0
14.10.25	47.27	41.26	6.01	450.990	484.930	446.140	480.930	-34.790	1.07	1.21	2.6770	0.0	24.0
15.10.25	50.67	43.38	7.29	425.540	465.830	420.360	461.620	-41.260	1.06	1.22	3.0590	0.0	24.0
16.10.25	51.24	43.75	7.49	440.540	473.550	435.030	469.180	-34.150	1.07	1.23	3.2520	0.0	24.0
17.10.25	51.30	44.14	7.16	460.100	503.600	454.390	498.870	-44.480	1.07	1.23	3.2430	0.0	24.0
18.10.25	50.98	43.82	7.16	446.490	499.360	440.970	494.790	-53.820	1.07	1.23	3.1490	0.0	24.0
19.10.25	51.30	44.06	7.24	439.250	498.120	433.740	493.520	-59.780	1.07	1.23	3.1300	0.0	24.0
20.10.25	50.97	43.88	7.09	439.620	498.540	434.180	493.890	-59.710	1.07	1.23	3.0740	0.0	24.0
Итого	---	---	---	11598.9	13088.7	11455.51	12961.86	-1506.350	---	---	72.9120	0.0	768.0
Среднее	44.46	39.89	4.57	---	---	---	---	---	1.05	1.18	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	104252.640	108809.010	102539.250	107564.510	1012.3360	-5025.260	3169.0	7641.0
20.10.25 24:00	115851.610	121897.749	113994.760	120526.369	1085.2480	-6531.610	3169.0	8409.0
Итого за период	11598.970	13088.739	11455.509	12961.859	72.9120	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Аксакова, 3
 Потребитель: АО "Жилуправление"
 Прибор: ТЭМ-106 Заводской номер: 3060469
 Формула: $Q = M1(h1 - h2)$
 Тип системы: Подача + расходомер

Система: 1

ТВ1

	ДУ, мм	Gmin, м3/ч	Gmax, м3/ч	Kv, л/имп	Fmax, КГц
1	50	3.25	78	10	---
2	50	2.85	66.39999999	10	---

Дата	Q, (Гкал)	M1, (т)	M2, (т)	dM, (т)	T1, (°C)	T2, (°C)	P1, (МПа)	P2, (МПа)	Время наработки, (ч)
19.09.25	0.456	76.68	76.87	-0.2	64.906	58.963	0.5	0.5	24.00
20.09.25	0.422	76.66	76.84	-0.2	65.057	59.553	0.5	0.5	23.99
21.09.25	0.486	76.23	76.32	-0.1	65.643	59.267	0.5	0.5	23.90
22.09.25	0.445	85.63	85.72	-0.1	65.115	59.921	0.5	0.5	24.00
23.09.25	0.434	81.55	81.60	-0.1	64.793	59.478	0.5	0.5	24.00
24.09.25	0.448	129.62	130.10	-0.5	65.227	61.776	0.5	0.5	24.00
25.09.25	0.445	177.19	178.14	-1.0	65.270	62.770	0.5	0.5	24.00
26.09.25	1.544	353.20	355.35	-2.1	65.094	60.725	0.5	0.5	24.00
27.09.25	2.150	440.84	445.29	-4.4	64.231	59.362	0.5	0.5	24.00
28.09.25	2.215	437.54	441.69	-4.2	66.610	61.551	0.5	0.5	24.00
29.09.25	2.160	425.24	429.13	-3.9	65.879	60.803	0.5	0.5	23.99
30.09.25	2.145	409.48	413.00	-3.5	65.366	60.131	0.5	0.5	24.00
01.10.25	2.153	426.95	430.79	-3.8	65.436	60.398	0.5	0.5	23.99
02.10.25	2.176	441.44	445.44	-4.0	66.143	61.217	0.5	0.5	24.00
03.10.25	2.197	465.99	470.29	-4.3	67.335	62.623	0.5	0.5	24.00
04.10.25	2.223	474.65	479.34	-4.7	67.498	62.822	0.5	0.5	23.94
05.10.25	2.134	474.55	479.29	-4.7	66.443	61.948	0.5	0.5	24.00
06.10.25	0.735	167.83	169.49	-1.7	66.267	61.894	0.5	0.5	8.51
07.10.25	2.043	451.92	456.38	-4.5	66.809	62.294	0.5	0.5	22.92
08.10.25	2.008	462.77	467.33	-4.6	66.484	62.150	0.5	0.5	23.43
09.10.25	2.112	482.03	486.80	-4.8	66.744	62.368	0.5	0.5	24.00
10.10.25	2.069	493.00	497.99	-5.0	66.383	62.192	0.5	0.5	24.00
11.10.25	2.012	493.99	499.48	-5.5	65.965	61.895	0.5	0.5	24.00
12.10.25	2.062	486.50	491.85	-5.4	66.090	61.854	0.5	0.5	24.00
13.10.25	2.101	485.55	490.69	-5.1	67.195	62.872	0.5	0.5	24.00
14.10.25	2.046	477.95	483.07	-5.1	66.100	61.822	0.5	0.5	24.00
15.10.25	2.080	461.89	466.88	-5.0	66.632	62.132	0.5	0.5	24.00
16.10.25	2.133	459.56	464.66	-5.1	66.523	61.885	0.5	0.5	24.00
17.10.25	2.089	452.72	457.75	-5.0	66.359	61.746	0.5	0.5	24.00
18.10.25	2.073	443.56	448.47	-4.9	66.683	62.012	0.5	0.5	24.00
19.10.25	2.119	444.56	449.48	-4.9	67.037	62.274	0.5	0.5	24.00
20.10.25	2.071	444.48	449.37	-4.9	66.452	61.797	0.5	0.5	24.00
Итого	53.99	11761.7	11874.9	-113.3	---	---	---	---	750.67
Среднее	---	---	---	---	66.06	61.39	0.5	0.5	---

Показания интеграторов

Дата	Q, (Гкал)	M1, (т)	M2, (т)	Время наработки, (ч)
18.09.25 24:00	4637.9	524723.8	531249.7	58900.2
20.10.25 24:00	4691.9	536485.6	543124.6	59650.9
Итого за период	54.0	11761.8	11874.9	750.7

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Гаражная, 5
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00169032

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0x818C

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	17.02	16.76	0.26	0.000	0.000	0.000	0.000	0.000	1.36	3.40	0.0000	0.0	24.0
20.09.25	16.98	16.72	0.26	0.000	0.000	0.000	0.000	0.000	1.37	2.07	0.0000	0.0	24.0
21.09.25	16.95	16.69	0.26	0.000	0.000	0.000	0.000	0.000	1.36	1.68	0.0000	0.0	24.0
22.09.25	16.94	16.68	0.26	0.000	0.000	0.000	0.000	0.000	1.36	3.72	0.0000	0.0	24.0
23.09.25	16.96	16.70	0.26	0.000	0.000	0.000	0.000	0.000	1.37	5.00	0.0000	0.0	24.0
24.09.25	16.98	16.71	0.27	0.000	0.000	0.000	0.000	0.000	1.39	4.97	0.0000	0.0	24.0
25.09.25	17.00	16.73	0.27	0.000	0.000	0.000	0.000	0.000	1.39	4.94	0.0000	0.0	24.0
26.09.25	39.39	34.86	4.53	120.830	123.590	119.940	122.840	-2.900	3.91	5.14	0.5430	0.0	24.0
27.09.25	40.20	36.90	3.30	254.160	259.500	252.240	257.820	-5.580	6.92	5.65	0.8390	0.0	24.0
28.09.25	40.39	37.35	3.04	247.170	251.790	245.250	250.110	-4.860	6.90	5.64	0.7530	0.0	24.0
29.09.25	43.32	38.95	4.37	240.970	245.040	238.850	243.320	-4.470	6.79	5.57	1.0460	0.0	24.0
30.09.25	47.47	42.25	5.22	246.200	249.930	243.570	247.780	-4.210	6.78	5.62	1.2740	0.0	24.0
01.10.25	47.41	41.95	5.46	243.640	246.570	241.040	244.470	-3.430	6.73	5.63	1.3210	0.0	24.0
02.10.25	47.47	41.87	5.60	248.530	250.360	245.890	248.220	-2.330	6.74	5.61	1.3810	0.0	24.0
03.10.25	48.17	42.53	5.64	245.970	247.010	243.320	244.890	-1.570	6.74	5.61	1.3770	0.0	24.0
04.10.25	48.17	42.29	5.88	251.540	251.640	248.890	249.480	-0.590	6.79	5.67	1.4680	0.0	24.0
05.10.25	48.11	42.39	5.72	251.800	251.540	249.130	249.380	-0.250	6.79	5.67	1.4280	0.0	24.0
06.10.25	47.13	41.75	5.38	251.850	251.540	249.270	249.470	-0.200	6.76	5.64	1.3430	0.0	24.0
07.10.25	45.02	40.24	4.78	251.620	251.390	249.220	249.470	-0.250	6.79	5.66	1.1920	0.0	24.0
08.10.25	45.11	40.36	4.75	251.790	251.570	249.390	249.650	-0.260	6.77	5.65	1.1920	0.0	24.0
09.10.25	44.92	40.18	4.74	251.610	251.280	249.210	249.360	-0.150	6.84	5.72	1.1850	0.0	24.0
10.10.25	44.73	40.14	4.59	251.890	251.530	249.530	249.610	-0.080	6.92	5.79	1.1440	0.0	24.0
11.10.25	44.47	39.96	4.51	254.680	254.380	252.330	252.480	-0.150	6.95	5.80	1.1410	0.0	24.0
12.10.25	45.11	40.31	4.80	254.920	254.600	252.490	252.680	-0.190	6.97	5.81	1.2150	0.0	24.0
13.10.25	46.81	41.59	5.22	255.020	254.640	252.380	252.490	-0.110	6.98	5.82	1.3200	0.0	24.0
14.10.25	46.39	41.35	5.04	255.270	254.940	252.690	252.850	-0.160	6.97	5.82	1.2770	0.0	24.0
15.10.25	47.06	41.78	5.28	255.380	255.050	252.740	252.890	-0.150	6.98	5.82	1.3380	0.0	24.0
16.10.25	46.89	41.55	5.34	254.810	254.430	252.170	252.270	-0.100	6.94	5.79	1.3520	0.0	24.0
17.10.25	48.32	42.51	5.81	252.110	251.720	249.330	249.510	-0.180	6.94	5.82	1.4500	0.0	24.0
18.10.25	50.86	44.36	6.50	248.650	248.160	245.620	245.820	-0.200	6.88	5.79	1.5980	0.0	24.0
19.10.25	51.90	45.26	6.64	251.040	250.490	247.920	248.090	-0.170	6.91	5.80	1.6480	0.0	24.0
20.10.25	50.58	44.34	6.24	250.860	250.320	247.860	248.030	-0.170	6.87	5.76	1.5470	0.0	24.0
Итого	---	---	---	6142.3	6163.0	6080.27	6112.98	-32.710	---	---	31.3720	0.0	768.0
Среднее	39.81	35.75	4.06	---	---	---	---	---	5.57	5.25	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	42852.020	42557.200	42270.370	42159.690	392.1880	110.680	2692.0	6800.0
20.10.25 24:00	48994.330	48720.210	48350.639	48272.670	423.5600	100077.970	2692.0	7568.0
Итого за период	6142.310	6163.010	6080.269	6112.979	31.3720	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ИМ2300, Суточный **с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Герцена, 20
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BA759

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	15.82	0.00	15.43	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	15.73	0.00	15.33	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	15.56	0.00	15.25	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	15.54	0.00	15.29	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	15.73	0.00	15.35	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	15.91	0.00	15.46	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	16.01	0.00	15.53	0.00	0.00	24.00	0.00	0.00
26.09.25	0.66	27.77	201.73	25.88	196.82	9.10	24.00	0.00	0.00
27.09.25	1.34	42.41	459.10	39.51	453.01	24.00	24.00	0.00	0.00
28.09.25	1.69	40.15	495.04	36.72	489.82	24.00	24.00	0.00	0.00
29.09.25	1.80	40.32	494.72	36.66	489.92	24.00	24.00	0.00	0.00
30.09.25	2.37	43.05	487.13	38.16	481.56	24.00	24.00	0.00	0.00
01.10.25	3.03	47.40	475.06	41.00	469.91	24.00	24.00	0.00	0.00
02.10.25	2.99	47.33	469.50	40.96	464.73	24.00	24.00	0.00	0.00
03.10.25	2.74	47.01	425.08	40.65	420.35	22.13	24.00	0.00	0.00
04.10.25	2.97	48.08	459.44	41.62	454.48	24.00	24.00	0.00	0.00
05.10.25	2.96	48.10	456.85	41.61	451.04	24.00	24.00	0.00	0.00
06.10.25	2.90	48.02	456.85	41.66	450.58	24.00	24.00	0.00	0.00
07.10.25	2.76	47.16	457.63	41.12	451.48	24.00	24.00	0.00	0.00
08.10.25	2.44	44.95	454.12	39.57	449.27	24.00	24.00	0.00	0.00
09.10.25	2.44	45.05	455.91	39.69	450.57	24.00	24.00	0.00	0.00
10.10.25	2.46	44.86	455.04	39.44	450.18	24.00	24.00	0.00	0.00
11.10.25	2.41	44.67	454.10	39.35	448.77	24.00	24.00	0.00	0.00
12.10.25	2.40	44.42	457.37	39.16	452.02	24.00	24.00	0.00	0.00
13.10.25	2.53	44.99	457.46	39.46	452.74	24.00	24.00	0.00	0.00
14.10.25	2.76	46.71	459.41	40.69	452.27	24.00	24.00	0.00	0.00
15.10.25	2.69	46.33	461.01	40.49	453.26	24.00	24.00	0.00	0.00
16.10.25	2.82	46.97	462.33	40.85	453.73	24.00	24.00	0.00	0.00
17.10.25	2.86	46.84	461.27	40.62	452.76	24.00	24.00	0.00	0.00
18.10.25	3.10	48.10	461.93	41.38	453.27	24.00	24.00	0.00	0.00
19.10.25	3.48	50.75	461.92	43.20	451.43	24.00	24.00	0.00	0.00
20.10.25	3.57	51.82	462.67	44.08	455.91	24.00	24.00	0.00	0.00
Итого	64.17	---	11302.67	---	11149.88	583.23	768.00	0.00	0.00
Среднее	---	38.861	---	34.412	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	11186.91	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Герцена, 22
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BA760

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	24.10	0.00	22.80	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	24.08	0.00	22.77	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	24.10	0.00	22.89	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	24.16	0.00	22.93	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	24.18	0.00	22.93	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	24.28	0.00	22.93	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	24.27	0.00	22.95	0.00	0.00	24.00	0.00	0.00
26.09.25	0.21	32.16	80.68	30.41	81.80	8.78	24.00	0.00	0.00
27.09.25	0.18	36.77	80.31	36.37	82.09	9.25	24.00	0.00	0.00
28.09.25	0.00	26.78	0.00	24.16	0.00	0.00	24.00	0.00	0.00
29.09.25	0.00	36.19	0.00	22.65	0.00	0.00	24.00	0.00	0.00
30.09.25	0.71	42.88	152.80	37.43	155.88	22.01	24.00	0.00	0.00
01.10.25	1.11	47.61	232.35	42.83	236.75	23.77	24.00	0.00	0.00
02.10.25	1.09	47.54	232.41	42.83	236.55	23.75	24.00	0.00	0.00
03.10.25	1.03	47.59	223.80	42.99	227.48	23.73	24.00	0.00	0.00
04.10.25	1.09	48.14	225.78	43.39	229.42	23.03	24.00	0.00	0.00
05.10.25	1.07	48.32	229.51	43.66	233.22	24.00	24.00	0.00	0.00
06.10.25	0.98	48.23	220.54	43.79	223.82	24.00	24.00	0.00	0.00
07.10.25	0.99	47.40	225.12	42.98	228.50	23.80	24.00	0.00	0.00
08.10.25	0.92	45.17	234.62	41.22	238.18	23.81	24.00	0.00	0.00
09.10.25	0.90	45.26	234.36	41.39	237.91	24.00	24.00	0.00	0.00
10.10.25	0.90	45.07	232.79	41.18	236.34	23.76	24.00	0.00	0.00
11.10.25	0.89	44.89	230.23	41.02	233.64	24.00	24.00	0.00	0.00
12.10.25	0.88	44.65	224.81	40.72	227.76	24.00	24.00	0.00	0.00
13.10.25	0.93	45.20	225.31	41.07	228.03	24.00	24.00	0.00	0.00
14.10.25	1.01	46.94	225.32	42.45	227.98	24.00	24.00	0.00	0.00
15.10.25	0.97	46.57	225.89	42.28	228.59	24.00	24.00	0.00	0.00
16.10.25	1.02	47.20	226.27	42.70	228.93	24.00	24.00	0.00	0.00
17.10.25	1.03	47.08	228.59	42.58	231.31	24.00	24.00	0.00	0.00
18.10.25	1.11	48.28	233.76	43.53	236.46	24.00	24.00	0.00	0.00
19.10.25	1.24	50.99	232.86	45.65	235.38	24.00	24.00	0.00	0.00
20.10.25	1.28	52.05	234.95	46.59	237.30	24.00	24.00	0.00	0.00
Итого	21.54	---	4893.06	---	4963.32	517.69	768.00	0.00	0.00
Среднее	---	40.254	---	36.440	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	3137.92	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Герцена, 24
 Потребитель: АО "Жилуправление"
 Прибор: Вzlёт ТСРВ-024 Заводской номер: 718979
 Тип системы: А32-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	16.94	16.93	0.01	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
20.09.25	16.87	16.87	0.00	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
21.09.25	16.87	16.87	0.00	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
22.09.25	16.93	16.94	-0.01	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
23.09.25	17.02	17.03	-0.01	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
24.09.25	17.12	17.12	0.00	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
25.09.25	17.38	17.20	0.18	4.06	3.13	0.92	0.000	0.000	4.10	3.14	0.96	0.107	24.000
26.09.25	44.87	41.44	3.43	445.61	434.42	11.19	0.000	0.000	450.02	438.15	11.87	1.987	24.000
27.09.25	39.97	36.64	3.33	399.49	389.91	9.58	0.000	0.000	402.62	392.48	10.14	1.678	24.000
28.09.25	40.29	36.40	3.89	402.60	393.17	9.42	0.000	0.000	405.81	395.73	10.08	1.909	24.000
29.09.25	41.35	36.93	4.42	398.76	389.22	9.53	0.000	0.000	402.10	391.83	10.28	2.111	24.000
30.09.25	47.08	40.70	6.38	380.05	371.32	8.72	0.000	0.000	384.15	374.34	9.81	2.776	24.000
01.10.25	47.57	41.02	6.55	371.87	363.35	8.51	0.000	0.000	375.97	366.35	9.62	2.782	24.000
02.10.25	47.61	41.17	6.44	367.19	358.76	8.43	0.000	0.000	371.24	361.74	9.50	2.709	24.000
03.10.25	47.98	41.41	6.57	361.66	353.32	8.33	0.000	0.000	365.71	356.30	9.41	2.718	24.000
04.10.25	48.32	41.64	6.68	356.90	348.67	8.23	0.000	0.000	360.95	351.63	9.32	2.721	24.000
05.10.25	48.21	41.56	6.65	356.32	348.04	8.27	0.000	0.000	360.34	350.99	9.36	2.708	24.000
06.10.25	48.19	41.58	6.61	357.42	349.43	7.99	0.000	0.000	361.46	352.39	9.07	2.691	24.000
07.10.25	45.51	39.74	5.77	353.56	345.73	7.82	0.000	0.000	357.13	348.41	8.72	2.345	24.000
08.10.25	45.18	39.54	5.64	354.90	347.26	7.63	0.000	0.000	358.44	349.93	8.51	2.302	24.000
09.10.25	45.14	39.49	5.65	353.62	346.10	7.51	0.000	0.000	357.14	348.75	8.39	2.291	24.000
10.10.25	45.03	39.50	5.53	353.02	345.61	7.40	0.000	0.000	356.52	348.26	8.26	2.242	24.000
11.10.25	44.94	39.47	5.47	353.90	346.55	7.35	0.000	0.000	357.40	349.20	8.19	2.223	24.000
12.10.25	44.59	39.17	5.42	355.84	348.51	7.33	0.000	0.000	359.30	351.13	8.17	2.213	24.000
13.10.25	46.35	40.30	6.05	355.55	348.29	7.26	0.000	0.000	359.27	351.06	8.21	2.439	24.000
14.10.25	47.14	41.03	6.11	356.03	348.78	7.24	0.000	0.000	359.88	351.66	8.22	2.468	24.000
15.10.25	46.56	40.57	5.99	357.02	349.74	7.27	0.000	0.000	360.80	352.57	8.23	2.432	24.000
16.10.25	47.18	40.89	6.29	355.93	348.69	7.23	0.000	0.000	359.79	351.55	8.24	2.531	24.000
17.10.25	46.99	40.70	6.29	356.05	348.78	7.27	0.000	0.000	359.88	351.61	8.27	2.529	24.000
18.10.25	51.13	43.54	7.59	355.56	348.41	7.14	0.000	0.000	360.05	351.64	8.41	3.003	24.000
19.10.25	51.35	43.86	7.49	355.64	348.51	7.12	0.000	0.000	360.17	351.79	8.38	2.974	24.000
20.10.25	51.86	44.32	7.54	357.89	350.73	7.15	0.000	0.000	362.54	354.10	8.44	3.011	24.000
Итого	---	---	---	9176.42	8974.44	201.97	---	---	9272.78	9046.75	226.03	61.897	768.000
Среднее	39.99	35.36	4.62	---	---	---	0.000	0.000	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Герцена, 24а
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00166608

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0х780В

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	16.96	16.64	0.32	0.000	0.000	0.000	0.000	0.000	1.11	1.17	0.0000	0.0	24.0
20.09.25	16.93	16.61	0.32	0.000	0.000	0.000	0.000	0.000	1.12	1.18	0.0000	0.0	24.0
21.09.25	16.96	16.65	0.31	0.000	0.000	0.000	0.000	0.000	1.12	1.18	0.0000	0.0	24.0
22.09.25	16.97	16.65	0.32	0.000	0.000	0.000	0.000	0.000	1.13	1.18	0.0000	0.0	24.0
23.09.25	17.01	16.68	0.33	0.000	0.000	0.000	0.000	0.000	1.13	1.18	0.0000	0.0	24.0
24.09.25	17.07	16.73	0.34	0.000	0.000	0.000	0.000	0.000	1.13	1.19	0.0000	0.0	24.0
25.09.25	17.10	16.74	0.36	0.000	0.000	0.000	0.000	0.000	1.12	1.18	0.0000	0.0	24.0
26.09.25	39.56	36.26	3.30	185.060	186.990	184.100	185.390	-1.290	3.67	3.48	0.6040	0.0	24.0
27.09.25	40.31	37.24	3.07	424.070	425.480	421.680	421.680	0.000	6.33	5.97	1.2960	0.0	24.0
28.09.25	40.50	37.34	3.16	431.380	432.310	428.780	428.600	0.180	6.31	5.96	1.3540	0.0	24.0
29.09.25	43.37	39.45	3.92	418.290	419.080	415.240	415.240	0.000	6.20	5.90	1.6260	0.0	24.0
30.09.25	47.57	42.71	4.86	402.310	402.260	398.360	398.360	0.000	6.21	5.93	1.9360	0.0	24.0
01.10.25	47.51	42.71	4.80	398.500	396.900	394.270	393.520	0.750	6.20	5.94	1.8910	0.0	24.0
02.10.25	47.57	42.81	4.76	392.180	389.870	388.050	386.490	1.560	6.17	5.91	1.8490	0.0	24.0
03.10.25	48.28	43.40	4.88	387.060	384.610	382.860	381.220	1.640	6.17	5.92	1.8650	0.0	24.0
04.10.25	48.27	43.37	4.90	384.740	382.210	380.540	378.850	1.690	6.22	5.97	1.8610	0.0	24.0
05.10.25	48.19	43.40	4.79	384.270	381.640	380.110	378.280	1.830	6.22	5.98	1.8200	0.0	24.0
06.10.25	47.21	42.66	4.55	383.170	380.610	379.150	377.350	1.800	6.19	5.94	1.7210	0.0	24.0
07.10.25	45.11	41.02	4.09	381.930	379.230	378.330	376.250	2.080	6.21	5.97	1.5450	0.0	24.0
08.10.25	45.20	41.14	4.06	384.930	382.300	381.270	379.180	2.090	6.20	5.95	1.5480	0.0	24.0
09.10.25	45.01	40.95	4.06	382.550	380.130	378.950	377.130	1.820	6.27	6.03	1.5400	0.0	24.0
10.10.25	44.82	40.85	3.97	380.510	378.270	376.950	375.260	1.690	6.35	6.10	1.4960	0.0	24.0
11.10.25	44.56	40.65	3.91	383.880	381.750	380.330	378.750	1.580	6.37	6.12	1.4850	0.0	24.0
12.10.25	45.21	41.03	4.18	385.130	383.120	381.480	380.090	1.390	6.38	6.13	1.5940	0.0	24.0
13.10.25	46.90	42.39	4.51	385.480	383.400	381.480	380.160	1.320	6.39	6.14	1.7180	0.0	24.0
14.10.25	46.48	42.14	4.34	385.820	383.910	381.880	380.660	1.220	6.39	6.14	1.6590	0.0	24.0
15.10.25	47.16	42.57	4.59	387.220	385.390	383.140	382.030	1.110	6.39	6.14	1.7560	0.0	24.0
16.10.25	46.99	42.37	4.62	384.570	382.930	380.590	379.730	0.860	6.36	6.11	1.7600	0.0	24.0
17.10.25	48.44	43.43	5.01	385.530	383.740	381.290	380.380	0.910	6.37	6.13	1.9050	0.0	24.0
18.10.25	50.94	45.42	5.52	385.650	383.300	380.960	379.550	1.410	6.32	6.08	2.1020	0.0	24.0
19.10.25	52.03	46.39	5.64	388.460	385.620	383.620	381.780	1.840	6.34	6.10	2.1610	0.0	24.0
20.10.25	50.72	45.46	5.26	388.220	385.400	383.540	381.650	1.890	6.30	6.06	2.0130	0.0	24.0
Итого	---	---	---	9580.9	9540.4	9486.95	9457.58	29.370	---	---	42.1050	0.0	768.0
Среднее	39.90	36.37	3.53	---	---	---	---	---	5.07	4.89	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	151899.290	152030.780	149809.670	150090.870	1079.0960	-281.200	1943.0	18130.0
20.10.25 24:00	161480.200	161571.229	159296.619	159548.449	1121.2010	-251.830	1943.0	18898.0
Итого за период	9580.910	9540.448	9486.948	9457.578	42.1050	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Герцена, 246
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00170297

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0хFD2E

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	16.22	15.96	0.26	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
20.09.25	16.06	15.83	0.23	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
21.09.25	16.08	15.82	0.26	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
22.09.25	16.31	16.07	0.24	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
23.09.25	16.55	16.31	0.24	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
24.09.25	16.93	16.63	0.30	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
25.09.25	16.72	16.43	0.29	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
26.09.25	39.59	36.17	3.42	181.100	181.270	179.790	180.180	-0.390	6.20	6.00	0.6120	0.0	24.0
27.09.25	40.30	37.19	3.11	398.140	398.630	395.040	395.990	-0.950	6.20	6.00	1.2290	0.0	24.0
28.09.25	40.48	37.31	3.17	394.280	395.010	391.230	392.410	-1.180	6.20	6.00	1.2400	0.0	24.0
29.09.25	43.29	39.38	3.91	379.490	379.230	376.160	376.480	-0.320	6.20	6.00	1.4650	0.0	24.0
30.09.25	47.57	42.72	4.85	362.890	362.770	359.050	359.650	-0.600	6.20	6.00	1.7350	0.0	24.0
01.10.25	47.51	42.71	4.80	357.170	357.840	353.350	354.720	-1.370	6.20	6.00	1.6960	0.0	24.0
02.10.25	47.57	42.79	4.78	353.140	354.160	349.390	351.070	-1.680	6.20	6.00	1.6660	0.0	24.0
03.10.25	48.27	43.38	4.89	347.880	349.440	344.050	346.310	-2.260	6.20	6.00	1.6780	0.0	24.0
04.10.25	48.27	43.35	4.92	344.960	346.860	341.120	343.740	-2.620	6.20	6.00	1.6780	0.0	24.0
05.10.25	48.19	43.35	4.84	345.060	346.990	341.270	343.870	-2.600	6.20	6.00	1.6480	0.0	24.0
06.10.25	47.25	42.65	4.60	344.130	346.110	340.500	343.140	-2.640	6.20	6.00	1.5650	0.0	24.0
07.10.25	45.11	40.98	4.13	342.340	344.540	339.000	341.890	-2.890	6.20	6.00	1.3970	0.0	24.0
08.10.25	45.20	41.10	4.10	343.190	345.590	339.830	342.870	-3.040	6.20	6.00	1.3940	0.0	24.0
09.10.25	45.01	40.92	4.09	342.200	344.350	338.920	341.710	-2.790	6.20	6.00	1.3830	0.0	24.0
10.10.25	44.83	40.81	4.02	341.890	343.680	338.620	341.040	-2.420	6.20	6.00	1.3600	0.0	24.0
11.10.25	44.57	40.59	3.98	344.460	346.570	341.210	343.950	-2.740	6.20	6.00	1.3580	0.0	24.0
12.10.25	45.19	41.00	4.19	344.940	347.170	341.570	344.480	-2.910	6.20	6.00	1.4270	0.0	24.0
13.10.25	46.89	42.42	4.47	345.150	346.990	341.550	344.110	-2.560	6.20	6.00	1.5260	0.0	24.0
14.10.25	46.48	42.18	4.30	345.830	347.710	342.320	344.860	-2.540	6.20	6.00	1.4690	0.0	24.0
15.10.25	47.15	42.67	4.48	346.520	348.380	342.920	345.450	-2.530	6.20	6.00	1.5330	0.0	24.0
16.10.25	47.00	42.48	4.52	345.150	347.220	341.550	344.300	-2.750	6.20	6.00	1.5450	0.0	24.0
17.10.25	48.37	43.51	4.86	345.290	347.400	341.470	344.330	-2.860	6.20	6.00	1.6570	0.0	24.0
18.10.25	50.94	45.57	5.37	344.970	346.730	340.770	343.400	-2.630	6.20	6.00	1.8290	0.0	24.0
19.10.25	52.01	46.53	5.48	348.560	350.140	344.220	346.540	-2.320	6.20	6.00	1.8820	0.0	24.0
20.10.25	50.75	45.58	5.17	348.390	349.880	344.180	346.480	-2.300	6.20	6.00	1.7780	0.0	24.0
Итого	---	---	---	8637.1	8674.6	8549.08	8602.97	-53.890	---	---	37.7500	0.0	768.0
Среднее	39.77	36.26	3.50	---	---	---	---	---	6.20	6.00	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	69247.569	69473.800	68273.330	68716.830	463.4420	-443.500	0.0	9998.0
20.10.25 24:00	77884.690	78148.460	76822.410	77319.799	501.1920	-497.390	0.0	10766.0
Итого за период	8637.121	8674.660	8549.080	8602.968	37.7500	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Герцена, 26
 Потребитель: АО "Жилуправление"
 Прибор: Вzlёт ТСРВ-024 Заводской номер: 801114
 Тип системы: А42-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	21.33	20.38	0.95	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
21.09.25	21.29	20.40	0.89	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
22.09.25	21.50	20.54	0.96	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
23.09.25	21.86	20.99	0.87	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
24.09.25	21.98	20.96	1.02	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
25.09.25	22.41	21.11	1.30	4.72	3.80	0.91	0.000	0.000	4.76	3.82	0.94	0.056	24.000
26.09.25	42.51	39.11	3.40	136.07	135.49	0.57	0.000	0.000	137.43	136.66	0.77	0.463	24.000
27.09.25	39.06	33.90	5.16	44.41	43.26	1.15	0.000	0.000	44.74	43.51	1.24	0.230	24.000
28.09.25	38.96	33.28	5.68	46.02	45.02	0.99	0.000	0.000	46.38	45.28	1.10	0.270	24.000
29.09.25	40.03	33.45	6.58	61.09	59.50	1.58	0.000	0.000	61.60	59.85	1.75	0.418	24.000
30.09.25	45.67	38.89	6.78	126.92	125.85	1.06	0.000	0.000	128.27	126.82	1.45	0.935	24.000
01.10.25	47.21	40.48	6.73	173.66	172.16	1.50	0.000	0.000	175.55	173.55	2.01	1.174	24.000
02.10.25	47.24	40.67	6.57	174.02	172.82	1.20	0.000	0.000	175.91	174.22	1.69	1.151	24.000
03.10.25	47.51	40.85	6.66	166.55	165.57	0.98	0.000	0.000	168.39	166.93	1.46	1.121	24.000
04.10.25	47.95	41.02	6.93	178.79	177.62	1.17	0.000	0.000	180.79	179.08	1.71	1.242	24.000
05.10.25	47.87	41.49	6.38	171.99	170.88	1.10	0.000	0.000	173.91	172.33	1.58	1.096	24.000
06.10.25	47.80	41.49	6.31	165.09	164.04	1.04	0.000	0.000	166.92	165.43	1.50	1.044	24.000
07.10.25	45.18	39.46	5.72	177.84	176.85	0.99	0.000	0.000	179.61	178.20	1.41	1.014	24.000
08.10.25	44.85	39.35	5.50	162.06	161.28	0.77	0.000	0.000	163.66	162.51	1.14	0.886	21.750
09.10.25	44.86	39.79	5.07	197.77	196.89	0.88	0.000	0.000	199.71	198.42	1.30	1.001	24.000
10.10.25	44.74	39.82	4.92	197.44	196.55	0.89	0.000	0.000	199.38	198.08	1.29	0.970	24.000
11.10.25	44.62	39.74	4.88	197.93	197.06	0.86	0.000	0.000	199.85	198.59	1.27	0.964	24.000
12.10.25	44.36	39.45	4.91	198.95	198.13	0.82	0.000	0.000	200.87	199.64	1.23	0.975	24.000
13.10.25	46.07	40.63	5.44	198.67	197.80	0.87	0.000	0.000	200.73	199.41	1.33	1.078	24.000
14.10.25	46.84	41.31	5.53	198.90	197.95	0.94	0.000	0.000	201.02	199.61	1.42	1.097	24.000
15.10.25	46.27	40.85	5.42	199.48	198.58	0.89	0.000	0.000	201.56	200.21	1.35	1.079	24.000
16.10.25	46.87	41.17	5.70	198.95	198.07	0.87	0.000	0.000	201.07	199.71	1.36	1.131	24.000
17.10.25	46.71	41.00	5.71	199.04	198.20	0.84	0.000	0.000	201.15	199.83	1.32	1.133	24.000
18.10.25	50.81	43.84	6.97	198.57	197.60	0.97	0.000	0.000	201.06	199.46	1.59	1.381	24.000
19.10.25	51.02	44.13	6.89	198.60	197.56	1.03	0.000	0.000	201.10	199.44	1.66	1.366	24.000
20.10.25	51.49	44.63	6.86	199.73	198.64	1.08	0.000	0.000	202.29	200.58	1.71	1.367	24.000
Итого	---	---	---	4173.24	4147.17	26.06	---	---	4217.72	4181.15	36.56	24.642	741.750
Среднее	41.19	36.26	4.93	---	---	---	0.000	0.000	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

ИМ2300, Суточный с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Герцена, 28
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ379

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	16.12	0.00	15.95	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	16.07	0.00	15.91	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	16.04	0.00	15.88	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	15.99	0.00	15.72	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	16.02	0.00	15.85	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	16.10	0.00	15.93	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	16.21	0.00	16.02	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	16.27	0.00	16.06	0.00	0.00	24.00	0.00	0.00
27.09.25	0.87	32.24	192.59	29.20	188.05	15.96	24.00	0.00	0.00
28.09.25	1.34	40.25	290.30	35.64	286.01	24.00	24.00	0.00	0.00
29.09.25	1.51	40.36	292.26	35.04	288.51	23.91	24.00	0.00	0.00
30.09.25	1.73	43.39	261.09	36.62	259.31	24.00	24.00	0.00	0.00
01.10.25	2.10	47.45	234.62	38.48	233.61	24.00	24.00	0.00	0.00
02.10.25	2.11	47.41	235.40	38.43	234.39	24.00	24.00	0.00	0.00
03.10.25	2.09	47.47	233.83	38.51	232.91	24.00	24.00	0.00	0.00
04.10.25	2.12	48.17	233.95	39.10	233.05	24.00	24.00	0.00	0.00
05.10.25	2.10	48.16	231.42	39.06	230.59	24.00	24.00	0.00	0.00
06.10.25	2.07	48.09	230.48	39.11	229.84	24.00	24.00	0.00	0.00
07.10.25	1.94	47.09	229.86	38.65	229.33	24.00	24.00	0.00	0.00
08.10.25	1.75	45.04	229.46	37.38	228.72	24.00	24.00	0.00	0.00
09.10.25	1.75	45.13	229.19	37.48	228.98	24.00	24.00	0.00	0.00
10.10.25	1.75	44.94	229.68	37.31	228.97	24.00	24.00	0.00	0.00
11.10.25	1.71	44.75	229.16	37.28	228.53	24.00	24.00	0.00	0.00
12.10.25	1.69	44.49	231.83	37.17	231.03	24.00	24.00	0.00	0.00
13.10.25	1.79	45.15	232.13	37.43	231.34	24.00	24.00	0.00	0.00
14.10.25	1.93	46.82	231.87	38.49	231.29	24.00	24.00	0.00	0.00
15.10.25	1.86	46.39	234.31	38.42	233.59	24.00	24.00	0.00	0.00
16.10.25	1.97	47.07	234.37	38.67	233.69	24.00	24.00	0.00	0.00
17.10.25	1.97	46.89	231.83	38.37	231.28	24.00	24.00	0.00	0.00
18.10.25	2.13	48.36	231.40	39.12	231.08	24.00	24.00	0.00	0.00
19.10.25	2.35	50.82	230.49	40.60	230.48	24.00	24.00	0.00	0.00
20.10.25	2.42	51.90	232.20	41.45	232.09	24.00	24.00	0.00	0.00
Итого	45.05	---	5673.72	---	5646.67	567.87	768.00	0.00	0.00
Среднее	---	38.333	---	32.323	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	19913.83	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Герцена, 30
 Потребитель: АО "Жилуправление"
 Прибор: Вzlёт ТСРВ-024М Заводской номер: 901916
 Тип системы: А42-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	17.69	17.20	0.49	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	0.000
20.09.25	17.70	17.22	0.48	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	0.000
21.09.25	17.64	17.12	0.52	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	0.000
22.09.25	17.63	17.10	0.53	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	0.000
23.09.25	17.72	17.19	0.53	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	0.000
24.09.25	17.81	17.24	0.57	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	0.000
25.09.25	17.87	17.28	0.59	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	0.000
26.09.25	31.22	28.66	2.56	154.55	153.89	0.66	0.000	0.000	155.79	154.89	0.89	0.548	12.583
27.09.25	40.16	36.29	3.87	273.69	273.73	-0.03	0.000	0.000	275.87	275.51	0.36	1.057	24.000
28.09.25	40.34	36.23	4.11	275.09	274.72	0.37	0.000	0.000	277.30	276.50	0.80	1.128	24.000
29.09.25	43.01	37.57	5.44	253.20	252.84	0.36	0.000	0.000	255.49	254.60	0.90	1.355	24.000
30.09.25	47.40	40.23	7.17	228.65	228.37	0.28	0.000	0.000	231.16	230.20	0.97	1.635	24.000
01.10.25	47.33	40.26	7.07	228.83	228.70	0.13	0.000	0.000	231.34	230.53	0.81	1.615	24.000
02.10.25	47.41	40.43	6.98	226.81	226.55	0.26	0.000	0.000	229.30	228.37	0.93	1.581	24.000
03.10.25	48.09	41.05	7.04	227.14	226.72	0.42	0.000	0.000	229.71	228.60	1.10	1.595	24.000
04.10.25	48.11	40.94	7.17	225.50	224.98	0.51	0.000	0.000	228.05	226.84	1.21	1.616	24.000
05.10.25	48.03	40.96	7.07	224.58	223.97	0.61	0.000	0.000	227.11	225.82	1.29	1.585	24.000
06.10.25	47.21	40.54	6.67	224.55	223.90	0.64	0.000	0.000	227.00	225.72	1.28	1.494	24.000
07.10.25	44.99	39.01	5.98	224.84	224.13	0.71	0.000	0.000	227.08	225.82	1.26	1.341	24.000
08.10.25	45.08	39.09	5.99	224.58	223.97	0.60	0.000	0.000	226.82	225.66	1.15	1.343	24.000
09.10.25	44.89	38.96	5.93	224.70	224.14	0.56	0.000	0.000	226.92	225.82	1.10	1.331	24.000
10.10.25	44.70	38.91	5.79	224.38	223.88	0.49	0.000	0.000	226.58	225.56	1.02	1.297	24.000
11.10.25	44.46	38.74	5.72	226.98	226.55	0.43	0.000	0.000	229.18	228.23	0.96	1.280	23.333
12.10.25	45.01	38.95	6.06	227.11	226.75	0.35	0.000	0.000	229.36	228.45	0.91	1.375	24.000
13.10.25	46.73	40.16	6.57	226.73	226.44	0.29	0.000	0.000	229.15	228.24	0.91	1.487	24.000
14.10.25	46.36	40.11	6.25	228.64	228.38	0.26	0.000	0.000	231.05	230.19	0.86	1.428	24.000
15.10.25	46.98	40.34	6.64	228.92	228.69	0.22	0.000	0.000	231.39	230.53	0.86	1.518	24.000
16.10.25	46.87	40.13	6.74	226.32	226.07	0.25	0.000	0.000	228.76	227.87	0.89	1.523	24.000
17.10.25	48.07	40.87	7.20	225.77	225.55	0.21	0.000	0.000	228.32	227.41	0.91	1.624	24.000
18.10.25	50.76	42.65	8.11	224.55	224.41	0.14	0.000	0.000	227.36	226.42	0.95	1.818	24.000
19.10.25	51.83	43.50	8.33	226.09	225.99	0.10	0.000	0.000	229.04	228.09	0.95	1.880	24.000
20.10.25	50.71	42.89	7.82	226.14	226.04	0.09	0.000	0.000	228.97	228.09	0.87	1.765	24.000
Итого	---	---	---	5708.35	5699.34	9.00	---	---	5768.10	5743.95	24.15	36.219	587.917
Среднее	39.68	34.62	5.06	---	---	---	0.000	0.000	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

ИМ2300, Суточный с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Герцена, 32
 Потребитель: АО "Жилуправление"
 Прибор: ИМ2300 Заводской номер: BA765

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	23.10	0.00	21.80	0.00	24.00	24.00	0.00	0.00
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-
26.09.25	0.00	23.27	0.00	22.01	0.00	24.00	24.00	0.00	0.00
27.09.25	0.00	33.58	0.00	30.59	0.00	23.95	24.00	0.00	0.00
28.09.25	0.00	40.19	0.00	36.72	0.00	24.00	24.00	0.00	0.00
29.09.25	0.00	40.37	0.00	37.04	0.00	24.00	24.00	0.00	0.00
30.09.25	0.00	43.12	0.00	37.85	0.00	24.00	24.00	0.00	0.00
01.10.25	0.00	47.44	0.00	40.37	0.00	24.00	24.00	0.00	0.00
02.10.25	0.00	47.36	0.00	40.48	0.00	23.93	24.00	0.00	0.00
03.10.25	0.00	47.45	0.00	40.93	0.00	24.00	24.00	0.00	0.00
04.10.25	0.00	47.98	0.00	41.33	0.00	23.17	24.00	0.00	0.00
05.10.25	0.00	48.15	0.00	41.40	0.00	24.00	24.00	0.00	0.00
06.10.25	0.00	48.07	0.00	41.47	0.00	24.00	24.00	0.00	0.00
07.10.25	0.00	47.20	0.00	40.60	0.00	24.00	24.00	0.00	0.00
08.10.25	0.00	45.02	0.00	39.02	0.00	24.00	24.00	0.00	0.00
09.10.25	0.00	45.11	0.00	39.21	0.00	23.99	23.99	0.00	0.00
10.10.25	0.49	44.84	82.35	38.92	0.00	23.37	23.37	0.00	0.00
11.10.25	0.96	44.73	169.22	39.06	0.00	24.00	24.00	0.00	0.00
12.10.25	0.96	44.48	171.16	38.87	0.00	24.00	24.00	0.00	0.00
13.10.25	1.01	45.06	170.99	39.14	0.00	24.00	24.00	0.00	0.00
14.10.25	1.09	46.78	171.05	40.36	0.00	24.00	24.00	0.00	0.00
15.10.25	1.06	46.39	172.50	40.23	0.00	24.00	24.00	0.00	0.00
16.10.25	1.11	47.03	172.89	40.57	0.00	24.00	24.00	0.00	0.00
17.10.25	1.12	46.90	171.02	40.32	0.00	24.00	24.00	0.00	0.00
18.10.25	1.21	48.17	170.68	41.04	0.00	24.00	24.00	0.00	0.00
19.10.25	1.34	50.80	169.93	42.87	0.00	24.00	24.00	0.00	0.00
20.10.25	1.39	51.87	171.23	43.70	0.00	24.00	24.00	0.00	0.00
Итого	11.74	---	1793.02	---	0.00	622.41	623.36	0.00	0.00
Среднее	---	44.018	---	38.304	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	4422.11	4219.17
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Герцена, 34
 Потребитель: АО "Жилуправление"
 Прибор: Вzlёт ТСРВ-024М Заводской номер: 1801920
 Тип системы: А42-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	15.37	15.04	0.33	0.00	0.00	0.00	0.900	0.600	0.00	0.00	0.00	0.000	0.000
20.09.25	15.36	15.05	0.31	0.00	0.00	0.00	0.900	0.600	0.00	0.00	0.00	0.000	0.000
21.09.25	15.35	15.04	0.31	0.00	0.00	0.00	0.900	0.600	0.00	0.00	0.00	0.000	0.000
22.09.25	15.54	15.29	0.25	0.00	0.00	0.00	0.900	0.600	0.00	0.00	0.00	0.000	0.000
23.09.25	15.64	15.35	0.29	0.00	0.00	0.00	0.900	0.600	0.00	0.00	0.00	0.000	0.000
24.09.25	15.78	15.55	0.23	0.00	0.00	0.00	0.900	0.600	0.00	0.00	0.00	0.000	0.000
25.09.25	15.57	15.18	0.39	0.00	0.00	0.00	0.900	0.600	0.00	0.00	0.00	0.000	0.000
26.09.25	24.10	22.01	2.09	123.22	120.32	2.90	0.900	0.600	124.12	121.03	3.09	0.538	8.983
27.09.25	40.21	36.04	4.17	346.09	348.06	-1.96	0.900	0.600	348.72	350.20	-1.49	1.462	24.000
28.09.25	40.45	35.93	4.52	351.02	353.31	-2.29	0.900	0.600	353.71	355.47	-1.76	1.606	24.000
29.09.25	43.71	37.45	6.26	326.80	329.15	-2.34	0.900	0.600	329.73	331.34	-1.61	2.037	24.000
30.09.25	47.39	39.55	7.84	307.72	310.37	-2.65	0.900	0.600	310.98	312.69	-1.71	2.426	24.000
01.10.25	47.37	39.75	7.62	309.67	312.53	-2.86	0.900	0.600	312.94	314.89	-1.94	2.374	24.000
02.10.25	47.42	39.84	7.58	305.63	308.63	-3.00	0.900	0.600	308.86	310.96	-2.10	2.330	24.000
03.10.25	48.14	40.44	7.70	305.14	308.29	-3.15	0.900	0.600	308.47	310.70	-2.23	2.363	24.000
04.10.25	48.10	40.36	7.74	302.10	305.26	-3.16	0.900	0.600	305.39	307.64	-2.25	2.350	24.000
05.10.25	48.06	40.42	7.64	301.13	304.20	-3.06	0.900	0.600	304.41	306.57	-2.16	2.313	24.000
06.10.25	46.82	39.73	7.09	301.58	304.52	-2.93	0.900	0.600	304.70	306.81	-2.11	2.153	24.000
07.10.25	44.96	38.55	6.41	300.98	303.76	-2.78	0.900	0.600	303.84	305.91	-2.07	1.942	24.000
08.10.25	45.08	38.68	6.40	299.81	302.38	-2.56	0.900	0.600	302.68	304.53	-1.85	1.931	24.000
09.10.25	44.87	38.49	6.38	299.77	302.20	-2.43	0.900	0.600	302.61	304.34	-1.72	1.925	24.000
10.10.25	44.68	38.51	6.17	299.98	302.24	-2.26	0.900	0.600	302.80	304.38	-1.58	1.865	24.000
11.10.25	44.40	38.35	6.05	303.13	305.26	-2.13	0.900	0.600	305.94	307.40	-1.46	1.849	24.000
12.10.25	45.18	38.70	6.48	303.44	305.42	-1.97	0.900	0.600	306.36	307.60	-1.23	1.980	24.000
13.10.25	46.79	39.79	7.00	303.33	305.23	-1.89	0.900	0.600	306.46	307.54	-1.07	2.137	24.000
14.10.25	46.32	39.65	6.67	306.49	308.37	-1.87	0.900	0.600	309.59	310.68	-1.09	2.057	24.000
15.10.25	47.04	40.06	6.98	305.96	307.77	-1.81	0.900	0.600	309.15	310.13	-0.98	2.152	24.000
16.10.25	46.80	39.75	7.05	302.83	304.60	-1.76	0.900	0.600	305.96	306.89	-0.93	2.151	24.000
17.10.25	48.59	40.81	7.78	302.23	303.97	-1.74	0.900	0.600	305.59	306.39	-0.80	2.364	24.000
18.10.25	50.80	42.34	8.46	301.19	302.93	-1.74	0.900	0.600	304.85	305.53	-0.68	2.560	24.000
19.10.25	51.88	43.24	8.64	303.17	304.94	-1.76	0.900	0.600	307.00	307.66	-0.66	2.633	24.000
20.10.25	50.32	42.36	7.96	303.24	305.02	-1.78	0.900	0.600	306.86	307.64	-0.78	2.429	24.000
Итого	---	---	---	7515.66	7568.73	-53.06	---	---	7591.73	7624.90	-33.18	51.929	584.983
Среднее	39.00	33.67	5.34	---	---	---	0.900	0.600	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Гоголя, 6
Потребитель: АО "Жилуправление"
Прибор: ТВ7-01 Заводской номер: 20103329

БД=1, ТВ1, СИ=7, КТЗ=0, ФРТ=0, КСН=0хВ1DC

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	16.68	16.17	н/д	0.51	6.12	6.12	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
20.09.25	16.63	16.13	н/д	0.50	6.12	6.12	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
21.09.25	16.56	16.07	н/д	0.50	6.12	6.12	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
22.09.25	16.65	16.19	н/д	0.46	6.12	6.12	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
23.09.25	16.75	16.61	н/д	0.14	6.12	6.12	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
24.09.25	16.87	16.46	н/д	0.41	6.12	6.12	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
25.09.25	16.12	23.48	н/д	-7.37	6.12	6.12	н/д	0.177	н/д	н/д	0.005	н/д	н/д	н/д	0	н/д	23	1
26.09.25	37.90	33.68	н/д	4.22	6.12	6.12	н/д	67.673	н/д	н/д	67.237	н/д	н/д	н/д	0.283	н/д	24	0
27.09.25	43.01	38.19	н/д	4.82	6.12	6.12	н/д	118.933	н/д	н/д	117.931	н/д	н/д	н/д	0.567	н/д	24	0
28.09.25	42.31	37.49	н/д	4.82	6.12	6.12	н/д	113.022	н/д	н/д	112.108	н/д	н/д	н/д	0.540	н/д	24	0
29.09.25	41.97	37.11	н/д	4.86	6.12	6.12	н/д	109.253	н/д	н/д	108.380	н/д	н/д	н/д	0.526	н/д	24	0
30.09.25	42.83	36.75	н/д	6.08	6.12	6.12	н/д	89.860	н/д	н/д	89.112	н/д	н/д	н/д	0.541	н/д	24	0
01.10.25	44.30	37.66	н/д	6.63	6.12	6.12	н/д	86.152	н/д	н/д	85.380	н/д	н/д	н/д	0.566	н/д	24	0
02.10.25	46.74	39.83	н/д	6.91	6.12	6.12	н/д	89.200	н/д	н/д	88.305	н/д	н/д	н/д	0.609	н/д	24	0
03.10.25	46.16	40.44	н/д	5.72	6.12	6.12	н/д	100.295	н/д	н/д	99.317	н/д	н/д	н/д	0.567	н/д	24	0
04.10.25	46.01	40.46	н/д	5.54	6.12	6.12	н/д	114.065	н/д	н/д	112.954	н/д	н/д	н/д	0.626	н/д	24	0
05.10.25	46.12	40.70	н/д	5.43	6.12	6.12	н/д	113.940	н/д	н/д	112.823	н/д	н/д	н/д	0.611	н/д	24	0
06.10.25	44.98	39.86	н/д	5.12	6.12	6.12	н/д	112.832	н/д	н/д	111.783	н/д	н/д	н/д	0.572	н/д	24	0
07.10.25	43.66	38.80	н/д	4.85	6.12	6.12	н/д	111.327	н/д	н/д	110.356	н/д	н/д	н/д	0.535	н/д	24	0
08.10.25	43.85	39.37	н/д	4.49	6.12	6.12	н/д	121.260	н/д	н/д	120.200	н/д	н/д	н/д	0.539	н/д	24	0
09.10.25	43.69	39.43	н/д	4.27	6.12	6.12	н/д	128.512	н/д	н/д	127.394	н/д	н/д	н/д	0.543	н/д	24	0
10.10.25	42.91	38.82	н/д	4.09	6.12	6.12	н/д	126.702	н/д	н/д	125.640	н/д	н/д	н/д	0.513	н/д	24	0
11.10.25	42.18	38.23	н/д	3.95	6.12	6.12	н/д	128.060	н/д	н/д	127.027	н/д	н/д	н/д	0.501	н/д	24	0
12.10.25	42.55	38.50	н/д	4.06	6.12	6.12	н/д	131.505	н/д	н/д	130.426	н/д	н/д	н/д	0.528	н/д	24	0
13.10.25	42.49	38.39	н/д	4.11	6.12	6.12	н/д	129.220	н/д	н/д	128.161	н/д	н/д	н/д	0.526	н/д	24	0
14.10.25	43.95	39.39	н/д	4.56	6.12	6.12	н/д	122.810	н/д	н/д	121.721	н/д	н/д	н/д	0.554	н/д	24	0
15.10.25	45.02	40.25	н/д	4.77	6.12	6.12	н/д	126.415	н/д	н/д	125.237	н/д	н/д	н/д	0.597	н/д	24	0
16.10.25	45.31	40.76	н/д	4.55	6.12	6.12	н/д	138.708	н/д	н/д	137.403	н/д	н/д	н/д	0.624	н/д	24	0
17.10.25	46.81	41.99	н/д	4.82	6.12	6.12	н/д	142.178	н/д	н/д	140.739	н/д	н/д	н/д	0.678	н/д	24	0
18.10.25	50.64	45.14	н/д	5.50	6.12	6.12	н/д	142.538	н/д	н/д	140.838	н/д	н/д	н/д	0.774	н/д	24	0
19.10.25	50.79	45.37	н/д	5.41	6.12	6.12	н/д	141.728	н/д	н/д	140.026	н/д	н/д	н/д	0.757	н/д	24	0
20.10.25	49.69	44.84	н/д	4.86	6.12	6.12	н/д	152.962	н/д	н/д	151.215	н/д	н/д	н/д	0.734	н/д	24	0
Итого	---	---	---	---	---	---	---	2959.327	---	---	2931.718	---	---	---	14.411	---	767	1
Среднее	44.89	39.97	---	4.92	6.12	6.12	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	28421.272	0.000	0.000	27980.103	0.000	0.000	0.000	216.605	0.000	13443	584
20.10.25 24:00	31380.600	0.000	0.000	30911.822	0.000	0.000	0.000	231.017	0.000	14210	585
Итого за период	2959.328	0.000	0.000	2931.719	0.000	0.000	---	14.412	0.000	767	1

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ИМ2300, Суточный с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Горького, 11
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ606

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	16.76	0.00	16.54	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	16.70	0.00	16.48	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	16.62	0.00	16.37	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	16.53	0.00	16.29	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	16.53	0.00	16.32	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	16.53	0.00	16.34	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	16.53	0.00	16.34	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	16.54	0.00	16.36	0.00	0.00	24.00	0.00	0.00
27.09.25	0.41	27.33	115.69	25.65	115.92	10.55	24.00	0.00	0.00
28.09.25	0.89	43.66	266.96	40.33	267.54	24.00	24.00	0.00	0.00
29.09.25	0.85	42.92	263.33	39.67	263.78	24.00	24.00	0.00	0.00
30.09.25	0.85	42.58	256.65	39.24	256.78	24.00	24.00	0.00	0.00
01.10.25	0.90	44.07	205.67	39.65	205.29	24.00	24.00	0.00	0.00
02.10.25	0.96	45.91	191.49	40.87	190.70	24.00	24.00	0.00	0.00
03.10.25	1.02	47.97	202.27	42.70	201.34	24.00	24.00	0.00	0.00
04.10.25	0.98	46.84	246.78	42.87	245.98	24.00	24.00	0.00	0.00
05.10.25	0.98	46.68	246.15	42.71	245.21	24.00	24.00	0.00	0.00
06.10.25	0.97	46.82	245.51	42.87	244.50	24.00	24.00	0.00	0.00
07.10.25	0.89	45.19	243.65	41.55	242.57	24.00	24.00	0.00	0.00
08.10.25	0.82	44.24	232.12	40.69	231.03	24.00	24.00	0.00	0.00
09.10.25	0.80	44.31	208.74	40.48	207.82	24.00	24.00	0.00	0.00
10.10.25	0.78	44.01	197.06	40.02	196.06	24.00	24.00	0.00	0.00
11.10.25	0.74	43.21	193.06	39.36	191.79	24.00	24.00	0.00	0.00
12.10.25	0.70	42.42	190.88	38.72	189.48	24.00	24.00	0.00	0.00
13.10.25	0.74	42.85	190.14	38.97	188.59	24.00	24.00	0.00	0.00
14.10.25	0.74	42.84	190.52	38.96	188.86	24.00	24.00	0.00	0.00
15.10.25	0.80	44.70	187.65	40.39	185.95	24.00	24.00	0.00	0.00
16.10.25	0.85	45.55	191.78	41.11	190.13	24.00	24.00	0.00	0.00
17.10.25	0.88	45.62	208.53	41.37	207.05	24.00	24.00	0.00	0.00
18.10.25	1.00	47.82	212.59	43.12	211.01	24.00	24.00	0.00	0.00
19.10.25	1.13	51.09	213.62	45.80	211.90	24.00	24.00	0.00	0.00
20.10.25	1.11	51.30	213.86	46.08	212.15	24.00	24.00	0.00	0.00
Итого	20.79	---	5114.70	---	5091.43	562.55	768.00	0.00	0.00
Среднее	---	37.583	---	34.507	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	1669.14	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Горького, 12
Потребитель: АО "Жилуправление"
Прибор: ТВ7-04.1 Заводской номер: 22180505

БД=1, ТВ1, СИ=6, КСН=0хВ27F

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
27.09.25	40.18	37.17	н/д	3.01	5.20	5.00	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
28.09.25	40.34	37.22	н/д	3.12	5.20	5.00	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
29.09.25	44.40	35.36	н/д	9.05	4.89	5.00	н/д	31.752	31.906	н/д	31.464	31.730	н/д	-0.266	0.285	н/д	13	11
30.09.25	47.16	36.87	н/д	10.29	4.74	5.00	н/д	56.553	57.457	н/д	55.970	57.111	н/д	-1.141	0.576	н/д	24	0
01.10.25	46.96	35.56	н/д	11.40	4.73	5.00	н/д	39.980	40.741	н/д	39.573	40.519	н/д	-0.946	0.451	н/д	24	0
02.10.25	46.99	34.57	н/д	12.43	4.70	5.00	н/д	35.515	36.320	н/д	35.154	36.133	н/д	-0.979	0.437	н/д	24	0
03.10.25	47.49	35.69	н/д	11.80	4.70	5.00	н/д	37.516	38.234	н/д	37.125	38.020	н/д	-0.896	0.438	н/д	24	0
04.10.25	47.69	36.00	н/д	11.69	4.75	5.00	н/д	41.107	41.769	н/д	40.674	41.532	н/д	-0.857	0.476	н/д	24	0
05.10.25	47.48	35.50	н/д	11.98	4.76	5.00	н/д	32.799	33.372	н/д	32.457	33.190	н/д	-0.732	0.389	н/д	24	0
06.10.25	46.98	35.63	н/д	11.36	4.72	5.00	н/д	38.592	39.129	н/д	38.199	38.912	н/д	-0.713	0.434	н/д	24	0
07.10.25	44.51	33.60	н/д	10.91	4.75	5.00	н/д	31.348	31.936	н/д	31.061	31.784	н/д	-0.722	0.339	н/д	24	0
08.10.25	44.68	34.34	н/д	10.34	4.73	5.00	н/д	37.231	37.723	н/д	36.891	37.532	н/д	-0.642	0.382	н/д	24	0
09.10.25	44.43	33.94	н/д	10.49	4.80	5.00	н/д	32.325	32.799	н/д	32.033	32.635	н/д	-0.603	0.336	н/д	24	0
10.10.25	44.56	34.01	н/д	10.54	4.89	5.00	н/д	31.851	32.325	н/д	31.560	32.163	н/д	-0.603	0.333	н/д	24	0
11.10.25	44.39	33.89	н/д	10.50	4.91	5.00	н/д	32.532	33.023	н/д	32.236	32.859	н/д	-0.623	0.339	н/д	24	0
12.10.25	44.80	35.50	н/д	9.29	4.92	5.00	н/д	52.850	53.112	н/д	52.362	52.819	н/д	-0.457	0.487	н/д	24	0
13.10.25	46.20	35.01	н/д	11.19	4.93	5.00	н/д	33.145	33.533	н/д	32.821	33.353	н/д	-0.533	0.367	н/д	24	0
14.10.25	45.07	32.24	н/д	12.83	4.93	5.00	н/д	25.283	25.794	н/д	25.047	25.680	н/д	-0.632	0.321	н/д	24	0
15.10.25	46.73	36.63	н/д	10.10	4.93	5.00	н/д	53.180	53.267	н/д	52.646	52.952	н/д	-0.305	0.532	н/д	24	0
16.10.25	46.60	36.53	н/д	10.07	4.89	5.00	н/д	53.120	53.201	н/д	52.588	52.888	н/д	-0.300	0.530	н/д	24	0
17.10.25	47.86	37.08	н/д	10.79	4.91	5.00	н/д	52.678	52.695	н/д	52.122	52.375	н/д	-0.253	0.563	н/д	24	0
18.10.25	50.41	37.08	н/д	13.33	4.86	5.00	н/д	36.497	36.647	н/д	36.068	36.422	н/д	-0.354	0.481	н/д	24	0
19.10.25	49.37	23.40	н/д	25.97	4.89	5.00	н/д	8.776	9.432	н/д	8.677	9.415	н/д	-0.738	0.225	н/д	24	0
20.10.25	48.86	30.94	н/д	17.92	4.85	5.00	н/д	19.489	19.961	н/д	19.274	19.880	н/д	-0.605	0.345	н/д	24	0
Итого	---	---	---	---	---	---	---	814.119	824.376	---	806.002	819.904	---	-13.900	9.066	---	517	59
Среднее	45.47	35.31	---	10.16	4.86	5.00	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
20.10.25 24:00	814.119	824.376	0.000	806.002	819.904	0.000	-13.902	9.065	0.000	517	73
Итого за период	н/д	н/д	н/д	н/д	н/д	н/д	---	н/д	н/д	н/д	н/д

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Горького, 13
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ411

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	15.50	0.00	15.20	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	15.48	0.00	15.16	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	15.44	0.00	15.12	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	15.41	0.00	15.09	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	15.71	0.00	15.46	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	15.79	0.00	15.52	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	15.98	0.00	15.68	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	15.70	0.00	15.36	0.00	0.00	24.00	0.00	0.00
27.09.25	0.32	25.24	102.79	23.64	104.01	9.52	24.00	0.00	0.00
28.09.25	0.78	44.59	267.73	41.66	271.96	24.00	24.00	0.00	0.00
29.09.25	0.76	43.81	264.01	40.91	268.56	24.00	24.00	0.00	0.00
30.09.25	0.77	43.47	259.38	40.45	263.68	24.00	24.00	0.00	0.00
01.10.25	0.83	44.88	204.44	40.80	207.96	24.00	24.00	0.00	0.00
02.10.25	0.88	46.68	188.36	41.98	191.66	24.00	24.00	0.00	0.00
03.10.25	0.95	49.01	196.10	43.93	199.20	24.00	24.00	0.00	0.00
04.10.25	0.92	47.85	243.79	44.08	247.69	24.00	24.00	0.00	0.00
05.10.25	0.92	47.65	242.77	43.84	246.57	24.00	24.00	0.00	0.00
06.10.25	0.91	47.77	242.15	44.02	246.11	24.00	24.00	0.00	0.00
07.10.25	0.83	46.29	240.28	42.81	244.26	24.00	24.00	0.00	0.00
08.10.25	0.80	45.15	236.91	41.78	240.48	24.00	24.00	0.00	0.00
09.10.25	0.79	45.23	220.80	41.63	223.92	24.00	24.00	0.00	0.00
10.10.25	0.78	44.95	207.00	41.18	209.88	24.00	24.00	0.00	0.00
11.10.25	0.73	44.11	201.76	40.49	204.67	24.00	24.00	0.00	0.00
12.10.25	0.70	43.33	199.35	39.79	202.17	24.00	24.00	0.00	0.00
13.10.25	0.74	43.74	198.74	40.00	201.66	24.00	24.00	0.00	0.00
14.10.25	0.75	43.70	198.78	39.93	201.74	24.00	24.00	0.00	0.00
15.10.25	0.80	45.48	195.63	41.36	198.69	24.00	24.00	0.00	0.00
16.10.25	0.85	46.45	198.36	42.16	201.51	24.00	24.00	0.00	0.00
17.10.25	0.88	46.56	217.48	42.50	220.98	24.00	24.00	0.00	0.00
18.10.25	0.98	48.47	221.31	44.03	224.96	24.00	24.00	0.00	0.00
19.10.25	1.11	52.12	222.20	47.11	226.04	24.00	24.00	0.00	0.00
20.10.25	1.10	52.29	222.39	47.34	226.36	24.00	24.00	0.00	0.00
Итого	19.88	---	5192.51	---	5274.72	561.52	768.00	0.00	0.00
Среднее	---	37.932	---	35.000	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	20.90	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1 Пульсар ДУ-40, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Горького, 30
 Потребитель: АО "Жилуправление"
 Прибор: 405 Заводской номер: 05579471
 ТВ1

Дата	T1	T2	V1	Q	Время раб. (ч)
19.09.25	18.0	17.9	0.000	0.000	0.00
20.09.25	17.9	17.8	0.000	0.000	0.00
21.09.25	17.9	17.7	0.000	0.000	0.00
22.09.25	17.8	17.7	0.000	0.000	0.00
23.09.25	17.9	18.0	0.000	0.000	0.00
24.09.25	19.2	23.7	0.000	0.000	0.00
25.09.25	18.8	21.4	0.000	0.000	0.00
26.09.25	27.6	26.0	37.945	0.204	9.00
27.09.25	44.8	40.2	105.000	0.486	24.00
28.09.25	44.1	39.5	103.000	0.467	24.00
29.09.25	43.8	39.1	101.320	0.459	24.00
30.09.25	45.4	39.7	86.352	0.485	24.00
01.10.25	47.3	41.1	83.188	0.514	24.00
02.10.25	49.2	42.8	88.867	0.545	24.00
03.10.25	48.0	43.1	107.125	0.528	24.00
04.10.25	47.9	43.0	107.086	0.527	24.00
05.10.25	48.1	43.1	107.062	0.525	24.00
06.10.25	46.3	41.8	105.906	0.475	24.00
07.10.25	45.4	41.1	104.320	0.452	24.00
08.10.25	45.5	41.1	104.211	0.449	24.00
09.10.25	45.2	40.8	101.500	0.439	24.00
10.10.25	44.4	40.1	98.859	0.416	24.00
11.10.25	43.5	39.4	97.953	0.398	24.00
12.10.25	44.0	39.7	97.820	0.421	24.00
13.10.25	44.0	39.7	97.703	0.419	24.00
14.10.25	46.0	41.2	96.422	0.459	24.00
15.10.25	46.8	41.9	100.336	0.480	24.00
16.10.25	46.8	42.2	108.727	0.495	24.00
17.10.25	49.3	44.2	111.336	0.563	24.00
18.10.25	52.4	46.8	111.617	0.620	24.00
19.10.25	52.6	47.1	112.039	0.618	24.00
20.10.25	50.9	46.0	119.641	0.576	24.00
Итого	---	---	2495.336	12.018	585.00
Среднее	39.9	36.4	---	---	---

Показания интеграторов

Дата	V1, м. куб	Q, Гкал	Время раб., ч
18.09.25 24:00	н/д	н/д	н/д
20.10.25 24:00	69408.273	478.927	15666.000
Итого за период	н/д	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1 Пульсар ДУ-40, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Горького, 32
 Потребитель: АО "Жилуправление"
 Прибор: 405 Заводской номер: 05578927
 ТВ1

Дата	T1	T2	V1	Q	Время раб. (ч)
19.09.25	17.0	16.8	0.000	0.000	0.00
20.09.25	16.9	16.7	0.000	0.000	0.00
21.09.25	16.9	16.7	0.000	0.000	0.00
22.09.25	17.0	16.8	0.000	0.000	0.00
23.09.25	17.1	16.9	0.000	0.000	0.00
24.09.25	17.3	17.2	0.000	0.000	0.00
25.09.25	28.3	25.6	36.000	0.221	10.00
26.09.25	42.2	37.1	84.965	0.433	24.00
27.09.25	44.9	39.3	86.602	0.477	24.00
28.09.25	44.2	38.6	84.898	0.466	24.00
29.09.25	43.8	38.2	83.645	0.462	24.00
30.09.25	45.4	38.5	72.125	0.494	24.00
01.10.25	47.4	39.8	69.781	0.524	24.00
02.10.25	49.3	41.4	74.402	0.559	24.00
03.10.25	48.1	42.0	90.137	0.546	24.00
04.10.25	48.0	41.8	90.055	0.547	24.00
05.10.25	48.1	42.0	90.008	0.543	24.00
06.10.25	46.3	40.7	89.047	0.493	24.00
07.10.25	45.5	40.0	87.754	0.473	24.00
08.10.25	45.5	40.1	87.688	0.470	24.00
09.10.25	45.2	39.7	85.426	0.462	24.00
10.10.25	44.4	39.1	83.238	0.436	24.00
11.10.25	43.6	38.5	82.527	0.420	24.00
12.10.25	44.1	38.6	82.438	0.441	24.00
13.10.25	44.1	38.7	82.305	0.439	24.00
14.10.25	46.1	40.1	81.289	0.484	24.00
15.10.25	46.8	40.8	84.645	0.507	24.00
16.10.25	46.9	41.1	91.566	0.525	24.00
17.10.25	49.4	43.0	93.738	0.597	24.00
18.10.25	52.4	45.3	93.961	0.658	24.00
19.10.25	52.7	45.6	94.074	0.655	24.00
20.10.25	50.9	44.7	100.316	0.613	24.00
Итого	---	---	2182.629	12.943	610.00
Среднее	40.5	35.7	---	---	---

Показания интеграторов

Дата	V1, м. куб	Q, Гкал	Время раб., ч
18.09.25 24:00	61935.699	551.466	16711.000
20.10.25 24:00	64118.328	564.409	17321.000
Итого за период	2182.629	12.943	610.000

Представитель абонента _____/_____

Представитель поставщика _____/_____

ИМ2300, Суточный с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Горького, 6
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ650

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	16.47	0.00	16.27	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	16.40	0.00	16.21	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	16.34	0.00	16.15	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	16.27	0.00	16.08	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	16.40	0.00	16.24	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	16.48	0.00	16.31	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	16.61	0.00	16.45	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	16.52	0.00	16.34	0.00	0.00	24.00	0.00	0.00
27.09.25	0.35	30.83	71.61	28.04	71.99	14.61	24.00	0.00	0.00
28.09.25	0.56	40.27	125.24	35.79	126.18	24.00	24.00	0.00	0.00
29.09.25	0.58	40.46	125.68	35.87	126.69	24.00	24.00	0.00	0.00
30.09.25	0.70	43.23	123.34	37.58	124.33	23.49	24.00	0.00	0.00
01.10.25	0.84	47.46	117.76	40.27	118.77	24.00	24.00	0.00	0.00
02.10.25	0.82	47.40	112.55	40.08	113.47	24.00	24.00	0.00	0.00
03.10.25	0.80	47.46	108.39	40.02	109.25	24.00	24.00	0.00	0.00
04.10.25	0.81	48.15	107.93	40.64	108.83	24.00	24.00	0.00	0.00
05.10.25	0.81	48.15	107.49	40.63	108.40	24.00	24.00	0.00	0.00
06.10.25	0.80	48.08	107.37	40.65	108.33	24.00	24.00	0.00	0.00
07.10.25	0.75	47.16	107.39	40.17	108.36	24.00	24.00	0.00	0.00
08.10.25	0.67	45.03	107.43	38.77	108.40	24.00	24.00	0.00	0.00
09.10.25	0.67	45.12	107.49	38.88	108.44	24.00	24.00	0.00	0.00
10.10.25	0.66	44.93	107.25	38.74	108.22	24.00	24.00	0.00	0.00
11.10.25	0.65	44.74	107.68	38.71	108.65	24.00	24.00	0.00	0.00
12.10.25	0.64	44.49	108.76	38.56	109.74	24.00	24.00	0.00	0.00
13.10.25	0.68	45.09	108.76	38.84	109.75	24.00	24.00	0.00	0.00
14.10.25	0.73	46.79	108.77	40.05	109.70	24.00	24.00	0.00	0.00
15.10.25	0.70	46.37	109.01	39.92	109.89	24.00	24.00	0.00	0.00
16.10.25	0.74	47.03	108.89	40.21	109.79	24.00	24.00	0.00	0.00
17.10.25	0.75	46.89	109.07	40.02	110.01	24.00	24.00	0.00	0.00
18.10.25	0.80	48.22	107.99	40.75	108.94	24.00	24.00	0.00	0.00
19.10.25	0.89	50.78	107.19	42.43	108.06	24.00	24.00	0.00	0.00
20.10.25	0.92	51.86	108.64	43.40	109.25	24.00	24.00	0.00	0.00
Итого	17.32	---	2621.68	---	2643.44	566.10	768.00	0.00	0.00
Среднее	---	38.359	---	33.408	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	1240.02	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Горького, 9
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ490

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	0.00	18.32	0.00	18.05	422.80	0.00	24.00	0.00	0.00
21.09.25	0.00	18.25	0.00	17.99	356.24	0.00	24.00	0.00	0.00
22.09.25	0.00	18.20	0.00	17.94	322.29	0.00	24.00	0.00	0.00
23.09.25	0.00	18.24	0.00	17.96	294.19	0.00	24.00	0.00	0.00
24.09.25	0.00	18.32	0.00	18.01	278.63	0.00	24.00	0.00	0.00
25.09.25	0.00	18.40	0.00	18.07	268.80	0.00	24.00	0.00	0.00
26.09.25	0.00	18.36	0.00	18.03	250.70	0.00	24.00	0.00	0.00
27.09.25	0.30	24.77	49.28	22.72	199.66	6.93	24.00	0.00	0.00
28.09.25	1.03	44.16	184.10	38.56	184.94	24.00	24.00	0.00	0.00
29.09.25	1.00	43.42	176.54	37.72	177.62	24.00	24.00	0.00	0.00
30.09.25	1.00	43.07	174.71	37.28	175.80	24.00	24.00	0.00	0.00
01.10.25	1.05	44.34	147.34	37.19	148.28	24.00	24.00	0.00	0.00
02.10.25	1.10	46.01	141.62	38.19	142.53	24.00	24.00	0.00	0.00
03.10.25	1.20	48.38	145.97	39.89	146.76	24.00	24.00	0.00	0.00
04.10.25	1.20	47.44	182.16	40.86	183.31	23.99	23.99	0.00	0.00
05.10.25	1.19	47.21	182.69	40.66	183.92	24.00	24.00	0.00	0.00
06.10.25	1.18	47.32	182.46	40.86	183.72	24.00	24.00	0.00	0.00
07.10.25	1.09	45.97	180.69	39.93	182.03	24.00	24.00	0.00	0.00
08.10.25	1.02	44.77	178.84	39.06	180.12	24.00	24.00	0.00	0.00
09.10.25	1.08	44.99	226.01	40.14	227.74	23.89	24.00	0.00	0.00
10.10.25	1.09	44.92	256.58	40.67	258.79	24.00	24.00	0.00	0.00
11.10.25	1.02	44.09	251.54	40.02	253.76	24.00	24.00	0.00	0.00
12.10.25	0.98	43.32	248.73	39.37	250.98	24.00	24.00	0.00	0.00
13.10.25	1.02	43.73	247.86	39.60	250.14	24.00	24.00	0.00	0.00
14.10.25	1.03	43.70	247.87	39.54	250.19	24.00	24.00	0.00	0.00
15.10.25	1.11	45.41	245.09	40.86	247.35	24.00	24.00	0.00	0.00
16.10.25	1.19	46.44	251.59	41.70	253.87	24.00	24.00	0.00	0.00
17.10.25	1.23	46.56	275.00	42.07	277.42	24.00	24.00	0.00	0.00
18.10.25	1.37	48.44	281.26	43.57	283.72	24.00	24.00	0.00	0.00
19.10.25	1.55	52.11	282.25	46.61	284.74	24.00	24.00	0.00	0.00
20.10.25	1.54	52.28	282.53	46.82	285.00	24.00	24.00	0.00	0.00
Итого	26.57	---	5022.71	---	7406.04	558.81	743.99	0.00	0.00
Среднее	---	39.063	---	34.837	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	2803.12	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Губкина, 14
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00173149

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0xC8BD

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
28.09.25	43.34	36.72	6.62	89.170	86.980	88.420	86.460	1.960	7.00	6.80	0.5880	0.0	24.0
29.09.25	44.79	36.73	8.06	79.060	77.050	78.340	76.570	1.770	7.00	6.80	0.6320	0.0	24.0
30.09.25	46.62	37.67	8.95	78.120	76.440	77.340	75.960	1.380	7.00	6.80	0.6910	0.0	24.0
01.10.25	48.75	39.54	9.21	81.510	79.980	80.560	79.420	1.140	7.00	6.80	0.7400	0.0	24.0
02.10.25	47.74	40.28	7.46	99.250	97.640	98.250	96.920	1.330	7.00	6.80	0.7330	0.0	24.0
03.10.25	47.54	40.12	7.42	99.390	97.720	98.430	97.000	1.430	7.00	6.80	0.7300	0.0	24.0
04.10.25	47.67	40.32	7.35	99.400	97.570	98.440	96.850	1.590	7.00	6.80	0.7200	0.0	24.0
05.10.25	46.16	39.38	6.78	99.070	97.150	98.110	96.430	1.680	7.00	6.80	0.6640	0.0	24.0
06.10.25	45.05	38.65	6.40	98.440	96.580	97.480	95.860	1.620	7.00	6.80	0.6240	0.0	24.0
07.10.25	45.14	38.75	6.39	97.150	95.450	96.190	94.730	1.460	7.00	6.80	0.6100	0.0	24.0
08.10.25	44.85	38.47	6.38	95.080	93.680	94.120	92.960	1.160	7.00	6.80	0.5980	0.0	24.0
09.10.25	44.01	37.88	6.13	93.180	91.820	92.280	91.100	1.180	7.00	6.80	0.5690	0.0	24.0
10.10.25	43.23	37.32	5.91	92.570	91.210	91.790	90.590	1.200	7.00	6.80	0.5430	0.0	24.0
11.10.25	43.65	37.37	6.28	92.660	91.230	91.940	90.750	1.190	7.00	6.80	0.5740	0.0	24.0
12.10.25	43.62	37.34	6.28	92.760	91.310	92.040	90.820	1.220	7.00	6.80	0.5770	0.0	24.0
13.10.25	45.41	38.55	6.86	92.150	90.660	91.290	90.030	1.260	7.00	6.80	0.6260	0.0	24.0
14.10.25	46.37	39.32	7.05	95.020	93.400	94.060	92.680	1.380	7.00	6.80	0.6580	0.0	24.0
15.10.25	46.46	39.68	6.78	103.630	101.850	102.670	101.130	1.540	7.00	6.80	0.6960	0.0	24.0
16.10.25	48.44	41.03	7.41	105.830	104.050	104.680	103.240	1.440	7.00	6.80	0.7760	0.0	24.0
17.10.25	52.01	43.69	8.32	106.800	104.990	105.360	104.030	1.330	7.00	6.80	0.8740	0.0	24.0
18.10.25	52.19	43.93	8.26	106.830	105.000	105.390	104.040	1.350	7.00	6.80	0.8660	0.0	24.0
19.10.25	50.75	43.08	7.67	106.970	105.250	105.670	104.320	1.350	7.00	6.80	0.8070	0.0	24.0
20.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-
Итого	---	---	---	2104.0	2067.0	2082.85	2051.89	30.960	---	---	14.8960	0.0	528.0
Среднее	46.53	39.35	7.18	---	---	---	---	---	7.00	6.80	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
26.09.25 24:00	0	0	0	0	0	0	0	0
20.10.25 24:00	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
Итого за период	н/д	н/д	н/д	н/д	н/д	---	н/д	н/д

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Губкина, 1
Потребитель: АО "Жилуправление"
Прибор ТВ7-04.1 Заводской номер: 23200150

БД=1, ТВ1, СИ=6, ФРТ=1, КСН=0хDDC1

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
28.09.25	43.92	38.99	н/д	4.93	6.64	6.52	н/д	217.545	213.770	н/д	215.646	212.325	н/д	3.321	1.192	н/д	24	0
29.09.25	43.54	38.58	н/д	4.96	6.34	6.23	н/д	209.848	206.295	н/д	208.050	204.942	н/д	3.107	1.151	н/д	24	0
30.09.25	44.96	38.52	н/д	6.45	6.33	6.29	н/д	166.827	163.898	н/д	165.291	162.823	н/д	2.468	1.160	н/д	24	0
01.10.25	46.77	39.79	н/д	6.98	6.58	6.54	н/д	164.383	161.488	н/д	162.730	160.362	н/д	2.368	1.230	н/д	24	0
02.10.25	48.94	41.69	н/д	7.25	6.39	6.34	н/д	169.083	166.085	н/д	167.214	164.786	н/д	2.429	1.313	н/д	24	0
03.10.25	47.90	42.14	н/д	5.76	5.06	4.95	н/д	206.615	203.145	н/д	204.426	201.511	н/д	2.915	1.301	н/д	24	0
04.10.25	47.69	41.97	н/д	5.72	4.99	4.88	н/д	206.473	203.008	н/д	204.303	201.388	н/д	2.915	1.291	н/д	24	0
05.10.25	47.82	42.16	н/д	5.66	5.00	4.90	н/д	206.315	202.853	н/д	204.143	201.215	н/д	2.927	1.279	н/д	24	0
06.10.25	46.33	41.06	н/д	5.26	5.00	4.90	н/д	205.428	202.050	н/д	203.396	200.509	н/д	2.887	1.189	н/д	24	0
07.10.25	45.18	40.20	н/д	4.99	5.01	4.90	н/д	205.122	201.783	н/д	203.198	200.315	н/д	2.883	1.129	н/д	24	0
08.10.25	45.27	40.26	н/д	5.01	5.00	4.91	н/д	201.825	198.467	н/д	199.926	197.032	н/д	2.894	1.117	н/д	24	0
09.10.25	44.99	39.93	н/д	5.05	4.91	4.83	н/д	196.803	193.485	н/д	194.968	192.097	н/д	2.872	1.099	н/д	24	0
10.10.25	44.15	39.24	н/д	4.91	4.89	4.81	н/д	190.637	187.485	н/д	188.937	186.202	н/д	2.736	1.035	н/д	24	0
11.10.25	43.37	38.55	н/д	4.81	4.85	4.78	н/д	187.053	184.012	н/д	185.441	182.798	н/д	2.643	0.994	н/д	24	0
12.10.25	43.78	38.73	н/д	5.05	4.83	4.76	н/д	186.857	183.805	н/д	185.214	182.573	н/д	2.641	1.037	н/д	24	0
13.10.25	43.75	38.69	н/д	5.05	4.88	4.81	н/д	186.882	183.835	н/д	185.243	182.603	н/д	2.640	1.038	н/д	24	0
14.10.25	45.53	39.97	н/д	5.55	4.86	4.79	н/д	185.503	182.445	н/д	183.732	181.135	н/д	2.597	1.124	н/д	24	0
15.10.25	46.50	40.77	н/д	5.73	4.90	4.83	н/д	187.560	184.462	н/д	185.692	183.083	н/д	2.609	1.170	н/д	24	0
16.10.25	46.59	40.84	н/д	5.75	4.72	4.65	н/д	181.225	186.643	н/д	179.420	185.238	н/д	-5.818	0.793	н/д	24	0
17.10.25	48.52	42.44	н/д	6.08	5.24	5.13	н/д	205.315	200.798	н/д	203.069	199.157	н/д	3.912	1.401	н/д	24	0
18.10.25	52.16	45.28	н/д	6.88	5.28	5.17	н/д	206.723	203.063	н/д	204.124	201.143	н/д	2.981	1.540	н/д	24	0
19.10.25	52.33	45.54	н/д	6.79	5.29	5.19	н/д	206.720	203.353	н/д	204.100	201.415	н/д	2.685	1.508	н/д	24	0
20.10.25	50.91	44.58	н/д	6.33	5.29	5.18	н/д	208.490	205.160	н/д	205.999	203.285	н/д	2.713	1.424	н/д	24	0
Итого	---	---	---	---	---	---	---	4489.232	4421.388	---	4444.262	4387.937	---	56.325	27.515	---	552	0
Среднее	46.60	40.93	---	5.67	5.32	5.23	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
20.10.25 24:00	38575.708	37982.327	0.000	38045.354	37609.149	0.000	436.205	333.516	0.000	8506	48
Итого за период	н/д	н/д	н/д	н/д	н/д	н/д	---	н/д	н/д	н/д	н/д

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1 Пульсар ДУ-40, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Губкина, 21
 Потребитель: АО "Жилуправление"
 Прибор: 378 Заводской номер: 02816791
 ТВ1

Дата	T1	T2	V1	Q	Время раб. (ч)
19.09.25	18.2	17.9	0.000	0.000	0.00
20.09.25	18.1	17.9	0.000	0.000	0.00
21.09.25	18.1	17.9	0.000	0.000	0.00
22.09.25	18.2	17.9	0.000	0.000	0.00
23.09.25	18.2	18.0	0.000	0.000	0.00
24.09.25	18.3	18.0	0.000	0.000	0.00
25.09.25	18.2	18.0	0.000	0.000	0.00
26.09.25	34.1	30.1	62.008	0.346	17.00
27.09.25	44.3	38.7	94.969	0.528	24.00
28.09.25	43.6	38.2	94.867	0.512	24.00
29.09.25	43.3	37.4	85.852	0.498	24.00
30.09.25	45.0	37.6	72.047	0.525	24.00
01.10.25	46.9	38.9	71.039	0.565	24.00
02.10.25	48.7	40.5	77.648	0.604	24.00
03.10.25	47.5	41.1	92.383	0.591	24.00
04.10.25	47.5	41.1	92.320	0.585	24.00
05.10.25	47.6	41.3	92.391	0.580	24.00
06.10.25	45.7	40.0	91.977	0.522	24.00
07.10.25	45.0	39.4	91.172	0.505	24.00
08.10.25	45.0	39.4	89.641	0.497	24.00
09.10.25	44.7	39.1	88.188	0.485	24.00
10.10.25	43.9	38.6	87.117	0.461	24.00
11.10.25	43.1	38.0	86.797	0.443	24.00
12.10.25	43.6	38.2	86.750	0.465	24.00
13.10.25	43.6	38.1	86.680	0.468	24.00
14.10.25	45.7	39.6	85.781	0.517	24.00
15.10.25	46.3	40.3	90.211	0.540	24.00
16.10.25	46.3	40.6	97.320	0.555	24.00
17.10.25	49.2	42.6	99.539	0.645	24.00
18.10.25	51.9	44.8	99.922	0.703	24.00
19.10.25	52.2	45.0	99.977	0.708	24.00
20.10.25	50.3	43.6	99.703	0.655	24.00
Итого	---	---	2216.297	13.502	593.00
Среднее	39.8	34.9	---	---	---

Показания интеграторов

Дата	V1, м. куб	Q, Гкал	Время раб., ч
18.09.25 24:00	86914.070	771.065	21684.000
20.10.25 24:00	89130.367	784.566	22277.000
Итого за период	2216.297	13.501	593.000

Представитель абонента _____/_____

Представитель поставщика _____/_____

ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Губкина, 22
Потребитель: АО "Жилуправление"
Прибор: ТЭМ-104 Заводской номер: 1648694
Формула: $Q = M1(hп - hо)$
Тип системы: Р-Подача

Система: 1
ТВ1

	ДУ, мм	Gmin, м3/ч	Gmax, м3/ч	Kv, л/имп	Fmax, КГц
1	50	1.5	60	---	---
2	50	1.5	60	---	---

Дата	Q, (Гкал)	M1, (т)	M2, (т)	dM, (т)	T1, (°C)	T2, (°C)	P1, (МПа)	P2, (МПа)	Время наработки, (ч)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-
26.09.25	н/д	н/д	н/д	н/д	36.39	15.80	0.9	0.5	н/д
27.09.25	0.000	0.00	0.00	0.0	15.03	14.73	0.9	0.5	24.00
28.09.25	0.000	0.00	0.00	0.0	14.53	14.26	0.9	0.5	24.00
29.09.25	0.000	0.00	0.00	0.0	14.05	13.77	0.9	0.5	24.00
30.09.25	0.960	150.59	150.57	0.0	45.76	39.46	0.9	0.5	24.00
01.10.25	1.729	284.12	284.90	-0.8	46.89	40.88	0.9	0.5	24.00
02.10.25	1.857	304.63	305.39	-0.8	49.02	43.01	0.9	0.5	24.00
03.10.25	1.782	371.17	372.72	-1.5	47.99	43.26	0.9	0.5	24.00
04.10.25	1.782	372.29	373.75	-1.5	47.80	43.09	0.9	0.5	24.00
05.10.25	1.750	373.38	374.48	-1.1	47.92	43.31	0.9	0.5	24.00
06.10.25	1.609	372.75	373.56	-0.8	46.41	42.17	0.9	0.5	24.00
07.10.25	1.505	370.47	371.35	-0.9	45.29	41.31	0.9	0.5	24.00
08.10.25	1.481	365.12	366.00	-0.9	45.38	41.41	0.9	0.5	24.00
09.10.25	1.453	357.75	358.64	-0.9	45.08	41.10	0.9	0.5	24.00
10.10.25	1.368	351.89	352.79	-0.9	44.25	40.45	0.9	0.5	24.00
11.10.25	1.326	350.66	351.58	-0.9	43.46	39.76	0.9	0.5	24.00
12.10.25	1.391	350.28	351.34	-1.1	43.88	39.99	0.9	0.5	24.00
13.10.25	1.386	350.27	351.43	-1.2	43.84	39.97	0.9	0.5	24.00
14.10.25	1.510	347.29	348.53	-1.2	45.66	41.39	0.9	0.5	24.00
15.10.25	1.603	363.76	364.82	-1.1	46.62	42.30	0.9	0.5	24.00
16.10.25	1.656	408.69	409.32	-0.6	46.73	42.75	0.9	0.5	24.00
17.10.25	1.838	418.91	418.70	0.2	48.70	44.39	0.9	0.5	24.00
18.10.25	2.070	422.70	421.56	1.1	52.31	47.49	0.9	0.5	24.00
19.10.25	2.050	424.79	423.26	1.5	52.49	47.75	0.9	0.5	24.00
20.10.25	1.923	426.80	425.03	1.8	51.03	46.61	0.9	0.5	24.00
Итого	34.03	7538.3	7549.7	-11.6	---	---	---	---	576.00
Среднее	---	---	---	---	42.66	38.02	0.9	0.5	---

Показания интеграторов

Дата	Q, (Гкал)	M1, (т)	M2, (т)	Время наработки, (ч)	Общее время раб. (ч)	Время неработы, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д	н/д	н/д
20.10.25 24:00	4199.20	571588.0	564073.7	47201.7	47196.00	5.665
Итого за период	н/д	н/д	н/д	н/д	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Губкина, 23
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00167058

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0x955A

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	19.35	18.73	0.62	0.000	0.000	0.000	0.000	0.000	7.00	6.80	0.0000	0.0	24.0
20.09.25	19.44	18.80	0.64	0.000	0.000	0.000	0.000	0.000	7.00	6.80	0.0000	0.0	24.0
21.09.25	19.48	18.84	0.64	0.000	0.000	0.000	0.000	0.000	7.00	6.80	0.0000	0.0	24.0
22.09.25	19.60	18.98	0.62	0.000	0.000	0.000	0.000	0.000	7.00	6.80	0.0000	0.0	24.0
23.09.25	19.66	19.04	0.62	0.000	0.000	0.000	0.000	0.000	7.00	6.80	0.0000	0.0	24.0
24.09.25	19.93	19.28	0.65	0.000	0.000	0.000	0.000	0.000	7.00	6.80	0.0000	0.0	24.0
25.09.25	47.12	42.72	4.40	69.490	68.360	68.770	67.760	1.010	7.00	6.80	0.3010	0.0	24.0
26.09.25	41.46	38.09	3.37	115.570	113.430	114.620	112.660	1.960	7.00	6.80	0.3870	0.0	24.0
27.09.25	44.67	40.98	3.69	123.390	120.380	122.190	119.420	2.770	7.00	6.80	0.4510	0.0	24.0
28.09.25	43.89	40.33	3.56	123.450	119.880	122.250	118.920	3.330	7.00	6.80	0.4330	0.0	24.0
29.09.25	43.55	39.84	3.71	115.910	112.430	114.850	111.580	3.270	7.00	6.80	0.4250	0.0	24.0
30.09.25	44.97	40.11	4.86	94.170	91.460	93.210	90.740	2.470	7.00	6.80	0.4570	0.0	24.0
01.10.25	46.78	41.44	5.34	92.770	90.020	91.800	89.300	2.500	7.00	6.80	0.4910	0.0	24.0
02.10.25	48.92	43.45	5.47	97.400	94.550	96.380	93.790	2.590	7.00	6.80	0.5260	0.0	24.0
03.10.25	47.92	43.67	4.25	120.740	116.990	119.490	116.030	3.460	7.00	6.80	0.5080	0.0	24.0
04.10.25	47.73	43.51	4.22	120.540	116.890	119.340	115.930	3.410	7.00	6.80	0.5040	0.0	24.0
05.10.25	47.86	43.67	4.19	120.600	116.880	119.400	115.920	3.480	7.00	6.80	0.5040	0.0	24.0
06.10.25	46.35	42.47	3.88	120.080	116.530	118.880	115.570	3.310	7.00	6.80	0.4600	0.0	24.0
07.10.25	45.23	41.59	3.64	118.940	115.330	117.740	114.370	3.370	7.00	6.80	0.4320	0.0	24.0
08.10.25	45.31	41.68	3.63	117.110	113.680	115.910	112.720	3.190	7.00	6.80	0.4210	0.0	24.0
09.10.25	45.03	41.37	3.66	115.130	111.670	113.950	110.710	3.240	7.00	6.80	0.4160	0.0	24.0
10.10.25	44.19	40.67	3.52	113.480	110.140	112.520	109.180	3.340	7.00	6.80	0.3940	0.0	24.0
11.10.25	43.41	39.99	3.42	112.990	109.660	112.030	108.800	3.230	7.00	6.80	0.3810	0.0	24.0
12.10.25	43.83	40.27	3.56	112.940	109.600	111.980	108.880	3.100	7.00	6.80	0.4030	0.0	24.0
13.10.25	43.80	40.29	3.51	112.800	109.500	111.840	108.760	3.080	7.00	6.80	0.3860	0.0	24.0
14.10.25	45.58	41.75	3.83	111.950	108.570	110.860	107.650	3.210	7.00	6.80	0.4230	0.0	24.0
15.10.25	46.54	42.54	4.00	115.570	112.130	114.370	111.170	3.200	7.00	6.80	0.4610	0.0	24.0
16.10.25	46.65	42.89	3.76	126.620	122.580	125.420	121.620	3.800	7.00	6.80	0.4670	0.0	24.0
17.10.25	48.62	44.53	4.09	129.490	125.450	128.080	124.280	3.800	7.00	6.80	0.5210	0.0	24.0
18.10.25	52.20	47.59	4.61	130.530	126.290	128.850	124.860	3.990	7.00	6.80	0.5960	0.0	24.0
19.10.25	52.38	47.79	4.59	130.370	126.360	128.690	124.920	3.770	7.00	6.80	0.5910	0.0	24.0
20.10.25	50.95	46.73	4.22	130.370	126.090	128.790	124.790	4.000	7.00	6.80	0.5410	0.0	24.0
Итого	---	---	---	2992.3	2904.8	2962.21	2880.33	81.880	---	---	11.8800	0.0	768.0
Среднее	41.32	37.92	3.39	---	---	---	---	---	7.00	6.80	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	27703.990	26907.420	27321.970	26605.160	142.4450	716.810	3020.0	7985.0
20.10.25 24:00	30696.390	29812.270	30284.180	29485.489	154.3250	798.690	3020.0	8753.0
Итого за период	2992.399	2904.850	2962.209	2880.329	11.8800	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Губкина, 23
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00177808

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0х320С

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Мг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	16.03	15.63	0.40	0.000	0.000	0.000	0.000	0.000	1.85	6.00	0.0000	0.0	24.0
20.09.25	15.99	15.60	0.39	0.480	0.480	0.480	0.480	0.000	1.86	6.00	0.0000	0.0	24.0
21.09.25	15.92	15.53	0.39	0.480	0.480	0.480	0.480	0.000	1.91	6.00	0.0000	0.0	24.0
22.09.25	15.96	15.56	0.40	0.000	0.000	0.000	0.000	0.000	2.07	6.00	0.0000	0.0	24.0
23.09.25	16.17	15.66	0.51	0.960	0.960	0.960	0.960	0.000	2.11	6.00	0.0000	0.0	24.0
24.09.25	17.35	16.39	0.96	0.480	0.480	0.480	0.480	0.000	2.06	6.00	0.0000	0.0	24.0
25.09.25	47.60	41.81	5.79	67.910	67.910	67.170	67.350	-0.180	1.87	6.00	0.3830	0.0	24.0
26.09.25	41.71	37.21	4.50	112.870	112.870	111.900	112.130	-0.230	1.72	6.00	0.4950	0.0	24.0
27.09.25	44.73	39.96	4.77	124.910	124.910	123.710	123.950	-0.240	1.26	6.00	0.5760	0.0	24.0
28.09.25	43.94	39.29	4.65	124.820	124.820	123.620	123.860	-0.240	1.10	6.00	0.5590	0.0	24.0
29.09.25	43.58	38.82	4.76	121.570	121.570	120.430	120.670	-0.240	1.53	6.00	0.5600	0.0	24.0
30.09.25	45.04	39.01	6.03	102.250	102.250	101.290	101.530	-0.240	1.43	6.00	0.6030	0.0	24.0
01.10.25	46.88	40.33	6.55	101.070	101.070	100.040	100.300	-0.260	1.52	6.00	0.6430	0.0	24.0
02.10.25	48.97	42.29	6.68	107.000	107.000	105.760	106.070	-0.310	1.57	6.00	0.6930	0.0	24.0
03.10.25	47.94	42.67	5.27	133.300	133.300	131.860	132.100	-0.240	1.58	6.00	0.6800	0.0	24.0
04.10.25	47.75	42.47	5.28	133.390	133.390	131.950	132.190	-0.240	1.47	6.00	0.6800	0.0	24.0
05.10.25	47.88	42.67	5.21	133.600	133.600	132.160	132.400	-0.240	1.55	6.00	0.6740	0.0	24.0
06.10.25	46.34	41.53	4.81	133.120	133.120	131.780	132.050	-0.270	1.05	6.00	0.6180	0.0	24.0
07.10.25	45.24	40.70	4.54	131.950	131.950	130.750	130.990	-0.240	1.26	6.00	0.5750	0.0	24.0
08.10.25	45.32	40.72	4.60	129.960	129.960	128.760	129.000	-0.240	1.26	6.00	0.5750	0.0	24.0
09.10.25	45.03	40.41	4.62	127.420	127.420	126.220	126.460	-0.240	1.29	6.00	0.5710	0.0	24.0
10.10.25	44.20	39.79	4.41	125.350	125.350	124.150	124.390	-0.240	1.29	6.00	0.5290	0.0	24.0
11.10.25	43.41	39.16	4.25	124.810	124.810	123.650	123.870	-0.220	1.09	6.00	0.5110	0.0	24.0
12.10.25	43.83	39.37	4.46	124.770	124.770	123.570	123.810	-0.240	1.82	6.00	0.5340	0.0	24.0
13.10.25	43.80	39.36	4.44	124.780	124.780	123.580	123.820	-0.240	1.68	6.00	0.5330	0.0	24.0
14.10.25	45.62	40.75	4.87	123.830	123.830	122.590	122.870	-0.280	1.48	6.00	0.5820	0.0	24.0
15.10.25	46.57	41.57	5.00	128.050	128.050	126.770	127.010	-0.240	1.54	6.00	0.6210	0.0	24.0
16.10.25	46.65	41.89	4.76	140.320	140.320	138.880	139.120	-0.240	2.88	6.00	0.6530	0.0	24.0
17.10.25	48.67	43.48	5.19	143.660	143.660	142.050	142.370	-0.320	1.37	6.00	0.7230	0.0	24.0
18.10.25	52.23	46.40	5.83	144.790	144.790	142.870	143.350	-0.480	1.36	6.00	0.8220	0.0	24.0
19.10.25	52.41	46.61	5.80	144.870	144.870	142.950	143.430	-0.480	4.93	6.00	0.8260	0.0	24.0
20.10.25	50.94	45.54	5.40	145.020	145.020	143.250	143.610	-0.360	1.96	6.00	0.7620	0.0	24.0
Итого	---	---	---	3257.7	3257.7	3224.11	3231.10	-6.990	---	---	15.9810	0.0	768.0
Среднее	40.74	36.50	4.23	---	---	---	---	---	1.71	6.00	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Мг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	30234.920	30234.920	29825.140	29921.079	195.9140	-95.940	1821.0	7266.0
20.10.25 24:00	33492.710	33492.710	33049.250	33152.179	211.8950	-102.930	1821.0	8034.0
Итого за период	3257.790	3257.790	3224.110	3231.099	15.9810	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Губкина, 23
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00231332

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0x4326

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	15.86	15.62	0.24	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
20.09.25	15.84	15.61	0.23	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
21.09.25	15.80	15.56	0.24	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
22.09.25	16.06	15.84	0.22	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
23.09.25	16.19	15.94	0.25	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
24.09.25	16.85	16.42	0.43	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
25.09.25	47.25	42.42	4.83	57.620	57.460	57.030	56.950	0.080	6.90	6.70	0.2750	0.0	24.0
26.09.25	41.52	37.89	3.63	97.660	97.210	96.880	96.550	0.330	6.90	6.70	0.3490	0.0	24.0
27.09.25	44.59	40.29	4.30	94.660	94.200	93.700	93.470	0.230	6.90	6.70	0.3970	0.0	24.0
28.09.25	43.80	39.62	4.18	94.350	93.750	93.420	93.030	0.390	6.90	6.70	0.3850	0.0	24.0
29.09.25	43.47	38.60	4.87	79.120	78.420	78.380	77.840	0.540	6.90	6.70	0.3840	0.0	24.0
30.09.25	44.87	38.15	6.72	60.880	60.140	60.400	59.660	0.740	6.90	6.70	0.4000	0.0	24.0
01.10.25	46.69	39.45	7.24	60.100	59.390	59.540	58.910	0.630	6.90	6.70	0.4290	0.0	24.0
02.10.25	48.93	41.34	7.59	61.890	61.180	61.170	60.700	0.470	6.90	6.70	0.4640	0.0	24.0
03.10.25	47.78	41.20	6.58	67.140	66.350	66.420	65.870	0.550	6.90	6.70	0.4360	0.0	24.0
04.10.25	47.58	40.90	6.68	66.620	65.790	65.900	65.310	0.590	6.90	6.70	0.4340	0.0	24.0
05.10.25	47.71	41.06	6.65	66.320	65.490	65.600	65.010	0.590	6.90	6.70	0.4320	0.0	24.0
06.10.25	46.20	40.03	6.17	65.960	65.070	65.240	64.590	0.650	6.90	6.70	0.4020	0.0	24.0
07.10.25	45.07	39.24	5.83	65.410	64.530	64.690	64.050	0.640	6.90	6.70	0.3790	0.0	24.0
08.10.25	45.16	39.35	5.81	64.680	63.800	63.980	63.320	0.660	6.90	6.70	0.3720	0.0	24.0
09.10.25	44.88	39.02	5.86	63.890	63.010	63.260	62.530	0.730	6.90	6.70	0.3710	0.0	24.0
10.10.25	44.04	38.49	5.55	63.270	62.350	62.790	61.870	0.920	6.90	6.70	0.3480	0.0	24.0
11.10.25	43.26	37.87	5.39	63.040	62.140	62.560	61.660	0.900	6.90	6.70	0.3390	0.0	24.0
12.10.25	43.68	37.99	5.69	62.980	62.080	62.500	61.600	0.900	6.90	6.70	0.3590	0.0	24.0
13.10.25	43.64	37.98	5.66	62.970	62.060	62.490	61.580	0.910	6.90	6.70	0.3590	0.0	24.0
14.10.25	45.44	39.26	6.18	62.670	61.770	62.060	61.290	0.770	6.90	6.70	0.3850	0.0	24.0
15.10.25	46.40	39.89	6.51	62.690	61.780	61.970	61.300	0.670	6.90	6.70	0.4060	0.0	24.0
16.10.25	46.49	39.85	6.64	63.450	62.510	62.730	62.030	0.700	6.90	6.70	0.4140	0.0	24.0
17.10.25	48.44	41.14	7.30	64.170	63.200	63.450	62.720	0.730	6.90	6.70	0.4610	0.0	24.0
18.10.25	52.05	43.83	8.22	64.260	63.320	63.540	62.840	0.700	6.90	6.70	0.5190	0.0	24.0
19.10.25	52.23	44.10	8.13	64.170	63.190	63.450	62.710	0.740	6.90	6.70	0.5110	0.0	24.0
20.10.25	50.56	44.27	6.29	80.150	79.090	79.220	78.390	0.830	6.90	6.70	0.4950	0.0	24.0
Итого	---	---	---	1780.1	1759.2	1762.37	1745.78	16.590	---	---	10.5050	0.0	768.0
Среднее	40.57	35.56	5.00	---	---	---	---	---	6.90	6.70	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	0.900	0.000	0.900	0.000	0.0010	0.900	1168.0	1191.0
20.10.25 24:00	1781.020	1759.279	1763.270	1745.780	10.5060	17.490	1168.0	1959.0
Итого за период	1780.120	1759.279	1762.370	1745.780	10.5050	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Губкина, 25
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00178829

БД=1, ТВ1, СИ=3, КТ3=0, ФРТ=0, КСН=0xF572

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	17.36	17.36	0.00	0.000	0.000	0.000	0.000	0.000	6.90	6.00	0.0000	0.0	24.0
20.09.25	17.28	17.28	0.00	0.000	0.000	0.000	0.000	0.000	6.90	6.00	0.0000	0.0	24.0
21.09.25	17.23	17.25	-0.02	0.000	0.000	0.000	0.000	0.000	6.90	6.00	0.0000	0.0	24.0
22.09.25	17.29	17.33	-0.04	0.000	0.000	0.000	0.000	0.000	6.90	6.00	0.0000	0.0	24.0
23.09.25	17.32	17.35	-0.03	0.000	0.000	0.000	0.000	0.000	6.90	6.00	0.0000	0.0	24.0
24.09.25	17.37	17.40	-0.03	0.000	0.000	0.000	0.000	0.000	6.90	6.00	0.0000	0.0	24.0
25.09.25	17.33	17.32	0.01	0.000	0.000	0.000	0.000	0.000	6.90	6.00	0.0000	0.0	24.0
26.09.25	16.92	16.81	0.11	0.000	0.000	0.000	0.000	0.000	6.90	6.00	0.0000	0.0	24.0
27.09.25	17.13	17.10	0.03	0.000	0.000	0.000	0.000	0.000	6.90	6.00	0.0000	0.0	24.0
28.09.25	17.47	17.35	0.12	0.000	0.000	0.000	0.000	0.000	6.90	6.00	0.0000	0.0	24.0
29.09.25	43.10	38.73	4.37	227.470	226.800	225.490	225.210	0.280	6.90	6.00	0.9830	0.0	24.0
30.09.25	44.80	39.95	4.85	371.090	367.830	367.600	365.070	2.530	6.90	6.00	1.7840	0.0	24.0
01.10.25	46.63	41.44	5.19	366.260	367.870	362.520	364.870	-2.350	6.90	6.00	1.8820	0.0	24.0
02.10.25	48.75	43.52	5.23	384.170	387.070	379.920	383.620	-3.700	6.90	6.00	1.9930	0.0	24.0
03.10.25	47.71	43.74	3.97	474.320	478.800	469.240	474.480	-5.240	6.90	6.00	1.8660	0.0	24.0
04.10.25	47.52	43.52	4.00	473.770	478.710	468.730	474.410	-5.680	6.90	6.00	1.8790	0.0	24.0
05.10.25	47.64	43.66	3.98	474.030	478.950	468.990	474.630	-5.640	6.90	6.00	1.8770	0.0	24.0
06.10.25	46.12	42.43	3.69	473.900	479.080	469.200	475.010	-5.810	6.90	6.00	1.7340	0.0	24.0
07.10.25	45.01	41.52	3.49	469.600	474.840	465.100	471.000	-5.900	6.90	6.00	1.6270	0.0	24.0
08.10.25	45.09	41.61	3.48	462.550	467.720	458.160	463.920	-5.760	6.90	6.00	1.5970	0.0	24.0
09.10.25	44.81	41.33	3.48	455.130	460.160	450.820	456.510	-5.690	6.90	6.00	1.5700	0.0	24.0
10.10.25	43.96	40.69	3.27	448.810	453.390	444.730	449.800	-5.070	6.90	6.00	1.4610	0.0	24.0
11.10.25	43.18	40.01	3.17	446.990	451.210	443.080	447.800	-4.720	6.90	6.00	1.4120	0.0	24.0
12.10.25	43.61	40.26	3.35	446.660	451.460	442.620	448.100	-5.480	6.90	6.00	1.4820	0.0	24.0
13.10.25	43.57	40.22	3.35	446.430	451.740	442.460	448.370	-5.910	6.90	6.00	1.4890	0.0	24.0
14.10.25	45.38	41.71	3.67	442.280	448.130	437.980	444.490	-6.510	6.90	6.00	1.6140	0.0	24.0
15.10.25	46.33	42.57	3.76	456.760	462.550	452.160	458.560	-6.400	6.90	6.00	1.7090	0.0	24.0
16.10.25	46.42	42.85	3.57	499.220	505.380	494.180	501.060	-6.880	6.90	6.00	1.7720	0.0	24.0
17.10.25	48.41	44.52	3.89	511.070	516.570	505.460	511.760	-6.300	6.90	6.00	1.9660	0.0	24.0
18.10.25	51.99	47.61	4.38	514.750	520.250	508.270	514.730	-6.460	6.90	6.00	2.2300	0.0	24.0
19.10.25	52.17	47.83	4.34	514.740	520.560	508.260	515.040	-6.780	6.90	6.00	2.2090	0.0	24.0
20.10.25	50.73	46.69	4.04	514.170	519.890	508.020	514.570	-6.550	6.90	6.00	2.0540	0.0	24.0
Итого	---	---	---	9874.1	9968.9	9772.99	9883.01	-110.020	---	---	38.1900	0.0	768.0
Среднее	37.36	34.65	2.70	---	---	---	---	---	6.90	6.00	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	67361.890	67966.800	66434.190	67247.800	463.1270	-813.610	1823.0	6129.0
20.10.25 24:00	77236.060	77935.760	76207.180	77130.810	501.3170	-923.630	1823.0	6897.0
Итого за период	9874.169	9968.959	9772.989	9883.009	38.1900	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ИМ2300, Суточный с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Губкина, 26
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BA876

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-
26.09.25	0.03	16.21	508.45	16.19	0.00	15.31	24.00	0.00	0.00
27.09.25	0.88	27.99	371.62	25.63	334.59	11.18	24.00	0.00	0.00
28.09.25	1.97	43.73	544.31	40.11	546.20	24.00	24.00	0.00	0.00
29.09.25	1.89	43.04	541.56	39.54	541.56	24.00	24.00	0.00	0.00
30.09.25	1.87	42.67	521.08	39.04	519.91	24.00	24.00	0.00	0.00
01.10.25	2.00	44.09	428.53	39.40	427.66	24.00	24.00	0.00	0.00
02.10.25	2.14	45.86	416.50	40.72	419.02	24.00	24.00	0.00	0.00
03.10.25	2.29	48.15	435.35	42.65	438.27	24.00	24.00	0.00	0.00
04.10.25	2.20	46.95	543.93	42.89	549.63	24.00	24.00	0.00	0.00
05.10.25	2.19	46.68	537.29	42.60	542.40	24.00	24.00	0.00	0.00
06.10.25	2.17	46.82	539.62	42.78	544.69	24.00	24.00	0.00	0.00
07.10.25	1.97	45.30	537.87	41.63	542.66	24.00	24.00	0.00	0.00
08.10.25	1.86	44.15	534.37	40.66	539.04	24.00	24.00	0.00	0.00
09.10.25	1.83	44.23	527.73	40.76	532.66	24.00	24.00	0.00	0.00
10.10.25	1.80	44.21	521.06	40.74	525.72	24.00	24.00	0.00	0.00
11.10.25	1.70	43.08	514.22	39.76	518.30	24.00	24.00	0.00	0.00
12.10.25	1.64	42.29	512.79	39.09	516.70	24.00	24.00	0.00	0.00
13.10.25	1.73	42.96	512.53	39.58	516.25	24.00	24.00	0.00	0.00
14.10.25	1.73	42.96	512.53	39.57	516.02	24.00	24.00	0.00	0.00
15.10.25	1.89	44.78	507.75	41.04	511.18	24.00	24.00	0.00	0.00
16.10.25	2.00	45.72	523.53	41.89	527.46	24.00	24.00	0.00	0.00
17.10.25	2.06	45.68	572.22	42.07	577.47	24.00	24.00	0.00	0.00
18.10.25	2.30	47.69	585.15	43.76	590.83	24.00	24.00	0.00	0.00
19.10.25	2.64	51.27	588.22	46.77	594.14	24.00	24.00	0.00	0.00
20.10.25	2.61	50.97	588.54	46.52	594.46	24.00	24.00	0.00	0.00
Итого	47.39	---	12926.75	---	12466.82	578.49	600.00	0.00	0.00
Среднее	---	43.499	---	39.816	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	50.20	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Губкина, 27
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВА900

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-
25.09.25	0.00	19.14	0.00	18.75	0.00	24.00	24.00	0.00	0.00
26.09.25	0.67	28.40	121.81	26.10	123.15	23.98	24.00	0.00	0.00
27.09.25	1.34	41.51	314.51	37.22	317.24	24.00	24.00	0.00	0.00
28.09.25	1.59	44.55	341.02	39.87	344.07	24.00	24.00	0.00	0.00
29.09.25	1.55	43.76	339.43	39.19	342.32	24.00	24.00	0.00	0.00
30.09.25	1.53	43.38	328.23	38.69	331.32	24.00	24.00	0.00	0.00
01.10.25	1.64	44.81	296.45	39.27	303.88	24.00	24.00	0.00	0.00
02.10.25	1.74	46.59	288.72	40.55	299.30	24.00	24.00	0.00	0.00
03.10.25	1.89	48.96	305.56	42.52	314.00	24.00	24.00	0.00	0.00
04.10.25	1.85	47.79	385.91	42.97	392.66	24.00	24.00	0.00	0.00
05.10.25	1.86	47.57	388.35	42.77	392.81	24.00	24.00	0.00	0.00
06.10.25	1.83	47.69	388.60	42.96	393.26	24.00	24.00	0.00	0.00
07.10.25	1.68	46.24	386.95	41.88	391.62	24.00	24.00	0.00	0.00
08.10.25	1.57	45.06	384.20	40.96	388.95	24.00	24.00	0.00	0.00
09.10.25	1.55	45.16	378.86	41.05	383.57	24.00	24.00	0.00	0.00
10.10.25	1.52	44.88	371.56	40.79	376.25	24.00	24.00	0.00	0.00
11.10.25	1.43	44.04	365.52	40.13	370.25	24.00	24.00	0.00	0.00
12.10.25	1.38	43.26	366.13	39.50	370.65	24.00	24.00	0.00	0.00
13.10.25	1.45	43.67	366.01	39.69	370.37	24.00	24.00	0.00	0.00
14.10.25	1.46	43.63	365.43	39.62	369.99	24.00	24.00	0.00	0.00
15.10.25	1.60	45.39	360.81	40.95	365.34	24.00	24.00	0.00	0.00
16.10.25	1.69	46.38	371.26	41.82	375.74	24.00	24.00	0.00	0.00
17.10.25	1.74	46.49	406.91	42.20	411.34	24.00	24.00	0.00	0.00
18.10.25	1.94	48.32	415.98	43.65	420.70	24.00	24.00	0.00	0.00
19.10.25	2.21	52.05	418.52	46.75	423.69	24.00	24.00	0.00	0.00
20.10.25	2.20	52.21	418.54	46.95	423.91	24.00	24.00	0.00	0.00
Итого	40.91	---	8875.27	---	8996.38	623.98	624.00	0.00	0.00
Среднее	---	44.267	---	39.877	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	6649.27	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Губкина, 28
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00168989

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0x4298

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Мг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	16.23	15.98	0.25	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
20.09.25	16.25	15.99	0.26	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
21.09.25	16.21	15.92	0.29	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
22.09.25	16.27	15.92	0.35	0.000	9.380	0.000	9.380	-9.380	6.20	6.00	0.0000	0.0	24.0
23.09.25	16.42	15.97	0.45	0.000	14.230	0.000	14.230	-14.230	6.20	6.00	0.0000	0.0	24.0
24.09.25	16.57	16.04	0.53	0.000	18.050	0.000	18.050	-18.050	6.20	6.00	0.0000	0.0	24.0
25.09.25	16.52	16.06	0.46	0.000	22.000	0.000	22.000	-22.000	6.20	6.00	0.0000	0.0	24.0
26.09.25	37.72	16.11	21.61	0.640	16.090	0.640	16.090	-15.450	6.20	6.00	0.0130	0.0	24.0
27.09.25	19.43	19.71	-0.28	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
28.09.25	18.98	19.83	-0.85	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
29.09.25	43.05	35.89	7.16	105.140	104.690	104.230	104.070	0.160	6.20	6.00	0.7380	0.0	24.0
30.09.25	44.67	36.26	8.41	153.740	150.820	152.300	149.860	2.440	6.20	6.00	1.2770	0.0	24.0
01.10.25	46.51	37.23	9.28	145.020	141.300	143.520	140.340	3.180	6.20	6.00	1.3270	0.0	24.0
02.10.25	48.69	39.24	9.45	151.310	147.060	149.620	145.980	3.640	6.20	6.00	1.4130	0.0	24.0
03.10.25	47.68	40.67	7.01	199.210	194.760	197.110	193.180	3.930	6.20	6.00	1.3820	0.0	24.0
04.10.25	47.50	40.10	7.40	182.210	178.500	180.280	177.140	3.140	6.20	6.00	1.3340	0.0	24.0
05.10.25	47.62	40.43	7.19	186.940	183.510	185.020	182.070	2.950	6.20	6.00	1.3310	0.0	24.0
06.10.25	46.14	39.52	6.62	186.570	183.160	184.760	181.840	2.920	6.20	6.00	1.2210	0.0	24.0
07.10.25	44.99	38.75	6.24	185.020	181.670	183.340	180.470	2.870	6.20	6.00	1.1430	0.0	24.0
08.10.25	45.09	38.95	6.14	185.730	182.850	183.970	181.570	2.400	6.20	6.00	1.1270	0.0	24.0
09.10.25	44.79	38.84	5.95	190.160	187.400	188.380	186.070	2.310	6.20	6.00	1.1190	0.0	24.0
10.10.25	43.96	38.32	5.64	189.560	186.720	187.880	185.520	2.360	6.20	6.00	1.0570	0.0	24.0
11.10.25	43.18	37.75	5.43	188.850	185.830	187.210	184.630	2.580	6.20	6.00	1.0170	0.0	24.0
12.10.25	43.59	37.86	5.73	188.440	185.630	186.760	184.430	2.330	6.20	6.00	1.0710	0.0	24.0
13.10.25	43.56	37.87	5.69	188.530	185.860	186.850	184.660	2.190	6.20	6.00	1.0570	0.0	24.0
14.10.25	45.33	39.11	6.22	187.250	184.480	185.440	183.160	2.280	6.20	6.00	1.1550	0.0	24.0
15.10.25	46.31	39.93	6.38	192.950	189.970	190.960	188.460	2.500	6.20	6.00	1.2150	0.0	24.0
16.10.25	46.42	40.37	6.05	210.800	208.040	208.640	206.360	2.280	6.20	6.00	1.2600	0.0	24.0
17.10.25	48.34	41.77	6.57	216.200	213.290	213.800	211.530	2.270	6.20	6.00	1.4000	0.0	24.0
18.10.25	51.97	44.54	7.43	217.490	214.410	214.770	212.490	2.280	6.20	6.00	1.5960	0.0	24.0
19.10.25	52.14	44.73	7.41	217.750	214.890	214.990	212.970	2.020	6.20	6.00	1.5900	0.0	24.0
20.10.25	50.74	43.87	6.87	218.230	215.330	215.580	213.360	2.220	6.20	6.00	1.4770	0.0	24.0
Итого	---	---	---	4087.7	4099.9	4046.05	4069.91	-23.860	---	---	27.3200	0.0	768.0
Среднее	37.90	32.48	5.41	---	---	---	---	---	6.20	6.00	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Мг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	39351.510	39056.930	38823.980	38703.380	370.0920	120.600	2332.0	6918.0
20.10.25 24:00	43439.249	43156.850	42870.030	42773.289	397.4120	100096.740	2332.0	7686.0
Итого за период	4087.739	4099.919	4046.049	4069.908	27.3200	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Губкина, 30
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00284441

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0х9D9D

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	17.63	17.50	0.13	7.680	0.000	7.680	0.000	7.680	7.00	6.00	0.0000	0.0	24.0
20.09.25	17.54	17.46	0.08	7.680	0.000	7.680	0.000	7.680	7.00	6.00	0.0000	0.0	24.0
21.09.25	17.49	17.40	0.09	7.360	0.000	7.360	0.000	7.360	7.00	6.00	0.0000	0.0	24.0
22.09.25	17.54	17.46	0.08	7.040	0.320	7.040	0.320	6.720	7.00	6.00	0.0000	0.0	24.0
23.09.25	17.63	17.49	0.14	7.680	0.000	7.680	0.000	7.680	7.00	6.00	0.0000	0.0	24.0
24.09.25	17.76	17.58	0.18	7.360	0.000	7.360	0.000	7.360	7.00	6.00	0.0000	0.0	24.0
25.09.25	17.78	17.60	0.18	7.680	0.000	7.680	0.000	7.680	7.00	6.00	0.0000	0.0	24.0
26.09.25	39.77	34.38	5.39	120.430	118.160	119.530	117.510	2.020	7.00	6.00	0.6920	0.0	24.0
27.09.25	44.20	38.42	5.78	222.070	223.720	220.050	222.190	-2.140	7.00	6.00	1.2760	0.0	24.0
28.09.25	43.49	37.97	5.52	220.460	222.230	218.540	220.790	-2.250	7.00	6.00	1.2080	0.0	24.0
29.09.25	43.20	37.39	5.81	202.590	204.530	200.840	203.220	-2.380	7.00	6.00	1.1690	0.0	24.0
30.09.25	44.52	36.33	8.19	145.030	147.440	143.730	146.570	-2.840	7.00	6.00	1.1770	0.0	24.0
01.10.25	46.43	36.71	9.72	128.230	131.220	126.970	130.450	-3.480	7.00	6.00	1.2320	0.0	24.0
02.10.25	48.68	38.46	10.22	131.600	135.230	130.140	134.270	-4.130	7.00	6.00	1.3300	0.0	24.0
03.10.25	47.63	40.35	7.28	186.760	191.190	184.800	189.720	-4.920	7.00	6.00	1.3450	0.0	24.0
04.10.25	47.54	38.89	8.65	149.940	154.200	148.420	153.170	-4.750	7.00	6.00	1.2830	0.0	24.0
05.10.25	47.65	39.47	8.18	160.610	165.050	158.930	163.850	-4.920	7.00	6.00	1.3040	0.0	24.0
06.10.25	46.23	38.67	7.56	160.030	164.460	158.460	163.260	-4.800	7.00	6.00	1.1960	0.0	24.0
07.10.25	45.04	37.97	7.07	158.920	163.290	157.480	162.090	-4.610	7.00	6.00	1.1160	0.0	24.0
08.10.25	45.14	38.29	6.85	164.580	169.010	163.060	167.850	-4.790	7.00	6.00	1.1180	0.0	24.0
09.10.25	44.83	38.45	6.38	178.820	183.430	177.140	182.230	-5.090	7.00	6.00	1.1310	0.0	24.0
10.10.25	43.98	38.08	5.90	180.440	185.050	178.760	183.850	-5.090	7.00	6.00	1.0530	0.0	24.0
11.10.25	43.21	37.51	5.70	179.890	184.420	178.290	183.220	-4.930	7.00	6.00	1.0160	0.0	24.0
12.10.25	43.61	37.64	5.97	179.750	184.310	178.070	183.110	-5.040	7.00	6.00	1.0630	0.0	24.0
13.10.25	43.57	37.55	6.02	179.600	184.260	177.920	183.060	-5.140	7.00	6.00	1.0750	0.0	24.0
14.10.25	45.29	38.72	6.57	178.070	182.820	176.330	181.550	-5.220	7.00	6.00	1.1580	0.0	24.0
15.10.25	46.30	39.55	6.75	183.370	188.260	181.600	186.900	-5.300	7.00	6.00	1.2260	0.0	24.0
16.10.25	46.44	39.99	6.45	200.820	205.910	198.900	204.440	-5.540	7.00	6.00	1.2820	0.0	24.0
17.10.25	48.26	41.25	7.01	205.480	210.790	203.250	209.130	-5.880	7.00	6.00	1.4260	0.0	24.0
18.10.25	51.96	43.97	7.99	206.690	212.200	204.050	210.280	-6.230	7.00	6.00	1.6290	0.0	24.0
19.10.25	52.12	44.20	7.92	206.550	212.130	203.910	210.210	-6.300	7.00	6.00	1.6150	0.0	24.0
20.10.25	50.78	43.37	7.41	207.560	213.050	205.080	211.170	-6.090	7.00	6.00	1.5200	0.0	24.0
Итого	---	---	---	4490.7	4536.6	4446.73	4504.41	-57.680	---	---	30.6400	0.0	768.0
Среднее	39.78	34.25	5.53	---	---	---	---	---	7.00	6.00	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	45294.510	46324.860	44696.750	45890.650	384.0190	-1193.900	19.0	8630.0
20.10.25 24:00	49785.280	50861.540	49143.480	50395.060	414.6590	-1251.580	19.0	9398.0
Итого за период	4490.769	4536.680	4446.730	4504.409	30.6400	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Губкина, 31
Потребитель: АО "Жилуправление"
Прибор: ТВ7-01 Заводской номер: 20133745

БД=1, ТВ1, СИ=7, КТЗ=0, ФРТ=0, КСН=0х93ВА

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	15.83	15.20	н/д	0.63	5.20	5.00	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
20.09.25	15.85	15.23	н/д	0.62	5.20	5.00	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
21.09.25	15.66	14.99	н/д	0.67	5.20	5.00	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
22.09.25	16.07	15.58	н/д	0.50	5.20	5.00	н/д	0.170	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	23	1
23.09.25	15.98	15.43	н/д	0.56	5.20	5.00	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
24.09.25	16.23	15.59	н/д	0.63	5.20	5.00	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
25.09.25	45.06	41.36	н/д	3.71	5.20	5.00	н/д	47.252	н/д	н/д	46.809	н/д	н/д	н/д	0.174	н/д	24	0
26.09.25	41.58	38.51	н/д	3.07	5.20	5.00	н/д	108.841	н/д	н/д	107.983	н/д	н/д	н/д	0.331	н/д	24	0
27.09.25	44.58	41.13	н/д	3.46	5.20	5.00	н/д	111.635	н/д	н/д	110.614	н/д	н/д	н/д	0.382	н/д	24	0
28.09.25	43.79	40.34	н/д	3.45	5.20	5.00	н/д	109.689	н/д	н/д	108.724	н/д	н/д	н/д	0.375	н/д	24	0
29.09.25	43.41	39.80	н/д	3.61	5.20	5.00	н/д	105.804	н/д	н/д	104.889	н/д	н/д	н/д	0.379	н/д	24	0
30.09.25	44.83	40.06	н/д	4.77	5.20	5.00	н/д	85.802	н/д	н/д	85.008	н/д	н/д	н/д	0.406	н/д	24	0
01.10.25	46.65	41.47	н/д	5.18	5.20	5.00	н/д	84.220	н/д	н/д	83.374	н/д	н/д	н/д	0.432	н/д	24	0
02.10.25	48.78	43.46	н/д	5.32	5.20	5.00	н/д	88.940	н/д	н/д	87.957	н/д	н/д	н/д	0.468	н/д	24	0
03.10.25	47.77	43.65	н/д	4.12	5.20	5.00	н/д	110.493	н/д	н/д	109.329	н/д	н/д	н/д	0.450	н/д	24	0
04.10.25	47.56	43.40	н/д	4.16	5.20	5.00	н/д	109.822	н/д	н/д	108.672	н/д	н/д	н/д	0.452	н/д	24	0
05.10.25	47.69	43.56	н/д	4.13	5.20	5.00	н/д	109.092	н/д	н/д	107.938	н/д	н/д	н/д	0.446	н/д	24	0
06.10.25	46.18	42.37	н/д	3.81	5.20	5.00	н/д	107.587	н/д	н/д	106.527	н/д	н/д	н/д	0.406	н/д	24	0
07.10.25	45.06	41.45	н/д	3.61	5.20	5.00	н/д	106.416	н/д	н/д	105.419	н/д	н/д	н/д	0.380	н/д	24	0
08.10.25	45.14	41.50	н/д	3.65	5.20	5.00	н/д	103.878	н/д	н/д	102.900	н/д	н/д	н/д	0.376	н/д	24	0
09.10.25	44.85	41.17	н/д	3.68	5.20	5.00	н/д	101.071	н/д	н/д	100.135	н/д	н/д	н/д	0.369	н/д	24	0
10.10.25	44.02	40.48	н/д	3.54	5.20	5.00	н/д	98.945	н/д	н/д	98.065	н/д	н/д	н/д	0.348	н/д	24	0
11.10.25	43.24	39.80	н/д	3.44	5.20	5.00	н/д	100.013	н/д	н/д	99.157	н/д	н/д	н/д	0.341	н/д	24	0
12.10.25	43.65	40.01	н/д	3.64	5.20	5.00	н/д	99.758	н/д	н/д	98.887	н/д	н/д	н/д	0.360	н/д	24	0
13.10.25	43.62	40.03	н/д	3.59	5.20	5.00	н/д	99.916	н/д	н/д	99.043	н/д	н/д	н/д	0.356	н/д	24	0
14.10.25	45.42	41.44	н/д	3.98	5.20	5.00	н/д	98.130	н/д	н/д	97.195	н/д	н/д	н/д	0.387	н/д	24	0
15.10.25	46.38	42.35	н/д	4.02	5.20	5.00	н/д	103.615	н/д	н/д	102.583	н/д	н/д	н/д	0.413	н/д	24	0
16.10.25	46.47	42.76	н/д	3.71	5.20	5.00	н/д	116.279	н/д	н/д	115.119	н/д	н/д	н/д	0.427	н/д	24	0
17.10.25	48.44	44.34	н/д	4.10	5.20	5.00	н/д	116.951	н/д	н/д	115.676	н/д	н/д	н/д	0.474	н/д	24	0
18.10.25	52.03	47.37	н/д	4.66	5.20	5.00	н/д	116.105	н/д	н/д	114.648	н/д	н/д	н/д	0.535	н/д	24	0
19.10.25	52.21	47.60	н/д	4.61	5.20	5.00	н/д	115.129	н/д	н/д	113.672	н/д	н/д	н/д	0.524	н/д	24	0
20.10.25	50.75	46.55	н/д	4.19	5.20	5.00	н/д	118.318	н/д	н/д	116.904	н/д	н/д	н/д	0.491	н/д	24	0
Итого	---	---	---	---	---	---	---	2673.871	---	---	2647.227	---	---	---	10.482	---	767	1
Среднее	46.23	42.27	---	3.96	5.20	5.00	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	20534.099	0.000	0.000	19027.373	0.000	0.000	0.000	124.581	0.000	9344	1638
20.10.25 24:00	23207.970	0.000	0.000	21674.599	0.000	0.000	0.000	135.062	0.000	10111	1639
Итого за период	2673.871	0.000	0.000	2647.226	0.000	0.000	---	10.481	0.000	767	1

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Губкина, 35
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00166935

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0х38А7

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
28.09.25	43.39	37.18	6.21	96.460	96.180	95.510	95.460	0.050	7.00	6.80	0.5950	0.0	24.0
29.09.25	43.05	36.67	6.38	92.560	91.970	91.740	91.350	0.390	7.00	6.80	0.5850	0.0	24.0
30.09.25	44.45	36.20	8.25	74.690	74.110	73.970	73.630	0.340	7.00	6.80	0.6070	0.0	24.0
01.10.25	46.25	37.22	9.03	73.630	73.010	72.900	72.530	0.370	7.00	6.80	0.6570	0.0	24.0
02.10.25	48.38	39.29	9.09	78.540	77.840	77.740	77.310	0.430	7.00	6.80	0.7080	0.0	24.0
03.10.25	47.44	40.31	7.13	98.940	98.110	97.980	97.390	0.590	7.00	6.80	0.6980	0.0	24.0
04.10.25	47.25	40.13	7.12	98.970	98.090	98.010	97.370	0.640	7.00	6.80	0.6960	0.0	24.0
05.10.25	47.38	40.28	7.10	99.120	98.190	98.160	97.470	0.690	7.00	6.80	0.6960	0.0	24.0
06.10.25	45.89	39.34	6.55	98.190	97.290	97.230	96.570	0.660	7.00	6.80	0.6360	0.0	24.0
07.10.25	44.78	38.61	6.17	97.500	96.620	96.540	95.900	0.640	7.00	6.80	0.5980	0.0	24.0
08.10.25	44.86	38.69	6.17	96.320	95.490	95.360	94.770	0.590	7.00	6.80	0.5880	0.0	24.0
09.10.25	44.58	38.42	6.16	94.270	93.490	93.310	92.770	0.540	7.00	6.80	0.5750	0.0	24.0
10.10.25	43.74	37.84	5.90	93.250	92.480	92.490	91.760	0.730	7.00	6.80	0.5510	0.0	24.0
11.10.25	42.97	37.38	5.59	96.120	95.350	95.260	94.670	0.590	7.00	6.80	0.5310	0.0	24.0
12.10.25	43.38	37.59	5.79	96.200	95.400	95.240	94.680	0.560	7.00	6.80	0.5520	0.0	24.0
13.10.25	43.34	37.42	5.92	95.420	94.600	94.540	93.900	0.640	7.00	6.80	0.5540	0.0	24.0
14.10.25	45.11	38.50	6.61	92.260	91.420	91.400	90.710	0.690	7.00	6.80	0.6070	0.0	24.0
15.10.25	46.08	39.21	6.87	95.220	94.300	94.260	93.580	0.680	7.00	6.80	0.6470	0.0	24.0
16.10.25	46.20	39.64	6.56	103.940	102.950	102.980	102.230	0.750	7.00	6.80	0.6730	0.0	24.0
17.10.25	48.15	41.07	7.08	106.510	105.440	105.360	104.630	0.730	7.00	6.80	0.7480	0.0	24.0
18.10.25	51.71	43.72	7.99	106.800	105.630	105.430	104.670	0.760	7.00	6.80	0.8420	0.0	24.0
19.10.25	51.89	43.97	7.92	105.690	104.530	104.360	103.570	0.790	7.00	6.80	0.8230	0.0	24.0
20.10.25	50.47	43.23	7.24	107.100	105.940	105.800	105.000	0.800	7.00	6.80	0.7670	0.0	24.0
Итого	---	---	---	2197.7	2178.4	2175.57	2161.92	13.650	---	---	14.9340	0.0	552.0
Среднее	46.11	39.21	6.90	---	---	---	---	---	7.00	6.80	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
26.09.25 24:00	0	0	0	0	0	0	0	0
20.10.25 24:00	23202.369	22872.509	22910.570	22678.390	207.4930	232.180	1056.0	10719.0
Итого за период	23202.369	22872.509	22910.570	22678.390	207.4930	---	1056.0	10719.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Губкина, 5
 Потребитель: АО "Жилуправление"
 Прибор: Вzlёт ТСРВ-024 Заводской номер: 902002
 Тип системы: А32-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	20.06	20.58	-0.52	0.00	0.00	0.00	0.131	0.600	0.00	0.00	0.00	0.000	0.000
20.09.25	19.94	20.46	-0.52	0.00	0.00	0.00	0.131	0.600	0.00	0.00	0.00	0.000	0.000
21.09.25	19.84	20.36	-0.52	0.00	0.00	0.00	0.132	0.600	0.00	0.00	0.00	0.000	0.000
22.09.25	19.74	20.25	-0.51	0.00	0.00	0.00	0.133	0.600	0.00	0.00	0.00	0.000	0.000
23.09.25	19.78	20.33	-0.55	0.00	0.00	0.00	0.133	0.600	0.00	0.00	0.00	0.000	0.000
24.09.25	19.80	20.32	-0.52	0.00	0.00	0.00	0.135	0.600	0.00	0.00	0.00	0.000	0.000
25.09.25	19.85	20.30	-0.45	0.00	0.00	0.00	0.134	0.600	0.00	0.00	0.00	0.000	0.000
26.09.25	25.06	24.58	0.48	53.15	53.83	-0.68	0.254	0.600	53.46	54.25	-0.78	0.055	1.167
27.09.25	44.43	41.58	2.85	204.88	207.53	-2.65	0.666	0.600	206.37	209.67	-3.31	0.157	5.917
28.09.25	44.03	41.22	2.81	198.74	201.40	-2.66	0.674	0.600	200.26	203.33	-3.07	0.112	4.333
29.09.25	43.74	40.97	2.77	200.99	203.14	-2.15	0.649	0.600	202.51	205.05	-2.54	0.136	5.250
30.09.25	44.31	40.86	3.45	168.93	169.25	-0.32	0.659	0.600	169.43	171.66	-2.23	0.515	21.083
01.10.25	45.93	42.10	3.83	161.20	161.20	0.00	0.632	0.600	161.61	163.77	-2.16	0.618	24.000
02.10.25	49.43	44.80	4.63	153.76	153.79	-0.03	0.702	0.600	154.31	156.47	-2.16	0.693	23.667
03.10.25	48.11	44.84	3.27	203.21	203.21	0	0.521	0.600	204.14	206.46	-2.33	0.658	24.000
04.10.25	47.68	44.53	3.15	203.46	203.46	0.00	0.515	0.600	204.39	206.65	-2.27	0.638	24.000
05.10.25	47.80	44.65	3.15	203.17	203.17	0	0.514	0.600	204.12	206.36	-2.25	0.636	24.000
06.10.25	47.30	44.28	3.02	202.41	203.22	-0.80	0.515	0.600	203.74	205.95	-2.21	0.422	15.833
07.10.25	45.11	42.38	2.73	200.99	203.30	-2.31	0.515	0.600	202.93	205.05	-2.12	0.007	0.250
08.10.25	45.27	42.55	2.72	198.76	201.09	-2.33	0.516	0.600	200.70	202.82	-2.12	0.000	0.000
09.10.25	45.13	42.33	2.80	194.79	196.97	-2.17	0.508	0.600	196.63	198.70	-2.07	0.029	1.167
10.10.25	44.46	41.76	2.70	188.45	190.59	-2.13	0.503	0.600	190.20	192.20	-2.00	0.016	0.667
11.10.25	43.80	41.12	2.68	183.68	185.82	-2.14	0.499	0.600	185.36	187.31	-1.95	0.000	0.000
12.10.25	43.62	40.88	2.74	183.37	185.49	-2.11	0.495	0.600	185.03	186.96	-1.93	0.002	0.083
13.10.25	43.74	40.94	2.80	183.41	185.51	-2.10	0.500	0.600	185.08	186.99	-1.91	0.002	0.083
14.10.25	44.94	41.94	3.00	182.90	184.39	-1.49	0.500	0.600	184.34	186.26	-1.92	0.183	7.000
15.10.25	46.48	43.24	3.24	180.89	180.93	-0.03	0.494	0.600	181.68	183.62	-1.93	0.571	23.583
16.10.25	46.68	43.59	3.09	197.84	198.14	-0.29	0.529	0.600	198.90	200.92	-2.02	0.528	20.917
17.10.25	46.93	43.78	3.15	200.25	200.52	-0.26	0.536	0.600	201.34	203.36	-2.03	0.556	21.167
18.10.25	52.34	48.47	3.87	202.51	202.51	0	0.541	0.600	203.84	206.06	-2.22	0.778	24.000
19.10.25	52.29	48.54	3.75	202.59	202.59	0	0.541	0.600	203.92	206.14	-2.22	0.755	24.000
20.10.25	51.59	47.95	3.64	198.85	198.91	-0.06	0.542	0.600	200.15	202.29	-2.15	0.711	23.333
Итого	---	---	---	4653.16	4679.95	-26.78	---	---	4684.43	4738.30	-53.87	8.777	319.500
Среднее	39.98	37.70	2.27	---	---	---	0.452	0.600	---	---	---	---	---

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Губкина, 9
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00182667

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0хD282

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Мг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	18.75	17.89	0.86	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
20.09.25	18.67	17.81	0.86	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
21.09.25	18.63	17.76	0.87	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
22.09.25	18.78	17.81	0.97	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
23.09.25	18.98	17.98	1.00	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
24.09.25	19.22	18.86	0.36	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
25.09.25	19.63	20.33	-0.70	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
26.09.25	41.19	36.44	4.75	90.440	91.130	90.090	90.130	-0.040	6.20	6.00	0.4260	0.0	24.0
27.09.25	44.48	39.45	5.03	182.940	183.980	181.930	181.860	0.070	6.20	6.00	0.9170	0.0	24.0
28.09.25	43.70	38.44	5.26	182.080	183.600	181.330	181.330	0.000	6.20	6.00	0.9540	0.0	24.0
29.09.25	43.32	38.09	5.23	182.140	183.580	181.390	181.390	0.000	6.20	6.00	0.9470	0.0	24.0
30.09.25	44.72	38.09	6.63	152.330	153.460	151.670	151.610	0.060	6.20	6.00	1.0070	0.0	24.0
01.10.25	46.52	38.99	7.53	145.610	142.930	144.780	141.180	3.600	6.20	6.00	1.0890	0.0	24.0
02.10.25	48.66	40.47	8.19	139.520	140.200	138.490	138.430	0.060	6.20	6.00	1.1320	0.0	24.0
03.10.25	47.66	41.12	6.54	174.760	175.630	173.480	173.480	0.000	6.20	6.00	1.1300	0.0	24.0
04.10.25	47.45	41.01	6.44	175.800	176.620	174.470	174.470	0.000	6.20	6.00	1.1190	0.0	24.0
05.10.25	47.58	41.22	6.36	175.760	176.530	174.370	174.370	0.000	6.20	6.00	1.1060	0.0	24.0
06.10.25	46.10	40.24	5.86	175.010	175.750	173.780	173.780	0.000	6.20	6.00	1.0180	0.0	24.0
07.10.25	44.97	39.42	5.55	173.600	174.400	172.480	172.480	0.000	6.20	6.00	0.9530	0.0	24.0
08.10.25	45.05	39.52	5.53	170.810	171.540	169.690	169.690	0.000	6.20	6.00	0.9350	0.0	24.0
09.10.25	44.77	39.26	5.51	167.730	168.470	166.610	166.610	0.000	6.20	6.00	0.9190	0.0	24.0
10.10.25	43.94	38.62	5.32	163.540	164.280	162.550	162.550	0.000	6.20	6.00	0.8620	0.0	24.0
11.10.25	43.16	38.02	5.14	162.150	162.930	161.220	161.220	0.000	6.20	6.00	0.8270	0.0	24.0
12.10.25	43.57	38.18	5.39	162.030	162.740	161.020	161.020	0.000	6.20	6.00	0.8640	0.0	24.0
13.10.25	43.54	38.15	5.39	161.910	162.620	160.900	160.900	0.000	6.20	6.00	0.8640	0.0	24.0
14.10.25	45.27	39.37	5.90	160.610	161.280	159.490	159.490	0.000	6.20	6.00	0.9400	0.0	24.0
15.10.25	46.28	40.19	6.09	164.910	165.540	163.690	163.690	0.000	6.20	6.00	0.9930	0.0	24.0
16.10.25	46.39	40.57	5.82	180.170	180.810	178.750	178.750	0.000	6.20	6.00	1.0390	0.0	24.0
17.10.25	48.32	41.94	6.38	183.820	184.410	182.220	182.220	0.000	6.20	6.00	1.1610	0.0	24.0
18.10.25	51.93	44.71	7.22	185.030	185.510	183.140	183.140	0.000	6.20	6.00	1.3170	0.0	24.0
19.10.25	52.11	44.93	7.18	185.000	185.510	183.150	183.150	0.000	6.20	6.00	1.3170	0.0	24.0
20.10.25	50.69	44.00	6.69	185.130	185.700	183.390	183.390	0.000	6.20	6.00	1.2270	0.0	24.0
Итого	---	---	---	4182.8	4199.1	4154.08	4150.33	3.750	---	---	25.0630	0.0	768.0
Среднее	40.12	35.27	4.84	---	---	---	---	---	6.20	6.00	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Мг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	38397.690	38467.990	38024.060	37958.990	315.2370	65.070	2999.0	8368.0
20.10.25 24:00	42404.760	42490.610	42003.770	41934.950	339.1940	68.820	2999.0	9112.0
Итого за период	4007.069	4022.620	3979.709	3975.959	23.9570	---	0.0	744.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Девонская, 10
Потребитель: АО "Жилуправление"
Прибор: ТВ7-04.1 Заводской номер: 20139264

БД=1, ТВ1, СИ=7, КТ3=0, ФРТ=0, КСН=0х5СЕ1

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	17.05	16.74	н/д	0.31	2.29	2.34	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
20.09.25	17.05	16.74	н/д	0.31	2.30	2.35	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
21.09.25	17.02	16.70	н/д	0.32	2.31	2.36	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
22.09.25	17.17	16.87	н/д	0.30	2.33	2.38	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
23.09.25	17.36	17.05	н/д	0.31	2.34	2.40	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
24.09.25	17.54	17.19	н/д	0.34	2.37	2.43	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
25.09.25	17.55	17.18	н/д	0.37	2.34	2.39	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
26.09.25	40.70	36.30	н/д	4.40	3.62	3.48	н/д	104.993	н/д	н/д	41.733	н/д	н/д	н/д	0.184	н/д	18	6
27.09.25	39.61	37.53	н/д	2.08	5.02	4.77	н/д	239.920	н/д	н/д	238.235	н/д	н/д	н/д	0.497	н/д	24	0
28.09.25	39.78	37.54	н/д	2.24	5.01	4.76	н/д	234.660	н/д	н/д	232.997	н/д	н/д	н/д	0.522	н/д	24	0
29.09.25	42.43	39.43	н/д	3.00	4.90	4.69	н/д	219.550	н/д	н/д	217.749	н/д	н/д	н/д	0.653	н/д	24	0
30.09.25	46.69	42.82	н/д	3.87	4.90	4.73	н/д	202.292	н/д	н/д	200.266	н/д	н/д	н/д	0.774	н/д	24	0
01.10.25	46.63	42.92	н/д	3.71	4.89	4.74	н/д	199.955	н/д	н/д	197.955	н/д	н/д	н/д	0.735	н/д	24	0
02.10.25	46.70	42.57	н/д	4.13	4.85	4.72	н/д	197.337	н/д	н/д	195.359	н/д	н/д	н/д	0.806	н/д	24	0
03.10.25	47.40	42.76	н/д	4.63	4.83	4.73	н/д	211.580	н/д	н/д	209.380	н/д	н/д	н/д	0.970	н/д	24	0
04.10.25	47.40	42.78	н/д	4.62	4.88	4.79	н/д	219.105	н/д	н/д	216.837	н/д	н/д	н/д	1.002	н/д	24	0
05.10.25	47.32	42.81	н/д	4.51	4.88	4.80	н/д	218.643	н/д	н/д	216.399	н/д	н/д	н/д	0.976	н/д	24	0
06.10.25	46.46	42.19	н/д	4.28	4.85	4.76	н/д	218.563	н/д	н/д	216.398	н/д	н/д	н/д	0.925	н/д	24	0
07.10.25	44.32	40.50	н/д	3.82	4.87	4.79	н/д	216.605	н/д	н/д	214.656	н/д	н/д	н/д	0.819	н/д	24	0
08.10.25	44.41	40.64	н/д	3.78	4.86	4.77	н/д	217.390	н/д	н/д	215.421	н/д	н/д	н/д	0.813	н/д	24	0
09.10.25	44.23	40.45	н/д	3.78	4.93	4.84	н/д	216.750	н/д	н/д	214.814	н/д	н/д	н/д	0.812	н/д	24	0
10.10.25	44.04	40.38	н/д	3.66	5.01	4.93	н/д	217.160	н/д	н/д	215.237	н/д	н/д	н/д	0.788	н/д	24	0
11.10.25	43.79	40.19	н/д	3.60	5.03	4.94	н/д	219.768	н/д	н/д	217.841	н/д	н/д	н/д	0.784	н/д	24	0
12.10.25	44.37	40.55	н/д	3.81	5.05	4.96	н/д	220.750	н/д	н/д	218.763	н/д	н/д	н/д	0.834	н/д	24	0
13.10.25	46.05	41.89	н/д	4.16	5.05	4.97	н/д	220.143	н/д	н/д	217.997	н/д	н/д	н/д	0.906	н/д	24	0
14.10.25	45.65	41.72	н/д	3.93	5.05	4.96	н/д	223.012	н/д	н/д	220.875	н/д	н/д	н/д	0.868	н/д	24	0
15.10.25	46.30	42.17	н/д	4.13	5.06	4.97	н/д	223.113	н/д	н/д	220.916	н/д	н/д	н/д	0.912	н/д	24	0
16.10.25	46.18	41.93	н/д	4.25	5.02	4.94	н/д	219.228	н/д	н/д	217.079	н/д	н/д	н/д	0.922	н/д	24	0
17.10.25	47.44	42.89	н/д	4.55	5.03	4.95	н/д	218.307	н/д	н/д	216.040	н/д	н/д	н/д	0.982	н/д	24	0
18.10.25	50.00	44.95	н/д	5.05	4.99	4.90	н/д	217.682	н/д	н/д	215.163	н/д	н/д	н/д	1.087	н/д	24	0
19.10.25	51.05	45.90	н/д	5.15	5.01	4.92	н/д	219.878	н/д	н/д	217.228	н/д	н/д	н/д	1.118	н/д	24	0
20.10.25	49.90	45.08	н/д	4.82	4.97	4.88	н/д	219.835	н/д	н/д	217.302	н/д	н/д	н/д	1.048	н/д	24	0
Итого	---	---	---	---	---	---	---	5336.219	---	---	5222.640	---	---	---	20.737	---	762	6
Среднее	45.66	41.69	---	3.97	4.34	4.26	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	0.340	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	203	796
20.10.25 24:00	5336.557	0.000	0.000	5222.641	0.000	0.000	0.000	20.735	0.000	965	802
Итого за период	5336.217	0.000	0.000	5222.641	0.000	0.000	---	20.735	0.000	762	6

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Девонская, 10а
 Потребитель: АО "Жилуправление"
 Прибор: Взлёт ТСРВ-024М Заводской номер: 1304498
 Тип системы: А42-00 Система: 1

ТБ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	16.83	16.42	0.41	1.04	5.16	-4.12	0.0	0.0	1.04	5.17	-4.13	0	6.42
20.09.25	16.85	16.40	0.45	0.33	2.23	-1.90	0.0	0.0	0.33	2.23	-1.91	0	4.58
21.09.25	16.80	16.36	0.44	0.34	2.78	-2.43	0.0	0.0	0.34	2.78	-2.44	0	5.27
22.09.25	16.94	16.51	0.43	0.81	1.39	-0.58	0.0	0.0	0.81	1.39	-0.58	0	6.88
23.09.25	17.19	16.79	0.40	0.35	0.74	-0.38	0.0	0.0	0.35	0.74	-0.38	0	6.20
24.09.25	17.37	16.97	0.40	0.24	0.50	-0.26	0.0	0.0	0.24	0.50	-0.26	0	5.32
25.09.25	19.05	17.17	1.88	0.24	0.56	-0.31	0.0	0.0	0.24	0.56	-0.31	0	3.75
26.09.25	27.16	23.90	3.26	50.88	52.76	-1.88	0.2	0.1	51.28	53.07	-1.79	0.243	9.45
27.09.25	40.21	36.04	4.17	257.70	267.38	-9.69	0.5	0.5	259.69	269.03	-9.35	1.044	22.65
28.09.25	40.37	36.00	4.37	274.00	284.01	-10.01	0.5	0.5	276.13	285.76	-9.63	1.156	22.70
29.09.25	42.44	37.31	5.13	271.91	279.58	-7.67	0.5	0.5	274.23	281.42	-7.19	1.354	23.07
30.09.25	47.53	40.52	7.01	255.55	260.24	-4.68	0.5	0.5	258.31	262.28	-3.97	1.770	23.52
01.10.25	47.55	40.48	7.07	248.95	253.69	-4.74	0.5	0.5	251.64	255.68	-4.05	1.730	23.50
02.10.25	47.62	40.40	7.22	241.63	244.54	-2.91	0.5	0.5	244.25	246.45	-2.20	1.733	23.82
03.10.25	48.23	40.62	7.61	223.70	229.40	-5.71	0.5	0.5	226.17	231.21	-5.04	1.679	23.60
04.10.25	48.31	40.48	7.83	219.80	226.52	-6.73	0.5	0.5	222.24	228.30	-6.05	1.688	23.37
05.10.25	48.20	40.51	7.69	216.12	223.68	-7.56	0.5	0.5	218.52	225.44	-6.92	1.623	23.05
06.10.25	47.89	40.34	7.55	220.68	225.11	-4.43	0.5	0.5	223.10	226.86	-3.76	1.663	23.62
07.10.25	45.28	38.66	6.62	219.40	222.59	-3.19	0.5	0.5	221.55	224.17	-2.62	1.446	23.77
08.10.25	45.25	38.75	6.50	220.70	223.49	-2.79	0.5	0.5	222.86	225.09	-2.23	1.426	23.87
09.10.25	45.09	38.51	6.58	217.23	222.08	-4.85	0.5	0.5	219.34	223.65	-4.31	1.414	23.65
10.10.25	44.90	38.54	6.36	218.86	222.28	-3.43	0.5	0.5	220.96	223.86	-2.89	1.374	23.63
11.10.25	44.70	38.42	6.28	220.95	224.40	-3.45	0.5	0.5	223.06	225.98	-2.92	1.356	23.08
12.10.25	44.96	38.55	6.41	216.30	223.64	-7.34	0.5	0.5	218.38	225.22	-6.84	1.342	22.97
13.10.25	46.78	39.72	7.06	216.62	223.38	-6.76	0.5	0.5	218.88	225.07	-6.18	1.496	23.30
14.10.25	46.69	39.88	6.81	221.99	226.22	-4.23	0.5	0.5	224.30	227.94	-3.64	1.493	23.58
15.10.25	47.13	39.93	7.20	223.56	228.10	-4.54	0.5	0.5	225.95	229.84	-3.89	1.602	23.37
16.10.25	47.11	39.81	7.30	220.53	225.03	-4.50	0.5	0.5	222.87	226.73	-3.87	1.581	23.37
17.10.25	47.68	40.03	7.65	220.13	223.72	-3.59	0.5	0.5	222.52	225.43	-2.91	1.671	23.63
18.10.25	51.04	42.30	8.74	218.31	222.92	-4.60	0.5	0.5	221.02	224.82	-3.80	1.883	23.53
19.10.25	51.86	42.93	8.93	219.87	223.75	-3.88	0.5	0.5	222.68	225.72	-3.04	1.933	23.43
20.10.25	51.35	42.80	8.55	219.40	224.24	-4.84	0.5	0.5	222.15	226.20	-4.05	1.843	23.35
Итого	---	---	---	5558.15	5696.12	-137.98	---	---	5615.46	5738.59	-123.14	37.544	609.28
Среднее	39.57	34.13	5.45	---	---	---	0.4	0.4	---	---	---	---	---

Показания интеграторов

Дата	Мтс	Q, (Гкал)
18.09.25 24:00	-1540.08	1823.008
20.10.25 24:00	-1606.47	1860.552
Итого за период	---	37.544

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Девонская, 12а
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00169009

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0x8691

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	17.48	17.29	0.19	0.000	0.000	0.000	0.000	0.000	1.14	1.22	0.0000	0.0	24.0
20.09.25	17.43	17.23	0.20	0.000	0.000	0.000	0.000	0.000	1.14	1.21	0.0000	0.0	24.0
21.09.25	17.51	17.29	0.22	0.000	0.000	0.000	0.000	0.000	1.13	1.21	0.0000	0.0	24.0
22.09.25	17.58	17.36	0.22	0.000	0.000	0.000	0.000	0.000	1.13	1.20	0.0000	0.0	24.0
23.09.25	17.67	17.44	0.23	0.000	0.000	0.000	0.000	0.000	1.13	1.20	0.0000	0.0	24.0
24.09.25	17.76	17.51	0.25	0.000	0.000	0.000	0.000	0.000	1.13	1.20	0.0000	0.0	24.0
25.09.25	17.92	17.61	0.31	0.000	0.000	0.000	0.000	0.000	1.12	1.19	0.0000	0.0	24.0
26.09.25	40.03	35.72	4.31	102.280	102.360	101.610	101.620	-0.010	3.69	3.56	0.4400	0.0	24.0
27.09.25	40.24	36.17	4.07	281.800	282.600	280.340	280.110	0.230	6.00	5.76	1.1390	0.0	24.0
28.09.25	40.42	36.21	4.21	285.170	286.510	283.830	283.830	0.000	5.98	5.75	1.1980	0.0	24.0
29.09.25	43.18	37.90	5.28	271.900	273.660	270.570	270.570	0.000	5.88	5.68	1.4280	0.0	24.0
30.09.25	47.51	40.63	6.88	253.290	255.290	251.900	251.900	0.000	5.88	5.73	1.7300	0.0	24.0
01.10.25	47.44	40.49	6.95	247.050	249.540	245.970	245.970	0.000	5.87	5.74	1.7050	0.0	24.0
02.10.25	47.51	40.33	7.18	237.460	240.660	236.820	236.820	0.000	5.83	5.71	1.6960	0.0	24.0
03.10.25	48.20	40.59	7.61	223.980	227.450	223.580	223.580	0.000	5.82	5.72	1.7000	0.0	24.0
04.10.25	48.21	40.47	7.74	219.740	223.410	219.470	219.470	0.000	5.87	5.78	1.6950	0.0	24.0
05.10.25	48.13	40.47	7.66	218.630	222.420	218.450	218.450	0.000	5.87	5.79	1.6680	0.0	24.0
06.10.25	47.20	39.94	7.26	218.100	222.220	218.140	218.140	0.000	5.84	5.75	1.5800	0.0	24.0
07.10.25	45.05	38.53	6.52	216.100	220.380	216.370	216.370	0.000	5.86	5.78	1.4060	0.0	24.0
08.10.25	45.14	38.69	6.45	216.910	221.010	217.060	217.060	0.000	5.85	5.76	1.3980	0.0	24.0
09.10.25	44.95	38.50	6.45	216.200	220.550	216.540	216.540	0.000	5.92	5.83	1.3990	0.0	24.0
10.10.25	44.76	38.46	6.30	216.440	220.830	216.780	216.780	0.000	6.00	5.91	1.3630	0.0	24.0
11.10.25	44.50	38.33	6.17	218.820	223.240	219.170	219.170	0.000	6.02	5.92	1.3490	0.0	24.0
12.10.25	45.12	38.66	6.46	219.980	224.400	220.240	220.240	0.000	6.03	5.94	1.4160	0.0	24.0
13.10.25	46.83	39.79	7.04	219.610	223.880	219.720	219.720	0.000	6.04	5.95	1.5430	0.0	24.0
14.10.25	46.42	39.70	6.72	222.090	226.580	222.310	222.310	0.000	6.04	5.95	1.4910	0.0	24.0
15.10.25	47.09	40.03	7.06	222.760	226.940	222.750	222.750	0.000	6.04	5.95	1.5660	0.0	24.0
16.10.25	46.94	39.76	7.18	218.880	223.240	219.030	219.030	0.000	6.01	5.92	1.5680	0.0	24.0
17.10.25	48.31	40.53	7.78	218.230	222.520	218.240	218.240	0.000	6.02	5.93	1.6970	0.0	24.0
18.10.25	50.87	42.23	8.64	217.580	221.580	217.280	217.280	0.000	5.98	5.89	1.8740	0.0	24.0
19.10.25	51.95	43.06	8.89	220.090	224.010	219.630	219.630	0.000	6.00	5.91	1.9480	0.0	24.0
20.10.25	50.72	42.43	8.29	219.830	223.680	219.470	219.470	0.000	5.96	5.86	1.8190	0.0	24.0
Итого	---	---	---	5622.9	5708.9	5615.27	5615.05	0.220	---	---	37.8160	0.0	768.0
Среднее	40.00	34.66	5.33	---	---	---	---	---	4.82	4.75	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	50210.410	50758.530	49911.410	49913.000	472.1270	-1.590	3288.0	7720.0
20.10.25 24:00	55833.330	56467.490	55526.679	55528.049	509.9430	-1.370	3288.0	8488.0
Итого за период	5622.919	5708.959	5615.268	5615.048	37.8160	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Девонская, 15
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00169016

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0х0СВ8

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	15.84	15.83	0.01	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
22.09.25	15.86	15.85	0.01	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
23.09.25	15.91	15.90	0.01	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
24.09.25	15.95	15.96	-0.01	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
25.09.25	15.97	16.03	-0.06	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
26.09.25	39.66	34.56	5.10	65.500	65.500	65.020	65.150	-0.130	6.25	5.88	0.3320	0.0	24.0
27.09.25	40.31	35.71	4.60	127.730	127.730	126.770	127.010	-0.240	6.23	5.67	0.5850	0.0	24.0
28.09.25	40.51	35.91	4.60	127.800	127.800	126.840	127.080	-0.240	6.22	5.67	0.5820	0.0	24.0
29.09.25	43.32	37.84	5.48	125.950	125.950	124.890	125.140	-0.250	6.10	5.56	0.6860	0.0	24.0
30.09.25	47.57	40.67	6.90	117.900	117.900	116.700	116.940	-0.240	6.05	5.59	0.8060	0.0	24.0
01.10.25	47.51	40.55	6.96	114.020	114.020	112.820	113.060	-0.240	6.04	5.61	0.7830	0.0	24.0
02.10.25	47.57	40.66	6.91	113.050	113.050	111.850	112.090	-0.240	6.01	5.59	0.7750	0.0	24.0
03.10.25	48.27	41.13	7.14	112.850	112.850	111.650	111.890	-0.240	6.00	5.59	0.7950	0.0	24.0
04.10.25	48.27	41.06	7.21	112.540	112.540	111.340	111.580	-0.240	6.06	5.65	0.8020	0.0	24.0
05.10.25	48.20	41.11	7.09	112.400	112.400	111.200	111.440	-0.240	6.07	5.65	0.7860	0.0	24.0
06.10.25	47.23	40.55	6.68	112.350	112.350	111.160	111.440	-0.280	6.05	5.63	0.7420	0.0	24.0
07.10.25	45.11	39.14	5.97	112.180	112.180	111.180	111.460	-0.280	6.10	5.67	0.6630	0.0	24.0
08.10.25	45.20	39.31	5.89	112.070	112.070	111.040	111.340	-0.300	6.08	5.66	0.6550	0.0	24.0
09.10.25	45.01	39.18	5.83	112.080	112.080	111.090	111.360	-0.270	6.15	5.73	0.6480	0.0	24.0
10.10.25	44.82	39.09	5.73	112.060	112.060	111.080	111.340	-0.260	6.23	5.81	0.6360	0.0	24.0
11.10.25	44.56	38.92	5.64	113.460	113.460	112.410	112.740	-0.330	6.25	5.82	0.6320	0.0	24.0
12.10.25	45.19	39.23	5.96	113.240	113.240	112.210	112.490	-0.280	6.26	5.84	0.6660	0.0	24.0
13.10.25	46.90	40.44	6.46	113.650	113.650	112.450	112.690	-0.240	6.25	5.83	0.7200	0.0	24.0
14.10.25	46.48	40.25	6.23	113.520	113.520	112.350	112.600	-0.250	6.25	5.83	0.6980	0.0	24.0
15.10.25	47.14	40.60	6.54	114.080	114.080	112.880	113.120	-0.240	6.25	5.83	0.7390	0.0	24.0
16.10.25	46.99	40.37	6.62	113.890	113.890	112.690	112.930	-0.240	6.22	5.80	0.7440	0.0	24.0
17.10.25	48.38	41.22	7.16	113.230	113.230	111.960	112.270	-0.310	6.22	5.80	0.8020	0.0	24.0
18.10.25	50.93	42.92	8.01	112.580	112.580	111.190	111.620	-0.430	6.15	5.74	0.8880	0.0	24.0
19.10.25	52.01	43.88	8.13	114.240	114.240	112.800	113.280	-0.480	6.17	5.75	0.9170	0.0	24.0
20.10.25	50.74	43.12	7.62	114.080	114.080	112.750	113.120	-0.370	6.14	5.72	0.8580	0.0	24.0
Итого	---	---	---	2826.4	2826.4	2798.32	2805.18	-6.860	---	---	17.9400	0.0	720.0
Среднее	41.24	35.89	5.34	---	---	---	---	---	6.28	5.88	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
19.09.25 24:00	0	0	0	0	0	0	0	0
20.10.25 24:00	27158.790	27158.790	26799.440	26913.469	242.3780	-114.030	2087.0	7743.0
Итого за период	27158.790	27158.790	26799.440	26913.469	242.3780	---	2087.0	7743.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Девонская, 16
Потребитель: АО "Жилуправление"
Прибор: Вzlёт ТСРВ-024М Заводской номер: 902533
Тип системы: А32-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
28.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
29.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
30.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
01.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-
02.10.25	47.49	39.77	7.72	209.71	209.69	0.02	0.0	0.0	211.06	212.27	-1.20	1.614	24.00
03.10.25	48.17	39.74	8.43	194.17	194.17	0.00	0.0	0.0	195.48	196.55	-1.07	1.633	24.00
04.10.25	48.18	39.69	8.49	191.32	191.32	0	0.0	0.0	192.60	193.68	-1.08	1.623	24.00
05.10.25	48.10	39.66	8.44	189.29	189.29	0.00	0.0	0.0	190.53	191.65	-1.12	1.594	24.00
06.10.25	47.23	39.25	7.98	189.89	189.89	0.00	0.0	0.0	191.03	192.24	-1.21	1.514	24.00
07.10.25	45.04	37.83	7.21	186.32	186.32	0	0.0	0.0	187.25	188.54	-1.29	1.340	24.00
08.10.25	45.13	38.01	7.12	188.92	188.92	0	0.0	0.0	189.84	191.22	-1.39	1.344	24.00
09.10.25	44.95	37.81	7.14	187.24	187.24	0.00	0.0	0.0	188.12	189.53	-1.40	1.334	24.00
10.10.25	44.76	37.87	6.89	188.96	188.96	0.00	0.0	0.0	189.80	191.29	-1.48	1.299	24.00
11.10.25	44.51	37.70	6.81	190.86	190.86	0	0.0	0.0	191.67	193.22	-1.55	1.296	24.00
12.10.25	45.08	38.05	7.03	193.70	193.70	0	0.0	0.0	194.53	196.17	-1.64	1.358	24.00
13.10.25	46.80	39.07	7.73	191.07	191.07	0.00	0.0	0.0	192.01	193.61	-1.61	1.473	24.00
14.10.25	46.41	39.14	7.27	197.10	197.10	0.00	0.0	0.0	198.01	199.75	-1.73	1.431	24.00
15.10.25	47.06	39.36	7.70	195.39	195.39	0.00	0.0	0.0	196.32	198.05	-1.72	1.501	24.00
16.10.25	46.93	39.04	7.89	192.11	192.11	0	0.0	0.0	193.03	194.70	-1.67	1.512	24.00
17.10.25	48.18	39.58	8.60	188.04	188.04	0.00	0.0	0.0	189.02	190.63	-1.61	1.615	24.00
18.10.25	50.83	41.34	9.49	189.46	189.46	0	0.0	0.0	190.65	192.21	-1.56	1.793	24.00
19.10.25	51.90	42.08	9.82	189.54	189.54	0	0.0	0.0	190.81	192.39	-1.58	1.857	24.00
20.10.25	50.73	41.57	9.16	191.64	191.64	0	0.0	0.0	192.82	194.47	-1.65	1.752	24.00
Итого	---	---	---	3644.74	3644.72	0.02	---	---	3664.59	3692.16	-27.57	28.883	456.00
Среднее	47.24	39.29	7.94	---	---	---	0.0	0.0	---	---	---	---	---

Показания интеграторов

Дата	Мтс	Q, (Гкал)
18.09.25 24:00	н/д	н/д
20.10.25 24:00	-11660.40	6401.145
Итого за период	---	н/д

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ИМ2300, Суточный с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Девонская, 19
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ491

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	15.94	0.00	15.76	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	15.79	0.00	15.68	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	15.85	0.00	15.69	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	15.90	0.00	15.68	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	16.16	0.00	16.06	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	16.12	0.00	16.01	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	16.28	0.00	16.12	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	15.86	0.00	15.71	0.00	0.00	24.00	0.00	0.00
27.09.25	0.31	23.60	75.62	22.03	76.28	8.64	24.00	0.00	0.00
28.09.25	0.76	40.20	197.79	36.36	199.27	24.00	24.00	0.00	0.00
29.09.25	0.77	40.39	198.01	36.47	198.77	24.00	24.00	0.00	0.00
30.09.25	0.91	43.22	192.11	38.44	192.74	24.00	24.00	0.00	0.00
01.10.25	1.06	47.42	173.86	41.31	174.33	24.00	24.00	0.00	0.00
02.10.25	1.02	47.36	166.39	41.20	166.65	24.00	24.00	0.00	0.00
03.10.25	1.00	47.42	163.76	41.33	164.44	24.00	24.00	0.00	0.00
04.10.25	1.00	48.12	162.73	41.95	163.59	24.00	24.00	0.00	0.00
05.10.25	1.00	48.12	161.47	41.91	162.54	24.00	24.00	0.00	0.00
06.10.25	0.97	48.05	161.02	42.01	162.03	24.00	24.00	0.00	0.00
07.10.25	0.91	47.11	160.36	41.41	161.50	24.00	24.00	0.00	0.00
08.10.25	0.82	44.98	159.81	39.86	161.07	24.00	24.00	0.00	0.00
09.10.25	0.81	45.08	159.84	40.01	160.64	24.00	24.00	0.00	0.00
10.10.25	0.80	44.88	158.74	39.81	159.24	24.00	24.00	0.00	0.00
11.10.25	0.79	44.69	158.31	39.72	158.70	24.00	24.00	0.00	0.00
12.10.25	0.78	44.43	160.62	39.59	160.75	24.00	24.00	0.00	0.00
13.10.25	0.82	45.04	160.20	39.89	160.53	24.00	24.00	0.00	0.00
14.10.25	0.89	46.74	160.06	41.14	160.43	24.00	24.00	0.00	0.00
15.10.25	0.87	46.33	160.51	40.91	160.84	24.00	24.00	0.00	0.00
16.10.25	0.91	47.00	160.11	41.30	160.48	24.00	24.00	0.00	0.00
17.10.25	0.92	46.85	159.88	41.06	160.28	24.00	24.00	0.00	0.00
18.10.25	0.99	48.22	158.49	41.95	158.85	24.00	24.00	0.00	0.00
19.10.25	1.08	50.76	157.29	43.90	157.69	24.00	24.00	0.00	0.00
20.10.25	1.11	51.85	160.44	44.93	160.60	24.00	24.00	0.00	0.00
Итого	21.30	---	3887.42	---	3902.24	560.64	768.00	0.00	0.00
Среднее	---	37.992	---	33.913	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	2032.44	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Девонская, 2
Потребитель: АО "Жилуправление"
Прибор: ТВ7-01 Заводской номер: 20134657

БД=1, ТВ1, СИ=6, КТЗ=0, ФРТ=0, КСН=0х40ЕF

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
28.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
29.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
30.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
01.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
02.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
03.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
04.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
05.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
07.10.25	45.07	42.35	н/д	2.71	6.12	6.12	н/д	391.025	0.000	н/д	387.376	0.000	н/д	387.376	1.050	н/д	24	0
08.10.25	45.09	42.36	н/д	2.73	6.12	6.12	н/д	175.273	0.000	н/д	173.635	0.000	н/д	173.635	0.474	н/д	11	13
09.10.25	44.99	42.33	н/д	2.65	6.12	6.12	н/д	228.807	0.000	н/д	226.689	0.000	н/д	226.689	0.600	н/д	14	10
10.10.25	44.77	42.15	н/д	2.62	6.12	6.12	н/д	392.497	0.000	н/д	388.875	0.000	н/д	388.875	1.019	н/д	24	0
11.10.25	44.61	41.97	н/д	2.64	6.12	6.12	н/д	396.147	0.000	н/д	376.495	0.000	н/д	376.495	0.992	н/д	23	1
12.10.25	45.13	42.39	н/д	2.74	6.12	6.12	н/д	396.450	0.000	н/д	392.761	0.000	н/д	392.761	1.077	н/д	24	0
13.10.25	46.84	43.88	н/д	2.96	6.12	6.12	н/д	396.698	0.000	н/д	392.693	0.000	н/д	392.693	1.162	н/д	24	0
14.10.25	46.43	43.59	н/д	2.85	6.12	6.12	н/д	397.480	0.000	н/д	393.534	0.000	н/д	393.534	1.119	н/д	24	0
15.10.25	47.09	44.10	н/д	2.99	6.12	6.12	н/д	397.323	0.000	н/д	393.257	0.000	н/д	393.257	1.173	н/д	24	0
16.10.25	46.94	43.91	н/д	3.03	6.12	6.12	н/д	396.395	0.000	н/д	392.367	0.000	н/д	392.367	1.186	н/д	24	0
17.10.25	48.28	44.99	н/д	3.29	6.12	6.12	н/д	394.677	0.000	н/д	390.431	0.000	н/д	390.431	1.285	н/д	24	0
18.10.25	50.87	47.22	н/д	3.65	6.12	6.12	н/д	392.168	0.000	н/д	387.469	0.000	н/д	387.469	1.412	н/д	24	0
19.10.25	51.95	48.24	н/д	3.72	6.12	6.12	н/д	397.958	0.000	н/д	392.979	0.000	н/д	392.979	1.459	н/д	24	0
20.10.25	50.72	47.22	н/д	3.50	6.12	6.12	н/д	397.348	0.000	н/д	392.631	0.000	н/д	392.631	1.375	н/д	24	0
Итого	---	---	---	---	---	---	---	5150.246	0.000	---	5081.192	0.000	---	5081.192	15.383	---	312	24
Среднее	47.22	44.19	---	3.03	6.12	6.12	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
20.10.25 24:00	5345.468	0.000	0.000	5274.492	0.000	0.000	5274.492	15.938	0.000	324	24
Итого за период	н/д	н/д	н/д	н/д	н/д	н/д	---	н/д	н/д	н/д	н/д

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Девонская, 4
Потребитель: АО "Жилуправление"
Прибор ТВ7-04.1 Заводской номер: 20140353

БД=1, ТВ1, СИ=6, КТЗ=0, ФРТ=0, КСН=0хС817

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	16.10	15.99	н/д	0.12	0.00	0.63	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
20.09.25	16.17	16.05	н/д	0.12	0.00	0.61	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
21.09.25	16.11	15.95	н/д	0.15	0.00	0.57	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
22.09.25	16.83	16.69	н/д	0.14	0.00	0.61	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
23.09.25	17.20	17.02	н/д	0.18	0.00	0.61	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
24.09.25	17.79	17.52	н/д	0.26	0.00	0.63	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
25.09.25	44.38	39.22	н/д	5.15	1.32	1.70	н/д	20.533	20.890	н/д	20.345	20.745	н/д	-0.400	0.105	н/д	24	0
26.09.25	42.39	38.26	н/д	4.13	4.19	4.19	н/д	55.318	56.283	н/д	54.861	55.916	н/д	-1.056	0.226	н/д	24	0
27.09.25	40.05	36.05	н/д	4.00	4.79	4.80	н/д	50.514	51.402	н/д	50.151	51.110	н/д	-0.959	0.200	н/д	24	0
28.09.25	40.22	36.07	н/д	4.15	4.77	4.79	н/д	50.289	51.162	н/д	49.923	50.874	н/д	-0.951	0.207	н/д	24	0
29.09.25	42.95	37.96	н/д	4.99	4.69	4.71	н/д	49.773	50.586	н/д	49.353	50.265	н/д	-0.912	0.246	н/д	24	0
30.09.25	47.23	41.15	н/д	6.08	4.73	4.75	н/д	48.326	49.049	н/д	47.828	48.672	н/д	-0.844	0.290	н/д	24	0
01.10.25	47.17	41.19	н/д	5.98	4.74	4.76	н/д	47.593	48.247	н/д	47.103	47.880	н/д	-0.777	0.282	н/д	24	0
02.10.25	47.24	41.35	н/д	5.89	4.71	4.73	н/д	47.533	48.124	н/д	47.044	47.752	н/д	-0.708	0.277	н/д	24	0
03.10.25	47.93	42.00	н/д	5.92	4.71	4.74	н/д	47.495	47.986	н/д	46.990	47.604	н/д	-0.614	0.278	н/д	24	0
04.10.25	47.93	42.02	н/д	5.92	4.77	4.79	н/д	47.504	47.891	н/д	47.001	47.508	н/д	-0.507	0.278	н/д	24	0
05.10.25	47.86	42.06	н/д	5.80	4.77	4.80	н/д	47.552	47.869	н/д	47.050	47.485	н/д	-0.435	0.273	н/д	24	0
06.10.25	46.97	41.50	н/д	5.47	4.74	4.76	н/д	47.553	47.865	н/д	47.069	47.491	н/д	-0.422	0.257	н/д	24	0
07.10.25	44.82	39.92	н/д	4.90	4.76	4.79	н/д	47.493	47.843	н/д	47.053	47.502	н/д	-0.449	0.230	н/д	24	0
08.10.25	44.92	40.11	н/д	4.80	4.74	4.76	н/д	48.195	48.592	н/д	47.750	48.241	н/д	-0.491	0.229	н/д	24	0
09.10.25	44.72	39.87	н/д	4.86	4.82	4.84	н/д	47.382	47.807	н/д	46.947	47.465	н/д	-0.519	0.228	н/д	24	0
10.10.25	44.53	39.82	н/д	4.71	4.90	4.92	н/д	47.449	47.909	н/д	47.019	47.569	н/д	-0.550	0.221	н/д	24	0
11.10.25	44.29	39.64	н/д	4.65	4.91	4.94	н/д	47.988	48.490	н/д	47.560	48.148	н/д	-0.588	0.221	н/д	24	0
12.10.25	44.87	39.99	н/д	4.88	4.93	4.95	н/д	48.030	48.556	н/д	47.585	48.206	н/д	-0.622	0.232	н/д	24	0
13.10.25	46.57	41.31	н/д	5.26	4.94	4.96	н/д	48.058	48.600	н/д	47.577	48.226	н/д	-0.649	0.250	н/д	24	0
14.10.25	46.18	41.13	н/д	5.05	4.93	4.96	н/д	48.139	48.696	н/д	47.665	48.322	н/д	-0.658	0.241	н/д	24	0
15.10.25	46.83	41.51	н/д	5.32	4.94	4.96	н/д	48.180	48.747	н/д	47.691	48.370	н/д	-0.679	0.253	н/д	24	0
16.10.25	46.69	41.26	н/д	5.43	4.90	4.93	н/д	48.081	48.658	н/д	47.599	48.283	н/д	-0.685	0.258	н/д	24	0
17.10.25	47.98	42.13	н/д	5.85	4.92	4.94	н/д	47.872	48.453	н/д	47.363	48.062	н/д	-0.698	0.277	н/д	24	0
18.10.25	50.57	44.08	н/д	6.49	4.88	4.90	н/д	47.641	48.212	н/д	47.077	47.783	н/д	-0.706	0.305	н/д	24	0
19.10.25	51.65	45.07	н/д	6.58	4.89	4.91	н/д	48.310	48.899	н/д	47.712	48.444	н/д	-0.732	0.314	н/д	24	0
20.10.25	50.46	44.29	н/д	6.17	4.85	4.87	н/д	48.192	48.812	н/д	47.622	48.375	н/д	-0.752	0.294	н/д	24	0
Итого	---	---	---	---	---	---	---	1230.993	1245.628	---	1218.938	1236.298	---	-17.363	6.472	---	768	0
Среднее	46.04	40.72	---	5.31	3.79	3.93	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	0.240	0.640	0.000	0.240	0.640	0.000	-0.400	0	0.000	1571	0
20.10.25 24:00	1231.233	1246.268	0.000	1219.177	1236.939	0.000	-17.762	6.472	0.000	2339	0
Итого за период	1230.993	1245.628	0.000	1218.937	1236.299	0.000	---	6.472	0.000	768	0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Девонская, 6
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00170287

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0x0993

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	15.94	15.64	0.30	0.000	0.000	0.000	0.000	0.000	6.00	5.00	0.0000	0.0	24.0
22.09.25	15.99	15.68	0.31	0.000	0.000	0.000	0.000	0.000	6.00	5.00	0.0000	0.0	24.0
23.09.25	16.03	15.71	0.32	0.000	0.000	0.000	0.000	0.000	6.00	5.00	0.0000	0.0	24.0
24.09.25	16.10	15.75	0.35	0.000	0.000	0.000	0.000	0.000	6.00	5.00	0.0000	0.0	24.0
25.09.25	26.40	24.64	1.76	0.000	0.000	0.000	0.000	0.000	6.00	5.00	0.0000	0.0	24.0
26.09.25	39.62	36.75	2.87	148.340	147.230	147.220	146.310	0.910	5.93	5.18	0.4230	0.0	24.0
27.09.25	40.16	37.22	2.94	279.230	277.950	277.070	276.130	0.940	6.31	5.76	0.8160	0.0	24.0
28.09.25	40.35	37.38	2.97	274.190	273.090	272.060	271.330	0.730	6.29	5.74	0.8080	0.0	24.0
29.09.25	43.18	39.57	3.61	266.390	264.910	264.060	262.940	1.120	6.19	5.66	0.9540	0.0	24.0
30.09.25	47.41	42.32	5.09	262.710	259.610	259.940	257.490	2.450	6.19	5.70	1.3230	0.0	24.0
01.10.25	47.35	41.84	5.51	276.050	269.810	273.170	267.650	5.520	6.18	5.71	1.5040	0.0	24.0
02.10.25	47.40	42.02	5.38	275.820	268.770	272.940	266.600	6.340	6.15	5.68	1.4650	0.0	24.0
03.10.25	48.10	42.67	5.43	275.580	267.820	272.630	265.510	7.120	6.14	5.68	1.4800	0.0	24.0
04.10.25	48.10	42.68	5.42	275.170	266.970	272.250	264.630	7.620	6.19	5.73	1.4760	0.0	24.0
05.10.25	48.03	42.73	5.30	274.860	266.520	271.910	264.220	7.690	6.20	5.74	1.4420	0.0	24.0
06.10.25	47.07	42.10	4.97	274.430	266.250	271.600	264.000	7.600	6.16	5.71	1.3510	0.0	24.0
07.10.25	44.96	40.50	4.46	274.000	265.890	271.360	263.770	7.590	6.19	5.73	1.2050	0.0	24.0
08.10.25	45.05	40.68	4.37	278.510	269.870	275.850	267.700	8.150	6.18	5.71	1.2050	0.0	24.0
09.10.25	44.85	40.50	4.35	276.080	267.420	273.440	265.280	8.160	6.25	5.78	1.1910	0.0	24.0
10.10.25	44.66	40.38	4.28	276.040	267.330	273.440	265.230	8.210	6.33	5.86	1.1720	0.0	24.0
11.10.25	44.41	40.19	4.22	278.940	270.000	276.350	267.900	8.450	6.35	5.87	1.1620	0.0	24.0
12.10.25	45.04	40.56	4.48	278.930	270.020	276.260	267.860	8.400	6.36	5.89	1.2360	0.0	24.0
13.10.25	46.73	41.90	4.83	278.830	269.800	275.950	267.640	8.310	6.37	5.90	1.3370	0.0	24.0
14.10.25	46.33	41.69	4.64	279.240	270.210	276.430	268.070	8.360	6.37	5.89	1.2800	0.0	24.0
15.10.25	46.99	42.12	4.87	279.390	270.300	276.510	268.140	8.370	6.37	5.89	1.3450	0.0	24.0
16.10.25	46.83	41.91	4.92	279.030	269.970	276.150	267.810	8.340	6.34	5.86	1.3590	0.0	24.0
17.10.25	48.23	42.89	5.34	278.000	268.890	274.950	266.590	8.360	6.35	5.88	1.4670	0.0	24.0
18.10.25	50.76	44.86	5.90	277.180	267.560	273.880	264.980	8.900	6.30	5.84	1.6180	0.0	24.0
19.10.25	51.84	45.83	6.01	281.580	271.580	277.990	268.940	9.050	6.32	5.85	1.6690	0.0	24.0
20.10.25	50.57	44.93	5.64	281.330	271.350	277.970	268.820	9.150	6.28	5.80	1.5660	0.0	24.0
Итого	---	---	---	6779.8	6599.1	6711.38	6545.54	165.840	---	---	31.8540	0.0	720.0
Среднее	41.48	37.45	4.02	---	---	---	---	---	6.21	5.63	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
19.09.25 24:00	0	0	0	0	0	0	0	0
20.10.25 24:00	54571.220	52766.840	53864.549	52273.729	421.2180	1590.820	2275.0	7959.0
Итого за период	54571.220	52766.840	53864.549	52273.729	421.2180	---	2275.0	7959.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Девонская, 8
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00166102

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0хВ9ФВ

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Мг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	16.08	15.73	0.35	0.000	0.000	0.000	0.000	0.000	1.00	3.22	0.0000	0.0	24.0
20.09.25	16.19	15.82	0.37	0.000	0.000	0.000	0.000	0.000	1.00	1.89	0.0000	0.0	24.0
21.09.25	16.22	15.84	0.38	0.000	0.000	0.000	0.000	0.000	1.00	1.50	0.0000	0.0	24.0
22.09.25	16.39	15.97	0.42	0.000	0.000	0.000	0.000	0.000	1.00	3.52	0.0000	0.0	24.0
23.09.25	16.40	15.99	0.41	0.480	0.480	0.480	0.480	0.000	1.21	4.87	0.0000	0.0	24.0
24.09.25	16.72	16.22	0.50	0.000	0.000	0.000	0.000	0.000	1.00	4.87	0.0000	0.0	24.0
25.09.25	44.52	38.10	6.42	69.530	70.160	68.880	69.660	-0.780	2.90	4.90	0.4410	0.0	24.0
26.09.25	42.60	38.05	4.55	161.440	162.440	160.010	161.320	-1.310	5.92	5.15	0.7300	0.0	24.0
27.09.25	40.28	36.40	3.88	151.270	151.400	150.070	150.440	-0.370	6.40	5.73	0.5820	0.0	24.0
28.09.25	40.47	36.58	3.89	148.960	149.240	147.760	148.280	-0.520	6.38	5.71	0.5750	0.0	24.0
29.09.25	43.38	37.71	5.67	149.630	149.950	148.290	148.940	-0.650	6.28	5.64	0.8400	0.0	24.0
30.09.25	47.53	39.83	7.70	151.720	151.890	150.050	150.690	-0.640	6.27	5.68	1.1520	0.0	24.0
01.10.25	47.47	39.91	7.56	148.800	149.090	147.170	147.890	-0.720	6.27	5.69	1.1110	0.0	24.0
02.10.25	47.53	39.98	7.55	148.490	148.800	146.830	147.600	-0.770	6.23	5.66	1.1100	0.0	24.0
03.10.25	48.23	40.54	7.69	148.550	148.860	146.870	147.660	-0.790	6.23	5.67	1.1280	0.0	24.0
04.10.25	48.22	40.56	7.66	148.600	149.020	146.920	147.820	-0.900	6.28	5.73	1.1240	0.0	24.0
05.10.25	48.15	40.69	7.46	148.830	149.020	147.150	147.820	-0.670	6.29	5.73	1.0960	0.0	24.0
06.10.25	47.21	40.15	7.06	148.640	148.900	147.080	147.730	-0.650	6.25	5.69	1.0360	0.0	24.0
07.10.25	45.09	38.78	6.31	148.800	148.760	147.360	147.800	-0.440	6.28	5.72	0.9310	0.0	24.0
08.10.25	45.18	38.96	6.22	149.330	149.570	147.890	148.570	-0.680	6.27	5.70	0.9230	0.0	24.0
09.10.25	44.99	38.77	6.22	148.440	148.760	147.000	147.800	-0.800	6.34	5.78	0.9130	0.0	24.0
10.10.25	44.79	38.75	6.04	148.710	149.010	147.280	148.040	-0.760	6.41	5.85	0.8880	0.0	24.0
11.10.25	44.53	38.56	5.97	150.650	150.740	149.240	149.780	-0.540	6.44	5.86	0.8910	0.0	24.0
12.10.25	45.16	38.91	6.25	150.980	150.880	149.540	149.880	-0.340	6.46	5.88	0.9330	0.0	24.0
13.10.25	46.86	40.06	6.80	151.080	150.990	149.540	149.790	-0.250	6.47	5.89	1.0140	0.0	24.0
14.10.25	46.45	39.90	6.55	151.340	151.130	149.780	149.960	-0.180	6.46	5.88	0.9780	0.0	24.0
15.10.25	47.12	40.23	6.89	151.570	151.360	149.910	150.160	-0.250	6.47	5.89	1.0330	0.0	24.0
16.10.25	46.96	40.00	6.96	151.080	151.230	149.550	150.030	-0.480	6.44	5.86	1.0410	0.0	24.0
17.10.25	48.34	40.80	7.54	150.770	150.530	149.130	149.330	-0.200	6.45	5.87	1.1210	0.0	24.0
18.10.25	50.88	42.55	8.33	149.950	149.750	148.090	148.550	-0.460	6.40	5.83	1.2330	0.0	24.0
19.10.25	51.96	43.48	8.48	152.030	152.040	150.110	150.600	-0.490	6.43	5.84	1.2730	0.0	24.0
20.10.25	50.71	42.78	7.93	151.990	152.150	150.190	150.830	-0.640	6.38	5.80	1.1870	0.0	24.0
Итого	---	---	---	3831.6	3836.1	3792.17	3807.45	-15.280	---	---	25.2840	0.0	768.0
Среднее	40.70	35.20	5.50	---	---	---	---	---	5.24	5.27	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Мг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	31100.100	31197.850	30666.430	30900.250	292.2430	-233.820	1794.0	7694.0
20.10.25 24:00	34931.760	35034.000	34458.600	34707.700	317.5270	-249.100	1794.0	8462.0
Итого за период	3831.660	3836.150	3792.169	3807.449	25.2840	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Комсомольская, 10
Потребитель: АО "Жилуправление"
Прибор: ТВ7-04.1 Заводской номер: 23190736

БД=1, ТВ1, СИ=6, КСН=0х1671

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
25.09.25	17.82	17.23	н/д	0.59	1.46	2.60	н/д	0.032	0.178	н/д	0.032	0.178	н/д	-0.146	0	н/д	24	0
26.09.25	37.93	25.80	н/д	12.13	4.10	4.25	н/д	4.006	4.423	н/д	3.980	4.413	н/д	-0.433	0.048	н/д	24	0
27.09.25	39.39	32.67	н/д	6.72	4.63	5.20	н/д	40.627	40.522	н/д	40.345	40.342	н/д	0.003	0.271	н/д	24	0
28.09.25	39.58	33.03	н/д	6.56	4.62	5.20	н/д	41.625	41.505	н/д	41.332	41.314	н/д	0.018	0.271	н/д	24	0
29.09.25	42.03	34.29	н/д	7.75	4.53	5.20	н/д	40.270	40.114	н/д	39.945	39.911	н/д	0.035	0.309	н/д	24	0
30.09.25	46.30	36.23	н/д	10.07	4.54	5.20	н/д	36.334	36.135	н/д	35.974	35.928	н/д	0.046	0.362	н/д	24	0
01.10.25	46.22	36.24	н/д	9.97	4.54	5.20	н/д	35.508	35.296	н/д	35.158	35.093	н/д	0.065	0.351	н/д	24	0
02.10.25	46.32	36.42	н/д	9.90	4.51	5.20	н/д	36.319	36.091	н/д	35.960	35.881	н/д	0.079	0.356	н/д	24	0
03.10.25	46.99	37.02	н/д	9.97	4.50	5.20	н/д	36.863	36.618	н/д	36.488	36.395	н/д	0.093	0.364	н/д	24	0
04.10.25	47.01	37.00	н/д	10.00	4.56	5.20	н/д	36.713	36.458	н/д	36.339	36.240	н/д	0.099	0.363	н/д	24	0
05.10.25	46.94	37.11	н/д	9.84	4.56	5.20	н/д	36.688	36.425	н/д	36.315	36.204	н/д	0.111	0.357	н/д	24	0
06.10.25	46.14	36.71	н/д	9.43	4.53	5.20	н/д	36.652	36.396	н/д	36.292	36.179	н/д	0.113	0.342	н/д	24	0
07.10.25	44.02	35.59	н/д	8.42	4.55	2.92	н/д	36.614	36.371	н/д	36.289	36.168	н/д	0.121	0.307	н/д	24	0
08.10.25	44.09	35.76	н/д	8.33	4.53	1.29	н/д	36.612	36.360	н/д	36.286	36.153	н/д	0.133	0.304	н/д	24	0
09.10.25	43.89	35.44	н/д	8.46	4.60	1.19	н/д	36.073	35.821	н/д	35.752	35.621	н/д	0.131	0.304	н/д	24	0
10.10.25	43.72	35.46	н/д	8.25	4.68	1.20	н/д	35.828	35.570	н/д	35.516	35.370	н/д	0.146	0.295	н/д	24	0
11.10.25	43.49	35.41	н/д	8.08	4.70	1.28	н/д	36.222	35.958	н/д	35.908	35.756	н/д	0.152	0.292	н/д	24	0
12.10.25	44.02	35.59	н/д	8.43	4.72	1.25	н/д	36.211	35.938	н/д	35.890	35.735	н/д	0.155	0.305	н/д	24	0
13.10.25	45.68	36.66	н/д	9.02	4.73	1.44	н/д	36.340	36.040	н/д	35.990	35.822	н/д	0.168	0.327	н/д	24	0
14.10.25	45.30	36.58	н/д	8.72	4.72	1.50	н/д	36.461	36.158	н/д	36.119	35.942	н/д	0.177	0.317	н/д	24	0
15.10.25	45.92	36.61	н/д	9.31	4.73	1.54	н/д	36.320	36.007	н/д	35.969	35.789	н/д	0.179	0.337	н/д	24	0
16.10.25	45.80	36.51	н/д	9.30	4.69	1.51	н/д	36.260	35.945	н/д	35.911	35.732	н/д	0.180	0.336	н/д	24	0
17.10.25	46.94	36.96	н/д	9.97	4.71	1.59	н/д	35.829	35.500	н/д	35.465	35.281	н/д	0.184	0.356	н/д	24	0
18.10.25	49.51	38.35	н/д	11.16	4.66	1.58	н/д	35.560	35.198	н/д	35.156	34.961	н/д	0.195	0.394	н/д	24	0
19.10.25	50.58	39.33	н/д	11.24	4.68	1.67	н/д	36.248	35.857	н/д	35.818	35.605	н/д	0.213	0.405	н/д	24	0
20.10.25	49.50	38.80	н/д	10.70	4.64	1.80	н/д	36.200	35.818	н/д	35.790	35.573	н/д	0.217	0.385	н/д	24	0
Итого	---	---	---	---	---	---	---	888.415	882.702	---	880.019	877.586	---	2.434	8.058	---	624	0
Среднее	45.27	36.14	---	9.13	4.48	3.10	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
20.10.25 24:00	888.417	882.699	0.000	880.021	877.587	0.000	2.434	8.059	0.000	925	0
Итого за период	н/д	н/д	н/д	н/д	н/д	н/д	---	н/д	н/д	н/д	н/д

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Комсомольская, 17а
 Потребитель: АО "Жилуправление"
 Прибор: Вzlёт ТСРВ-024 Заводской номер: 902185
 Тип системы: А32-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	16.43	16.37	0.06	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
20.09.25	16.41	16.34	0.07	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
21.09.25	16.39	16.32	0.07	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
22.09.25	16.42	16.34	0.08	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
23.09.25	16.45	16.35	0.10	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
24.09.25	16.55	16.42	0.13	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
25.09.25	16.58	16.46	0.12	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
26.09.25	21.72	20.47	1.25	14.76	14.55	0.21	0.000	0.000	14.87	14.65	0.22	0.094	21.483
27.09.25	39.67	36.59	3.08	140.46	139.42	1.03	0.000	0.000	141.55	140.34	1.20	0.463	24.000
28.09.25	39.87	36.66	3.21	140.67	139.66	1.00	0.000	0.000	141.76	140.59	1.17	0.483	24.000
29.09.25	41.32	37.05	4.27	139.96	138.39	1.56	0.000	0.000	141.12	139.34	1.78	0.673	24.000
30.09.25	46.98	40.50	6.48	227.52	226.61	0.90	0.000	0.000	229.96	228.44	1.52	1.504	24.000
01.10.25	47.19	41.54	5.65	180.49	180.05	0.43	0.000	0.000	182.43	181.59	0.84	1.036	24.000
02.10.25	47.22	41.81	5.41	168.12	167.60	0.52	0.000	0.000	169.93	169.05	0.88	0.927	24.000
03.10.25	47.68	40.71	6.97	172.42	171.77	0.65	0.000	0.000	174.32	173.17	1.15	1.242	24.000
04.10.25	47.93	40.41	7.52	198.23	197.91	0.31	0.000	0.000	200.44	199.49	0.95	1.498	24.000
05.10.25	47.83	40.46	7.37	196.97	196.67	0.30	0.000	0.000	199.16	198.25	0.91	1.460	24.000
06.10.25	47.68	40.43	7.25	198.51	198.21	0.30	0.000	0.000	200.71	199.81	0.90	1.446	24.000
07.10.25	45.02	38.64	6.38	196.33	195.97	0.35	0.000	0.000	198.27	197.40	0.87	1.264	24.000
08.10.25	44.86	38.57	6.29	198.30	197.92	0.38	0.000	0.000	200.25	199.36	0.89	1.259	24.000
09.10.25	44.78	38.52	6.26	197.44	197.05	0.38	0.000	0.000	199.37	198.48	0.89	1.246	24.000
10.10.25	44.60	38.54	6.06	198.03	197.62	0.40	0.000	0.000	199.96	199.07	0.89	1.212	24.000
11.10.25	44.45	38.47	5.98	200.19	199.76	0.43	0.000	0.000	202.12	201.21	0.92	1.210	24.000
12.10.25	44.49	38.48	6.01	201.87	201.41	0.45	0.000	0.000	203.82	202.87	0.94	1.226	24.000
13.10.25	46.20	39.49	6.71	201.40	200.95	0.44	0.000	0.000	203.50	202.49	1.01	1.364	24.000
14.10.25	46.59	40.02	6.57	203.85	203.41	0.44	0.000	0.000	206.01	205.01	1.00	1.350	24.000
15.10.25	46.41	39.78	6.63	205.97	205.48	0.49	0.000	0.000	208.13	207.07	1.06	1.380	24.000
16.10.25	46.79	39.90	6.89	202.59	202.10	0.48	0.000	0.000	204.75	203.68	1.07	1.411	24.000
17.10.25	46.89	39.74	7.15	198.38	197.90	0.47	0.000	0.000	200.50	199.44	1.07	1.433	24.000
18.10.25	50.79	42.36	8.43	198.99	198.58	0.40	0.000	0.000	201.47	200.33	1.14	1.689	24.000
19.10.25	51.15	42.64	8.51	199.27	198.87	0.39	0.000	0.000	201.79	200.65	1.15	1.707	24.000
20.10.25	51.23	42.94	8.29	201.41	200.99	0.41	0.000	0.000	203.96	202.81	1.16	1.683	24.000
Итого	---	---	---	4582.11	4568.85	13.26	---	---	4630.16	4604.60	25.55	30.262	765.483
Среднее	38.89	34.04	4.85	---	---	---	0.000	0.000	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Комсомольская, 19а
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВА769

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	0.00	16.39	2.58	16.03	2.81	24.00	24.00	0.00	0.00
21.09.25	0.00	16.39	2.73	16.07	2.83	24.00	24.00	0.00	0.00
22.09.25	0.00	16.40	2.87	16.11	2.73	24.00	24.00	0.00	0.00
23.09.25	0.00	16.40	3.04	16.12	2.76	24.00	24.00	0.00	0.00
24.09.25	0.00	16.48	3.17	16.21	2.80	24.00	24.00	0.00	0.00
25.09.25	0.00	16.59	3.26	16.30	2.89	24.00	24.00	0.00	0.00
26.09.25	0.57	27.06	211.33	25.90	212.23	23.58	24.00	0.00	0.00
27.09.25	32.64	45.47	327.05	-113.76	298.48	21.30	21.30	0.00	0.00
28.09.25	68.95	45.14	228.38	-238.77	162.78	24.00	24.00	0.00	0.00
29.09.25	69.81	45.31	230.72	-239.19	163.17	24.00	24.00	0.00	0.00
30.09.25	71.89	47.93	235.14	-239.48	165.21	24.00	24.00	0.00	0.00
01.10.25	80.59	52.12	260.05	-239.61	182.73	24.00	24.00	0.00	0.00
02.10.25	75.86	52.09	244.63	-239.84	171.58	24.00	24.00	0.00	0.00
03.10.25	73.94	52.14	238.68	-239.51	167.16	24.00	24.00	0.00	0.00
04.10.25	75.65	52.80	243.66	-239.55	170.69	24.00	24.00	0.00	0.00
05.10.25	76.06	52.86	245.11	-239.35	171.60	24.00	24.00	0.00	0.00
06.10.25	76.22	52.79	245.13	-239.96	171.19	24.00	24.00	0.00	0.00
07.10.25	75.90	51.86	245.04	-239.72	171.22	24.00	24.00	0.00	0.00
08.10.25	74.88	49.72	243.26	-239.91	169.74	24.00	24.00	0.00	0.00
09.10.25	38.95	47.53	244.22	-102.59	205.03	23.60	24.00	0.00	0.00
10.10.25	1.38	44.94	243.83	39.25	240.69	24.00	24.00	0.00	0.00
11.10.25	1.35	44.75	244.04	39.21	240.89	24.00	24.00	0.00	0.00
12.10.25	1.34	44.49	246.81	39.05	243.64	24.00	24.00	0.00	0.00
13.10.25	1.42	45.09	247.43	39.35	244.34	24.00	24.00	0.00	0.00
14.10.25	1.55	46.80	246.86	40.50	243.72	24.00	24.00	0.00	0.00
15.10.25	1.50	46.40	249.37	40.38	246.15	24.00	24.00	0.00	0.00
16.10.25	1.58	47.06	247.19	40.66	243.67	24.00	24.00	0.00	0.00
17.10.25	1.61	46.91	247.38	40.41	244.01	24.00	24.00	0.00	0.00
18.10.25	1.73	48.25	246.81	41.21	243.46	24.00	24.00	0.00	0.00
19.10.25	1.92	50.83	245.72	42.99	242.31	24.00	24.00	0.00	0.00
20.10.25	1.97	51.91	248.21	43.94	244.58	24.00	24.00	0.00	0.00
Итого	909.26	---	6173.70	---	5277.09	740.48	741.30	0.00	0.00
Среднее	---	41.642	---	-73.598	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	6524.52	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Комсомольская, 20
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00177887

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0x551С

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	16.80	16.95	-0.15	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
20.09.25	16.77	16.91	-0.14	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
21.09.25	16.68	16.81	-0.13	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
22.09.25	16.83	16.94	-0.11	0.000	0.000	0.000	0.000	0.000	6.90	7.57	0.0000	0.0	24.0
23.09.25	17.06	17.06	0.00	0.000	0.000	0.000	0.000	0.000	6.90	7.00	0.0000	0.0	24.0
24.09.25	17.18	17.17	0.01	0.000	0.000	0.000	0.000	0.000	6.90	4.31	0.0000	0.0	24.0
25.09.25	28.73	27.70	1.03	195.700	198.590	193.820	196.930	-3.110	6.90	2.51	0.7740	0.0	24.0
26.09.25	42.30	39.09	3.21	470.600	474.450	466.620	470.990	-4.370	6.90	4.90	1.5030	0.0	24.0
27.09.25	40.18	37.13	3.05	487.720	490.860	484.110	487.710	-3.600	6.90	3.29	1.5080	0.0	24.0
28.09.25	40.36	37.09	3.27	485.150	488.990	481.480	485.800	-4.320	6.90	2.01	1.6170	0.0	24.0
29.09.25	43.23	39.09	4.14	477.760	481.510	473.600	478.040	-4.440	6.90	5.61	1.9680	0.0	24.0
30.09.25	47.44	42.30	5.14	464.270	468.470	459.390	464.470	-5.080	6.90	5.54	2.3710	0.0	24.0
01.10.25	47.38	42.29	5.09	462.090	467.070	457.270	463.200	-5.930	6.90	6.88	2.3250	0.0	24.0
02.10.25	47.41	42.31	5.10	456.600	461.100	451.820	457.260	-5.440	6.90	6.19	2.3090	0.0	24.0
03.10.25	48.15	43.00	5.15	460.050	465.570	455.060	461.500	-6.440	6.90	6.55	2.3380	0.0	24.0
04.10.25	48.14	43.01	5.13	458.420	464.190	453.380	460.110	-6.730	6.90	5.15	2.3410	0.0	24.0
05.10.25	48.04	42.98	5.06	458.010	464.230	453.070	460.150	-7.080	6.90	4.48	2.3120	0.0	24.0
06.10.25	47.11	42.33	4.78	457.420	463.920	452.650	459.990	-7.340	6.90	3.95	2.1840	0.0	24.0
07.10.25	44.98	40.71	4.27	456.380	463.100	452.060	459.490	-7.430	6.90	3.27	1.9580	0.0	24.0
08.10.25	45.08	40.83	4.25	456.830	463.760	452.510	460.110	-7.600	6.90	2.93	1.9510	0.0	24.0
09.10.25	44.89	40.65	4.24	456.330	463.060	452.010	459.460	-7.450	6.90	3.41	1.9440	0.0	24.0
10.10.25	44.69	40.56	4.13	456.590	463.760	452.320	460.160	-7.840	6.90	3.04	1.9030	0.0	24.0
11.10.25	44.44	40.39	4.05	461.230	468.690	456.990	465.030	-8.040	6.90	2.90	1.8800	0.0	24.0
12.10.25	45.06	40.77	4.29	461.780	469.540	457.410	465.830	-8.420	6.90	2.65	1.9960	0.0	24.0
13.10.25	46.77	42.10	4.67	461.930	470.070	457.160	466.060	-8.900	6.90	2.74	2.1690	0.0	24.0
14.10.25	46.36	41.85	4.51	462.650	470.810	457.980	466.840	-8.860	6.90	2.73	2.0960	0.0	24.0
15.10.25	47.02	42.28	4.74	462.970	471.230	458.170	467.150	-8.980	6.90	2.89	2.2050	0.0	24.0
16.10.25	46.87	42.09	4.78	461.230	468.290	456.460	464.360	-7.900	6.90	2.71	2.2150	0.0	24.0
17.10.25	48.26	43.05	5.21	460.220	466.710	455.160	462.610	-7.450	6.90	2.58	2.4060	0.0	24.0
18.10.25	50.81	45.04	5.77	458.190	465.900	452.680	461.430	-8.750	6.90	3.68	2.6370	0.0	24.0
19.10.25	51.89	45.98	5.91	461.960	470.650	456.200	465.850	-9.650	6.90	2.36	2.7330	0.0	24.0
20.10.25	50.62	45.09	5.53	461.740	470.660	456.250	466.110	-9.860	6.90	3.46	2.5500	0.0	24.0
Итого	---	---	---	11773.8	11935.1	11655.63	11836.64	-181.010	---	---	54.1930	0.0	768.0
Среднее	40.23	36.61	3.62	---	---	---	---	---	6.90	4.29	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	95552.950	96383.410	94257.050	95387.870	664.4000	-1130.820	990.0	9993.0
20.10.25 24:00	107326.770	108318.590	105912.680	107224.510	718.5930	-1311.830	990.0	10761.0
Итого за период	11773.820	11935.179	11655.629	11836.640	54.1930	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Комсомольская, 21
 Потребитель: АО "Жилуправление"
 Прибор: Вzlёт TCRB-024 Заводской номер: 802467
 Тип системы: A32-00 Система: 1

TB1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
28.09.25	40.12	36.48	3.64	165.95	165.86	0.08	0.005	0.000	167.24	166.96	0.27	0.606	24.000
29.09.25	41.52	37.18	4.34	159.60	159.18	0.41	0.005	0.000	160.89	160.32	0.58	0.705	24.000
30.09.25	47.02	39.78	7.24	145.50	145.24	0.25	0.005	0.000	147.04	146.39	0.65	1.076	24.000
01.10.25	47.33	39.15	8.18	163.99	163.97	0.02	0.005	0.000	165.72	165.26	0.47	1.340	24.000
02.10.25	47.37	39.23	8.14	160.72	160.63	0.08	0.005	0.000	162.46	161.86	0.61	1.308	24.000
03.10.25	47.81	39.23	8.58	151.71	151.53	0.18	0.005	0.000	153.40	152.68	0.71	1.306	24.000
04.10.25	48.01	39.11	8.90	149.08	148.90	0.17	0.005	0.000	150.75	150.02	0.73	1.332	24.000
05.10.25	47.93	39.12	8.81	148.12	147.93	0.18	0.005	0.000	149.77	149.05	0.73	1.310	24.000
06.10.25	47.79	39.18	8.61	148.68	148.49	0.18	0.005	0.000	150.33	149.61	0.72	1.284	24.000
07.10.25	45.14	37.59	7.55	146.78	146.56	0.21	0.005	0.000	148.24	147.58	0.66	1.115	24.000
08.10.25	44.96	37.56	7.40	147.54	147.35	0.18	0.005	0.000	148.99	148.37	0.62	1.097	24.000
09.10.25	44.89	37.48	7.41	146.94	146.74	0.20	0.005	0.000	148.38	147.75	0.63	1.094	24.000
10.10.25	44.72	37.51	7.21	147.21	147.00	0.20	0.005	0.000	148.65	148.02	0.63	1.067	24.000
11.10.25	44.57	37.42	7.15	148.24	148.02	0.21	0.005	0.000	149.68	149.04	0.64	1.066	24.000
12.10.25	44.58	37.38	7.20	149.39	149.22	0.17	0.005	0.000	150.84	150.24	0.60	1.080	24.000
13.10.25	46.28	38.33	7.95	148.92	148.80	0.12	0.005	0.000	150.48	149.87	0.60	1.186	24.000
14.10.25	46.71	38.84	7.87	149.95	149.81	0.13	0.004	0.000	151.54	150.92	0.62	1.183	24.000
15.10.25	46.47	38.57	7.90	150.87	150.73	0.13	0.004	0.000	152.46	151.84	0.62	1.195	24.000
16.10.25	46.89	38.71	8.18	149.28	149.10	0.17	0.005	0.000	150.87	150.20	0.67	1.226	24.000
17.10.25	46.95	38.57	8.38	147.69	147.49	0.19	0.005	0.000	149.27	148.57	0.70	1.242	24.000
18.10.25	50.86	41.06	9.80	149.12	149.01	0.11	0.004	0.000	150.99	150.24	0.75	1.462	24.000
19.10.25	51.17	41.20	9.97	148.00	147.87	0.12	0.004	0.000	149.87	149.11	0.77	1.478	24.000
20.10.25	51.31	41.65	9.66	150.83	150.69	0.14	0.005	0.000	152.75	151.97	0.78	1.460	24.000
Итого	---	---	---	3474.08	3470.14	3.94	---	---	3510.63	3495.86	14.77	27.219	552.000
Среднее	46.54	38.71	7.83	---	---	---	0.005	0.000	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Комсомольская, 21а
 Потребитель: АО "Жилуправление"
 Прибор: ИМ2300 Заводской номер: ВВ673

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	15.82	0.00	15.25	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	15.76	0.00	15.19	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	15.83	0.00	15.23	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	15.92	0.00	15.30	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	16.06	0.00	15.46	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	16.21	0.00	15.57	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	16.41	0.00	16.31	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	16.50	9.11	16.29	0.01	10.25	24.00	0.00	0.00
27.09.25	0.39	24.73	77.09	22.53	72.59	21.15	21.50	0.00	0.00
28.09.25	0.99	40.43	191.22	35.22	197.64	24.00	24.00	0.00	0.00
29.09.25	0.90	40.59	171.78	35.34	177.95	24.00	24.00	0.00	0.00
30.09.25	0.91	43.33	148.59	37.11	153.84	24.00	24.00	0.00	0.00
01.10.25	1.04	47.57	125.36	39.29	130.23	24.00	24.00	0.00	0.00
02.10.25	1.20	47.53	135.96	38.69	141.57	23.95	24.00	0.00	0.00
03.10.25	1.27	47.62	144.08	38.80	150.32	24.00	24.00	0.00	0.00
04.10.25	1.28	48.30	135.20	38.80	140.97	24.00	24.00	0.00	0.00
05.10.25	1.29	48.30	131.88	38.49	138.01	24.00	24.00	0.00	0.00
06.10.25	1.26	48.22	130.95	38.56	137.01	24.00	24.00	0.00	0.00
07.10.25	1.20	47.32	130.68	38.14	136.79	24.00	24.00	0.00	0.00
08.10.25	1.07	45.17	129.60	36.92	135.91	24.00	24.00	0.00	0.00
09.10.25	1.06	45.27	130.03	37.10	136.12	24.00	24.00	0.00	0.00
10.10.25	1.06	45.08	129.64	36.92	135.83	24.00	24.00	0.00	0.00
11.10.25	1.03	44.89	129.77	36.95	135.92	24.00	24.00	0.00	0.00
12.10.25	1.02	44.64	131.35	36.85	137.49	24.00	24.00	0.00	0.00
13.10.25	1.08	45.23	131.88	37.05	138.01	24.00	24.00	0.00	0.00
14.10.25	1.16	46.93	131.58	38.09	137.43	24.00	24.00	0.00	0.00
15.10.25	1.13	46.55	132.91	38.06	138.68	24.00	24.00	0.00	0.00
16.10.25	1.18	47.19	133.56	38.35	139.45	24.00	24.00	0.00	0.00
17.10.25	1.18	47.05	131.17	38.02	137.17	24.00	24.00	0.00	0.00
18.10.25	1.27	48.34	130.90	38.60	136.81	24.00	24.00	0.00	0.00
19.10.25	1.41	50.93	130.31	40.09	136.19	24.00	24.00	0.00	0.00
20.10.25	1.45	52.01	131.59	40.94	137.09	24.00	24.00	0.00	0.00
Итого	26.83	---	3236.19	---	3359.03	583.35	765.50	0.00	0.00
Среднее	---	38.179	---	31.860	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	2036.09	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Комсомольская, 23
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ522

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	15.88	0.00	15.73	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	15.81	0.00	15.67	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	15.75	0.00	15.62	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	15.73	0.00	15.59	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	15.81	0.00	15.64	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	15.94	0.00	15.74	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	16.05	0.00	15.82	0.00	0.00	24.00	0.00	0.00
26.09.25	0.66	31.43	161.93	29.23	159.92	12.14	24.00	0.00	0.00
27.09.25	0.78	42.69	214.79	39.07	212.42	24.00	24.00	0.00	0.00
28.09.25	0.70	40.46	193.60	36.84	192.13	24.00	24.00	0.00	0.00
29.09.25	0.66	40.63	188.22	37.11	187.08	24.00	24.00	0.00	0.00
30.09.25	0.80	43.39	182.26	39.00	181.28	24.00	24.00	0.00	0.00
01.10.25	1.13	47.69	174.94	41.23	174.08	24.00	24.00	0.00	0.00
02.10.25	1.27	47.63	175.25	40.36	174.76	24.00	24.00	0.00	0.00
03.10.25	1.29	47.70	175.68	40.37	175.32	24.00	24.00	0.00	0.00
04.10.25	1.32	48.39	173.58	40.79	173.32	24.00	24.00	0.00	0.00
05.10.25	1.32	48.40	171.88	40.70	171.65	24.00	24.00	0.00	0.00
06.10.25	1.30	48.32	171.51	40.73	171.25	24.00	24.00	0.00	0.00
07.10.25	1.22	47.43	171.29	40.27	170.92	24.00	24.00	0.00	0.00
08.10.25	1.09	45.25	170.22	38.85	169.87	24.00	24.00	0.00	0.00
09.10.25	1.07	45.35	170.37	39.04	170.11	24.00	24.00	0.00	0.00
10.10.25	1.07	45.16	169.97	38.83	169.73	24.00	24.00	0.00	0.00
11.10.25	1.04	44.96	169.96	38.83	169.63	24.00	24.00	0.00	0.00
12.10.25	1.03	44.71	171.89	38.72	171.41	24.00	24.00	0.00	0.00
13.10.25	1.09	45.30	172.34	38.97	171.68	24.00	24.00	0.00	0.00
14.10.25	1.17	47.02	172.05	40.18	171.50	24.00	24.00	0.00	0.00
15.10.25	1.14	46.63	172.60	40.04	172.04	24.00	24.00	0.00	0.00
16.10.25	1.07	46.32	147.41	39.04	145.19	21.57	24.00	0.00	0.00
17.10.25	1.10	47.02	161.49	40.27	160.45	23.11	24.00	0.00	0.00
18.10.25	1.30	48.42	170.57	40.80	170.27	23.73	24.00	0.00	0.00
19.10.25	1.46	51.05	172.02	42.53	171.77	24.00	24.00	0.00	0.00
20.10.25	1.50	52.13	173.49	43.45	173.20	24.00	24.00	0.00	0.00
Итого	27.58	---	4349.31	---	4330.98	584.55	768.00	0.00	0.00
Среднее	---	39.202	---	34.221	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	2510.53	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Комсомольская, 23а
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00182343

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0х3С57

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	15.26	14.83	0.43	0.000	0.000	0.000	0.000	0.000	6.20	2.66	0.0000	0.0	24.0
20.09.25	15.31	14.85	0.46	0.000	0.000	0.000	0.000	0.000	6.20	2.67	0.0000	0.0	24.0
21.09.25	15.28	14.80	0.48	0.000	0.000	0.000	0.000	0.000	6.20	2.67	0.0000	0.0	24.0
22.09.25	15.45	14.92	0.53	0.000	0.000	0.000	0.000	0.000	6.20	2.68	0.0000	0.0	24.0
23.09.25	15.67	15.11	0.56	0.000	0.000	0.000	0.000	0.000	6.20	2.69	0.0000	0.0	24.0
24.09.25	15.80	15.15	0.65	0.000	0.000	0.000	0.000	0.000	6.20	2.70	0.0000	0.0	24.0
25.09.25	15.75	15.21	0.54	0.000	0.000	0.000	0.000	0.000	6.20	2.67	0.0000	0.0	24.0
26.09.25	39.43	34.80	4.63	109.170	104.810	108.390	104.220	4.170	6.20	4.13	0.4970	0.0	24.0
27.09.25	40.19	36.45	3.74	205.600	198.470	204.040	197.270	6.770	6.20	5.96	0.7640	0.0	24.0
28.09.25	40.36	36.90	3.46	195.950	190.230	194.510	189.030	5.480	6.20	5.96	0.6700	0.0	24.0
29.09.25	43.19	39.15	4.04	187.980	182.040	186.360	180.750	5.610	6.20	5.89	0.7530	0.0	24.0
30.09.25	47.41	42.54	4.87	184.900	179.140	182.980	177.680	5.300	6.20	5.93	0.8920	0.0	24.0
01.10.25	47.35	41.46	5.89	185.720	180.490	183.790	179.060	4.730	6.20	5.94	1.0790	0.0	24.0
02.10.25	47.42	40.58	6.84	191.610	185.360	189.630	183.920	5.710	6.20	5.92	1.2980	0.0	24.0
03.10.25	48.11	41.02	7.09	188.790	183.110	186.770	181.670	5.100	6.20	5.92	1.3220	0.0	24.0
04.10.25	48.11	40.71	7.40	187.720	182.510	185.730	181.070	4.660	6.20	5.98	1.3720	0.0	24.0
05.10.25	48.03	40.65	7.38	187.700	182.630	185.710	181.190	4.520	6.20	5.99	1.3690	0.0	24.0
06.10.25	47.05	39.90	7.15	174.050	169.950	172.230	168.670	3.560	6.20	5.71	1.2320	0.0	24.0
07.10.25	44.97	38.62	6.35	185.780	179.090	184.090	177.890	6.200	6.20	5.98	1.1680	0.0	24.0
08.10.25	45.07	38.78	6.29	185.650	179.110	183.970	177.910	6.060	6.20	5.96	1.1540	0.0	24.0
09.10.25	44.88	38.61	6.27	185.130	179.060	183.450	177.860	5.590	6.20	6.03	1.1470	0.0	24.0
10.10.25	44.69	38.58	6.11	184.940	179.200	183.260	178.000	5.260	6.20	6.11	1.1190	0.0	24.0
11.10.25	44.43	38.41	6.02	186.730	181.240	185.060	180.040	5.020	6.20	6.13	1.1080	0.0	24.0
12.10.25	45.04	38.66	6.38	186.890	181.590	185.160	180.380	4.780	5.97	6.14	1.1770	0.0	24.0
13.10.25	46.74	39.87	6.87	186.830	181.620	184.910	180.180	4.730	6.20	6.15	1.2690	0.0	24.0
14.10.25	46.34	39.71	6.63	187.470	182.370	185.580	180.980	4.600	6.20	6.15	1.2300	0.0	24.0
15.10.25	47.01	40.09	6.92	188.070	183.070	186.150	181.630	4.520	6.20	6.15	1.2840	0.0	24.0
16.10.25	46.85	39.82	7.03	187.170	181.940	185.250	180.500	4.750	6.20	6.12	1.3010	0.0	24.0
17.10.25	48.21	40.65	7.56	186.930	181.510	184.910	180.070	4.840	6.20	6.14	1.3920	0.0	24.0
18.10.25	50.78	42.44	8.34	186.140	180.770	183.840	179.240	4.600	6.20	6.09	1.5310	0.0	24.0
19.10.25	51.85	43.36	8.49	187.880	182.640	185.480	180.960	4.520	6.20	6.11	1.5740	0.0	24.0
20.10.25	50.61	42.64	7.97	187.770	182.710	185.500	181.150	4.350	6.20	6.07	1.4790	0.0	24.0
Итого	---	---	---	4612.5	4474.6	4566.75	4441.32	125.430	---	---	29.1810	0.0	768.0
Среднее	39.45	34.35	5.10	---	---	---	---	---	6.19	5.23	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	37495.710	38517.230	36981.580	38172.030	371.6800	-1190.450	2804.0	8269.0
20.10.25 24:00	42108.280	42991.889	41548.330	42613.349	400.8610	-1065.020	2804.0	9037.0
Итого за период	4612.570	4474.659	4566.750	4441.319	29.1810	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Комсомольская, 25
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BA785

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	0.00	17.78	1.89	17.37	0.00	21.43	24.00	0.00	0.00
21.09.25	0.00	17.79	2.12	17.09	0.00	24.00	24.00	0.00	0.00
22.09.25	0.00	17.89	2.11	17.10	0.00	24.00	24.00	0.00	0.00
23.09.25	0.00	18.32	2.13	17.68	0.00	24.00	24.00	0.00	0.00
24.09.25	0.00	18.75	2.42	17.88	0.00	24.00	24.00	0.00	0.00
25.09.25	0.00	19.26	2.59	18.04	0.00	24.00	24.00	0.00	0.00
26.09.25	0.64	29.67	190.57	28.10	188.28	23.99	24.00	0.00	0.00
27.09.25	0.94	42.43	357.55	39.82	356.03	24.00	24.00	0.00	0.00
28.09.25	0.75	40.28	321.66	37.95	320.06	24.00	24.00	0.00	0.00
29.09.25	0.77	40.45	317.17	38.02	315.65	24.00	24.00	0.00	0.00
30.09.25	0.87	43.28	305.56	40.41	303.94	24.00	24.00	0.00	0.00
01.10.25	1.51	47.53	311.83	42.73	309.93	24.00	24.00	0.00	0.00
02.10.25	1.77	47.48	333.01	42.14	330.88	24.00	24.00	0.00	0.00
03.10.25	1.74	47.54	328.41	42.22	326.23	24.00	24.00	0.00	0.00
04.10.25	1.78	48.24	324.51	42.74	322.07	24.00	24.00	0.00	0.00
05.10.25	1.79	48.24	323.39	42.69	320.97	24.00	24.00	0.00	0.00
06.10.25	1.76	48.16	323.11	42.70	320.66	24.00	24.00	0.00	0.00
07.10.25	1.67	47.22	322.46	42.05	320.18	24.00	24.00	0.00	0.00
08.10.25	1.48	45.08	320.77	40.45	318.53	24.00	24.00	0.00	0.00
09.10.25	1.47	45.17	321.31	40.57	318.93	24.00	24.00	0.00	0.00
10.10.25	1.46	44.98	320.61	40.41	318.30	24.00	24.00	0.00	0.00
11.10.25	1.42	44.79	320.65	40.36	318.13	24.00	24.00	0.00	0.00
12.10.25	1.40	44.53	323.94	40.21	321.38	24.00	24.00	0.00	0.00
13.10.25	1.47	45.14	324.39	40.59	321.85	24.00	24.00	0.00	0.00
14.10.25	1.60	46.85	324.02	41.90	321.36	24.00	24.00	0.00	0.00
15.10.25	1.55	46.45	324.92	41.68	322.45	24.00	24.00	0.00	0.00
16.10.25	1.63	47.11	332.31	42.20	329.78	24.00	24.00	0.00	0.00
17.10.25	1.64	46.96	326.81	41.93	324.39	24.00	24.00	0.00	0.00
18.10.25	1.77	48.32	323.46	42.84	321.05	24.00	24.00	0.00	0.00
19.10.25	1.95	50.90	321.04	44.80	318.69	24.00	24.00	0.00	0.00
20.10.25	2.02	51.98	323.85	45.73	321.25	24.00	24.00	0.00	0.00
Итого	36.85	---	7980.57	---	7910.97	741.42	744.00	0.00	0.00
Среднее	---	40.276	---	36.465	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	6128.55	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Комсомольская, 25а
Потребитель: АО "Жилуправление"
Прибор: ТВ7-04.1 Заводской номер: 24213200

БД=1, ТВ1, СИ=6, КСН=0х0Е5В

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	15.76	15.12	н/д	0.64	0.08	5.60	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
20.09.25	15.69	15.08	н/д	0.61	0.08	5.60	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
21.09.25	15.66	15.04	н/д	0.62	0.08	5.60	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
22.09.25	16.07	15.48	н/д	0.59	0.08	5.60	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
23.09.25	16.14	15.59	н/д	0.55	0.08	5.60	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
24.09.25	16.42	15.81	н/д	0.61	0.08	5.60	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
25.09.25	16.11	15.53	н/д	0.58	0.08	5.60	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
26.09.25	39.31	36.31	н/д	2.99	1.67	5.60	н/д	128.958	127.940	н/д	128.055	127.200	н/д	0.855	0.382	н/д	24	0
27.09.25	40.29	37.33	н/д	2.96	4.64	5.60	н/д	315.770	318.160	н/д	313.463	316.213	н/д	-2.750	0.925	н/д	24	0
28.09.25	40.47	37.40	н/д	3.07	4.55	5.60	н/д	315.135	314.130	н/д	312.812	312.196	н/д	0.616	0.959	н/д	24	0
29.09.25	43.06	38.90	н/д	4.16	4.76	5.60	н/д	275.245	274.592	н/д	272.910	272.733	н/д	0.176	1.134	н/д	24	0
30.09.25	47.55	41.84	н/д	5.71	4.51	5.60	н/д	236.060	235.572	н/д	233.594	233.703	н/д	-0.109	1.333	н/д	24	0
01.10.25	47.49	41.48	н/д	6.00	4.53	5.60	н/д	234.020	233.613	н/д	231.573	231.794	н/д	-0.221	1.389	н/д	24	0
02.10.25	47.55	41.45	н/д	6.10	4.80	5.60	н/д	232.048	231.875	н/д	229.632	230.068	н/д	-0.436	1.401	н/д	24	0
03.10.25	48.25	41.82	н/д	6.43	4.75	5.60	н/д	229.523	228.783	н/д	227.051	226.954	н/д	0.097	1.458	н/д	24	0
04.10.25	48.25	41.56	н/д	6.69	4.70	5.60	н/д	228.033	227.840	н/д	225.573	226.047	н/д	-0.474	1.508	н/д	24	0
05.10.25	48.17	41.60	н/д	6.57	4.07	5.60	н/д	227.827	228.053	н/д	225.385	226.262	н/д	-0.876	1.478	н/д	24	0
06.10.25	47.15	41.30	н/д	5.85	4.63	5.60	н/д	246.495	246.583	н/д	243.959	244.674	н/д	-0.714	1.426	н/д	24	0
07.10.25	45.10	40.32	н/д	4.78	4.64	5.60	н/д	277.145	276.965	н/д	274.543	274.939	н/д	-0.396	1.310	н/д	24	0
08.10.25	45.20	40.52	н/д	4.68	4.63	5.60	н/д	282.497	281.995	н/д	279.843	279.911	н/д	-0.068	1.308	н/д	24	0
09.10.25	45.01	40.35	н/д	4.65	4.48	5.60	н/д	281.885	281.337	н/д	279.262	279.282	н/д	-0.020	1.297	н/д	24	0
10.10.25	44.81	40.30	н/д	4.52	4.53	5.60	н/д	281.810	281.280	н/д	279.213	279.222	н/д	-0.009	1.260	н/д	24	0
11.10.25	44.55	40.09	н/д	4.47	4.58	5.60	н/д	284.592	284.030	н/д	281.989	281.979	н/д	0.010	1.258	н/д	24	0
12.10.25	45.17	40.46	н/д	4.71	4.53	5.60	н/д	285.098	284.452	н/д	282.432	282.350	н/д	0.082	1.328	н/д	24	0
13.10.25	46.88	41.80	н/д	5.09	4.35	5.60	н/д	285.085	284.380	н/д	282.190	282.134	н/д	0.056	1.432	н/д	24	0
14.10.25	46.48	41.59	н/д	4.88	4.65	5.60	н/д	286.013	285.315	н/д	283.157	283.061	н/д	0.097	1.381	н/д	24	0
15.10.25	47.14	42.03	н/д	5.11	4.56	5.60	н/д	286.585	285.840	н/д	283.642	283.540	н/д	0.101	1.446	н/д	24	0
16.10.25	46.99	41.80	н/д	5.19	4.49	5.60	н/д	284.905	284.050	н/д	282.006	281.794	н/д	0.212	1.461	н/д	24	0
17.10.25	48.36	42.75	н/д	5.61	4.55	5.60	н/д	284.492	283.560	н/д	281.401	281.192	н/д	0.209	1.577	н/д	24	0
18.10.25	50.93	44.75	н/д	6.18	4.27	5.60	н/д	283.578	282.582	н/д	280.174	279.974	н/д	0.200	1.729	н/д	24	0
19.10.25	52.02	45.71	н/д	6.31	4.37	5.60	н/д	286.217	285.170	н/д	282.631	282.436	н/д	0.194	1.780	н/д	24	0
20.10.25	50.76	44.82	н/д	5.94	4.60	5.60	н/д	285.835	284.818	н/д	282.406	282.183	н/д	0.223	1.676	н/д	24	0
Итого	---	---	---	---	---	---	---	6644.851	6632.915	---	6578.896	6581.841	---	-2.945	33.636	---	768	0
Среднее	46.31	41.19	---	5.12	3.48	5.60	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	0.012	4.105	0.000	0.012	4.104	0.000	-4.092	0	0.000	506	0
20.10.25 24:00	6644.862	6637.020	0.000	6578.909	6585.945	0.000	-7.036	33.636	0.000	1274	0
Итого за период	6644.850	6632.915	0.000	6578.897	6581.841	0.000	---	33.636	0.000	768	0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Комсомольская, 27
 Потребитель: АО "Жилуправление"
 Прибор: Вzlёт ТСРВ-024 Заводской номер: 719860
 Тип системы: А42-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	16.37	15.75	0.62	0.00	0.00	0.00	0.000	0.265	0.00	0.00	0.00	0.000	9.850
20.09.25	0.00	0.00	0.00	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	0.000
21.09.25	0.00	0.00	0.00	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	0.000
22.09.25	0.00	0.00	0.00	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	0.000
23.09.25	17.27	15.86	1.41	0.00	0.00	0.00	0.000	0.006	0.00	0.00	0.00	0.000	9.083
24.09.25	17.57	16.22	1.35	0.00	0.00	0.00	0.000	0.391	0.00	0.00	0.00	0.000	13.083
25.09.25	27.06	24.61	2.45	144.27	0.00	144.26	0.000	0.404	145.59	0.00	145.59	0.636	24.000
26.09.25	41.66	37.29	4.37	282.00	0.00	282.00	0.000	0.449	284.46	0.00	284.46	1.176	24.000
27.09.25	39.90	35.28	4.62	231.08	0.00	231.08	0.000	0.508	232.89	0.00	232.89	1.041	24.000
28.09.25	40.06	35.29	4.77	229.74	0.00	229.73	0.000	0.506	231.55	0.00	231.55	1.068	24.000
29.09.25	42.67	36.32	6.35	208.18	0.00	208.18	0.000	0.499	210.03	0.00	210.03	1.279	24.000
30.09.25	46.96	38.52	8.44	191.30	0.00	191.29	0.000	0.504	193.35	0.00	193.35	1.590	24.000
01.10.25	46.91	38.64	8.27	191.62	0.00	191.61	0.000	0.504	193.67	0.00	193.67	1.560	24.000
02.10.25	46.98	38.82	8.16	190.31	0.00	190.30	0.000	0.501	192.35	0.00	192.35	1.530	24.000
03.10.25	47.65	39.43	8.22	190.29	0.00	190.29	0.000	0.501	192.40	0.00	192.40	1.541	24.000
04.10.25	47.67	39.36	8.31	188.61	0.00	188.60	0.000	0.507	190.69	0.00	190.69	1.545	24.000
05.10.25	47.60	39.41	8.19	187.89	0.00	187.88	0.000	0.507	189.96	0.00	189.96	1.515	24.000
06.10.25	46.77	39.04	7.73	187.89	0.00	187.89	0.000	0.504	189.90	0.00	189.90	1.431	24.000
07.10.25	44.61	37.72	6.89	187.82	0.00	187.81	0.000	0.507	189.65	0.00	189.65	1.272	24.000
08.10.25	44.70	37.82	6.88	187.49	0.00	187.48	0.000	0.505	189.32	0.00	189.32	1.267	24.000
09.10.25	44.52	37.66	6.86	187.66	0.00	187.66	0.000	0.512	189.48	0.00	189.48	1.264	24.000
10.10.25	44.33	37.62	6.71	187.49	0.00	187.48	0.000	0.519	189.29	0.00	189.29	1.235	24.000
11.10.25	44.09	37.49	6.60	189.74	0.00	189.74	0.000	0.521	191.55	0.00	191.55	1.230	24.000
12.10.25	44.63	37.66	6.97	190.07	0.00	190.07	0.000	0.522	191.92	0.00	191.92	1.302	24.000
13.10.25	46.32	38.74	7.58	189.83	0.00	189.83	0.000	0.523	191.82	0.00	191.82	1.414	24.000
14.10.25	45.88	38.65	7.23	190.16	0.00	190.16	0.000	0.522	192.11	0.00	192.11	1.351	24.000
15.10.25	46.54	38.92	7.62	191.66	0.00	191.65	0.000	0.523	193.68	0.00	193.68	1.436	24.000
16.10.25	46.43	38.66	7.77	189.58	0.00	189.57	0.000	0.520	191.57	0.00	191.57	1.450	24.000
17.10.25	47.63	39.32	8.31	188.94	0.00	188.93	0.000	0.521	191.02	0.00	191.02	1.547	24.000
18.10.25	50.25	41.00	9.25	188.10	0.00	188.09	0.000	0.517	190.40	0.00	190.40	1.716	24.000
19.10.25	51.31	41.89	9.42	189.26	0.00	189.25	0.000	0.519	191.67	0.00	191.67	1.758	24.000
20.10.25	50.21	41.34	8.87	189.17	0.00	189.16	0.000	0.515	191.48	0.00	191.48	1.654	24.000
Итого	---	---	---	5070.12	0.00	5070.11	---	---	5121.79	0.00	5121.79	35.807	656.017
Среднее	38.27	32.32	5.94	---	---	---	0.000	0.431	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Комсомольская, 29
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BA852

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	0.00	16.02	2.76	15.76	0.00	24.00	24.00	0.00	0.00
22.09.25	0.00	15.98	1.95	15.70	0.00	24.00	24.00	0.00	0.00
23.09.25	0	16.15	0.39	15.92	0.00	24.00	24.00	0.00	0.00
24.09.25	0.02	16.34	596.19	16.31	0.00	15.47	24.00	0.00	0.00
25.09.25	0.24	16.33	1098.54	16.11	0.00	24.00	24.00	0.00	0.00
26.09.25	0.16	15.83	815.76	15.63	0.00	24.00	24.00	0.00	0.00
27.09.25	0.44	26.97	402.63	24.73	0.00	23.54	24.00	0.00	0.00
28.09.25	0.83	39.55	202.36	35.43	0.00	24.00	24.00	0.00	0.00
29.09.25	0.93	39.71	205.09	35.18	0.00	24.00	24.00	0.00	0.00
30.09.25	1.18	42.22	195.77	36.12	0.00	24.00	24.00	0.00	0.00
01.10.25	1.43	46.72	176.23	38.58	0.00	24.00	24.00	0.00	0.00
02.10.25	1.41	46.64	176.77	38.64	0.00	24.00	24.00	0.00	0.00
03.10.25	1.40	46.72	175.79	38.72	0.00	24.00	24.00	0.00	0.00
04.10.25	1.44	47.38	176.94	39.21	0.00	24.00	24.00	0.00	0.00
05.10.25	1.44	47.41	175.32	39.20	0.00	24.00	24.00	0.00	0.00
06.10.25	1.41	47.33	174.47	39.22	0.00	24.00	24.00	0.00	0.00
07.10.25	1.35	46.60	174.39	38.86	0.00	24.00	24.00	0.00	0.00
08.10.25	1.20	44.33	174.24	37.44	0.00	24.00	24.00	0.00	0.00
09.10.25	1.19	44.42	173.92	37.53	0.00	24.00	24.00	0.00	0.00
10.10.25	1.19	44.24	174.06	37.39	0.00	24.00	24.00	0.00	0.00
11.10.25	1.16	44.04	173.87	37.36	0.00	24.00	24.00	0.00	0.00
12.10.25	1.15	43.81	176.05	37.23	0.00	24.00	24.00	0.00	0.00
13.10.25	1.21	44.31	176.32	37.43	0.00	24.00	24.00	0.00	0.00
14.10.25	1.32	46.03	176.21	38.55	0.00	24.00	24.00	0.00	0.00
15.10.25	1.27	45.62	177.67	38.46	0.00	24.00	24.00	0.00	0.00
16.10.25	1.33	46.25	178.10	38.78	0.00	24.00	24.00	0.00	0.00
17.10.25	1.34	46.17	176.04	38.53	0.00	24.00	24.00	0.00	0.00
18.10.25	1.43	47.24	175.59	39.09	0.00	24.00	24.00	0.00	0.00
19.10.25	1.59	50.00	174.60	40.89	0.00	24.00	24.00	0.00	0.00
20.10.25	1.64	51.04	175.58	41.68	0.00	24.00	24.00	0.00	0.00
Итого	30.70	---	7033.60	---	0.00	711.01	720.00	0.00	0.00
Среднее	---	39.047	---	33.323	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	5302.69	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Комсомольская, 31
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00169027

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0xC225

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	16.21	15.95	0.26	45.340	17.420	45.340	17.420	27.920	1.00	1.01	0.0100	0.0	24.0
20.09.25	16.16	15.92	0.24	52.510	9.100	52.510	9.100	43.410	1.00	1.01	0.0120	0.0	24.0
21.09.25	16.13	15.84	0.29	59.880	6.080	59.880	6.080	53.800	1.00	1.01	0.0180	0.0	24.0
22.09.25	16.46	16.17	0.29	69.110	0.000	69.110	0.000	69.110	1.00	1.01	0.0240	0.0	24.0
23.09.25	16.55	16.25	0.30	70.390	0.000	70.390	0.000	70.390	1.00	1.01	0.0240	0.0	24.0
24.09.25	16.85	16.47	0.38	62.780	0.000	62.780	0.000	62.780	1.00	1.01	0.0250	0.0	24.0
25.09.25	17.37	38.46	-21.09	25.500	1.350	25.500	1.340	24.160	2.80	2.88	0.0150	0.0	24.0
26.09.25	17.52	17.69	-0.17	0.000	0.000	0.000	0.000	0.000	3.93	4.07	0.0000	0.0	24.0
27.09.25	18.10	19.62	-1.52	0.000	0.000	0.000	0.000	0.000	3.62	3.75	0.0000	0.0	24.0
28.09.25	16.04	19.59	-3.55	3.200	8.010	3.200	8.010	-4.810	2.43	2.52	0.0000	0.0	24.0
29.09.25	43.64	36.17	7.47	104.800	114.240	103.950	113.400	-9.450	4.34	4.09	0.6360	0.0	24.0
30.09.25	47.48	39.71	7.77	175.280	174.750	173.740	173.060	0.680	6.31	5.91	1.3480	0.0	24.0
01.10.25	47.43	39.17	8.26	182.370	182.320	180.770	180.610	0.160	6.35	5.94	1.4910	0.0	24.0
02.10.25	47.49	39.34	8.15	181.820	182.190	180.310	180.310	0.000	6.34	5.93	1.4670	0.0	24.0
03.10.25	48.18	40.03	8.15	182.390	182.940	180.920	180.920	0.000	6.36	5.94	1.4750	0.0	24.0
04.10.25	48.19	40.04	8.15	181.080	181.670	179.620	179.620	0.000	6.43	6.01	1.4640	0.0	24.0
05.10.25	48.12	40.11	8.01	180.660	181.240	179.230	179.230	0.000	6.45	6.02	1.4330	0.0	24.0
06.10.25	47.19	39.63	7.56	180.700	181.330	179.340	179.340	0.000	6.43	5.99	1.3560	0.0	24.0
07.10.25	45.06	38.29	6.77	180.490	181.200	179.340	179.340	0.000	6.47	6.02	1.2140	0.0	24.0
08.10.25	45.15	38.46	6.69	180.170	180.940	179.050	179.050	0.000	6.46	6.01	1.1950	0.0	24.0
09.10.25	44.96	38.29	6.67	180.220	181.000	179.120	179.120	0.000	6.54	6.08	1.1910	0.0	24.0
10.10.25	44.77	38.26	6.51	180.170	180.860	179.040	179.040	0.000	6.62	6.16	1.1650	0.0	24.0
11.10.25	44.52	38.10	6.42	182.220	182.930	181.090	181.090	0.000	6.65	6.18	1.1610	0.0	24.0
12.10.25	45.12	38.37	6.75	182.340	183.040	181.180	181.180	0.000	6.67	6.20	1.2210	0.0	24.0
13.10.25	46.82	39.52	7.30	182.340	182.890	180.870	180.870	0.000	6.67	6.20	1.3190	0.0	24.0
14.10.25	46.34	39.37	6.97	183.970	184.540	182.560	182.560	0.000	6.67	6.20	1.2730	0.0	24.0
15.10.25	47.06	39.71	7.35	184.110	184.690	182.670	182.670	0.000	6.67	6.20	1.3410	0.0	24.0
16.10.25	46.91	39.35	7.56	181.750	182.760	180.630	180.500	0.130	6.64	6.17	1.3620	0.0	24.0
17.10.25	48.26	40.09	8.17	181.540	182.630	180.320	180.320	0.000	6.65	6.19	1.4730	0.0	24.0
18.10.25	50.82	41.79	9.03	181.500	181.940	179.880	179.880	0.000	6.61	6.14	1.6230	0.0	24.0
19.10.25	51.91	42.68	9.23	183.000	183.220	181.050	181.050	0.000	6.63	6.16	1.6690	0.0	24.0
20.10.25	50.68	42.01	8.67	182.850	183.190	181.060	181.060	0.000	6.59	6.12	1.5680	0.0	24.0
Итого	---	---	---	4304.4	3978.4	4274.45	3936.17	338.280	---	---	29.5730	0.0	768.0
Среднее	37.60	33.13	4.47	---	---	---	---	---	5.01	4.72	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	38817.100	38768.330	38382.410	38302.140	404.9930	80.270	2659.0	8347.0
20.10.25 24:00	43121.579	42746.800	42656.859	42238.310	434.5660	418.550	2659.0	9115.0
Итого за период	4304.478	3978.470	4274.448	3936.169	29.5730	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Комсомольская, 35
 Потребитель: АО "Жилуправление"
 Прибор: Вzlёт ТСРВ-024 Заводской номер: 718940
 Тип системы: А32-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	17.20	17.27	-0.07	0.00	0.00	0.00	0.159	0.161	0.00	0.00	0.00	0.000	24.000
20.09.25	17.13	17.16	-0.03	0.00	0.00	0.00	0.158	0.160	0.00	0.00	0.00	0.000	24.000
21.09.25	17.09	17.27	-0.18	0.00	0.00	0.00	0.157	0.160	0.00	0.00	0.00	0.000	24.000
22.09.25	17.08	17.13	-0.05	0.00	0.00	0.00	0.157	0.159	0.00	0.00	0.00	0.000	24.000
23.09.25	17.11	17.19	-0.08	0.00	0.00	0.00	0.157	0.159	0.00	0.00	0.00	0.000	24.000
24.09.25	17.15	17.18	-0.03	0.00	0.00	0.00	0.158	0.159	0.00	0.00	0.00	0.000	24.000
25.09.25	17.18	17.29	-0.11	0.00	0.00	0.00	0.157	0.160	0.00	0.00	0.00	0.000	24.000
26.09.25	22.65	21.90	0.75	69.87	69.18	0.68	0.218	0.212	70.43	69.73	0.71	0.308	24.000
27.09.25	39.92	37.42	2.50	432.49	429.86	2.62	0.568	0.524	435.76	432.72	3.04	1.182	24.000
28.09.25	40.27	37.61	2.66	432.02	429.73	2.28	0.573	0.533	435.35	432.62	2.73	1.238	24.000
29.09.25	41.26	38.30	2.96	436.41	434.09	2.31	0.565	0.528	439.94	437.12	2.82	1.377	24.000
30.09.25	46.98	42.42	4.56	376.78	374.58	2.20	0.555	0.529	380.74	377.79	2.95	1.810	24.000
01.10.25	47.54	42.86	4.68	376.61	374.36	2.24	0.556	0.530	380.66	377.64	3.02	1.857	24.000
02.10.25	47.59	42.99	4.60	376.88	375.28	1.59	0.555	0.531	380.94	378.59	2.35	1.801	24.000
03.10.25	47.92	43.31	4.61	377.27	375.78	1.49	0.551	0.526	381.39	379.15	2.24	1.803	24.000
04.10.25	48.31	43.64	4.67	374.67	373.16	1.50	0.558	0.534	378.83	376.55	2.28	1.816	24.000
05.10.25	48.19	43.57	4.62	371.73	370.01	1.71	0.558	0.534	375.83	373.36	2.47	1.791	24.000
06.10.25	48.20	43.61	4.59	372.00	370.12	1.88	0.555	0.531	376.11	373.48	2.63	1.790	24.000
07.10.25	45.53	41.56	3.97	371.92	369.90	2.02	0.557	0.533	375.59	372.95	2.65	1.558	24.000
08.10.25	45.17	41.26	3.91	370.53	368.39	2.13	0.556	0.533	374.13	371.38	2.75	1.535	24.000
09.10.25	45.13	41.24	3.89	371.25	369.07	2.17	0.556	0.532	374.85	372.06	2.79	1.534	24.000
10.10.25	45.04	41.22	3.82	370.32	368.10	2.22	0.570	0.546	373.90	371.08	2.82	1.506	24.000
11.10.25	44.96	41.13	3.83	373.32	371.06	2.25	0.571	0.547	376.91	374.05	2.86	1.523	24.000
12.10.25	44.52	40.82	3.70	375.32	373.05	2.27	0.573	0.549	378.87	376.01	2.86	1.482	24.000
13.10.25	46.29	42.10	4.19	375.01	372.73	2.28	0.574	0.550	378.84	375.88	2.96	1.666	24.000
14.10.25	47.13	42.91	4.22	376.25	373.92	2.32	0.574	0.550	380.22	377.20	3.02	1.687	24.000
15.10.25	46.54	42.41	4.13	380.48	378.18	2.30	0.574	0.550	384.40	381.42	2.99	1.668	24.000
16.10.25	47.16	42.80	4.36	374.91	372.70	2.21	0.571	0.547	378.88	375.95	2.93	1.730	24.000
17.10.25	46.94	42.56	4.38	373.67	371.44	2.23	0.572	0.549	377.59	374.65	2.94	1.730	24.000
18.10.25	51.05	45.77	5.28	372.74	370.55	2.18	0.570	0.547	377.34	374.25	3.09	2.066	24.000
19.10.25	51.33	46.07	5.26	372.95	370.76	2.18	0.567	0.544	377.60	374.52	3.07	2.059	24.000
20.10.25	51.88	46.65	5.23	374.25	372.10	2.15	0.565	0.542	379.02	375.96	3.07	2.055	24.000
Итого	---	---	---	9229.65	9178.11	51.53	---	---	9324.13	9256.09	68.03	40.572	768.000
Среднее	39.30	36.14	3.15	---	---	---	0.465	0.445	---	---	---	---	---

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Комсомольская, 37
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: CF598

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-
28.09.25	1.83	40.38	451.85	36.32	455.59	24.00	24.00	0.00	0.00
29.09.25	1.84	40.56	452.39	36.48	455.96	24.00	24.00	0.00	0.00
30.09.25	2.15	43.39	418.58	38.18	423.80	24.00	24.00	0.00	0.00
01.10.25	2.56	47.64	383.23	40.94	390.43	24.00	24.00	0.00	0.00
02.10.25	2.53	47.58	383.17	40.97	391.81	24.00	24.00	0.00	0.00
03.10.25	2.47	47.64	380.02	41.13	388.72	24.00	24.00	0.00	0.00
04.10.25	2.49	48.34	379.87	41.76	388.75	24.00	24.00	0.00	0.00
05.10.25	2.51	48.34	376.07	41.66	384.94	24.00	24.00	0.00	0.00
06.10.25	2.45	48.27	374.48	41.70	383.41	24.00	24.00	0.00	0.00
07.10.25	2.31	47.34	374.79	41.16	384.34	24.00	24.00	0.00	0.00
08.10.25	2.07	45.19	374.84	39.66	384.43	24.00	24.00	0.00	0.00
09.10.25	2.05	45.28	373.80	39.77	383.48	24.00	24.00	0.00	0.00
10.10.25	2.04	45.09	374.01	39.61	383.54	24.00	24.00	0.00	0.00
11.10.25	2.00	44.89	373.99	39.54	384.32	24.00	24.00	0.00	0.00
12.10.25	2.00	44.64	378.37	39.35	388.63	24.00	24.00	0.00	0.00
13.10.25	2.09	45.25	378.92	39.72	389.23	24.00	24.00	0.00	0.00
14.10.25	2.27	46.96	378.33	40.96	388.81	24.00	24.00	0.00	0.00
15.10.25	2.19	46.56	381.89	40.81	392.50	24.00	24.00	0.00	0.00
16.10.25	2.30	47.22	381.83	41.18	391.66	24.00	24.00	0.00	0.00
17.10.25	2.32	47.07	377.54	40.91	388.06	24.00	24.00	0.00	0.00
18.10.25	2.50	48.42	376.31	41.76	386.72	24.00	24.00	0.00	0.00
19.10.25	2.74	51.00	374.37	43.67	385.41	24.00	24.00	0.00	0.00
20.10.25	2.81	52.08	376.87	44.60	388.20	24.00	24.00	0.00	0.00
Итого	52.52	---	8875.52	---	9082.74	552.00	552.00	0.00	0.00
Среднее	---	46.484	---	40.515	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	4367.90	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

ИМ2300, Суточный с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Комсомольская, 39
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: CF597

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	18.27	0.00	18.26	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	18.24	0.00	18.24	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	18.16	0.00	18.15	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	18.10	0.00	18.08	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	18.23	0.00	18.19	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	18.37	0.00	18.30	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	18.48	0.00	18.38	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	18.30	0.00	18.18	0.00	0.00	24.00	0.00	0.00
27.09.25	0.91	31.43	211.83	28.78	213.20	14.49	24.00	0.00	0.00
28.09.25	1.57	40.38	374.36	36.17	376.77	24.00	24.00	0.00	0.00
29.09.25	1.62	40.56	374.21	36.21	377.85	24.00	24.00	0.00	0.00
30.09.25	1.92	43.37	346.10	37.75	350.18	24.00	24.00	0.00	0.00
01.10.25	2.31	47.63	316.68	40.31	320.75	24.00	24.00	0.00	0.00
02.10.25	2.27	47.57	317.22	40.38	320.73	24.00	24.00	0.00	0.00
03.10.25	2.24	47.63	314.31	40.50	318.14	24.00	24.00	0.00	0.00
04.10.25	2.26	48.33	313.62	41.10	317.74	24.00	24.00	0.00	0.00
05.10.25	2.25	48.33	310.56	41.06	314.45	24.00	24.00	0.00	0.00
06.10.25	2.22	48.26	309.43	41.06	312.58	24.00	24.00	0.00	0.00
07.10.25	2.11	47.34	310.13	40.53	313.28	24.00	24.00	0.00	0.00
08.10.25	1.89	45.18	311.19	39.08	313.74	24.00	24.00	0.00	0.00
09.10.25	1.88	45.27	310.49	39.19	312.94	24.00	24.00	0.00	0.00
10.10.25	1.88	45.08	310.84	39.03	313.25	24.00	24.00	0.00	0.00
11.10.25	1.83	44.89	310.75	38.99	313.05	24.00	24.00	0.00	0.00
12.10.25	1.82	44.63	314.46	38.82	316.53	24.00	24.00	0.00	0.00
13.10.25	1.92	45.24	314.36	39.13	316.70	24.00	24.00	0.00	0.00
14.10.25	2.07	46.95	312.71	40.32	315.64	24.00	24.00	0.00	0.00
15.10.25	2.00	46.55	315.67	40.20	318.54	24.00	24.00	0.00	0.00
16.10.25	2.10	47.21	315.89	40.53	318.80	24.00	24.00	0.00	0.00
17.10.25	2.13	47.06	312.40	40.22	315.60	24.00	24.00	0.00	0.00
18.10.25	2.28	48.40	310.97	41.04	314.50	24.00	24.00	0.00	0.00
19.10.25	2.53	50.99	309.48	42.81	312.16	24.00	24.00	0.00	0.00
20.10.25	2.60	52.07	310.77	43.68	313.31	24.00	24.00	0.00	0.00
Итого	48.61	---	7558.43	---	7630.43	566.49	768.00	0.00	0.00
Среднее	---	38.953	---	34.146	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	3995.54	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Комсомольская, 41
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BA732

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	15.42	0.00	15.41	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	15.46	0.00	15.43	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	15.47	0.00	15.44	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	15.48	0.00	15.44	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	15.57	0.00	15.54	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	15.67	0.00	15.63	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	15.96	0.00	15.92	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	18.30	0.00	18.00	0.00	0.00	24.00	0.00	0.00
27.09.25	0.71	30.45	154.23	27.29	154.10	13.17	24.00	0.00	0.00
28.09.25	1.36	40.06	322.67	35.84	326.49	24.00	24.00	0.00	0.00
29.09.25	1.49	40.22	328.77	35.67	332.66	24.00	24.00	0.00	0.00
30.09.25	1.77	42.88	306.89	37.11	310.18	22.47	23.19	0.00	0.00
01.10.25	2.27	47.36	316.70	40.19	318.17	24.00	24.00	0.00	0.00
02.10.25	2.26	47.28	314.33	40.08	316.40	24.00	24.00	0.00	0.00
03.10.25	2.22	47.36	307.25	40.11	309.48	24.00	24.00	0.00	0.00
04.10.25	2.24	48.03	303.33	40.64	305.63	24.00	24.00	0.00	0.00
05.10.25	2.22	48.06	297.37	40.57	299.51	24.00	24.00	0.00	0.00
06.10.25	2.18	47.97	293.31	40.51	295.54	24.00	24.00	0.00	0.00
07.10.25	2.08	47.19	290.87	40.03	293.20	24.00	24.00	0.00	0.00
08.10.25	1.84	44.90	286.49	38.47	288.70	24.00	24.00	0.00	0.00
09.10.25	1.83	44.99	282.96	38.50	285.03	24.00	24.00	0.00	0.00
10.10.25	1.82	44.80	280.07	38.28	282.20	24.00	24.00	0.00	0.00
11.10.25	1.77	44.60	279.10	38.24	281.22	24.00	24.00	0.00	0.00
12.10.25	1.79	44.35	281.19	37.99	283.24	24.00	24.00	0.00	0.00
13.10.25	1.85	44.88	278.74	38.22	280.99	24.00	24.00	0.00	0.00
14.10.25	2.01	46.64	278.69	39.40	280.88	24.00	24.00	0.00	0.00
15.10.25	1.94	46.29	282.96	39.40	284.87	24.00	24.00	0.00	0.00
16.10.25	2.03	46.89	283.46	39.70	285.60	24.00	24.00	0.00	0.00
17.10.25	2.05	46.79	274.84	39.32	277.15	24.00	24.00	0.00	0.00
18.10.25	2.18	47.93	270.65	39.86	272.92	24.00	24.00	0.00	0.00
19.10.25	2.43	50.71	270.38	41.70	272.59	24.00	24.00	0.00	0.00
20.10.25	2.51	51.77	271.38	42.49	273.65	24.00	24.00	0.00	0.00
Итого	46.85	---	6856.63	---	6910.40	563.64	767.19	0.00	0.00
Среднее	---	38.117	---	33.013	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	8575.54	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1 Пульсар ДУ-40, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Комсомольская, 6
 Потребитель: АО "Жилуправление"
 Прибор: 378 Заводской номер: 02816814
 ТВ1

Дата	T1	T2	V1	Q	Время раб. (ч)
19.09.25	-	-	-	-	-
20.09.25	-	-	-	-	-
21.09.25	-	-	-	-	-
22.09.25	-	-	-	-	-
23.09.25	-	-	-	-	-
24.09.25	60.0	51.9	108.758	0.865	24.00
25.09.25	49.9	43.9	96.918	0.578	24.00
26.09.25	41.6	36.2	73.785	0.393	24.00
27.09.25	44.1	37.6	67.453	0.437	24.00
28.09.25	43.5	36.9	66.406	0.431	24.00
29.09.25	43.1	36.3	64.809	0.434	24.00
30.09.25	44.6	36.0	53.262	0.455	24.00
01.10.25	46.6	36.8	50.223	0.485	24.00
02.10.25	48.4	38.2	54.129	0.526	24.00
03.10.25	47.3	39.0	63.941	0.523	24.00
04.10.25	47.2	38.9	63.574	0.521	24.00
05.10.25	47.4	39.2	63.547	0.516	24.00
06.10.25	45.5	38.0	62.805	0.466	24.00
07.10.25	44.8	37.5	62.078	0.447	24.00
08.10.25	44.8	37.6	62.180	0.446	24.00
09.10.25	44.4	37.1	60.594	0.438	24.00
10.10.25	43.7	36.7	59.203	0.411	24.00
11.10.25	42.9	36.1	58.742	0.394	24.00
12.10.25	43.3	36.2	58.711	0.413	24.00
13.10.25	43.3	36.3	58.602	0.409	24.00
14.10.25	45.3	37.5	57.750	0.450	24.00
15.10.25	46.1	38.1	60.297	0.476	24.00
16.10.25	46.1	38.4	64.836	0.495	24.00
17.10.25	48.8	40.1	66.219	0.568	24.00
18.10.25	51.6	42.1	66.312	0.624	24.00
19.10.25	51.9	42.3	66.453	0.624	24.00
20.10.25	50.1	41.7	71.289	0.587	24.00
Итого	---	---	1762.875	13.413	648.00
Среднее	46.5	38.8	---	---	---

Показания интеграторов

Дата	V1, м. куб	Q, Гкал	Время раб., ч
18.09.25 24:00	н/д	н/д	н/д
20.10.25 24:00	66501.820	710.935	22415.000
Итого за период	н/д	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Картунова, 10
Потребитель: АО "Жилуправление"
Прибор: ТВ7-04 Заводской номер: 24217692

БД=1, ТВ1, СИ=6, КСН=0х4672

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
28.09.25	39.16	34.24	н/д	4.92	6.50	6.34	н/д	205.340	199.305	н/д	203.952	198.324	н/д	5.628	1.003	н/д	24	0
29.09.25	45.70	37.14	н/д	8.56	6.51	6.40	н/д	197.430	190.840	н/д	195.481	189.686	н/д	5.795	1.672	н/д	24	0
30.09.25	42.31	36.25	н/д	6.06	7.10	6.93	н/д	257.370	250.250	н/д	255.301	248.856	н/д	6.445	1.546	н/д	24	0
01.10.25	45.31	38.46	н/д	6.85	7.02	6.81	н/д	271.225	263.820	н/д	268.676	262.096	н/д	6.580	1.839	н/д	24	0
02.10.25	50.05	42.36	н/д	7.69	6.82	6.57	н/д	292.815	285.015	н/д	289.444	282.716	н/д	6.728	2.224	н/д	24	0
03.10.25	51.45	43.58	н/д	7.87	6.81	6.55	н/д	294.980	287.010	н/д	291.395	284.547	н/д	6.849	2.293	н/д	24	0
04.10.25	52.02	43.98	н/д	8.03	6.81	6.55	н/д	295.485	287.460	н/д	291.800	284.939	н/д	6.861	2.344	н/д	24	0
05.10.25	48.67	41.56	н/д	7.11	6.66	6.45	н/д	274.965	267.300	н/д	271.962	265.222	н/д	6.740	1.932	н/д	24	0
06.10.25	43.73	37.79	н/д	5.94	6.47	6.29	н/д	255.950	248.695	н/д	253.731	247.133	н/д	6.598	1.506	н/д	24	0
07.10.25	42.74	37.13	н/д	5.61	6.51	6.32	н/д	263.975	256.845	н/д	261.797	255.313	н/д	6.484	1.468	н/д	24	0
08.10.25	44.40	38.59	н/д	5.81	6.57	6.36	н/д	272.785	265.775	н/д	270.342	264.022	н/д	6.320	1.571	н/д	24	0
09.10.25	43.78	38.12	н/д	5.65	6.58	6.37	н/д	271.965	265.125	н/д	269.602	263.439	н/д	6.163	1.523	н/д	24	0
10.10.25	43.84	38.26	н/д	5.58	6.51	6.30	н/д	272.515	265.800	н/д	270.124	264.090	н/д	6.034	1.506	н/д	24	0
11.10.25	43.85	38.23	н/д	5.61	6.58	6.37	н/д	271.990	265.400	н/д	269.618	263.693	н/д	5.926	1.513	н/д	24	0
12.10.25	43.53	37.88	н/д	5.65	6.58	6.36	н/д	271.880	265.385	н/д	269.541	263.727	н/д	5.814	1.522	н/д	24	0
13.10.25	43.32	37.70	н/д	5.63	6.57	6.36	н/д	271.710	265.360	н/д	269.421	263.702	н/д	5.719	1.515	н/д	24	0
14.10.25	43.88	38.07	н/д	5.81	6.49	6.29	н/д	267.525	261.345	н/д	265.199	259.676	н/д	5.523	1.539	н/д	24	0
15.10.25	44.58	38.46	н/д	6.12	6.42	6.22	н/д	266.230	260.105	н/д	263.840	258.410	н/д	5.430	1.615	н/д	24	0
16.10.25	44.23	38.40	н/д	5.83	5.17	4.99	н/д	169.310	155.690	н/д	167.807	154.667	н/д	13.140	0.978	н/д	24	0
17.10.25	43.46	38.22	н/д	5.24	7.40	7.14	н/д	212.055	203.925	н/д	210.250	202.633	н/д	7.617	1.101	н/д	24	0
18.10.25	46.42	39.53	н/д	6.89	7.14	6.93	н/д	257.215	250.730	н/д	254.681	249.001	н/д	5.679	1.754	н/д	24	0
19.10.25	48.94	41.45	н/д	7.49	7.12	6.93	н/д	259.975	253.290	н/д	257.112	251.346	н/д	5.766	1.926	н/д	24	0
20.10.25	50.10	42.25	н/д	7.85	7.17	6.97	н/д	271.265	264.840	н/д	268.158	262.713	н/д	5.444	2.105	н/д	24	0
Итого	---	---	---	---	---	---	---	5945.955	5779.310	---	5889.234	5739.951	---	149.283	37.995	---	552	0
Среднее	45.63	39.18	---	6.45	6.67	6.47	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
20.10.25 24:00	23730.090	24025.340	0.000	23491.875	23859.560	0.000	-367.684	159.386	0.000	3420	2210
Итого за период	н/д	н/д	н/д	н/д	н/д	н/д	---	н/д	н/д	н/д	н/д

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Картунова, 12
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00178911

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0x8A69

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	21.24	20.65	0.59	42.780	102.810	42.760	102.570	-59.810	1.01	1.05	0.0270	0.0	24.0
20.09.25	21.29	20.70	0.59	55.680	110.600	55.670	110.360	-54.690	1.01	1.05	0.0330	0.0	24.0
21.09.25	21.14	20.60	0.54	55.490	116.670	55.480	116.430	-60.950	1.01	1.05	0.0330	0.0	24.0
22.09.25	21.26	20.60	0.66	21.020	49.500	21.020	49.390	-28.370	2.39	2.86	0.0190	0.0	24.0
23.09.25	22.31	21.54	0.77	0.000	0.000	0.000	0.000	0.000	2.07	3.40	0.0000	0.0	24.0
24.09.25	21.92	21.42	0.50	0.000	0.000	0.000	0.000	0.000	1.98	3.26	0.0000	0.0	24.0
25.09.25	36.46	33.63	2.83	243.830	241.990	242.320	240.720	1.600	5.17	5.56	0.6760	0.0	24.0
26.09.25	38.07	35.05	3.02	397.480	393.710	394.760	391.490	3.270	7.39	7.20	1.1900	0.0	24.0
27.09.25	40.16	36.50	3.66	372.860	371.000	370.030	368.730	1.300	7.40	7.25	1.3530	0.0	24.0
28.09.25	40.06	36.17	3.89	357.560	356.520	354.880	354.350	0.530	7.40	7.26	1.3780	0.0	24.0
29.09.25	46.90	40.15	6.75	326.720	327.790	323.250	325.300	-2.050	7.42	7.32	2.1860	0.0	24.0
30.09.25	43.22	38.84	4.38	397.320	397.510	393.850	394.730	-0.880	8.01	7.82	1.7210	0.0	24.0
01.10.25	46.41	41.39	5.02	418.760	419.630	414.540	416.270	-1.730	7.92	7.71	2.0790	0.0	24.0
02.10.25	51.18	45.54	5.64	452.010	453.320	446.510	448.940	-2.430	7.73	7.48	2.5150	0.0	24.0
03.10.25	52.57	46.80	5.77	455.920	457.580	450.060	452.870	-2.810	7.72	7.46	2.6000	0.0	24.0
04.10.25	53.17	47.30	5.87	456.230	458.040	450.240	453.270	-3.030	7.72	7.46	2.6400	0.0	24.0
05.10.25	49.69	44.55	5.14	424.430	426.190	419.570	422.250	-2.680	7.58	7.36	2.1530	0.0	24.0
06.10.25	44.64	40.36	4.28	396.520	397.890	392.840	394.850	-2.010	7.39	7.20	1.6790	0.0	24.0
07.10.25	43.73	39.66	4.07	409.400	410.330	405.730	407.310	-1.580	7.43	7.23	1.6460	0.0	24.0
08.10.25	45.36	41.17	4.19	423.080	423.690	419.010	420.340	-1.330	7.49	7.27	1.7530	0.0	24.0
09.10.25	44.73	40.65	4.08	421.950	422.270	418.000	418.990	-0.990	7.50	7.28	1.7060	0.0	24.0
10.10.25	44.80	40.76	4.04	422.890	422.970	418.930	419.690	-0.760	7.43	7.20	1.6910	0.0	24.0
11.10.25	44.82	40.73	4.09	422.050	422.170	418.080	418.880	-0.800	7.50	7.27	1.7070	0.0	24.0
12.10.25	44.49	40.34	4.15	422.260	421.900	418.320	418.680	-0.360	7.49	7.27	1.7350	0.0	24.0
13.10.25	44.29	40.19	4.10	421.800	421.450	417.910	418.280	-0.370	7.48	7.26	1.7150	0.0	24.0
14.10.25	44.87	40.61	4.26	415.380	414.880	411.460	411.690	-0.230	7.41	7.20	1.7520	0.0	24.0
15.10.25	45.59	41.06	4.53	413.350	413.210	409.350	409.940	-0.590	7.34	7.13	1.8520	0.0	24.0
16.10.25	45.00	40.65	4.35	423.030	422.850	419.070	419.580	-0.510	7.99	7.77	1.8160	0.0	24.0
17.10.25	44.71	40.30	4.41	413.700	415.460	409.860	412.310	-2.450	8.26	8.05	1.8050	0.0	24.0
18.10.25	47.54	42.26	5.28	408.250	411.360	403.970	407.940	-3.970	8.03	7.83	2.1260	0.0	24.0
19.10.25	50.06	44.37	5.69	406.600	409.100	401.840	405.320	-3.480	8.02	7.82	2.2860	0.0	24.0
20.10.25	51.25	45.38	5.87	417.210	419.100	412.110	415.080	-2.970	8.07	7.87	2.4140	0.0	24.0
Итого	---	---	---	10715.5	10931.4	10611.42	10846.55	-235.130	---	---	48.2860	0.0	768.0
Среднее	41.02	37.18	3.84	---	---	---	---	---	6.43	6.38	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	101099.930	99198.219	94189.939	94013.580	612.5760	176.360	2423.0	7070.0
20.10.25 24:00	111815.489	110129.710	104801.360	104860.130	660.8620	-58.770	2423.0	7838.0
Итого за период	10715.559	10931.491	10611.421	10846.550	48.2860	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Картунова, 14
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВА733

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-
28.09.25	-	-	-	-	-	-	-	-	-
29.09.25	0.00	40.87	0.00	35.27	0.00	0.00	24.00	0.00	0.00
30.09.25	0.00	49.79	0.00	39.14	0.00	0.00	24.00	0.00	0.00
01.10.25	0.00	44.11	0.00	37.46	0.00	0.00	24.00	0.00	0.00
02.10.25	0.00	46.87	0.00	39.34	0.00	0.00	24.00	0.00	0.00
03.10.25	0.00	52.12	0.00	43.57	0.00	0.00	24.00	0.00	0.00
04.10.25	2.07	53.60	234.40	44.78	0.00	11.50	24.00	0.00	0.00
05.10.25	4.27	54.19	476.59	45.21	0.00	24.00	24.00	0.00	0.00
06.10.25	3.55	50.54	445.37	42.62	0.00	24.00	24.00	0.00	0.00
07.10.25	2.77	45.64	414.54	38.95	0.00	24.00	24.00	0.00	0.00
08.10.25	2.69	44.43	427.36	38.13	0.00	24.00	24.00	0.00	0.00
09.10.25	2.91	46.28	444.03	39.72	0.00	24.00	24.00	0.00	0.00
10.10.25	2.86	45.62	444.42	39.18	0.00	24.00	24.00	0.00	0.00
11.10.25	2.81	45.68	444.76	39.34	0.00	24.00	24.00	0.00	0.00
12.10.25	2.83	45.69	444.39	39.31	0.00	24.00	24.00	0.00	0.00
13.10.25	2.87	45.40	444.25	38.93	0.00	24.00	24.00	0.00	0.00
14.10.25	2.85	45.16	443.84	38.73	0.00	24.00	24.00	0.00	0.00
15.10.25	2.88	45.75	436.93	39.15	0.00	24.00	24.00	0.00	0.00
16.10.25	3.02	46.46	434.46	39.50	0.00	24.00	24.00	0.00	0.00
17.10.25	2.67	45.94	399.53	39.37	0.00	24.00	24.00	0.00	0.00
18.10.25	2.88	45.59	430.50	38.90	0.00	24.00	24.00	0.00	0.00
19.10.25	3.38	48.31	428.01	40.38	0.00	24.00	24.00	0.00	0.00
20.10.25	3.61	51.07	425.15	42.57	0.00	24.00	24.00	0.00	0.00
Итого	50.92	---	7218.53	---	0.00	395.50	528.00	0.00	0.00
Среднее	---	47.232	---	39.980	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	13090.21	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Картунова, 15
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00177123

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0хС83А

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	23.48	26.12	-2.64	8.250	0.000	8.250	0.000	8.250	1.03	5.40	0.0000	0.0	24.0
20.09.25	23.44	26.04	-2.60	0.000	0.000	0.000	0.000	0.000	1.03	5.40	0.0000	0.0	24.0
21.09.25	23.33	25.95	-2.62	0.000	0.000	0.000	0.000	0.000	1.03	5.40	0.0000	0.0	24.0
22.09.25	23.28	25.87	-2.59	0.000	0.000	0.000	0.000	0.000	1.03	5.40	0.0000	0.0	24.0
23.09.25	23.81	26.42	-2.61	0.000	0.000	0.000	0.000	0.000	1.03	5.40	0.0000	0.0	24.0
24.09.25	23.99	26.60	-2.61	0.000	0.000	0.000	0.000	0.000	1.03	5.40	0.0000	0.0	24.0
25.09.25	39.24	37.30	1.94	296.480	294.520	294.330	292.600	1.730	4.11	5.40	0.5780	0.0	24.0
26.09.25	42.69	40.07	2.62	495.340	495.940	491.080	492.160	-1.080	6.24	5.40	1.2960	0.0	24.0
27.09.25	49.33	45.85	3.48	507.320	507.790	501.560	502.770	-1.210	5.87	5.40	1.7510	0.0	24.0
28.09.25	50.53	46.82	3.71	504.390	505.590	498.360	500.370	-2.010	5.84	5.40	1.8490	0.0	24.0
29.09.25	49.94	46.12	3.82	513.560	515.920	507.590	510.720	-3.130	5.87	5.40	1.9370	0.0	24.0
30.09.25	48.87	44.91	3.96	507.620	510.840	501.960	505.960	-4.000	5.97	5.40	1.9920	0.0	24.0
01.10.25	47.52	43.30	4.22	440.360	442.560	435.710	438.650	-2.940	6.41	5.40	1.8460	0.0	24.0
02.10.25	45.93	40.80	5.13	322.910	322.390	319.780	319.830	-0.050	6.62	5.40	1.6420	0.0	24.0
03.10.25	45.70	41.20	4.50	372.280	370.520	368.620	367.540	1.080	6.67	5.40	1.6670	0.0	24.0
04.10.25	43.54	40.20	3.34	471.660	470.250	467.460	466.650	0.810	6.65	5.40	1.5720	0.0	24.0
05.10.25	43.19	39.92	3.27	469.390	468.130	465.300	464.550	0.750	6.65	5.40	1.5310	0.0	24.0
06.10.25	44.54	40.43	4.11	388.540	386.930	384.940	383.940	1.000	6.63	5.40	1.5840	0.0	24.0
07.10.25	45.17	41.26	3.91	414.960	413.390	411.000	410.050	0.950	6.49	5.40	1.6140	0.0	24.0
08.10.25	43.97	40.74	3.23	473.660	472.360	469.360	468.640	0.720	6.28	5.40	1.5260	0.0	24.0
09.10.25	44.26	40.95	3.31	474.270	473.040	469.880	469.320	0.560	6.36	5.40	1.5630	0.0	24.0
10.10.25	44.40	41.11	3.29	471.830	470.670	467.470	466.920	0.550	6.45	5.40	1.5420	0.0	24.0
11.10.25	44.15	40.89	3.26	470.140	468.990	465.860	465.250	0.610	6.45	5.40	1.5220	0.0	24.0
12.10.25	43.68	40.42	3.26	469.130	468.000	464.910	464.430	0.480	6.36	5.40	1.5220	0.0	24.0
13.10.25	44.01	40.66	3.35	469.250	468.020	465.010	464.350	0.660	6.34	5.40	1.5580	0.0	24.0
14.10.25	45.29	41.76	3.53	476.290	474.380	471.700	470.490	1.210	6.29	5.40	1.6670	0.0	24.0
15.10.25	48.61	44.66	3.95	487.300	485.680	481.920	481.120	0.800	6.11	5.40	1.9090	0.0	24.0
16.10.25	46.26	42.56	3.70	479.470	478.350	474.660	474.340	0.320	6.31	5.40	1.7650	0.0	24.0
17.10.25	47.88	43.95	3.93	486.020	484.860	480.810	480.440	0.370	6.40	5.40	1.8940	0.0	24.0
18.10.25	47.43	43.54	3.89	483.410	482.570	478.330	478.250	0.080	6.13	5.40	1.8610	0.0	24.0
19.10.25	47.72	43.79	3.93	483.750	482.840	478.540	478.520	0.020	6.30	5.40	1.8850	0.0	24.0
20.10.25	47.52	43.64	3.88	484.430	483.440	479.280	479.110	0.170	6.35	5.40	1.8630	0.0	24.0
Итого	---	---	---	11922.0	11897.9	11803.67	11796.97	6.700	---	---	42.9360	0.0	768.0
Среднее	41.64	39.18	2.46	---	---	---	---	---	5.26	5.40	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	61610.420	54253.170	60834.990	53671.820	360.8930	7163.170	2375.0	4406.0
20.10.25 24:00	73532.430	66151.139	72638.659	65468.790	403.8290	7169.870	2375.0	5174.0
Итого за период	11922.009	11897.968	11803.669	11796.970	42.9360	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Картунова, 17
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00224100

БД=1, ТВ1, СИ=1, КТЗ=1, ФРТ=0, КСН=0хСС0D

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	22.43	23.55	-1.12	0.000	0.000	0.000	0.000	0.000	2.83	1.02	0.0000	0.0	24.0
20.09.25	22.35	23.46	-1.11	0.000	0.000	0.000	0.000	0.000	2.82	1.02	0.0000	0.0	24.0
21.09.25	22.27	23.39	-1.12	0.000	0.000	0.000	0.000	0.000	2.80	1.02	0.0000	0.0	24.0
22.09.25	22.27	23.39	-1.12	0.000	0.000	0.000	0.000	0.000	2.79	1.02	0.0000	0.0	24.0
23.09.25	22.44	23.68	-1.24	0.000	0.000	0.000	0.000	0.000	2.77	1.02	0.0000	0.0	24.0
24.09.25	22.49	23.71	-1.22	0.000	0.000	0.000	0.000	0.000	2.76	1.02	0.0000	0.0	24.0
25.09.25	39.40	37.09	2.31	355.670	407.720	353.080	405.070	-51.990	4.63	3.51	0.8640	0.0	24.0
26.09.25	42.82	39.83	2.99	655.950	645.150	650.230	640.290	9.940	5.92	5.40	1.9440	0.0	24.0
27.09.25	49.47	45.49	3.98	659.680	649.900	652.090	643.550	8.540	5.55	5.04	2.5970	0.0	24.0
28.09.25	50.67	46.42	4.25	653.150	642.680	645.300	636.170	9.130	5.51	5.02	2.7430	0.0	24.0
29.09.25	50.09	45.84	4.25	646.970	634.650	639.360	628.390	10.970	5.55	5.07	2.7240	0.0	24.0
30.09.25	49.02	44.75	4.27	613.000	600.570	606.090	594.950	11.140	5.67	5.24	2.5850	0.0	24.0
01.10.25	47.66	43.21	4.45	527.750	516.800	522.130	512.250	9.880	6.17	5.84	2.3180	0.0	24.0
02.10.25	46.01	40.59	5.42	380.680	372.850	376.840	369.970	6.870	6.47	6.30	2.0440	0.0	24.0
03.10.25	45.80	41.03	4.77	439.020	431.350	434.680	427.940	6.740	6.49	6.25	2.0710	0.0	24.0
04.10.25	43.69	40.11	3.58	556.680	548.050	551.720	543.890	7.830	6.39	6.03	1.9720	0.0	24.0
05.10.25	43.33	39.83	3.50	550.950	542.880	546.140	538.800	7.340	6.40	6.04	1.9130	0.0	24.0
06.10.25	44.65	40.23	4.42	450.850	444.870	446.660	441.460	5.200	6.43	6.18	1.9700	0.0	24.0
07.10.25	45.30	41.10	4.20	484.870	478.580	480.200	474.790	5.410	6.27	5.99	2.0130	0.0	24.0
08.10.25	44.13	40.66	3.47	556.480	548.970	551.370	544.670	6.700	6.02	5.66	1.9140	0.0	24.0
09.10.25	44.41	40.86	3.55	556.850	549.380	551.700	545.030	6.670	6.10	5.74	1.9580	0.0	24.0
10.10.25	44.55	41.02	3.53	552.420	544.920	547.290	540.600	6.690	6.19	5.83	1.9310	0.0	24.0
11.10.25	44.30	40.80	3.50	551.580	544.030	546.480	539.780	6.700	6.19	5.83	1.9120	0.0	24.0
12.10.25	43.83	40.31	3.52	550.250	542.850	545.260	538.670	6.590	6.10	5.74	1.9140	0.0	24.0
13.10.25	44.15	40.57	3.58	550.270	542.820	545.210	538.590	6.620	6.09	5.73	1.9490	0.0	24.0
14.10.25	45.44	41.65	3.79	564.300	556.680	558.820	552.090	6.730	6.03	5.66	2.1120	0.0	24.0
15.10.25	48.74	44.51	4.23	581.650	573.850	575.150	568.480	6.670	5.84	5.46	2.4320	0.0	24.0
16.10.25	46.40	42.43	3.97	571.500	563.950	565.720	559.190	6.530	6.05	5.68	2.2470	0.0	24.0
17.10.25	48.01	43.79	4.22	579.380	571.770	573.140	566.600	6.540	6.13	5.75	2.4160	0.0	24.0
18.10.25	47.56	43.37	4.19	576.650	569.480	570.520	564.440	6.080	5.87	5.49	2.3930	0.0	24.0
19.10.25	47.85	43.62	4.23	576.900	569.850	570.680	564.810	5.870	6.04	5.66	2.4140	0.0	24.0
20.10.25	47.65	43.49	4.16	577.570	570.470	571.440	565.370	6.070	6.08	5.71	2.3750	0.0	24.0
Итого	---	---	---	14321.0	14165.0	14177.30	14045.84	131.460	---	---	55.7250	0.0	768.0
Среднее	41.53	38.55	2.98	---	---	---	---	---	5.40	4.75	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	21306.350	21390.350	21102.650	21224.219	87.9000	-121.570	2500.0	1857.0
20.10.25 24:00	35627.370	35555.420	35279.950	35270.059	143.6250	9.890	2500.0	2625.0
Итого за период	14321.020	14165.070	14177.299	14045.840	55.7250	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ИМ2300, Суточный с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Картунова, 2
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BA726

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	21.39	0.00	20.87	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	21.34	0.00	20.83	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	21.30	0.00	20.79	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	21.27	0.00	20.73	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	21.52	0.00	26.31	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	21.47	0.00	21.52	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	22.20	0.11	21.06	0.00	0.05	24.00	0.00	0.00
26.09.25	0.41	28.87	72.60	25.91	0.00	9.46	24.00	0.00	0.00
27.09.25	0.96	38.28	189.71	33.16	0.00	24.00	24.00	0.00	0.00
28.09.25	1.11	40.34	196.56	34.69	0.00	24.00	24.00	0.00	0.00
29.09.25	1.16	40.23	197.49	34.35	0.00	24.00	24.00	0.00	0.00
30.09.25	1.52	48.13	178.56	38.71	0.00	23.09	24.00	0.00	0.00
01.10.25	1.39	43.40	217.07	37.00	0.00	24.00	24.00	0.00	0.00
02.10.25	1.61	46.30	224.43	39.15	0.00	24.00	24.00	0.00	0.00
03.10.25	1.90	51.39	242.43	43.55	0.00	24.00	24.00	0.00	0.00
04.10.25	1.96	52.82	242.87	44.73	0.00	24.00	24.00	0.00	0.00
05.10.25	2.04	53.41	244.33	45.06	0.00	24.00	24.00	0.00	0.00
06.10.25	1.71	49.71	224.80	42.14	0.00	24.00	24.00	0.00	0.00
07.10.25	1.42	44.91	210.12	38.12	0.00	24.00	24.00	0.00	0.00
08.10.25	1.42	43.87	217.44	37.32	0.00	24.00	24.00	0.00	0.00
09.10.25	1.51	45.62	224.96	38.88	0.00	24.00	24.00	0.00	0.00
10.10.25	1.48	44.98	224.50	38.37	0.00	24.00	24.00	0.00	0.00
11.10.25	1.50	45.05	224.45	38.34	0.00	24.00	24.00	0.00	0.00
12.10.25	1.51	45.06	224.09	38.29	0.00	24.00	24.00	0.00	0.00
13.10.25	1.52	44.73	223.85	37.91	0.00	24.00	24.00	0.00	0.00
14.10.25	1.51	44.53	223.63	37.74	0.00	24.00	24.00	0.00	0.00
15.10.25	1.52	45.08	219.55	38.13	0.00	24.00	24.00	0.00	0.00
16.10.25	1.58	45.80	218.17	38.54	0.00	24.00	24.00	0.00	0.00
17.10.25	1.57	45.25	218.41	38.04	0.00	24.00	24.00	0.00	0.00
18.10.25	1.57	44.91	217.40	37.66	0.00	24.00	24.00	0.00	0.00
19.10.25	1.74	47.67	215.75	39.58	0.00	24.00	24.00	0.00	0.00
20.10.25	1.84	50.25	214.27	41.65	0.00	24.00	24.00	0.00	0.00
Итого	37.46	---	5307.55	---	0.00	584.60	768.00	0.00	0.00
Среднее	---	40.034	---	34.660	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	1733.84	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Картунова, 8
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00182527

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0хD46A

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	22.45	22.50	-0.05	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
22.09.25	24.57	29.25	-4.68	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
23.09.25	23.10	23.71	-0.61	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
24.09.25	22.83	22.68	0.15	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
25.09.25	30.35	27.84	2.51	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
26.09.25	38.04	34.55	3.49	155.450	151.820	154.420	150.990	3.430	7.25	7.11	0.5390	0.0	24.0
27.09.25	40.20	36.09	4.11	347.240	341.880	344.620	339.850	4.770	8.04	8.01	1.4110	0.0	24.0
28.09.25	40.10	35.70	4.40	339.510	334.440	337.010	332.480	4.530	8.04	8.02	1.4820	0.0	24.0
29.09.25	46.86	39.34	7.52	309.320	304.720	306.080	302.490	3.590	8.05	8.06	2.2820	0.0	24.0
30.09.25	43.25	38.38	4.87	372.610	368.530	369.360	366.020	3.340	8.62	8.59	1.7960	0.0	24.0
01.10.25	46.39	40.81	5.58	392.140	388.170	388.190	385.180	3.010	8.52	8.48	2.1620	0.0	24.0
02.10.25	51.17	44.93	6.24	422.620	418.400	417.480	414.480	3.000	8.30	8.25	2.6010	0.0	24.0
03.10.25	52.58	46.20	6.38	426.820	422.430	421.360	418.210	3.150	8.29	8.24	2.6820	0.0	24.0
04.10.25	53.17	46.65	6.52	429.390	424.210	423.780	419.920	3.860	8.29	8.24	2.7610	0.0	24.0
05.10.25	49.70	43.96	5.74	402.900	396.420	398.250	392.870	5.380	8.16	8.12	2.2800	0.0	24.0
06.10.25	44.66	39.91	4.75	377.860	370.910	374.320	368.170	6.150	7.99	7.96	1.7770	0.0	24.0
07.10.25	43.74	39.24	4.50	389.950	382.520	386.480	379.750	6.730	8.03	7.99	1.7370	0.0	24.0
08.10.25	45.39	40.77	4.62	402.720	395.050	398.870	392.010	6.860	8.07	8.04	1.8390	0.0	24.0
09.10.25	44.75	40.26	4.49	401.860	394.230	398.110	391.270	6.840	8.08	8.05	1.7850	0.0	24.0
10.10.25	44.81	40.29	4.52	392.460	384.360	388.770	381.470	7.300	7.89	7.86	1.7530	0.0	24.0
11.10.25	44.84	40.33	4.51	402.730	394.180	398.950	391.200	7.750	8.08	8.04	1.7930	0.0	24.0
12.10.25	44.51	39.92	4.59	402.720	394.680	399.010	391.720	7.290	8.08	8.04	1.8260	0.0	24.0
13.10.25	44.31	39.73	4.58	402.320	394.530	398.650	391.650	7.000	8.07	8.03	1.8190	0.0	24.0
14.10.25	44.89	40.17	4.72	397.420	389.650	393.690	386.760	6.930	8.00	7.97	1.8540	0.0	24.0
15.10.25	45.60	40.58	5.02	394.900	387.000	391.090	384.030	7.060	7.92	7.90	1.9600	0.0	24.0
16.10.25	45.02	40.16	4.86	403.810	395.670	400.000	392.710	7.290	8.57	8.53	1.9410	0.0	24.0
17.10.25	44.74	39.84	4.90	395.980	387.010	392.320	384.180	8.140	8.85	8.82	1.9180	0.0	24.0
18.10.25	47.54	41.64	5.90	389.230	380.110	385.140	377.050	8.090	8.62	8.60	2.2670	0.0	24.0
19.10.25	50.07	43.72	6.35	387.370	378.660	382.870	375.320	7.550	8.60	8.59	2.4280	0.0	24.0
20.10.25	51.23	44.73	6.50	401.540	392.640	396.680	388.990	7.690	8.65	8.63	2.5730	0.0	24.0
Итого	---	---	---	9540.8	9372.2	9445.50	9298.77	146.730	---	---	49.2660	0.0	720.0
Среднее	42.36	38.12	4.23	---	---	---	---	---	7.87	7.81	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
19.09.25 24:00	0	0	0	0	0	0	0	0
20.10.25 24:00	15957.449	19311.550	15817.150	19193.390	67.0910	-3376.240	2208.0	2151.0
Итого за период	15957.449	19311.550	15817.150	19193.390	67.0910	---	2208.0	2151.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Крупской, 5
 Потребитель: АО "Жилуправление"
 Прибор: Взлёт ТСРВ-024М Заводской номер: 1304521
 Тип системы: А42-00 Система: 1

ТБ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	30.85	30.94	-0.09	0.00	0.00	0.00	0.0	1.2	0.00	0.00	0.00	0.000	0.17
20.09.25	30.60	30.66	-0.06	0.00	0.00	0.00	0.0	1.2	0.00	0.00	0.00	0.000	0.33
21.09.25	30.62	30.74	-0.12	0.00	0.00	0.00	0.0	1.2	0.00	0.00	0.00	0.000	0.17
22.09.25	31.34	35.32	-3.98	0.00	0.00	0.00	0.0	1.2	0.00	0.00	0.00	0.000	0.00
23.09.25	28.33	31.01	-2.68	0.00	0.00	0.00	0.0	1.2	0.00	0.00	0.00	0.000	0.00
24.09.25	28.07	30.25	-2.18	0.00	0.00	0.00	0.0	1.2	0.00	0.00	0.00	0.000	0.10
25.09.25	33.08	33.92	-0.84	39.39	15.64	23.75	0.0	1.2	40.16	15.87	24.29	0.320	3.25
26.09.25	66.05	60.58	5.47	281.53	111.78	169.75	0.0	1.2	287.29	113.66	173.62	1.471	24.00
27.09.25	63.03	57.98	5.05	272.74	108.18	164.56	0.0	1.2	277.84	109.85	167.99	1.309	24.00
28.09.25	65.75	59.97	5.78	253.25	100.38	152.87	0.0	1.2	258.38	102.04	156.34	1.403	24.00
29.09.25	64.96	58.57	6.39	229.24	90.81	138.43	0.0	1.2	233.79	92.26	141.54	1.372	23.50
30.09.25	65.45	56.69	8.76	157.97	62.66	95.32	0.0	1.2	161.16	63.59	97.57	1.344	24.00
01.10.25	64.15	55.35	8.80	152.55	60.50	92.05	0.0	1.2	155.53	61.37	94.16	1.302	24.00
02.10.25	65.60	57.43	8.17	170.26	114.14	56.12	0.0	1.2	173.70	115.87	57.83	1.349	24.00
03.10.25	66.50	58.44	8.06	177.54	175.92	1.62	0.0	1.2	181.22	178.69	2.52	1.381	24.00
04.10.25	67.02	59.29	7.73	189.95	188.28	1.67	0.0	1.2	193.93	191.32	2.61	1.422	24.00
05.10.25	66.02	58.37	7.65	185.21	183.66	1.55	0.0	1.2	188.99	186.54	2.45	1.372	24.00
06.10.25	65.57	57.91	7.66	179.67	178.22	1.44	0.0	1.2	183.29	180.98	2.31	1.331	24.00
07.10.25	65.88	58.05	7.83	175.16	173.81	1.35	0.0	1.2	178.72	176.51	2.21	1.328	24.00
08.10.25	64.79	57.39	7.40	179.74	178.36	1.38	0.0	1.2	183.42	181.19	2.24	1.372	24.00
09.10.25	66.20	58.65	7.55	182.15	180.78	1.38	0.0	1.2	185.89	183.64	2.25	1.330	24.00
10.10.25	65.87	58.71	7.16	188.84	187.39	1.45	0.0	1.2	192.68	190.37	2.31	1.306	24.00
11.10.25	65.59	58.56	7.03	188.36	186.93	1.43	0.0	1.2	192.15	189.88	2.27	1.277	23.75
12.10.25	65.70	58.48	7.22	186.33	184.94	1.39	0.0	1.2	190.10	187.85	2.25	1.299	24.00
13.10.25	66.52	58.95	7.57	184.02	182.68	1.34	0.0	1.2	187.83	185.60	2.23	1.350	24.00
14.10.25	65.31	58.20	7.11	185.53	184.16	1.38	0.0	1.2	189.25	187.03	2.21	1.274	24.00
15.10.25	65.55	58.19	7.36	182.76	181.42	1.34	0.0	1.2	186.44	184.25	2.19	1.301	24.00
16.10.25	65.44	57.95	7.49	180.59	179.28	1.31	0.0	1.2	184.22	182.06	2.16	1.308	24.00
17.10.25	65.16	57.61	7.55	178.08	176.79	1.30	0.0	1.2	181.63	179.49	2.14	1.302	24.00
18.10.25	65.51	57.68	7.83	174.86	173.59	1.26	0.0	1.2	178.37	176.26	2.12	1.325	24.00
19.10.25	65.81	58.02	7.79	175.38	174.13	1.25	0.0	1.2	178.94	176.83	2.11	1.323	24.00
20.10.25	65.24	57.76	7.48	179.34	178.05	1.29	0.0	1.2	182.93	180.79	2.14	1.296	23.75
Итого	---	---	---	4830.45	3912.46	917.99	---	---	4927.87	3973.81	954.06	33.766	603.02
Среднее	57.86	52.43	5.44	---	---	---	0.0	1.2	---	---	---	---	---

Показания интеграторов

Дата	Мтс	Q, (Гкал)
18.09.25 24:00	18509.26	604.569
20.10.25 24:00	19424.51	638.278
Итого за период	---	33.709

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Кувykiна, 17
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00178898

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0хВ0ЕЗ

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Мг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	17.61	16.98	0.63	8.800	5.760	8.800	5.760	3.040	1.02	1.00	0.0000	0.0	24.0
20.09.25	17.58	16.97	0.61	7.130	5.760	7.130	5.760	1.370	1.02	1.00	0.0000	0.0	24.0
21.09.25	17.56	16.95	0.61	7.630	5.760	7.630	5.760	1.870	1.02	1.00	0.0000	0.0	24.0
22.09.25	17.66	17.10	0.56	6.050	5.760	6.050	5.760	0.290	1.02	1.00	0.0000	0.0	24.0
23.09.25	62.14	55.48	6.66	82.140	85.990	80.650	84.750	-4.100	1.03	2.98	0.4890	0.0	24.0
24.09.25	20.11	19.14	0.97	0.000	5.760	0.000	5.760	-5.760	1.02	3.91	0.0000	0.0	24.0
25.09.25	66.25	58.05	8.20	108.450	116.930	106.260	115.080	-8.820	1.03	3.86	0.7330	0.0	24.0
26.09.25	66.52	59.87	6.65	296.400	314.650	290.390	309.480	-19.090	1.04	7.01	1.9000	0.0	24.0
27.09.25	64.76	58.02	6.74	274.580	290.260	269.320	285.740	-16.420	1.04	7.01	1.7850	0.0	24.0
28.09.25	67.07	59.92	7.15	270.800	286.340	265.260	281.610	-16.350	1.04	6.98	1.8630	0.0	24.0
29.09.25	66.38	58.84	7.54	224.290	237.060	219.750	233.300	-13.550	1.47	6.88	1.6300	0.0	24.0
30.09.25	65.48	57.28	8.20	223.740	235.340	219.340	231.760	-12.420	1.04	7.04	1.7740	0.0	24.0
01.10.25	65.75	57.72	8.03	231.880	244.030	227.290	240.260	-12.970	1.04	7.38	1.7970	0.0	24.0
02.10.25	66.39	58.60	7.79	239.480	253.420	234.660	249.400	-14.740	1.04	7.40	1.7940	0.0	24.0
03.10.25	67.59	59.65	7.94	240.820	255.020	235.850	250.810	-14.960	1.04	7.40	1.8440	0.0	24.0
04.10.25	67.62	59.68	7.94	241.920	256.290	236.880	252.120	-15.240	1.04	7.37	1.8500	0.0	24.0
05.10.25	66.58	58.97	7.61	241.380	255.660	236.500	251.580	-15.080	1.04	7.38	1.7680	0.0	24.0
06.10.25	66.34	58.89	7.45	242.830	257.190	237.940	253.100	-15.160	1.04	7.38	1.7430	0.0	24.0
07.10.25	67.03	59.30	7.73	233.540	247.280	228.740	243.320	-14.580	1.04	7.25	1.7400	0.0	24.0
08.10.25	66.73	58.86	7.87	223.160	236.060	218.610	232.340	-13.730	1.04	6.96	1.6940	0.0	24.0
09.10.25	66.97	58.37	8.60	205.370	216.980	201.170	213.570	-12.400	1.04	6.97	1.7050	0.0	24.0
10.10.25	66.61	58.31	8.30	208.960	220.760	204.700	217.340	-12.640	1.04	6.99	1.6740	0.0	24.0
11.10.25	66.19	58.08	8.11	208.460	220.170	204.260	216.750	-12.490	1.04	7.00	1.6300	0.0	24.0
12.10.25	66.35	57.98	8.37	205.840	217.300	201.690	213.990	-12.300	1.04	6.96	1.6630	0.0	24.0
13.10.25	67.47	58.72	8.75	204.720	216.110	200.470	212.670	-12.200	1.04	6.95	1.7290	0.0	24.0
14.10.25	66.38	57.87	8.51	203.000	214.270	198.860	210.990	-12.130	1.04	6.95	1.6680	0.0	24.0
15.10.25	66.86	58.03	8.83	198.960	210.040	194.840	206.810	-11.970	1.04	6.88	1.6980	0.0	24.0
16.10.25	66.78	58.19	8.59	208.120	219.960	203.900	216.510	-12.610	1.04	6.95	1.7260	0.0	24.0
17.10.25	66.66	57.91	8.75	205.250	216.880	201.060	213.510	-12.450	1.04	7.04	1.7340	0.0	24.0
18.10.25	66.98	57.91	9.07	199.130	210.100	195.060	206.860	-11.800	1.04	6.82	1.7460	0.0	24.0
19.10.25	67.35	58.20	9.15	199.530	210.220	195.450	206.880	-11.430	1.04	7.00	1.7600	0.0	24.0
20.10.25	66.84	57.83	9.01	198.530	209.000	194.480	205.770	-11.290	1.04	7.04	1.7290	0.0	24.0
Итого	---	---	---	5850.8	6182.1	5732.99	6085.10	-352.110	---	---	44.8660	0.0	768.0
Среднее	58.89	51.98	6.90	---	---	---	---	---	1.05	5.99	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Мг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	84105.310	85977.870	82274.990	84615.159	902.8060	-2340.170	2301.0	17196.0
20.10.25 24:00	89956.200	92159.979	88007.979	90700.260	947.6720	-2692.280	2301.0	17964.0
Итого за период	5850.889	6182.109	5732.989	6085.100	44.8660	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Кувykiна, 7
 Потребитель: АО "Жилуправление"
 Прибор: ИМ2300 Заводской номер: ВВ680

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-
28.09.25	0.88	63.77	115.09	56.14	115.40	24.00	24.00	0.00	0.00
29.09.25	0.91	66.10	111.30	57.89	111.40	24.00	24.00	0.00	0.00
30.09.25	0.83	63.60	103.76	55.54	103.61	23.69	24.00	0.00	0.00
01.10.25	0.73	61.88	79.00	52.58	78.67	24.00	24.00	0.00	0.00
02.10.25	0.57	55.09	75.33	47.46	74.83	24.00	24.00	0.00	0.00
03.10.25	0.48	51.91	58.04	43.18	57.56	24.00	24.00	0.00	0.00
04.10.25	0.46	53.07	41.55	42.09	41.27	24.00	24.00	0.00	0.00
05.10.25	0.41	50.83	38.20	39.98	37.85	24.00	24.00	0.00	0.00
06.10.25	0.40	50.22	38.08	39.60	37.75	24.00	24.00	0.00	0.00
07.10.25	0.51	54.53	45.89	43.46	45.58	24.00	24.00	0.00	0.00
08.10.25	0.44	53.15	40.87	42.67	40.47	24.00	24.00	0.00	0.00
09.10.25	0.27	43.61	29.35	34.31	28.79	24.00	24.00	0.00	0.00
10.10.25	0.30	44.85	29.68	34.88	29.09	24.00	24.00	0.00	0.00
11.10.25	0.30	45.11	29.76	35.03	29.16	24.00	24.00	0.00	0.00
12.10.25	0.30	44.86	29.67	34.85	29.09	24.00	24.00	0.00	0.00
13.10.25	0.32	45.45	30.57	34.90	29.85	24.00	24.00	0.00	0.00
14.10.25	0.39	49.67	33.15	37.78	32.47	24.00	24.00	0.00	0.00
15.10.25	0.37	48.59	32.51	37.16	31.85	24.00	24.00	0.00	0.00
16.10.25	0.37	48.46	32.09	36.89	31.38	24.00	24.00	0.00	0.00
17.10.25	0.65	57.81	59.72	46.70	58.98	24.00	24.00	0.00	0.00
18.10.25	0.80	65.71	75.17	55.03	74.66	24.00	24.00	0.00	0.00
19.10.25	0.77	65.99	63.42	53.90	62.74	24.00	24.00	0.00	0.00
20.10.25	0.76	66.34	63.07	54.26	62.22	24.00	24.00	0.00	0.00
Итого	12.22	---	1255.27	---	1244.67	551.69	552.00	0.00	0.00
Среднее	---	54.374	---	44.186	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	815.82	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Куйбышева, 19
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00168994

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0х3Е73

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	15.67	15.53	0.14	0.000	0.000	0.000	0.000	0.000	6.90	1.04	0.0000	0.0	24.0
20.09.25	15.65	15.51	0.14	0.480	0.480	0.480	0.480	0.000	6.90	1.04	0.0000	0.0	24.0
21.09.25	15.65	15.48	0.17	0.000	0.000	0.000	0.000	0.000	6.90	1.04	0.0000	0.0	24.0
22.09.25	15.77	15.59	0.18	0.000	0.000	0.000	0.000	0.000	6.90	1.04	0.0000	0.0	24.0
23.09.25	15.99	15.78	0.21	0.000	0.000	0.000	0.000	0.000	6.90	1.04	0.0000	0.0	24.0
24.09.25	16.23	15.96	0.27	0.000	0.000	0.000	0.000	0.000	6.90	1.04	0.0000	0.0	24.0
25.09.25	16.15	15.91	0.24	0.000	0.000	0.000	0.000	0.000	6.90	1.04	0.0000	0.0	24.0
26.09.25	15.78	15.55	0.23	0.000	0.000	0.000	0.000	0.000	6.90	1.04	0.0000	0.0	24.0
27.09.25	64.63	51.17	13.46	107.260	123.400	105.200	121.870	-16.670	6.90	1.02	1.4330	0.0	24.0
28.09.25	66.10	45.07	21.03	92.920	96.360	91.150	95.450	-4.300	6.90	1.04	1.9260	0.0	24.0
29.09.25	64.70	37.68	27.02	65.210	67.350	64.010	66.870	-2.860	6.90	1.07	1.7330	0.0	24.0
30.09.25	63.89	40.24	23.65	74.920	78.120	73.540	77.470	-3.930	6.90	1.08	1.7460	0.0	24.0
01.10.25	65.96	46.80	19.16	110.600	116.570	108.410	115.350	-6.940	6.90	1.09	2.0930	0.0	24.0
02.10.25	65.94	49.26	16.68	162.320	171.920	159.200	170.000	-10.800	6.90	1.08	2.6720	0.0	24.0
03.10.25	67.15	50.47	16.68	164.810	173.950	161.480	171.830	-10.350	6.90	1.10	2.7090	0.0	24.0
04.10.25	67.18	49.78	17.40	152.680	160.860	149.570	158.950	-9.380	6.90	1.10	2.6160	0.0	24.0
05.10.25	66.06	47.89	18.17	133.120	140.370	130.440	138.820	-8.380	6.90	1.11	2.3820	0.0	24.0
06.10.25	65.63	45.03	20.60	106.700	112.750	104.650	111.660	-7.010	6.90	1.12	2.1640	0.0	24.0
07.10.25	66.21	44.74	21.47	100.730	106.570	98.760	105.610	-6.850	6.90	1.12	2.1310	0.0	24.0
08.10.25	65.95	44.61	21.34	98.510	104.300	96.550	103.340	-6.790	6.90	1.13	2.0700	0.0	24.0
09.10.25	66.18	44.31	21.87	97.340	103.080	95.420	102.120	-6.700	6.90	1.13	2.0950	0.0	24.0
10.10.25	65.86	44.57	21.29	98.120	103.860	96.200	102.900	-6.700	6.90	1.13	2.0580	0.0	24.0
11.10.25	65.45	44.88	20.57	100.590	106.560	98.680	105.600	-6.920	6.90	1.13	2.0410	0.0	24.0
12.10.25	65.55	44.29	21.26	99.380	105.200	97.460	104.240	-6.780	6.90	1.13	2.0790	0.0	24.0
13.10.25	66.68	44.65	22.03	99.400	105.230	97.430	104.270	-6.840	6.90	1.13	2.1550	0.0	24.0
14.10.25	65.53	43.94	21.59	96.970	102.760	95.050	101.800	-6.750	6.90	1.13	2.0620	0.0	24.0
15.10.25	66.04	43.37	22.67	93.090	98.770	91.280	97.810	-6.530	6.90	1.14	2.0780	0.0	24.0
16.10.25	65.89	42.62	23.27	91.360	96.970	89.570	96.060	-6.490	6.90	1.14	2.0900	0.0	24.0
17.10.25	65.75	42.78	22.97	93.820	99.480	91.960	98.550	-6.590	6.90	1.13	2.1180	0.0	24.0
18.10.25	66.04	42.23	23.81	90.410	95.920	88.670	95.200	-6.530	6.90	1.12	2.1190	0.0	24.0
19.10.25	66.43	42.92	23.51	92.750	98.300	90.890	97.420	-6.530	6.90	1.12	2.1470	0.0	24.0
20.10.25	65.82	42.35	23.47	90.150	95.670	88.380	94.840	-6.460	6.90	1.12	2.0830	0.0	24.0
Итого	---	---	---	2513.6	2664.8	2464.43	2638.51	-174.080	---	---	50.8000	0.0	768.0
Среднее	53.35	37.52	15.82	---	---	---	---	---	6.90	1.09	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	25668.329	27001.660	25128.239	26716.160	545.1100	-1587.920	3217.0	8151.0
20.10.25 24:00	28181.969	29666.459	27592.669	29354.670	595.9100	-1762.000	3217.0	8919.0
Итого за период	2513.639	2664.798	2464.430	2638.509	50.8000	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Лермонтова, 11
 Потребитель: АО "Жилуправление"
 Прибор: Вzlёт ТСРВ-024 Заводской номер: 802876
 Тип системы: А32-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	15.83	15.70	0.13	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
20.09.25	15.97	15.83	0.14	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
21.09.25	15.83	15.68	0.15	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
22.09.25	16.84	16.79	0.05	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
23.09.25	17.02	16.91	0.11	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
24.09.25	17.67	17.60	0.07	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
25.09.25	16.56	16.22	0.34	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
26.09.25	26.00	20.29	5.71	28.18	28.13	0.04	0.000	0.000	28.40	28.24	0.16	0.323	24.000
27.09.25	44.08	31.35	12.73	57.22	57.20	0.01	0.000	0.000	57.76	57.48	0.28	0.727	24.000
28.09.25	43.37	31.07	12.30	56.30	56.54	-0.24	0.000	0.000	56.82	56.81	0.01	0.684	24.000
29.09.25	43.00	30.59	12.41	54.63	54.98	-0.34	0.000	0.000	55.13	55.23	-0.11	0.665	24.000
30.09.25	44.00	28.90	15.10	44.52	44.78	-0.26	0.000	0.000	44.94	44.96	-0.02	0.664	24.000
01.10.25	45.55	29.35	16.20	43.83	44.12	-0.28	0.000	0.000	44.27	44.30	-0.03	0.700	24.000
02.10.25	48.42	30.39	18.03	43.73	44.06	-0.33	0.000	0.000	44.23	44.27	-0.03	0.764	24.000
03.10.25	47.40	32.86	14.54	55.07	55.58	-0.51	0.000	0.000	55.67	55.87	-0.20	0.782	24.000
04.10.25	47.08	32.71	14.37	54.91	55.43	-0.52	0.000	0.000	55.51	55.72	-0.22	0.771	24.000
05.10.25	47.19	32.97	14.22	54.96	55.50	-0.53	0.000	0.000	55.56	55.79	-0.23	0.763	24.000
06.10.25	46.15	32.73	13.42	54.79	55.31	-0.52	0.000	0.000	55.35	55.60	-0.25	0.717	24.000
07.10.25	44.63	32.18	12.45	54.39	54.91	-0.51	0.000	0.000	54.92	55.19	-0.27	0.659	24.000
08.10.25	44.75	32.25	12.50	53.76	54.26	-0.50	0.000	0.000	54.28	54.54	-0.26	0.654	24.000
09.10.25	44.50	32.02	12.48	52.90	53.39	-0.49	0.000	0.000	53.41	53.66	-0.25	0.643	24.000
10.10.25	43.74	31.85	11.89	51.94	52.42	-0.47	0.000	0.000	52.43	52.68	-0.25	0.601	24.000
11.10.25	42.98	31.49	11.49	51.75	52.22	-0.47	0.000	0.000	52.22	52.48	-0.26	0.579	24.000
12.10.25	43.25	31.38	11.87	51.72	52.20	-0.48	0.000	0.000	52.19	52.45	-0.26	0.597	24.000
13.10.25	43.21	31.33	11.88	51.69	52.19	-0.49	0.000	0.000	52.17	52.44	-0.27	0.597	24.000
14.10.25	44.72	32.04	12.68	51.33	51.83	-0.49	0.000	0.000	51.83	52.09	-0.26	0.633	24.000
15.10.25	45.86	32.54	13.32	52.11	52.63	-0.52	0.000	0.000	52.64	52.91	-0.26	0.675	24.000
16.10.25	46.10	33.26	12.84	57.37	57.98	-0.61	0.000	0.000	57.96	58.30	-0.33	0.715	24.000
17.10.25	47.25	33.80	13.45	58.74	59.40	-0.65	0.000	0.000	59.38	59.73	-0.34	0.767	24.000
18.10.25	51.60	35.78	15.82	59.14	59.83	-0.69	0.000	0.000	59.90	60.20	-0.31	0.909	24.000
19.10.25	51.68	36.11	15.57	59.14	59.83	-0.69	0.000	0.000	59.90	60.21	-0.31	0.894	24.000
20.10.25	50.66	35.89	14.77	59.86	60.56	-0.69	0.000	0.000	60.61	60.94	-0.34	0.857	24.000
Итого	---	---	---	1313.98	1325.29	-11.31	---	---	1327.49	1332.09	-4.60	17.341	768.000
Среднее	38.84	28.43	10.41	---	---	---	0.000	0.000	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Лермонтова, 12
 Потребитель: АО "Жилуправление"
 Прибор: Взлёт ТСРВ-024 Заводской номер: 900910
 Тип системы: А32-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	0.00	0.00	0.00	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	0.000
20.09.25	0.00	0.00	0.00	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	0.000
21.09.25	0.00	0.00	0.00	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	0.000
22.09.25	0.00	0.00	0.00	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	0.000
23.09.25	17.47	17.29	0.18	0.00	0.00	0.00	0.015	0.375	0.00	0.00	0.00	0	3.750
24.09.25	17.80	17.65	0.15	0.00	0.00	0.00	0.016	0.376	0.00	0.00	0.00	0.000	24.000
25.09.25	17.77	17.60	0.17	0.00	0.00	0.00	0.016	0.374	0.00	0.00	0.00	0.000	24.000
26.09.25	42.17	38.88	3.29	323.54	323.19	0.35	0.674	0.687	325.92	326.12	-0.21	1.099	24.000
27.09.25	43.17	38.37	4.80	238.20	238.01	0.19	0.622	0.637	240.11	239.86	0.25	1.142	24.000
28.09.25	43.83	38.61	5.22	249.32	249.31	0.00	0.640	0.657	251.52	251.13	0.39	1.297	24.000
29.09.25	43.55	38.19	5.36	249.62	249.56	0.05	0.627	0.645	251.77	251.37	0.40	1.335	24.000
30.09.25	43.54	37.39	6.15	219.10	218.94	0.15	0.618	0.638	221.02	220.44	0.58	1.336	24.000
01.10.25	45.52	38.34	7.18	202.67	202.42	0.24	0.590	0.610	204.64	203.86	0.79	1.457	24.000
02.10.25	48.34	40.01	8.33	195.39	195.21	0.17	0.684	0.704	197.54	196.69	0.85	1.620	24.000
03.10.25	48.09	41.29	6.80	247.43	247.34	0.08	0.505	0.522	250.06	249.45	0.61	1.639	24.000
04.10.25	47.36	41.17	6.19	259.10	259.07	0.03	0.484	0.500	261.78	261.26	0.52	1.601	24.000
05.10.25	47.47	41.30	6.17	258.82	258.80	0.01	0.482	0.498	261.52	260.99	0.52	1.593	24.000
06.10.25	47.50	41.44	6.06	258.67	258.65	0.01	0.483	0.499	261.37	260.85	0.52	1.565	24.000
07.10.25	44.84	39.50	5.34	257.09	257.07	0.01	0.484	0.500	259.49	259.05	0.44	1.370	24.000
08.10.25	45.00	39.60	5.40	254.71	254.67	0.03	0.484	0.500	257.11	256.65	0.46	1.372	24.000
09.10.25	44.93	39.50	5.43	250.93	250.92	0.00	0.478	0.495	253.30	252.84	0.46	1.358	24.000
10.10.25	44.37	39.09	5.28	245.20	245.18	0.01	0.472	0.489	247.47	247.00	0.48	1.292	24.000
11.10.25	43.95	38.77	5.18	243.88	243.87	0.00	0.470	0.487	246.11	245.65	0.46	1.260	24.000
12.10.25	43.04	38.08	4.96	243.54	243.53	0.01	0.466	0.483	245.67	245.24	0.43	1.203	24.000
13.10.25	43.48	38.27	5.21	243.54	243.54	0.00	0.470	0.486	245.72	245.27	0.45	1.266	24.000
14.10.25	43.97	38.64	5.33	242.83	242.82	0.00	0.472	0.489	245.04	244.58	0.46	1.288	24.000
15.10.25	46.41	40.41	6.00	239.57	239.56	0.01	0.464	0.481	242.00	241.47	0.53	1.433	24.000
16.10.25	46.40	40.73	5.67	264.53	264.51	0.02	0.495	0.510	267.14	266.71	0.43	1.494	24.000
17.10.25	44.85	39.95	4.90	228.78	228.78	0	0.431	0.460	231.00	230.70	0.30	1.251	24.000
18.10.25	50.73	44.25	6.48	0.00	0.00	0.00	0.492	0.506	0.00	0.00	0.00	0.000	24.000
19.10.25	51.88	45.20	6.68	0.00	0.00	0.00	0.516	0.528	0.00	0.00	0.00	0.000	24.000
20.10.25	51.74	45.26	6.48	0.00	0.00	0.00	0.516	0.528	0.00	0.00	0.00	0.000	24.000
Итого	---	---	---	5416.44	5414.96	1.48	---	---	5467.31	5457.18	10.13	30.272	651.750
Среднее	37.47	32.96	4.51	---	---	---	0.411	0.458	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Лермонтова, 4
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ630

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	16.97	0.00	16.14	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	16.93	0.00	16.10	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	16.89	0.00	16.09	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	16.86	0.00	16.09	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	16.93	0.00	16.13	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	16.86	0.00	16.35	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	16.94	0.00	16.52	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	33.13	0.00	30.81	51.89	0.00	24.00	0.00	0.00
27.09.25	0.00	40.85	0.00	37.29	79.98	0.00	24.00	0.00	0.00
28.09.25	0.00	43.88	0.00	39.51	75.53	0.00	24.00	0.00	0.00
29.09.25	0.00	43.12	0.00	38.78	73.52	0.00	24.00	0.00	0.00
30.09.25	0.00	42.77	0.00	38.32	70.36	0.00	24.00	0.00	0.00
01.10.25	0.00	44.15	0.00	38.40	59.97	0.00	24.00	0.00	0.00
02.10.25	0.00	45.92	0.00	39.42	57.82	0.00	24.00	0.00	0.00
03.10.25	0.00	48.19	0.00	41.10	61.96	0.00	24.00	0.00	0.00
04.10.25	0.00	47.06	0.00	41.65	76.45	0.00	24.00	0.00	0.00
05.10.25	0.00	46.86	0.00	41.49	76.31	0.00	24.00	0.00	0.00
06.10.25	0.00	46.99	0.00	41.67	76.21	0.00	24.00	0.00	0.00
07.10.25	0.00	45.52	0.00	40.62	75.71	0.00	24.00	0.00	0.00
08.10.25	0.00	44.40	0.00	39.75	74.66	0.00	24.00	0.00	0.00
09.10.25	0.00	43.95	0.00	39.36	53.38	0.00	24.00	0.00	0.00
10.10.25	0.42	41.67	74.94	37.25	28.12	8.62	23.35	0.00	0.00
11.10.25	0.95	43.38	188.47	38.34	0.00	21.63	21.66	0.00	0.00
12.10.25	1.00	42.61	208.23	37.79	0.00	24.00	24.00	0.00	0.00
13.10.25	1.04	43.02	207.65	38.00	0.00	24.00	24.00	0.00	0.00
14.10.25	1.04	42.99	207.71	37.97	0.00	24.00	24.00	0.00	0.00
15.10.25	1.13	44.75	205.19	39.22	0.00	24.00	24.00	0.00	0.00
16.10.25	1.19	45.70	208.94	39.96	0.00	24.00	24.00	0.00	0.00
17.10.25	1.24	45.81	226.17	40.33	0.00	24.00	24.00	0.00	0.00
18.10.25	1.38	47.71	230.91	41.74	0.00	24.00	24.00	0.00	0.00
19.10.25	1.56	51.27	231.64	44.50	0.00	24.00	24.00	0.00	0.00
20.10.25	1.56	51.44	231.86	44.71	0.00	24.00	24.00	0.00	0.00
Итого	12.51	---	2221.71	---	991.87	246.25	765.01	0.00	0.00
Среднее	---	38.610	---	34.419	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	2016.97	0.00
20.10.25 24:00	2030.89	0.00
Итого за период	13.92	0.00

Представитель абонента _____/_____

Представитель поставщика _____/_____

ИМ2300, Суточный с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Лермонтова, 6
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ644

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	15.81	0.00	15.71	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	15.76	0.00	15.66	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	15.72	0.00	15.60	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	15.66	0.00	15.55	0.00	0.00	24.00	0.00	0.00
23.09.25	0	16.06	0.00	15.64	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	15.88	0.00	15.68	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	15.99	0.00	15.88	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	15.84	0.00	15.73	0.00	0.00	24.00	0.00	0.00
27.09.25	0.34	25.05	66.78	23.07	66.09	8.91	24.00	0.00	0.00
28.09.25	0.93	44.36	192.73	39.53	190.92	24.00	24.00	0.00	0.00
29.09.25	0.92	43.58	190.99	38.74	189.04	24.00	24.00	0.00	0.00
30.09.25	0.91	43.22	188.96	38.37	186.84	24.00	24.00	0.00	0.00
01.10.25	0.98	44.63	158.02	38.43	156.17	24.00	24.00	0.00	0.00
02.10.25	1.07	46.43	151.09	39.31	149.45	24.00	24.00	0.00	0.00
03.10.25	1.15	48.72	156.27	41.02	154.66	24.00	24.00	0.00	0.00
04.10.25	1.13	47.57	192.95	41.72	190.83	24.00	24.00	0.00	0.00
05.10.25	1.13	47.37	192.65	41.50	190.43	24.00	24.00	0.00	0.00
06.10.25	1.12	47.50	192.42	41.67	190.25	24.00	24.00	0.00	0.00
07.10.25	1.02	45.99	191.11	40.65	188.87	24.00	24.00	0.00	0.00
08.10.25	0.95	44.88	188.40	39.81	186.07	24.00	24.00	0.00	0.00
09.10.25	0.94	44.96	190.34	39.94	187.88	24.00	24.00	0.00	0.00
10.10.25	0.92	44.66	177.79	39.38	175.67	24.00	24.00	0.00	0.00
11.10.25	0.87	43.84	165.37	38.56	163.22	24.00	24.00	0.00	0.00
12.10.25	0.83	43.06	158.93	37.81	156.90	24.00	24.00	0.00	0.00
13.10.25	0.87	43.47	158.45	37.96	156.39	24.00	24.00	0.00	0.00
14.10.25	0.87	43.44	158.51	37.96	156.33	24.00	24.00	0.00	0.00
15.10.25	0.94	45.22	156.54	39.19	154.53	24.00	24.00	0.00	0.00
16.10.25	0.99	46.18	159.34	39.92	157.31	24.00	24.00	0.00	0.00
17.10.25	1.03	46.29	172.47	40.28	170.39	24.00	24.00	0.00	0.00
18.10.25	1.15	48.23	176.13	41.70	174.06	24.00	24.00	0.00	0.00
19.10.25	1.31	51.83	176.75	44.41	174.76	24.00	24.00	0.00	0.00
20.10.25	1.29	52.00	176.83	44.71	174.89	24.00	24.00	0.00	0.00
Итого	23.66	---	4089.82	---	4041.95	560.91	768.00	0.00	0.00
Среднее	---	37.788	---	33.472	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	1747.18	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Лермонтова, 9
 Потребитель: АО "Жилуправление"
 Прибор: Вzlёт ТСРВ-024 Заводской номер: 801971
 Тип системы: А32-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	13.89	13.70	0.19	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	24.000
20.09.25	13.86	13.66	0.20	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	24.000
21.09.25	13.84	13.64	0.20	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	24.000
22.09.25	14.05	13.78	0.27	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	24.000
23.09.25	14.37	14.02	0.35	0.00	0.00	-0.00	0.590	0.549	0.00	0.00	-0.00	0	24.000
24.09.25	14.56	14.17	0.39	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	24.000
25.09.25	14.66	14.25	0.41	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	24.000
26.09.25	19.92	18.26	1.66	52.04	51.86	0.17	0.590	0.549	52.29	52.25	0.04	0.331	24.000
27.09.25	43.74	36.37	7.37	176.42	176.39	0.03	0.590	0.549	177.71	177.81	-0.11	1.298	24.000
28.09.25	43.72	36.16	7.56	170.61	170.61	0	0.590	0.549	171.43	172.39	-0.96	1.287	24.000
29.09.25	43.46	35.73	7.73	168.10	167.79	0.31	0.590	0.549	169.36	169.04	0.32	1.308	24.000
30.09.25	43.73	34.62	9.11	141.71	140.84	0.87	0.590	0.549	142.99	141.65	1.34	1.310	24.000
01.10.25	45.47	35.28	10.19	133.72	132.79	0.93	0.590	0.549	135.03	133.57	1.45	1.394	24.000
02.10.25	48.82	36.64	12.18	123.69	122.98	0.71	0.590	0.549	125.08	123.77	1.31	1.515	24.000
03.10.25	47.77	38.63	9.14	168.22	167.48	0.74	0.590	0.549	170.05	168.67	1.38	1.565	24.000
04.10.25	47.33	38.44	8.89	168.40	167.71	0.69	0.590	0.549	170.19	168.88	1.31	1.523	24.000
05.10.25	47.45	38.60	8.85	168.31	167.67	0.64	0.590	0.549	170.11	168.85	1.26	1.513	24.000
06.10.25	47.18	38.61	8.57	168.05	167.47	0.58	0.590	0.549	169.83	168.65	1.18	1.463	24.000
07.10.25	44.78	37.11	7.67	167.11	166.51	0.60	0.590	0.549	168.71	167.59	1.11	1.302	24.000
08.10.25	44.96	37.24	7.72	165.45	164.82	0.62	0.590	0.549	167.04	165.91	1.13	1.299	24.000
09.10.25	44.86	37.12	7.74	163.04	162.38	0.65	0.590	0.549	164.60	163.44	1.16	1.285	24.000
10.10.25	44.22	36.69	7.53	159.57	158.93	0.64	0.590	0.549	161.06	159.94	1.11	1.223	24.000
11.10.25	43.70	36.37	7.33	158.83	158.17	0.66	0.590	0.549	160.28	159.16	1.11	1.186	24.000
12.10.25	43.17	35.83	7.34	158.67	158.04	0.63	0.590	0.549	160.07	159.00	1.08	1.185	24.000
13.10.25	43.43	35.91	7.52	158.65	158.02	0.62	0.590	0.549	160.07	158.98	1.09	1.215	24.000
14.10.25	44.41	36.54	7.87	157.86	157.27	0.58	0.590	0.549	159.34	158.26	1.08	1.262	24.000
15.10.25	46.19	37.63	8.56	156.13	155.61	0.52	0.590	0.549	157.71	156.65	1.06	1.354	24.000
16.10.25	46.36	38.23	8.13	174.49	173.93	0.55	0.590	0.549	176.27	175.14	1.13	1.439	24.000
17.10.25	46.35	38.27	8.08	179.38	178.83	0.54	0.590	0.549	181.21	180.07	1.14	1.468	24.000
18.10.25	51.88	41.85	10.03	180.84	180.41	0.42	0.590	0.549	183.14	181.92	1.23	1.830	24.000
19.10.25	51.90	42.07	9.83	180.87	180.44	0.42	0.590	0.549	183.18	181.96	1.21	1.794	24.000
20.10.25	51.40	41.93	9.47	182.43	182.03	0.39	0.590	0.549	184.71	183.56	1.14	1.740	24.000
Итого	---	---	---	3982.59	3968.97	13.62	---	---	4021.44	3997.13	24.31	34.088	768.000
Среднее	38.29	31.79	6.50	---	---	---	0.590	0.549	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Луначарского, 4
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00166967

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0x2EB8

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
28.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
29.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
30.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
01.10.25	65.45	44.74	20.71	165.890	164.880	162.650	163.340	-0.690	6.20	6.00	3.3640	0.0	24.0
02.10.25	66.23	45.25	20.98	167.970	168.600	164.610	166.920	-2.310	6.20	6.00	3.4500	0.0	24.0
03.10.25	67.44	46.08	21.36	170.440	171.930	166.950	170.250	-3.300	6.20	6.00	3.5630	0.0	24.0
04.10.25	67.50	46.46	21.04	171.060	172.580	167.500	170.900	-3.400	6.20	6.00	3.5170	0.0	24.0
05.10.25	66.46	46.40	20.06	171.850	173.530	168.470	171.840	-3.370	6.20	6.00	3.3760	0.0	24.0
06.10.25	66.21	47.00	19.21	172.170	173.940	168.770	172.140	-3.370	6.20	6.00	3.2380	0.0	24.0
07.10.25	66.87	48.03	18.84	171.870	173.790	168.420	171.870	-3.450	6.20	6.00	3.1730	0.0	24.0
08.10.25	66.62	48.11	18.51	168.740	170.740	165.300	168.880	-3.580	6.20	6.00	3.0590	0.0	24.0
09.10.25	66.87	48.01	18.86	166.810	168.700	163.430	166.890	-3.460	6.20	6.00	3.0780	0.0	24.0
10.10.25	66.37	46.32	20.05	126.060	128.010	123.520	126.720	-3.200	6.20	6.00	2.4680	0.0	24.0
11.10.25	66.03	41.78	24.25	86.940	89.600	85.170	88.890	-3.720	6.20	6.00	2.0590	0.0	24.0
12.10.25	66.05	42.66	23.39	105.160	107.810	103.080	106.870	-3.790	6.20	6.00	2.4070	0.0	24.0
13.10.25	67.16	43.11	24.05	99.310	101.790	97.300	100.930	-3.630	6.20	6.00	2.3360	0.0	24.0
14.10.25	66.06	42.50	23.56	100.650	103.240	98.650	102.310	-3.660	6.20	6.00	2.3210	0.0	24.0
15.10.25	66.62	42.23	24.39	98.040	100.630	96.060	99.780	-3.720	6.20	6.00	2.3390	0.0	24.0
16.10.25	66.59	44.54	22.05	129.030	131.480	126.390	130.280	-3.890	6.20	6.00	2.7810	0.0	24.0
17.10.25	66.42	44.32	22.10	126.090	128.540	123.560	127.380	-3.820	6.20	6.00	2.7280	0.0	24.0
18.10.25	66.80	44.68	22.12	128.130	130.530	125.610	129.260	-3.650	6.20	6.00	2.7740	0.0	24.0
19.10.25	67.05	42.56	24.49	102.750	105.280	100.650	104.320	-3.670	6.20	6.00	2.4650	0.0	24.0
20.10.25	66.39	42.43	23.96	105.320	107.930	103.190	106.940	-3.750	6.20	6.00	2.4710	0.0	24.0
Итого	---	---	---	2734.2	2773.5	2679.28	2746.71	-67.430	---	---	56.9670	0.0	480.0
Среднее	66.55	44.86	21.69	---	---	---	---	---	6.20	6.00	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
29.09.25 24:00	0	0	0	0	0	0	0	0
20.10.25 24:00	3123.340	3136.840	3060.810	3105.990	63.3780	-45.180	0.0	1833.0
Итого за период	3123.340	3136.840	3060.810	3105.990	63.3780	---	0.0	1833.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Луначарского, 6
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВА763

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	19.48	0.00	18.73	0.00	24.00	24.00	0.00	0.00
20.09.25	0.00	19.25	0.00	18.61	0.00	24.00	24.00	0.00	0.00
21.09.25	0.00	19.40	0.00	18.84	0.00	23.98	23.98	0.00	0.00
22.09.25	0.00	19.52	0.00	19.01	0.00	24.00	24.00	0.00	0.00
23.09.25	0.00	19.90	0.00	19.29	0.00	24.00	24.00	0.00	0.00
24.09.25	0.00	16.98	0.00	15.80	0.00	24.00	24.00	0.00	0.00
25.09.25	0.00	16.95	0.00	16.40	0.00	24.00	24.00	0.00	0.00
26.09.25	0.00	16.24	0.00	16.10	0.00	17.49	24.00	0.00	0.00
27.09.25	0.00	16.04	0.00	16.23	0.00	0.36	24.00	0.00	0.00
28.09.25	0.00	44.76	0.00	40.17	0.00	14.10	24.00	0.00	0.00
29.09.25	0.00	67.06	0.00	60.34	0.00	24.00	24.00	0.00	0.00
30.09.25	0.00	66.23	0.00	59.67	0.00	23.87	24.00	0.00	0.00
01.10.25	0.00	65.68	0.00	59.13	0.00	24.00	24.00	0.00	0.00
02.10.25	0.00	65.64	0.00	59.37	0.00	24.00	24.00	0.00	0.00
03.10.25	0.00	66.45	0.00	60.25	0.00	24.00	24.00	0.00	0.00
04.10.25	0.00	67.64	0.00	61.45	0.00	24.00	24.00	0.00	0.00
05.10.25	0.00	67.74	0.00	61.54	0.00	24.00	24.00	0.00	0.00
06.10.25	0.00	66.69	0.00	60.79	0.00	24.00	24.00	0.00	0.00
07.10.25	0.00	66.43	0.00	60.30	0.00	24.00	24.00	0.00	0.00
08.10.25	0.00	67.08	0.00	60.61	0.00	24.00	24.00	0.00	0.00
09.10.25	2.22	66.86	349.15	60.40	348.69	24.00	24.00	0.00	0.00
10.10.25	4.21	67.11	633.38	60.45	633.43	24.00	24.00	0.00	0.00
11.10.25	4.11	66.74	639.61	60.31	638.86	24.00	24.00	0.00	0.00
12.10.25	4.09	66.31	656.53	60.08	655.99	23.94	24.00	0.00	0.00
13.10.25	4.21	66.43	649.29	59.94	648.86	24.00	24.00	0.00	0.00
14.10.25	4.32	67.57	647.85	60.90	647.63	24.00	24.00	0.00	0.00
15.10.25	4.12	66.42	634.31	59.92	633.51	24.00	24.00	0.00	0.00
16.10.25	4.21	67.00	608.91	60.07	607.92	24.00	24.00	0.00	0.00
17.10.25	4.25	66.89	595.80	59.75	595.53	24.00	24.00	0.00	0.00
18.10.25	4.21	66.71	605.48	59.75	604.71	24.00	24.00	0.00	0.00
19.10.25	4.25	67.06	585.58	59.79	585.04	24.00	24.00	0.00	0.00
20.10.25	4.25	67.43	598.00	60.30	596.97	24.00	24.00	0.00	0.00
Итого	48.45	---	7203.89	---	7197.14	727.74	767.98	0.00	0.00
Среднее	---	52.428	---	47.634	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	10621.31	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Матросова, 123
Потребитель: АО "Жилуправление"
Прибор: ТВ7-04.1 Заводской номер: 20140326

БД=1, ТВ1, СИ=6, КТ3=0, ФРТ=0, КСН=0х5А21

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
24.09.25	17.94	17.12	н/д	0.82	2.08	2.12	н/д	0.000	0.489	н/д	0.000	0.489	н/д	-0.489	0.000	н/д	24	0
25.09.25	18.04	17.17	н/д	0.87	1.77	1.81	н/д	0.000	0.466	н/д	0.000	0.466	н/д	-0.466	0.000	н/д	24	0
26.09.25	42.68	39.29	н/д	3.38	1.88	1.89	н/д	41.562	41.616	н/д	41.213	41.328	н/д	-0.116	0.139	н/д	24	0
27.09.25	43.17	40.29	н/д	2.89	2.07	2.03	н/д	114.165	113.523	н/д	113.177	112.676	н/д	0.502	0.327	н/д	24	0
28.09.25	46.84	43.30	н/д	3.54	1.97	1.92	н/д	113.826	113.080	н/д	112.661	112.099	н/д	0.563	0.399	н/д	24	0
29.09.25	50.10	45.62	н/д	4.49	2.22	2.19	н/д	113.753	112.973	н/д	112.419	111.875	н/д	0.544	0.504	н/д	24	0
30.09.25	50.38	45.67	н/д	4.71	2.48	2.45	н/д	112.738	111.883	н/д	111.384	110.789	н/д	0.595	0.524	н/д	24	0
01.10.25	45.75	41.71	н/д	4.04	2.65	2.64	н/д	113.078	112.243	н/д	111.965	111.332	н/д	0.633	0.452	н/д	24	0
02.10.25	43.18	39.53	н/д	3.66	2.49	2.47	н/д	112.987	112.285	н/д	112.009	111.484	н/д	0.524	0.409	н/д	24	0
03.10.25	41.82	38.26	н/д	3.56	2.22	2.21	н/д	112.707	112.007	н/д	111.795	111.262	н/д	0.534	0.397	н/д	24	0
04.10.25	46.59	42.19	н/д	4.40	2.46	2.44	н/д	112.855	112.130	н/д	111.707	111.205	н/д	0.502	0.491	н/д	24	0
05.10.25	45.40	41.27	н/д	4.13	2.28	2.27	н/д	112.679	111.961	н/д	111.587	111.083	н/д	0.505	0.461	н/д	24	0
06.10.25	44.66	40.67	н/д	3.99	2.67	2.65	н/д	112.732	111.988	н/д	111.680	111.138	н/д	0.542	0.445	н/д	24	0
07.10.25	42.73	39.16	н/д	3.57	2.94	2.93	н/д	113.113	112.426	н/д	112.165	111.644	н/д	0.520	0.401	н/д	24	0
08.10.25	43.32	39.61	н/д	3.71	2.83	2.82	н/д	113.089	112.383	н/д	112.112	111.579	н/д	0.533	0.415	н/д	24	0
09.10.25	44.50	40.70	н/д	3.80	2.74	2.73	н/д	112.953	112.261	н/д	111.911	111.409	н/д	0.501	0.425	н/д	24	0
10.10.25	41.79	38.52	н/д	3.28	2.40	2.38	н/д	112.733	112.064	н/д	111.827	111.311	н/д	0.516	0.366	н/д	24	0
11.10.25	43.06	39.54	н/д	3.52	2.47	2.46	н/д	112.768	112.084	н/д	111.804	111.290	н/д	0.515	0.393	н/д	24	0
12.10.25	44.10	40.28	н/д	3.82	2.56	2.55	н/д	112.720	112.010	н/д	111.704	111.180	н/д	0.524	0.426	н/д	24	0
13.10.25	43.54	39.97	н/д	3.57	2.40	2.39	н/д	112.630	111.952	н/д	111.642	111.137	н/д	0.505	0.398	н/д	24	0
14.10.25	41.67	38.37	н/д	3.30	2.23	2.21	н/д	112.419	111.747	н/д	111.520	111.005	н/д	0.515	0.368	н/д	24	0
15.10.25	44.63	40.73	н/д	3.90	2.48	2.46	н/д	112.518	111.786	н/д	111.476	110.937	н/д	0.538	0.435	н/д	24	0
16.10.25	47.38	42.95	н/д	4.43	2.50	2.48	н/д	112.594	111.832	н/д	111.414	110.881	н/д	0.533	0.494	н/д	24	0
17.10.25	45.76	41.72	н/д	4.04	2.31	2.29	н/д	112.453	111.730	н/д	111.353	110.837	н/д	0.516	0.449	н/д	24	0
18.10.25	45.22	41.35	н/д	3.87	2.21	2.19	н/д	112.283	111.579	н/д	111.210	110.703	н/д	0.507	0.430	н/д	24	0
19.10.25	43.06	39.71	н/д	3.35	2.05	2.02	н/д	112.040	111.401	н/д	111.077	110.602	н/д	0.475	0.372	н/д	24	0
20.10.25	44.02	40.37	н/д	3.65	2.21	2.18	н/д	112.037	111.395	н/д	111.030	110.569	н/д	0.461	0.405	н/д	24	0
Итого	---	---	---	---	---	---	---	2749.432	2733.294	---	2723.842	2712.310	---	11.532	10.325	---	648	0
Среднее	44.66	40.87	---	3.79	2.35	2.34	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
20.10.25 24:00	2749.937	2735.957	0.000	2724.346	2714.972	0.000	9.374	10.326	0.000	1767	0
Итого за период	н/д	н/д	н/д	н/д	н/д	н/д	---	н/д	н/д	н/д	н/д

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Мичурина, 3
 Потребитель: АО "Жилуправление"
 Прибор: Вzlёт ТСРВ-024 Заводской номер: 900043
 Тип системы: А42-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	15.67	15.02	0.65	0.00	0.00	0.00	0.042	0.600	0.00	0.00	0.00	0.000	0.000
20.09.25	15.61	14.88	0.73	0.00	0.00	0.00	0.041	0.600	0.00	0.00	0.00	0.000	0.000
21.09.25	15.44	14.76	0.68	0.00	0.00	0.00	0.040	0.600	0.00	0.00	0.00	0.000	0.000
22.09.25	15.64	14.86	0.78	0.00	0.00	0.00	0.040	0.600	0.00	0.00	0.00	0.000	0.000
23.09.25	15.78	15.05	0.73	0.00	0.00	0.00	0.040	0.600	0.00	0.00	0.00	0.000	0.000
24.09.25	16.03	15.20	0.83	0.00	0.00	0.00	0.047	0.600	0.00	0.00	0.00	0.000	0.000
25.09.25	16.07	15.23	0.84	0.00	0.00	0.00	0.187	0.600	0.00	0.00	0.00	0.000	0.000
26.09.25	20.74	19.57	1.17	57.88	57.89	-0.01	0.494	0.600	58.30	58.25	0.05	0.071	1.567
27.09.25	44.20	41.61	2.59	307.08	307.00	0.08	0.620	0.600	309.94	309.53	0.41	0.029	0.833
28.09.25	43.90	41.40	2.50	305.19	304.99	0.20	0.629	0.600	307.99	307.47	0.51	0.000	0.000
29.09.25	43.62	41.16	2.46	308.07	307.88	0.19	0.606	0.600	310.86	310.35	0.51	0.017	0.500
30.09.25	44.12	41.05	3.07	260.16	259.73	0.42	0.618	0.600	262.55	261.81	0.75	0.363	10.500
01.10.25	45.79	42.00	3.79	220.02	219.83	0.18	0.593	0.600	222.21	221.68	0.53	0.831	24.000
02.10.25	49.26	44.68	4.58	205.82	205.65	0.17	0.669	0.600	208.18	207.60	0.58	0.920	23.750
03.10.25	47.99	44.40	3.59	246.73	246.51	0.21	0.469	0.600	249.44	248.82	0.62	0.877	24.000
04.10.25	47.57	44.05	3.52	249.12	248.90	0.22	0.463	0.600	251.81	251.19	0.62	0.867	24.000
05.10.25	47.68	44.17	3.51	248.98	248.77	0.20	0.463	0.600	251.68	251.08	0.60	0.865	24.000
06.10.25	47.26	43.87	3.39	248.53	248.33	0.20	0.463	0.600	251.18	250.60	0.58	0.749	21.167
07.10.25	45.00	41.97	3.03	247.00	246.80	0.19	0.463	0.600	249.39	248.87	0.52	0.591	18.917
08.10.25	45.17	42.13	3.04	244.57	244.37	0.20	0.465	0.600	246.96	246.43	0.53	0.591	19.167
09.10.25	45.04	41.98	3.06	240.96	240.76	0.20	0.457	0.600	243.30	242.78	0.52	0.536	17.417
10.10.25	44.37	41.41	2.96	234.54	234.34	0.19	0.453	0.600	236.75	236.25	0.50	0.227	7.583
11.10.25	43.75	40.85	2.90	232.08	231.89	0.18	0.451	0.600	234.20	233.72	0.48	0.266	9.167
12.10.25	43.48	40.55	2.93	231.62	231.44	0.18	0.447	0.600	233.72	233.24	0.48	0.204	7.083
13.10.25	43.63	40.63	3.00	231.64	231.47	0.17	0.452	0.600	233.75	233.28	0.47	0.397	13.750
14.10.25	44.74	41.57	3.17	230.82	230.65	0.17	0.453	0.600	233.03	232.54	0.50	0.366	11.417
15.10.25	46.35	42.91	3.44	228.02	227.85	0.17	0.446	0.600	230.37	229.84	0.52	0.767	23.667
16.10.25	46.57	43.34	3.23	254.99	254.79	0.20	0.478	0.600	257.63	257.06	0.57	0.816	24.000
17.10.25	46.73	43.50	3.23	260.03	259.87	0.15	0.484	0.600	262.74	262.21	0.53	0.828	23.833
18.10.25	52.20	48.18	4.02	262.91	262.79	0.11	0.490	0.600	266.31	265.69	0.62	1.049	24.000
19.10.25	52.16	48.26	3.90	263.04	262.91	0.13	0.490	0.600	266.44	265.81	0.62	1.018	24.000
20.10.25	51.52	47.78	3.74	262.63	262.48	0.15	0.491	0.600	265.95	265.32	0.62	0.962	23.417
Итого	---	---	---	6082.43	6077.86	4.57	---	---	6144.68	6131.41	13.26	14.209	401.733
Среднее	38.85	36.19	2.66	---	---	---	0.408	0.600	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Новоселов, 12
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00166606

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0х302С

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	20.72	20.95	-0.23	225.920	225.920	225.440	225.520	-0.080	1.85	5.40	0.0110	0.0	24.0
20.09.25	20.67	21.41	-0.74	226.350	226.350	225.870	225.890	-0.020	1.62	5.40	0.0030	0.0	24.0
21.09.25	20.76	22.20	-1.44	230.220	230.220	229.740	229.740	0.000	1.53	5.40	0.0000	0.0	24.0
22.09.25	20.52	22.83	-2.31	97.360	97.360	97.170	97.150	0.020	2.76	5.40	0.0000	0.0	24.0
23.09.25	21.15	22.12	-0.97	0.000	0.000	0.000	0.000	0.000	3.44	5.40	0.0000	0.0	24.0
24.09.25	21.68	22.60	-0.92	0.000	0.000	0.000	0.000	0.000	3.32	5.40	0.0000	0.0	24.0
25.09.25	38.47	35.36	3.11	90.910	90.910	90.260	90.360	-0.100	5.03	5.40	0.2850	0.0	24.0
26.09.25	38.10	35.11	2.99	246.130	246.130	244.480	244.720	-0.240	7.65	5.40	0.7410	0.0	24.0
27.09.25	40.18	36.63	3.55	254.970	254.970	253.060	253.340	-0.280	7.95	5.40	0.9110	0.0	24.0
28.09.25	40.08	36.30	3.78	252.780	252.780	250.900	251.240	-0.340	7.88	5.40	0.9600	0.0	24.0
29.09.25	46.90	40.31	6.59	246.770	246.770	244.150	244.840	-0.690	7.90	5.40	1.6130	0.0	24.0
30.09.25	43.26	38.50	4.76	344.240	344.240	341.230	341.830	-0.600	8.32	5.40	1.6380	0.0	24.0
01.10.25	45.63	40.49	5.14	246.220	246.220	243.830	244.310	-0.480	6.89	5.40	1.2630	0.0	24.0
02.10.25	51.23	45.51	5.72	312.300	312.300	308.500	309.280	-0.780	8.06	5.40	1.7760	0.0	24.0
03.10.25	52.63	46.45	6.18	357.150	357.150	352.590	353.500	-0.910	8.04	5.40	2.1920	0.0	24.0
04.10.25	53.23	46.79	6.44	380.220	380.220	375.230	376.290	-1.060	8.03	5.40	2.4340	0.0	24.0
05.10.25	49.75	44.01	5.74	359.120	359.120	354.960	355.850	-0.890	7.81	5.40	2.0520	0.0	24.0
06.10.25	44.64	39.75	4.89	342.140	342.140	338.960	339.590	-0.630	7.61	5.40	1.6720	0.0	24.0
07.10.25	43.75	39.12	4.63	361.010	361.010	357.810	358.420	-0.610	7.76	5.40	1.6730	0.0	24.0
08.10.25	45.40	40.59	4.81	378.430	378.430	374.780	375.490	-0.710	8.05	5.40	1.8160	0.0	24.0
09.10.25	44.77	40.12	4.65	380.960	380.960	377.420	378.080	-0.660	8.05	5.40	1.7710	0.0	24.0
10.10.25	44.84	40.24	4.60	381.560	381.560	377.970	378.680	-0.710	7.98	5.40	1.7520	0.0	24.0
11.10.25	44.86	40.25	4.61	381.790	381.790	378.200	378.910	-0.710	8.02	5.40	1.7600	0.0	24.0
12.10.25	44.53	39.87	4.66	381.590	381.590	378.110	378.750	-0.640	7.99	5.40	1.7780	0.0	24.0
13.10.25	44.33	39.71	4.62	381.660	381.660	378.190	378.790	-0.600	8.07	5.40	1.7650	0.0	24.0
14.10.25	44.91	40.08	4.83	375.590	375.590	372.080	372.720	-0.640	7.95	5.40	1.8100	0.0	24.0
15.10.25	45.63	40.58	5.05	373.630	373.630	370.000	370.750	-0.750	7.86	5.40	1.8850	0.0	24.0
16.10.25	45.05	40.03	5.02	384.430	384.430	380.790	381.530	-0.740	8.52	5.40	1.9310	0.0	24.0
17.10.25	44.75	39.73	5.02	390.810	390.810	387.200	387.920	-0.720	8.73	5.40	1.9630	0.0	24.0
18.10.25	47.58	41.68	5.90	389.250	389.250	385.140	386.070	-0.930	8.53	5.40	2.2910	0.0	24.0
19.10.25	50.14	43.74	6.40	387.690	387.690	383.150	384.170	-1.020	8.31	5.40	2.4660	0.0	24.0
20.10.25	51.33	44.69	6.64	393.810	393.810	388.990	390.100	-1.110	8.36	5.40	2.5990	0.0	24.0
Итого	---	---	---	9555.0	9555.0	9466.20	9483.83	-17.630	---	---	44.8110	0.0	768.0
Среднее	40.98	37.11	3.86	---	---	---	---	---	6.87	5.40	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	90945.190	90945.190	89759.380	90052.930	657.9410	-293.550	209.0	9279.0
20.10.25 24:00	100500.199	100500.199	99225.579	99536.760	702.7520	-311.180	209.0	10047.0
Итого за период	9555.008	9555.008	9466.198	9483.830	44.8110	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Новоселов, 14
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00179200

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0x2D8A

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Мг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	21.30	21.45	-0.15	0.000	11.520	0.000	11.520	-11.520	1.02	1.04	0.0000	0.0	24.0
20.09.25	21.33	21.48	-0.15	0.000	11.520	0.000	11.520	-11.520	1.02	1.04	0.0000	0.0	24.0
21.09.25	21.28	21.41	-0.13	0.000	11.520	0.000	11.520	-11.520	1.02	1.04	0.0000	0.0	24.0
22.09.25	21.47	25.90	-4.43	0.000	8.250	0.000	8.230	-8.230	1.02	2.45	0.0000	0.0	24.0
23.09.25	21.63	31.44	-9.81	0.000	0.480	0.000	0.480	-0.480	1.02	6.34	0.0000	0.0	24.0
24.09.25	21.65	21.82	-0.17	0.000	0.000	0.000	0.000	0.000	1.02	7.86	0.0000	0.0	24.0
25.09.25	36.51	33.69	2.82	119.310	115.940	118.570	115.350	3.220	5.03	7.69	0.3380	0.0	24.0
26.09.25	38.06	34.92	3.14	220.240	214.310	218.770	213.120	5.650	8.05	7.68	0.6880	0.0	24.0
27.09.25	40.12	36.50	3.62	234.510	229.040	232.780	227.620	5.160	8.10	7.76	0.8400	0.0	24.0
28.09.25	40.03	36.23	3.80	237.890	232.970	236.130	231.530	4.600	8.10	7.77	0.8990	0.0	24.0
29.09.25	45.25	39.19	6.06	190.820	183.860	188.970	182.540	6.430	6.83	6.61	1.1770	0.0	24.0
30.09.25	43.18	38.44	4.74	330.750	326.240	327.890	324.010	3.880	8.70	8.33	1.5560	0.0	24.0
01.10.25	46.49	41.02	5.47	357.170	353.850	353.550	351.060	2.490	8.62	8.21	1.9380	0.0	24.0
02.10.25	51.20	45.03	6.17	389.540	388.300	384.790	384.630	0.160	8.43	7.96	2.3740	0.0	24.0
03.10.25	52.60	46.26	6.34	391.260	390.600	386.280	386.700	-0.420	8.42	7.95	2.4450	0.0	24.0
04.10.25	53.20	46.72	6.48	391.010	391.140	385.910	387.150	-1.240	8.42	7.95	2.5010	0.0	24.0
05.10.25	49.70	43.98	5.72	362.140	362.600	357.960	359.320	-1.360	8.26	7.85	2.0490	0.0	24.0
06.10.25	44.62	39.83	4.79	335.680	336.240	332.570	333.750	-1.180	8.07	7.71	1.5920	0.0	24.0
07.10.25	43.72	39.19	4.53	346.510	347.610	343.400	345.080	-1.680	8.11	7.74	1.5530	0.0	24.0
08.10.25	45.35	40.67	4.68	358.810	360.400	355.370	357.630	-2.260	8.18	7.77	1.6610	0.0	24.0
09.10.25	44.71	40.17	4.54	358.150	359.700	354.830	357.030	-2.200	8.19	7.78	1.6100	0.0	24.0
10.10.25	44.78	40.27	4.51	358.240	359.820	354.890	357.130	-2.240	8.11	7.71	1.6030	0.0	24.0
11.10.25	44.80	40.25	4.55	358.010	359.550	354.650	356.900	-2.250	8.18	7.78	1.6100	0.0	24.0
12.10.25	44.46	39.88	4.58	357.950	359.380	354.710	356.680	-1.970	8.18	7.78	1.6230	0.0	24.0
13.10.25	44.27	39.70	4.57	357.840	359.220	354.610	356.580	-1.970	8.17	7.77	1.6180	0.0	24.0
14.10.25	44.86	40.10	4.76	352.130	353.440	348.850	350.800	-1.950	8.10	7.71	1.6610	0.0	24.0
15.10.25	45.59	40.56	5.03	350.610	350.800	347.220	348.130	-0.910	8.02	7.64	1.7430	0.0	24.0
16.10.25	45.01	40.11	4.90	351.100	350.900	347.760	348.260	-0.500	8.67	8.28	1.7000	0.0	24.0
17.10.25	44.70	39.81	4.89	349.020	349.350	345.770	346.760	-0.990	8.94	8.56	1.6910	0.0	24.0
18.10.25	47.57	41.79	5.78	347.520	348.220	343.870	345.420	-1.550	8.71	8.34	1.9850	0.0	24.0
19.10.25	50.10	43.84	6.26	346.110	347.160	342.100	344.070	-1.970	8.70	8.33	2.1370	0.0	24.0
20.10.25	51.28	44.71	6.57	358.010	359.030	353.650	355.690	-2.040	8.75	8.37	2.3220	0.0	24.0
Итого	---	---	---	8510.3	8532.9	8425.85	8466.21	-40.360	---	---	42.9140	0.0	768.0
Среднее	40.96	37.38	3.57	---	---	---	---	---	6.82	7.03	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Мг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	77487.420	77068.220	76418.610	76278.840	570.5220	139.770	2212.0	7065.0
20.10.25 24:00	85997.749	85601.180	84844.460	84745.049	613.4360	100099.410	2212.0	7833.0
Итого за период	8510.328	8532.959	8425.850	8466.209	42.9140	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Новоселов, 18
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00166275

БД=1, ТВ1, СИ=3, КТ3=1, КСН=0хДФ93

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	21.88	20.60	1.28	0.000	0.000	0.000	0.000	0.000	5.60	5.40	0.0000	0.0	24.0
20.09.25	21.85	20.49	1.36	0.000	0.000	0.000	0.000	0.000	5.60	5.40	0.0000	0.0	24.0
21.09.25	21.80	20.48	1.32	0.000	0.000	0.000	0.000	0.000	5.60	5.40	0.0000	0.0	24.0
22.09.25	21.94	22.31	-0.37	0.000	0.750	0.000	0.750	-0.750	5.60	5.40	0.0000	0.0	24.0
23.09.25	21.05	21.07	-0.02	0.000	0.000	0.000	0.000	0.000	5.60	5.40	0.0000	0.0	24.0
24.09.25	21.23	21.16	0.07	0.000	0.000	0.000	0.000	0.000	5.60	5.40	0.0000	0.0	24.0
25.09.25	38.56	34.80	3.76	116.120	116.280	115.300	115.640	-0.340	5.60	5.40	0.4450	0.0	24.0
26.09.25	38.22	34.72	3.50	308.780	313.940	306.690	312.150	-5.460	5.60	5.40	1.0720	0.0	24.0
27.09.25	40.31	36.14	4.17	294.070	300.000	291.820	298.140	-6.320	5.60	5.40	1.2140	0.0	24.0
28.09.25	40.21	35.90	4.31	287.690	294.340	285.470	292.580	-7.110	5.60	5.40	1.2280	0.0	24.0
29.09.25	47.36	39.04	8.32	293.470	299.560	290.250	297.370	-7.120	5.60	5.40	2.3930	0.0	24.0
30.09.25	43.39	37.35	6.04	435.430	442.890	431.560	439.980	-8.420	5.60	5.40	2.6020	0.0	24.0
01.10.25	46.61	39.69	6.92	460.910	468.030	456.190	464.520	-8.330	5.60	5.40	3.1510	0.0	24.0
02.10.25	51.37	43.66	7.71	501.950	508.590	495.750	504.020	-8.270	5.60	5.40	3.8200	0.0	24.0
03.10.25	52.78	44.85	7.93	506.130	512.530	499.530	507.660	-8.130	5.60	5.40	3.9560	0.0	24.0
04.10.25	53.38	45.27	8.11	507.170	513.470	500.430	508.520	-8.090	5.60	5.40	4.0550	0.0	24.0
05.10.25	49.91	42.77	7.14	471.860	477.780	466.300	473.660	-7.360	5.60	5.40	3.3230	0.0	24.0
06.10.25	44.82	38.89	5.93	439.060	444.490	434.900	441.300	-6.400	5.60	5.40	2.5750	0.0	24.0
07.10.25	43.89	38.28	5.61	453.380	458.410	449.270	455.250	-5.980	5.60	5.40	2.5190	0.0	24.0
08.10.25	45.54	39.73	5.81	469.990	474.460	465.420	470.940	-5.520	5.60	5.40	2.6970	0.0	24.0
09.10.25	44.90	39.30	5.60	468.800	472.970	464.340	469.520	-5.180	5.60	5.40	2.5950	0.0	24.0
10.10.25	44.97	39.40	5.57	469.270	473.240	464.810	469.780	-4.970	5.60	5.40	2.5830	0.0	24.0
11.10.25	44.99	39.36	5.63	469.360	473.230	464.880	469.760	-4.880	5.60	5.40	2.6120	0.0	24.0
12.10.25	44.66	38.97	5.69	469.510	473.310	465.090	469.870	-4.780	5.60	5.40	2.6400	0.0	24.0
13.10.25	44.46	38.82	5.64	469.290	473.000	464.900	469.640	-4.740	5.60	5.40	2.6180	0.0	24.0
14.10.25	45.04	39.22	5.82	461.760	465.370	457.330	462.000	-4.670	5.60	5.40	2.6590	0.0	24.0
15.10.25	45.77	39.66	6.11	459.220	462.780	454.700	459.350	-4.650	5.60	5.40	2.7750	0.0	24.0
16.10.25	45.20	39.22	5.98	459.840	463.120	455.410	459.760	-4.350	5.60	5.40	2.7210	0.0	24.0
17.10.25	44.89	38.94	5.95	457.890	461.120	453.560	457.810	-4.250	5.60	5.40	2.6930	0.0	24.0
18.10.25	47.72	40.64	7.08	455.970	459.070	451.070	455.480	-4.410	5.60	5.40	3.1890	0.0	24.0
19.10.25	50.29	42.65	7.64	454.260	457.150	448.880	453.230	-4.350	5.60	5.40	3.4220	0.0	24.0
20.10.25	51.48	43.53	7.95	461.510	464.260	455.790	460.090	-4.300	5.60	5.40	3.6180	0.0	24.0
Итого	---	---	---	11102.6	11224.1	10989.64	11138.77	-149.130	---	---	69.1750	0.0	768.0
Среднее	41.26	36.15	5.11	---	---	---	---	---	5.60	5.40	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	100933.030	96691.230	99575.640	95743.220	863.0050	3832.420	215.0	9278.0
20.10.25 24:00	112035.720	107915.369	110565.280	106881.989	932.1800	103683.290	215.0	10046.0
Итого за период	11102.690	11224.139	10989.640	11138.769	69.1750	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Островского, 15
Потребитель: АО "Жилуправление"
Прибор: ТВ7-04.1 Заводской номер: 20127903

БД=1, ТВ1, СИ=7, КСН=0х7BAE

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	19.58	19.17	н/д	0.40	5.80	0.99	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
20.09.25	19.52	19.13	н/д	0.39	5.80	0.99	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
21.09.25	19.49	19.10	н/д	0.39	5.80	0.99	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
22.09.25	19.57	19.17	н/д	0.40	5.80	0.99	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
23.09.25	19.63	19.22	н/д	0.41	5.80	0.99	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
24.09.25	19.61	19.19	н/д	0.42	5.80	0.99	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
25.09.25	19.33	18.96	н/д	0.37	5.80	0.98	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
26.09.25	18.66	18.30	н/д	0.36	5.80	0.95	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
27.09.25	44.46	38.24	н/д	6.23	5.80	3.87	н/д	73.390	н/д	н/д	72.726	н/д	н/д	н/д	0.450	н/д	24	0
28.09.25	44.03	38.63	н/д	5.40	5.80	6.09	н/д	128.225	н/д	н/д	127.091	н/д	н/д	н/д	0.682	н/д	24	0
29.09.25	43.64	38.00	н/д	5.64	5.80	5.79	н/д	129.768	н/д	н/д	128.637	н/д	н/д	н/д	0.722	н/д	24	0
30.09.25	45.08	37.98	н/д	7.09	5.80	5.88	н/д	113.925	н/д	н/д	112.859	н/д	н/д	н/д	0.797	н/д	24	0
01.10.25	46.89	39.29	н/д	7.60	5.80	6.14	н/д	112.298	н/д	н/д	111.156	н/д	н/д	н/д	0.841	н/д	24	0
02.10.25	49.06	41.22	н/д	7.83	5.80	5.92	н/д	116.620	н/д	н/д	115.318	н/д	н/д	н/д	0.900	н/д	24	0
03.10.25	48.02	41.83	н/д	6.19	5.80	4.45	н/д	142.107	н/д	н/д	140.594	н/д	н/д	н/д	0.871	н/д	24	0
04.10.25	47.81	41.68	н/д	6.14	5.80	4.39	н/д	141.948	н/д	н/д	140.453	н/д	н/д	н/д	0.863	н/д	24	0
05.10.25	47.94	41.86	н/д	6.08	5.80	4.40	н/д	141.708	н/д	н/д	140.204	н/д	н/д	н/д	0.852	н/д	24	0
06.10.25	46.45	40.85	н/д	5.59	5.80	4.40	н/д	141.212	н/д	н/д	139.806	н/д	н/д	н/д	0.782	н/д	24	0
07.10.25	45.30	40.03	н/д	5.27	5.80	4.41	н/д	140.325	н/д	н/д	139.007	н/д	н/д	н/д	0.733	н/д	24	0
08.10.25	45.39	40.14	н/д	5.25	5.80	4.42	н/д	138.417	н/д	н/д	137.106	н/д	н/д	н/д	0.720	н/д	24	0
09.10.25	45.11	39.80	н/д	5.30	5.80	4.36	н/д	134.810	н/д	н/д	133.543	н/д	н/д	н/д	0.709	н/д	24	0
10.10.25	44.27	39.06	н/д	5.21	5.80	4.38	н/д	128.465	н/д	н/д	127.315	н/д	н/д	н/д	0.664	н/д	24	0
11.10.25	43.49	38.23	н/д	5.25	5.80	4.37	н/д	122.735	н/д	н/д	121.673	н/д	н/д	н/д	0.640	н/д	24	0
12.10.25	43.90	38.37	н/д	5.53	5.80	4.34	н/д	122.645	н/д	н/д	121.565	н/д	н/д	н/д	0.673	н/д	24	0
13.10.25	43.87	38.31	н/д	5.56	5.80	4.39	н/д	122.707	н/д	н/д	121.632	н/д	н/д	н/д	0.677	н/д	24	0
14.10.25	45.65	39.54	н/д	6.10	5.80	4.38	н/д	121.872	н/д	н/д	120.702	н/д	н/д	н/д	0.737	н/д	24	0
15.10.25	46.63	40.22	н/д	6.41	5.80	4.42	н/д	122.105	н/д	н/д	120.881	н/д	н/д	н/д	0.775	н/д	24	0
16.10.25	46.72	40.46	н/д	6.26	5.80	4.64	н/д	129.102	н/д	н/д	127.808	н/д	н/д	н/д	0.800	н/д	24	0
17.10.25	48.65	41.85	н/д	6.80	5.80	4.67	н/д	131.725	н/д	н/д	130.285	н/д	н/д	н/д	0.886	н/д	24	0
18.10.25	52.29	44.63	н/д	7.66	5.80	4.71	н/д	132.705	н/д	н/д	131.031	н/д	н/д	н/д	1.003	н/д	24	0
19.10.25	52.46	44.88	н/д	7.59	5.80	4.73	н/д	132.768	н/д	н/д	131.075	н/д	н/д	н/д	0.994	н/д	24	0
20.10.25	51.03	44.04	н/д	7.00	5.80	4.71	н/д	134.135	н/д	н/д	132.516	н/д	н/д	н/д	0.927	н/д	24	0
Итого	---	---	---	---	---	---	---	3055.717	---	---	3024.983	---	---	---	18.698	---	768	0
Среднее	46.67	40.48	---	6.19	5.80	3.82	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	0.005	0.000	0.000	0.005	0.000	0.000	0.000	-0.000	0.000	230	769
20.10.25 24:00	3055.723	0.000	0.000	3024.988	0.000	0.000	0.000	18.698	0.000	998	769
Итого за период	3055.718	0.000	0.000	3024.983	0.000	0.000	---	18.698	0.000	768	0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Островского, 19
 Потребитель: АО "Жилуправление"
 Прибор: Вzlёт ТСРВ-024 Заводской номер: 801959
 Тип системы: А32-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	20.16	24.59	-4.43	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	23.817
20.09.25	20.21	24.54	-4.33	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	23.800
21.09.25	20.25	24.61	-4.36	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	23.817
22.09.25	20.28	24.63	-4.35	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	23.767
23.09.25	20.56	25.00	-4.44	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	23.683
24.09.25	20.54	24.65	-4.11	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	23.400
25.09.25	20.26	23.82	-3.56	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	23.167
26.09.25	21.41	24.08	-2.67	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	23.417
27.09.25	43.47	36.80	6.67	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	23.900
28.09.25	44.01	37.25	6.76	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	24.000
29.09.25	43.72	37.09	6.63	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	24.000
30.09.25	43.76	36.39	7.37	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	24.000
01.10.25	45.73	37.17	8.56	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	24.000
02.10.25	48.64	38.97	9.67	10.72	10.72	0	0.590	0.549	10.78	10.87	-0.09	0.115	24.000
03.10.25	48.23	40.18	8.05	85.99	86.01	-0.02	0.590	0.549	86.44	87.17	-0.72	0.676	24.000
04.10.25	47.51	40.12	7.39	89.86	89.86	0	0.590	0.549	90.32	91.06	-0.75	0.663	24.000
05.10.25	47.62	40.23	7.39	89.73	89.73	0	0.590	0.549	90.16	90.95	-0.79	0.663	24.000
06.10.25	47.62	40.38	7.24	89.64	89.64	0	0.590	0.549	90.07	90.88	-0.81	0.649	24.000
07.10.25	44.95	38.59	6.36	89.24	89.24	0	0.590	0.549	89.56	90.41	-0.85	0.567	24.000
08.10.25	45.11	38.75	6.36	88.60	88.61	-0.00	0.590	0.549	88.92	89.78	-0.87	0.563	24.000
09.10.25	45.05	38.72	6.33	87.00	87.00	0	0.590	0.549	87.31	88.16	-0.85	0.550	24.000
10.10.25	44.47	38.22	6.25	84.15	84.15	0	0.590	0.549	84.41	85.26	-0.85	0.525	24.000
11.10.25	44.05	37.76	6.29	81.82	81.82	0	0.590	0.549	82.04	82.89	-0.85	0.514	24.000
12.10.25	43.13	37.07	6.06	81.65	81.65	0	0.590	0.549	81.84	82.70	-0.85	0.494	24.000
13.10.25	43.58	37.19	6.39	81.65	81.65	0	0.590	0.549	81.86	82.71	-0.85	0.521	24.000
14.10.25	44.12	37.62	6.50	81.48	81.48	0.00	0.590	0.549	81.70	82.56	-0.86	0.529	24.000
15.10.25	46.52	39.23	7.29	80.17	80.17	0.00	0.590	0.549	80.47	81.28	-0.81	0.584	24.000
16.10.25	46.50	39.44	7.06	85.98	85.99	-0.00	0.590	0.549	86.32	87.17	-0.86	0.605	24.000
17.10.25	46.33	39.41	6.92	87.64	87.68	-0.03	0.590	0.549	87.99	88.87	-0.88	0.605	23.833
18.10.25	51.66	42.96	8.70	89.46	89.46	0	0.590	0.549	89.98	90.85	-0.87	0.777	24.000
19.10.25	52.00	43.43	8.57	89.44	89.44	0.00	0.590	0.549	89.97	90.85	-0.88	0.766	24.000
20.10.25	51.82	43.47	8.35	89.10	89.10	0	0.590	0.549	89.62	90.52	-0.90	0.744	24.000
Итого	---	---	---	1563.33	1563.41	-0.07	---	---	1569.78	1584.95	-15.17	11.108	764.600
Среднее	39.79	35.39	4.40	---	---	---	0.590	0.549	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Островского, 21
Потребитель: АО "Жилуправление"
Прибор: ТВ7-04.1 Заводской номер: 22168615

БД=1, ТВ1, СИ=6, КТЗ=0, ФРТ=0, КСН=0х817А

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	16.38	н/д	н/д	н/д	1.41	2.11	н/д	0.000	0.000	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
20.09.25	16.24	н/д	н/д	н/д	1.41	2.02	н/д	0.000	0.000	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
21.09.25	16.33	н/д	н/д	н/д	1.42	2.08	н/д	0.000	0.000	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
22.09.25	16.47	н/д	н/д	н/д	1.42	2.15	н/д	0.000	0.000	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
23.09.25	16.66	н/д	н/д	н/д	1.43	2.18	н/д	0.000	0.000	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
24.09.25	16.82	н/д	н/д	н/д	1.43	2.13	н/д	0.000	0.000	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
25.09.25	16.68	н/д	н/д	н/д	1.41	2.24	н/д	0.000	0.000	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
26.09.25	21.16	н/д	н/д	н/д	1.44	2.44	н/д	17.385	14.715	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
27.09.25	16.28	н/д	н/д	н/д	0.53	1.83	н/д	0.000	0.000	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
28.09.25	16.38	н/д	н/д	н/д	0.53	1.83	н/д	0.000	0.000	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
29.09.25	16.08	н/д	н/д	н/д	0.53	1.69	н/д	0.000	0.000	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
30.09.25	34.22	н/д	н/д	н/д	3.60	4.29	н/д	101.535	100.295	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
01.10.25	46.66	н/д	н/д	н/д	6.18	6.54	н/д	168.235	165.765	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
02.10.25	48.97	н/д	н/д	н/д	5.97	6.25	н/д	164.760	162.905	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
03.10.25	47.55	41.83	н/д	5.72	4.55	4.80	н/д	189.585	187.975	н/д	117.892	117.155	н/д	0.736	0.674	н/д	15	9
04.10.25	47.59	41.88	н/д	5.71	4.47	4.73	н/д	190.870	188.855	н/д	188.868	187.355	н/д	1.512	1.077	н/д	24	0
05.10.25	47.72	42.12	н/д	5.59	4.48	3.46	н/д	190.090	188.740	н/д	188.091	187.203	н/д	0.888	1.055	н/д	24	0
06.10.25	46.23	41.09	н/д	5.14	4.49	1.31	н/д	189.395	188.045	н/д	187.524	186.568	н/д	0.955	0.976	н/д	24	0
07.10.25	45.09	40.23	н/д	4.85	4.49	4.12	н/д	188.230	186.850	н/д	186.472	185.485	н/д	0.987	0.905	н/д	24	0
08.10.25	45.18	40.34	н/д	4.83	4.50	4.65	н/д	185.475	184.285	н/д	183.727	182.928	н/д	0.799	0.887	н/д	24	0
09.10.25	44.89	39.99	н/д	4.90	4.42	4.57	н/д	182.065	181.150	н/д	180.376	179.852	н/д	0.525	0.882	н/д	24	0
10.10.25	44.06	39.37	н/д	4.69	4.41	4.52	н/д	177.795	177.070	н/д	176.209	175.843	н/д	0.365	0.824	н/д	24	0
11.10.25	43.27	38.71	н/д	4.56	4.37	4.45	н/д	176.160	175.690	н/д	174.650	174.522	н/д	0.128	0.795	н/д	24	0
12.10.25	43.69	38.86	н/д	4.83	4.35	4.42	н/д	175.920	175.505	н/д	174.376	174.321	н/д	0.055	0.841	н/д	24	0
13.10.25	43.65	38.81	н/д	4.84	4.40	4.46	н/д	175.915	175.510	н/д	174.376	174.332	н/д	0.044	0.843	н/д	24	0
14.10.25	45.38	40.09	н/д	5.29	4.39	4.43	н/д	174.855	174.165	н/д	173.195	172.906	н/д	0.289	0.915	н/д	24	0
15.10.25	46.40	41.02	н/д	5.39	4.42	4.45	н/д	179.150	178.565	н/д	177.369	177.206	н/д	0.163	0.954	н/д	24	0
16.10.25	46.51	41.38	н/д	5.14	4.66	4.66	н/д	195.115	194.425	н/д	193.168	192.921	н/д	0.248	0.991	н/д	24	0
17.10.25	48.43	42.75	н/д	5.68	4.70	4.70	н/д	199.495	198.430	н/д	197.330	196.778	н/д	0.552	1.120	н/д	24	0
18.10.25	52.08	45.58	н/д	6.50	4.74	4.73	н/д	200.930	199.695	н/д	198.413	197.781	н/д	0.632	1.289	н/д	24	0
19.10.25	52.25	45.86	н/д	6.39	4.76	4.74	н/д	200.945	199.800	н/д	198.399	197.864	н/д	0.535	1.268	н/д	24	0
20.10.25	50.84	44.93	н/д	5.91	4.75	4.72	н/д	200.830	200.025	н/д	198.427	198.156	н/д	0.272	1.172	н/д	24	0
Итого	---	---	---	---	---	---	---	3824.735	3798.460	---	3268.862	3259.176	---	9.685	17.468	---	423	345
Среднее	28.67	41.46	---	5.34	3.44	3.68	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	0.010	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	655	391
20.10.25 24:00	3824.745	3798.460	0.000	3268.861	3259.177	0.000	9.685	17.470	0.000	1078	736
Итого за период	3824.735	3798.460	0.000	3268.861	3259.177	0.000	---	17.470	0.000	423	345

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Островского, 35
 Потребитель: АО "Жилуправление"
 Прибор: Взлёт ТСРВ-026 Заводской номер: 903817
 Тип системы: А42-00 Система: 1

ТБ1

Дата	Q, Гкал	M1, т	M2, т	dM, т	V1, м3	V2, м3	dV, м3	P1, МПа	P2, МПа	T1, °C	T2, °C	dT, °C	Тнар, ч
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	0.000	0.000	6.504	6.504	0.000	6.511	-6.511	0.00	0.00	16.71	16.32	0.39	24.00
21.09.25	0.000	0.000	7.393	7.393	0.000	7.401	-7.401	0.00	0.00	16.62	16.29	0.33	24.00
22.09.25	0.000	0.000	7.377	7.377	0.000	7.386	-7.386	0.00	0.00	17.38	17.03	0.35	24.00
23.09.25	0.073	1.688	5.758	4.070	1.721	5.768	-4.047	0.00	0.29	22.88	20.43	2.45	24.00
24.09.25	0.000	0.000	4.779	4.779	0.000	4.785	-4.785	0.00	0.49	18.32	18.47	-54.77	24.00
25.09.25	0.000	0.000	4.736	4.736	0.000	4.741	-4.741	0.00	0.39	16.67	16.91	-0.24	24.00
26.09.25	0.000	0.000	4.699	4.699	0.000	4.703	-4.703	0.00	0.33	14.46	14.83	-0.37	24.00
27.09.25	0.000	0.000	4.695	4.695	0.000	4.699	-4.699	0.00	0.31	14.71	15.07	-0.37	24.00
28.09.25	0.000	0.000	4.672	4.672	0.000	4.675	-4.675	0.00	0.29	13.44	13.92	-0.49	24.00
29.09.25	1.441	139.358	144.436	5.078	142.112	146.478	-4.367	0.44	0.53	45.45	39.20	252.01	24.00
30.09.25	1.958	178.356	183.688	5.331	181.943	186.304	-4.361	0.62	0.61	65.59	54.62	10.97	24.00
01.10.25	2.264	209.342	215.413	6.071	213.505	218.457	-4.952	0.75	0.74	65.53	54.68	10.85	24.00
02.10.25	2.320	242.941	249.280	6.339	247.856	253.038	-5.181	0.76	0.74	66.31	56.67	9.64	24.00
03.10.25	2.451	283.959	290.792	6.834	289.883	295.479	-5.597	0.77	0.73	67.40	58.76	8.63	24.00
04.10.25	2.454	288.177	295.037	6.861	294.208	299.829	-5.620	0.77	0.73	67.53	59.01	8.51	24.00
05.10.25	2.338	287.127	293.968	6.841	292.963	298.638	-5.676	0.77	0.73	66.48	58.34	8.14	24.00
06.10.25	2.301	279.864	286.857	6.993	285.509	291.362	-5.853	0.76	0.73	66.20	57.97	8.22	24.00
07.10.25	2.275	263.752	270.712	6.960	269.167	274.994	-5.827	0.74	0.72	66.80	58.17	8.63	24.00
08.10.25	2.229	277.770	284.760	6.990	283.443	289.325	-5.882	0.72	0.70	66.62	58.58	8.03	24.00
09.10.25	2.279	290.288	297.339	7.051	296.258	302.172	-5.914	0.72	0.70	66.86	58.99	7.86	24.00
10.10.25	2.210	300.829	307.968	7.139	306.954	312.999	-6.045	0.72	0.70	66.51	59.16	7.34	24.00
11.10.25	2.140	298.497	305.598	7.101	304.504	310.552	-6.048	0.72	0.70	66.09	58.92	7.16	24.00
12.10.25	2.170	292.987	300.048	7.061	298.908	304.899	-5.991	0.72	0.69	66.23	58.82	7.40	24.00
13.10.25	2.258	291.722	298.790	7.068	297.800	303.739	-5.939	0.72	0.69	67.32	59.58	7.74	24.00
14.10.25	2.154	288.865	295.944	7.079	294.706	300.723	-6.017	0.72	0.69	66.25	58.78	7.46	24.00
15.10.25	2.215	279.854	286.857	7.003	285.592	291.495	-5.903	0.71	0.68	66.74	58.83	7.91	24.00
16.10.25	2.248	278.984	285.952	6.968	284.687	290.537	-5.850	0.72	0.69	66.65	58.58	8.06	24.00
17.10.25	2.229	274.365	281.333	6.968	279.948	285.810	-5.862	0.72	0.70	66.49	58.36	8.12	24.00
18.10.25	2.246	269.925	276.864	6.939	275.469	281.290	-5.821	0.70	0.68	66.80	58.48	8.32	24.00
19.10.25	2.317	273.969	280.949	6.980	279.649	285.469	-5.820	0.72	0.70	67.16	58.69	8.46	24.00
20.10.25	2.284	279.237	286.212	6.974	284.934	290.771	-5.836	0.72	0.70	66.56	58.37	8.18	24.00
Итого	48.855	5871.854	6069.410	197.556	5991.718	6165.027	-173.309	---	---	---	---	---	744.00
Среднее	---	---	---	---	---	---	---	0.51	0.56	51.44	45.51	12.09	---

Показания интеграторов

Дата	Q, Гкал	Мтс, т
18.09.25 24:00	н/д	н/д
20.10.25 24:00	н/д	н/д
Итого за период	н/д	---

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Островского, 37
 Потребитель: АО "Жилуправление"
 Прибор: Взлёт ТСРВ-024М Заводской номер: 1303571
 Тип системы: А42-00 Система: 1

ТБ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	19.62	20.67	-1.05	0.00	0.00	0.00	0.9	0.1	0.00	0.00	0.00	0.000	0.00
20.09.25	19.65	20.70	-1.05	0.00	0.00	0.00	0.9	0.1	0.00	0.00	0.00	0.000	0.00
21.09.25	19.74	20.81	-1.07	0.00	0.00	0.00	0.9	0.1	0.00	0.00	0.00	0.000	0.00
22.09.25	19.90	20.95	-1.05	0.00	0.00	0.00	0.9	0.1	0.00	0.00	0.00	0.000	0.00
23.09.25	20.25	21.29	-1.04	0.00	0.00	0.00	0.9	0.1	0.00	0.00	0.00	0.000	0.00
24.09.25	20.34	21.22	-0.88	0.00	0.00	0.00	0.9	0.1	0.00	0.00	0.00	0.000	0.00
25.09.25	30.91	30.05	0.86	76.23	75.15	1.08	0.9	0.2	77.74	76.37	1.37	0.552	5.55
26.09.25	66.92	59.98	6.94	279.00	278.59	0.41	0.9	0.7	284.78	283.32	1.46	1.942	24.00
27.09.25	64.50	56.84	7.66	232.50	232.15	0.35	0.9	0.7	236.94	235.66	1.28	1.782	23.97
28.09.25	67.24	58.89	8.35	237.92	237.64	0.28	0.9	0.7	242.82	241.47	1.35	1.985	23.93
29.09.25	66.15	57.49	8.66	228.38	228.18	0.20	0.9	0.7	232.96	231.71	1.25	1.962	23.73
30.09.25	66.49	55.91	10.58	123.72	123.54	0.18	0.9	0.7	126.31	125.42	0.89	1.315	20.93
01.10.25	65.31	54.71	10.60	1.00	0.00	1.00	0.9	0.7	1.02	0.00	1.02	0.011	23.98
02.10.25	66.39	56.62	9.77	2.66	0.00	2.65	0.9	0.8	2.71	0.00	2.71	0.026	24.00
03.10.25	67.46	58.39	9.07	3.36	0.01	3.34	0.9	0.8	3.43	0.01	3.41	0.031	23.98
04.10.25	67.76	58.84	8.92	4.49	0.55	3.94	0.9	0.7	4.58	0.56	4.03	0.040	24.00
05.10.25	66.78	58.14	8.64	4.10	1.21	2.88	0.9	0.7	4.18	1.23	2.95	0.036	23.98
06.10.25	66.35	57.77	8.58	122.03	121.18	0.85	0.9	0.7	124.48	123.06	1.42	1.048	23.90
07.10.25	66.99	57.67	9.32	213.54	214.85	-1.31	0.9	0.7	217.91	218.17	-0.27	1.981	23.93
08.10.25	66.99	58.23	8.76	228.98	230.50	-1.52	0.9	0.7	233.67	234.15	-0.47	2.003	23.97
09.10.25	67.04	58.73	8.31	243.72	245.43	-1.71	0.9	0.7	248.73	249.38	-0.64	2.027	23.98
10.10.25	66.76	59.00	7.76	256.62	258.50	-1.88	0.9	0.7	261.84	262.68	-0.84	1.990	23.95
11.10.25	66.40	58.70	7.70	256.37	258.32	-1.95	0.9	0.7	261.53	262.46	-0.93	1.971	23.78
12.10.25	66.40	58.50	7.90	251.90	253.82	-1.92	0.9	0.7	256.99	257.88	-0.88	1.997	24.00
13.10.25	67.47	59.23	8.24	249.14	251.15	-2.01	0.9	0.7	254.32	255.26	-0.93	2.053	23.97
14.10.25	66.53	58.52	8.01	250.08	252.10	-2.02	0.9	0.7	255.14	256.12	-0.98	2.004	23.95
15.10.25	66.91	58.42	8.49	240.76	242.73	-1.97	0.9	0.7	245.70	246.60	-0.91	2.050	24.00
16.10.25	66.90	58.25	8.65	239.46	241.42	-1.96	0.9	0.7	244.35	245.23	-0.88	2.071	23.97
17.10.25	66.69	57.97	8.72	235.99	237.91	-1.92	0.9	0.7	240.78	241.63	-0.85	2.060	23.97
18.10.25	66.94	57.95	8.99	231.77	233.63	-1.86	0.9	0.7	236.53	237.30	-0.77	2.091	24.00
19.10.25	67.44	58.40	9.04	233.50	235.33	-1.84	0.9	0.7	238.33	239.06	-0.73	2.105	23.93
20.10.25	66.83	58.06	8.77	237.03	238.87	-1.85	0.9	0.7	241.86	242.62	-0.76	2.067	23.68
Итого	---	---	---	4684.22	4692.77	-8.55	---	---	4779.64	4767.36	12.28	39.199	601.05
Среднее	56.81	50.22	6.60	---	---	---	0.9	0.6	---	---	---	---	---

Показания интеграторов

Дата	Мтс	Q, (Гкал)
18.09.25 24:00	-645.50	1415.558
20.10.25 24:00	-654.00	1454.757
Итого за период	---	39.199

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Островского, 39
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00164489

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0х3460

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	19.60	18.26	1.34	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
21.09.25	19.47	18.16	1.31	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
22.09.25	19.94	18.60	1.34	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
23.09.25	20.09	18.74	1.35	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
24.09.25	20.19	18.84	1.35	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
25.09.25	19.75	18.21	1.54	0.480	0.960	0.480	0.960	-0.480	3.03	2.89	0.0010	0.0	24.0
26.09.25	62.89	39.86	23.03	20.700	22.720	20.330	22.560	-2.230	3.57	3.36	0.4560	0.0	24.0
27.09.25	65.05	45.16	19.89	65.520	67.370	64.270	66.730	-2.460	7.41	4.26	1.2400	0.0	24.0
28.09.25	66.77	46.70	20.07	160.380	161.470	157.180	159.800	-2.620	8.03	7.74	3.1550	0.0	24.0
29.09.25	65.93	44.72	21.21	150.710	151.890	147.750	150.430	-2.680	8.02	7.77	3.1320	0.0	24.0
30.09.25	65.77	41.45	24.32	105.340	105.130	103.310	104.280	-0.970	7.94	7.80	2.5080	0.0	24.0
01.10.25	65.42	41.39	24.03	122.140	121.590	119.770	120.660	-0.890	8.46	8.33	2.8720	0.0	24.0
02.10.25	66.11	43.38	22.73	130.040	131.430	127.480	130.260	-2.780	8.19	8.02	2.8870	0.0	24.0
03.10.25	67.32	45.63	21.69	149.110	148.600	146.120	147.150	-1.030	8.59	8.36	3.1620	0.0	24.0
04.10.25	67.40	45.82	21.58	151.720	150.580	148.620	149.130	-0.510	8.57	8.33	3.2030	0.0	24.0
05.10.25	66.36	45.52	20.84	151.120	149.850	148.140	148.410	-0.270	8.58	8.34	3.0840	0.0	24.0
06.10.25	65.92	45.48	20.44	101.570	100.500	99.570	99.550	0.020	8.55	8.31	2.0400	0.0	24.0
07.10.25	66.82	54.90	11.92	333.200	334.010	326.480	329.370	-2.890	8.33	8.19	3.8890	0.0	24.0
08.10.25	67.16	53.44	13.72	172.400	172.630	168.910	170.330	-1.420	8.11	7.90	2.3230	0.0	24.0
09.10.25	66.61	38.57	28.04	53.730	53.000	52.650	52.600	0.050	8.13	7.85	1.4760	0.0	24.0
10.10.25	66.20	36.37	29.83	47.890	47.800	46.940	47.530	-0.590	8.17	7.86	1.3970	0.0	24.0
11.10.25	65.84	36.85	28.99	50.290	50.170	49.320	49.850	-0.530	8.18	7.87	1.4310	0.0	24.0
12.10.25	66.00	40.76	25.24	81.040	80.550	79.460	79.910	-0.450	8.11	7.82	2.0030	0.0	24.0
13.10.25	67.06	40.31	26.75	72.160	71.860	70.700	71.280	-0.580	8.10	7.81	1.8890	0.0	24.0
14.10.25	66.00	37.92	28.08	58.880	58.400	57.700	58.000	-0.300	8.09	7.80	1.6170	0.0	24.0
15.10.25	66.57	41.01	25.56	81.200	81.100	79.570	80.460	-0.890	8.00	7.74	2.0320	0.0	24.0
16.10.25	66.52	42.96	23.56	99.740	99.440	97.750	98.590	-0.840	8.10	7.85	2.3000	0.0	24.0
17.10.25	66.32	42.39	23.93	97.650	96.790	95.710	95.980	-0.270	8.15	7.90	2.2860	0.0	24.0
18.10.25	66.67	42.47	24.20	94.800	94.180	92.890	93.380	-0.490	7.95	7.72	2.2460	0.0	24.0
19.10.25	66.97	40.78	26.19	79.650	79.500	78.040	78.870	-0.830	8.12	7.88	2.0410	0.0	24.0
20.10.25	66.18	40.83	25.35	82.560	81.940	80.930	81.290	-0.360	8.16	7.91	2.0510	0.0	24.0
Итого	---	---	---	2714.0	2713.4	2660.07	2687.36	-27.290	---	---	56.7210	0.0	744.0
Среднее	57.25	38.24	19.01	---	---	---	---	---	7.54	7.21	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	0	0	0	0	0	0	0	0
20.10.25 24:00	45428.880	44951.060	44474.600	44388.540	758.1550	86.060	188.0	10067.0
Итого за период	45428.880	44951.060	44474.600	44388.540	758.1550	---	188.0	10067.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Островского, 41
 Потребитель: АО "Жилуправление"
 Прибор: Взлёт ТСРВ-024М Заводской номер: 902767
 Тип системы: А42-00 Система: 1

ТБ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.0	0.00	0.00	0.00	0.000	0.00
20.09.25	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.0	0.00	0.00	0.00	0.000	0.00
21.09.25	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.0	0.00	0.00	0.00	0.000	0.00
22.09.25	15.96	15.77	0.19	0.00	0.00	0.00	0.1	0.0	0.00	0.00	0.00	0	11.42
23.09.25	16.13	16.01	0.12	0.00	0.00	0.00	0.1	0.0	0.00	0.00	0.00	0.000	24.00
24.09.25	18.51	18.33	0.18	0.00	0.00	0.00	0.1	0.0	0.00	0.00	0.00	0.000	24.00
25.09.25	30.26	27.29	2.97	72.07	74.05	-1.98	0.3	0.0	73.48	75.08	-1.60	0.814	24.00
26.09.25	66.17	54.63	11.54	293.32	297.18	-3.86	0.7	0.0	299.28	301.48	-2.20	3.412	24.00
27.09.25	63.58	50.66	12.92	261.59	265.23	-3.65	0.7	0.0	266.48	268.53	-2.04	3.410	24.00
28.09.25	66.24	51.91	14.33	257.48	261.73	-4.25	0.7	0.0	262.69	265.15	-2.46	3.718	24.00
29.09.25	65.29	51.31	13.98	258.55	262.91	-4.36	0.7	0.0	263.64	266.26	-2.62	3.635	24.00
30.09.25	65.32	50.29	15.03	231.53	236.16	-4.63	0.7	0.0	236.11	239.06	-2.96	3.514	24.00
01.10.25	64.39	49.45	14.94	227.94	232.34	-4.41	0.7	0.0	232.33	235.12	-2.79	3.434	24.00
02.10.25	65.61	51.59	14.02	249.73	254.63	-4.91	0.5	0.0	254.71	257.94	-3.24	3.514	24.00
03.10.25	66.61	52.37	14.24	253.15	257.20	-4.04	0.6	0.0	258.34	260.61	-2.27	3.631	24.00
04.10.25	66.99	52.83	14.16	258.08	263.17	-5.09	0.7	0.0	263.42	266.72	-3.30	3.684	24.00
05.10.25	65.98	52.29	13.69	255.85	260.25	-4.40	0.7	0.0	260.98	263.69	-2.71	3.536	24.00
06.10.25	65.43	51.80	13.63	248.13	252.21	-4.08	0.7	0.0	253.04	255.50	-2.46	3.420	24.00
07.10.25	65.63	51.62	14.01	233.59	237.90	-4.31	0.7	0.0	238.25	240.99	-2.75	3.310	24.00
08.10.25	66.05	52.82	13.23	252.81	256.73	-3.92	0.7	0.0	257.90	260.19	-2.29	3.370	24.00
09.10.25	66.27	52.68	13.59	248.60	252.22	-3.62	0.7	0.0	253.63	255.59	-1.96	3.406	24.00
10.10.25	65.92	52.99	12.93	257.81	260.80	-2.98	0.7	0.0	262.98	264.33	-1.35	3.365	24.00
11.10.25	65.58	52.74	12.84	256.79	259.58	-2.79	0.7	0.0	261.89	263.06	-1.17	3.332	24.00
12.10.25	65.58	52.36	13.22	254.26	257.21	-2.96	0.7	0.0	259.31	260.62	-1.31	3.390	24.00
13.10.25	66.33	52.69	13.64	250.67	253.61	-2.94	0.7	0.0	255.75	257.00	-1.25	3.447	24.00
14.10.25	64.99	52.03	12.96	249.31	252.31	-3.00	0.7	0.0	254.18	255.61	-1.44	3.261	24.00
15.10.25	65.30	51.56	13.74	240.25	243.62	-3.37	0.7	0.0	244.98	246.76	-1.78	3.330	24.00
16.10.25	65.26	51.29	13.97	249.66	252.76	-3.11	0.7	0.0	254.57	255.99	-1.42	3.511	24.00
17.10.25	65.43	50.95	14.48	237.65	240.69	-3.04	0.7	0.0	242.35	243.71	-1.37	3.472	24.00
18.10.25	65.88	50.81	15.07	231.76	234.88	-3.12	0.7	0.0	236.40	237.82	-1.42	3.520	24.00
19.10.25	66.27	51.21	15.06	232.76	235.83	-3.08	0.7	0.0	237.46	238.82	-1.36	3.534	24.00
20.10.25	65.69	51.09	14.60	237.09	240.09	-3.00	0.7	0.0	241.81	243.12	-1.31	3.488	24.00
Итого	---	---	---	6300.44	6395.30	-94.86	---	---	6425.96	6478.77	-52.81	87.457	683.42
Среднее	53.83	42.92	10.91	---	---	---	0.5	0.0	---	---	---	---	---

Показания интеграторов

Дата	Мтс	Q, (Гкал)
18.09.25 24:00	0.00	0.000
20.10.25 24:00	58525.75	3201.770
Итого за период	---	3201.770

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Островского, 42
Потребитель: АО "Жилуправление"
Прибор: ТВ7-04.1 Заводской номер: 23192557

БД=1, ТВ1, СИ=7, КСН=0хСАFD

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	19.99	19.47	н/д	0.52	0.00	2.10	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
21.09.25	20.07	19.53	н/д	0.54	0.00	2.10	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
22.09.25	20.32	19.82	н/д	0.50	0.00	2.10	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
23.09.25	20.79	20.14	н/д	0.64	0.00	2.10	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
24.09.25	21.25	20.39	н/д	0.86	0.00	2.09	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
25.09.25	21.01	20.20	н/д	0.81	0.00	2.09	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
26.09.25	63.66	52.34	н/д	11.32	0.05	2.18	н/д	76.573	н/д	н/д	75.135	н/д	н/д	н/д	0.847	н/д	24	0
27.09.25	64.61	53.87	н/д	10.74	0.19	2.24	н/д	108.808	н/д	н/д	106.714	н/д	н/д	н/д	1.143	н/д	24	0
28.09.25	66.72	55.63	н/д	11.09	0.24	2.24	н/д	107.760	н/д	н/д	105.562	н/д	н/д	н/д	1.168	н/д	24	0
29.09.25	66.03	55.04	н/д	10.99	0.23	2.22	н/д	106.455	н/д	н/д	104.321	н/д	н/д	н/д	1.143	н/д	24	0
30.09.25	65.06	53.30	н/д	11.76	0.23	2.21	н/д	91.792	н/д	н/д	90.003	н/д	н/д	н/д	1.055	н/д	24	0
01.10.25	65.67	53.90	н/д	11.77	0.24	2.21	н/д	93.570	н/д	н/д	91.715	н/д	н/д	н/д	1.076	н/д	24	0
02.10.25	66.18	54.82	н/д	11.35	0.25	2.21	н/д	98.720	н/д	н/д	96.738	н/д	н/д	н/д	1.095	н/д	24	0
03.10.25	67.45	56.02	н/д	11.43	0.27	2.20	н/д	101.868	н/д	н/д	99.753	н/д	н/д	н/д	1.137	н/д	24	0
04.10.25	67.33	56.13	н/д	11.20	0.27	2.20	н/д	102.952	н/д	н/д	100.820	н/д	н/д	н/д	1.126	н/д	24	0
05.10.25	66.32	55.56	н/д	10.76	0.27	2.20	н/д	102.505	н/д	н/д	100.436	н/д	н/д	н/д	1.078	н/д	24	0
06.10.25	66.11	55.10	н/д	11.02	0.27	2.19	н/д	97.957	н/д	н/д	95.991	н/д	н/д	н/д	1.054	н/д	24	0
07.10.25	66.88	55.72	н/д	11.16	0.28	2.19	н/д	97.747	н/д	н/д	95.744	н/д	н/д	н/д	1.066	н/д	24	0
08.10.25	66.44	55.77	н/д	10.67	0.29	2.18	н/д	99.067	н/д	н/д	97.062	н/д	н/д	н/д	1.033	н/д	24	0
09.10.25	66.78	56.17	н/д	10.61	0.30	2.18	н/д	100.757	н/д	н/д	98.702	н/д	н/д	н/д	1.045	н/д	24	0
10.10.25	66.47	56.14	н/д	10.33	0.30	2.18	н/д	103.073	н/д	н/д	100.986	н/д	н/д	н/д	1.040	н/д	24	0
11.10.25	66.03	55.86	н/д	10.17	0.30	2.18	н/д	102.482	н/д	н/д	100.434	н/д	н/д	н/д	1.018	н/д	24	0
12.10.25	66.19	55.78	н/д	10.41	0.31	2.17	н/д	100.925	н/д	н/д	98.896	н/д	н/д	н/д	1.027	н/д	24	0
13.10.25	67.33	56.61	н/д	10.73	0.32	2.17	н/д	101.018	н/д	н/д	98.925	н/д	н/д	н/д	1.058	н/д	24	0
14.10.25	66.19	55.69	н/д	10.51	0.30	2.16	н/д	99.120	н/д	н/д	97.126	н/д	н/д	н/д	1.017	н/д	24	0
15.10.25	66.62	55.62	н/д	11.00	0.30	2.14	н/д	96.800	н/д	н/д	94.830	н/д	н/д	н/д	1.040	н/д	24	0
16.10.25	66.58	55.41	н/д	11.16	0.30	2.13	н/д	96.825	н/д	н/д	94.862	н/д	н/д	н/д	1.056	н/д	24	0
17.10.25	66.45	55.22	н/д	11.23	0.30	2.13	н/д	95.665	н/д	н/д	93.728	н/д	н/д	н/д	1.050	н/д	24	0
18.10.25	66.75	55.26	н/д	11.48	0.30	2.12	н/д	93.817	н/д	н/д	91.903	н/д	н/д	н/д	1.052	н/д	24	0
19.10.25	67.14	55.64	н/д	11.49	0.30	2.11	н/д	94.120	н/д	н/д	92.183	н/д	н/д	н/д	1.057	н/д	24	0
20.10.25	66.58	55.44	н/д	11.14	0.29	2.10	н/д	96.835	н/д	н/д	94.870	н/д	н/д	н/д	1.054	н/д	24	0
Итого	---	---	---	---	---	---	---	2467.211	---	---	2417.439	---	---	---	26.535	---	744	0
Среднее	66.33	55.32	---	11.01	0.22	2.16	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
20.10.25 24:00	24837.655	0.000	0.000	24313.266	0.000	0.000	0.000	283.345	0.000	13527	3070
Итого за период	н/д	н/д	н/д	н/д	н/д	н/д	---	н/д	н/д	н/д	н/д

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Островского, 45
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00179174

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0х1CFD

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	15.21	15.19	0.02	0.000	0.000	0.000	0.000	0.000	2.90	2.34	0.0000	0.0	24.0
20.09.25	15.24	15.21	0.03	0.000	0.000	0.000	0.000	0.000	2.92	2.31	0.0000	0.0	24.0
21.09.25	15.20	15.14	0.06	0.000	0.000	0.000	0.000	0.000	2.84	2.37	0.0000	0.0	24.0
22.09.25	15.74	15.57	0.17	0.000	0.000	0.000	0.000	0.000	2.90	2.33	0.0000	0.0	24.0
23.09.25	15.89	15.71	0.18	0.000	0.000	0.000	0.000	0.000	2.87	2.27	0.0000	0.0	24.0
24.09.25	16.15	15.93	0.22	0.000	0.000	0.000	0.000	0.000	2.88	2.27	0.0000	0.0	24.0
25.09.25	66.15	59.39	6.76	148.300	147.720	145.360	145.300	0.060	3.72	2.63	0.9970	0.0	24.0
26.09.25	66.90	60.14	6.76	367.710	369.010	360.250	362.810	-2.560	5.49	3.48	2.4490	0.0	24.0
27.09.25	64.86	57.73	7.13	329.870	331.140	323.550	325.980	-2.430	5.36	3.20	2.3160	0.0	24.0
28.09.25	67.21	59.54	7.67	326.410	327.560	319.750	322.190	-2.440	5.04	3.49	2.4610	0.0	24.0
29.09.25	66.38	58.84	7.54	327.240	328.300	320.710	323.040	-2.330	5.27	3.33	2.4300	0.0	24.0
30.09.25	65.86	57.76	8.10	290.440	291.390	284.710	286.850	-2.140	5.21	3.49	2.3150	0.0	24.0
01.10.25	65.93	57.95	7.98	295.430	296.300	289.610	291.680	-2.070	5.15	3.62	2.3190	0.0	24.0
02.10.25	66.57	59.05	7.52	316.670	317.640	310.310	312.500	-2.190	5.00	3.37	2.3420	0.0	24.0
03.10.25	67.78	60.17	7.61	324.090	325.130	317.390	319.650	-2.260	5.02	3.46	2.4230	0.0	24.0
04.10.25	67.84	60.34	7.50	327.930	328.830	321.120	323.300	-2.180	4.97	3.28	2.4200	0.0	24.0
05.10.25	66.79	59.51	7.28	326.070	326.860	319.480	321.540	-2.060	4.80	3.30	2.3320	0.0	24.0
06.10.25	66.54	59.09	7.45	312.930	313.710	306.640	308.660	-2.020	4.78	3.40	2.2940	0.0	24.0
07.10.25	67.19	59.63	7.56	309.890	310.600	303.540	305.480	-1.940	4.79	3.42	2.3010	0.0	24.0
08.10.25	66.93	59.74	7.19	321.320	322.120	314.790	316.800	-2.010	4.45	3.64	2.2630	0.0	24.0
09.10.25	67.20	59.84	7.36	318.360	319.050	311.820	313.780	-1.960	4.35	3.39	2.3030	0.0	24.0
10.10.25	66.86	59.87	6.99	328.160	328.830	321.490	323.360	-1.870	4.44	3.75	2.2470	0.0	24.0
11.10.25	66.43	59.48	6.95	326.250	326.950	319.700	321.570	-1.870	4.40	3.38	2.2290	0.0	24.0
12.10.25	66.58	59.29	7.29	321.970	322.560	315.490	317.310	-1.820	4.51	3.65	2.3070	0.0	24.0
13.10.25	67.59	60.05	7.54	320.340	321.000	313.740	315.630	-1.890	4.29	3.29	2.3710	0.0	24.0
14.10.25	66.41	59.15	7.26	320.710	321.410	314.280	316.210	-1.930	4.47	3.59	2.2840	0.0	24.0
15.10.25	66.86	59.34	7.52	319.470	320.100	313.040	314.910	-1.870	4.55	3.71	2.3590	0.0	24.0
16.10.25	66.66	59.17	7.49	244.920	242.060	239.940	238.140	1.800	3.91	3.32	1.8600	0.0	24.0
17.10.25	66.87	59.39	7.48	312.850	313.530	306.520	308.410	-1.890	4.88	3.33	2.3020	0.0	24.0
18.10.25	67.20	59.40	7.80	308.960	309.600	302.630	304.570	-1.940	4.53	3.43	2.3640	0.0	24.0
19.10.25	67.55	59.73	7.82	307.520	308.040	301.170	303.000	-1.830	4.71	3.27	2.3600	0.0	24.0
20.10.25	66.95	59.30	7.65	316.910	317.400	310.470	312.220	-1.750	4.81	3.41	2.3830	0.0	24.0
Итого	---	---	---	8070.7	8086.8	7907.50	7954.89	-47.390	---	---	59.0310	0.0	768.0
Среднее	57.17	51.11	6.05	---	---	---	---	---	4.38	3.20	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	35053.940	35265.050	34297.830	34757.880	471.6650	-460.050	1683.0	7614.0
20.10.25 24:00	43124.659	43351.890	42205.329	42712.770	530.6960	-507.440	1683.0	8382.0
Итого за период	8070.718	8086.839	7907.498	7954.889	59.0310	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Островского, 47
 Потребитель: АО "Жилуправление"
 Прибор: Взлёт ТСРВ-024М Заводской номер: 1600628
 Тип системы: А42-00 Система: 1

ТБ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	15.19	14.95	0.24	0.00	0.00	0.00	0.0	0.0	0.00	0.00	0.00	0.000	0.00
20.09.25	15.21	14.98	0.23	0.00	0.00	0.00	0.0	0.0	0.00	0.00	0.00	0.000	0.00
21.09.25	15.21	14.96	0.25	0.00	0.00	0.00	0.0	0.0	0.00	0.00	0.00	0.000	0.00
22.09.25	15.70	15.37	0.33	0.00	0.00	0.00	0.0	0.0	0.00	0.00	0.00	0.000	0.00
23.09.25	15.89	15.60	0.29	0.00	0.00	0.00	0.0	0.0	0.00	0.00	0.00	0.000	0.00
24.09.25	16.45	17.17	-0.72	0.00	0.00	0.00	0.0	0.0	0.00	0.00	0.00	0.000	0.00
25.09.25	26.14	25.67	0.47	91.91	90.94	0.97	0.0	0.0	93.74	92.43	1.31	0.645	5.00
26.09.25	67.32	60.68	6.64	415.05	416.49	-1.44	0.0	0.0	423.91	423.83	0.08	2.755	24.00
27.09.25	64.32	57.41	6.91	360.68	362.14	-1.46	0.0	0.0	367.71	367.86	-0.15	2.489	24.00
28.09.25	67.15	59.55	7.60	354.31	355.93	-1.62	0.0	0.0	361.79	361.94	-0.16	2.691	24.00
29.09.25	66.17	58.81	7.36	357.02	358.57	-1.56	0.0	0.0	364.35	364.49	-0.14	2.619	24.00
30.09.25	66.56	58.48	8.08	321.12	322.57	-1.45	0.0	0.0	327.81	327.86	-0.05	2.598	24.00
01.10.25	65.10	57.12	7.98	309.69	311.17	-1.49	0.0	0.0	315.89	316.07	-0.18	2.471	24.00
02.10.25	66.58	59.15	7.43	343.55	345.36	-1.81	0.0	0.0	350.69	351.12	-0.43	2.551	24.00
03.10.25	67.45	59.93	7.52	347.42	348.91	-1.49	0.0	0.0	354.82	354.88	-0.06	2.611	24.00
04.10.25	68.00	60.43	7.57	357.24	359.06	-1.82	0.0	0.0	364.96	365.30	-0.34	2.703	24.00
05.10.25	66.99	59.67	7.32	353.99	356.07	-2.09	0.0	0.0	361.42	362.11	-0.69	2.589	24.00
06.10.25	66.53	59.21	7.32	344.37	346.46	-2.09	0.0	0.0	351.52	352.25	-0.74	2.520	24.00
07.10.25	66.84	59.36	7.48	332.95	335.12	-2.17	0.0	0.0	339.92	340.76	-0.83	2.488	24.00
08.10.25	63.85	58.26	5.59	278.78	280.06	-1.28	0.0	0.0	284.70	284.84	-0.14	2.109	21.50
09.10.25	67.18	59.99	7.19	338.70	340.14	-1.44	0.0	0.0	345.86	345.97	-0.11	2.433	24.00
10.10.25	66.64	59.73	6.91	343.51	344.78	-1.27	0.0	0.0	350.70	350.66	0.04	2.402	24.00
11.10.25	66.54	59.70	6.84	355.33	356.84	-1.52	0.0	0.0	362.70	362.90	-0.20	2.430	24.00
12.10.25	66.65	59.63	7.02	352.48	354.11	-1.63	0.0	0.0	359.82	360.11	-0.29	2.475	24.00
13.10.25	67.49	60.09	7.40	345.66	347.15	-1.49	0.0	0.0	353.03	353.12	-0.09	2.556	24.00
14.10.25	66.68	59.64	7.04	346.20	347.67	-1.47	0.0	0.0	353.42	353.56	-0.15	2.437	24.00
15.10.25	67.14	59.60	7.54	332.10	333.39	-1.29	0.0	0.0	339.11	339.04	0.07	2.503	24.00
16.10.25	67.02	59.56	7.46	340.32	341.55	-1.24	0.0	0.0	347.48	347.33	0.15	2.536	24.00
17.10.25	66.79	59.17	7.62	328.15	329.32	-1.17	0.0	0.0	335.01	334.82	0.19	2.500	24.00
18.10.25	67.15	59.24	7.91	320.03	321.15	-1.12	0.0	0.0	326.79	326.52	0.26	2.530	24.00
19.10.25	67.44	59.58	7.86	321.18	322.29	-1.11	0.0	0.0	328.02	327.74	0.28	2.524	24.00
20.10.25	66.84	59.19	7.65	326.61	327.72	-1.11	0.0	0.0	333.45	333.20	0.25	2.496	24.00
Итого	---	---	---	8618.35	8654.99	-36.64	---	---	8798.61	8800.73	-2.12	63.662	602.50
Среднее	55.82	50.06	5.76	---	---	---	0.0	0.0	---	---	---	---	---

Показания интеграторов

Дата	Мтс	Q, (Гкал)
18.09.25 24:00	16236.28	2627.848
20.10.25 24:00	16199.64	2691.510
Итого за период	---	63.662

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Островского, 49
 Потребитель: АО "Жилуправление"
 Прибор: Вzlёт ТСРВ-024 Заводской номер: 901036
 Тип системы: А42-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	14.15	13.67	0.48	0.00	0.00	0.00	0.000	0.017	0.00	0.00	0.00	0.000	0.000
20.09.25	14.30	13.84	0.46	0.00	0.00	0.00	0.000	0.017	0.00	0.00	0.00	0.000	0.000
21.09.25	14.40	13.89	0.51	0.00	0.00	0.00	0.000	0.017	0.00	0.00	0.00	0.000	0.000
22.09.25	14.95	14.51	0.44	0.00	0.00	0.00	0.000	0.017	0.00	0.00	0.00	0.000	0.083
23.09.25	15.20	14.73	0.47	0.00	0.00	0.00	0.000	0.017	0.00	0.00	0.00	0.000	0.000
24.09.25	15.56	15.02	0.54	0.00	0.00	0.00	0.000	0.017	0.00	0.00	0.00	0.000	0.083
25.09.25	23.98	21.56	2.42	87.75	0.00	87.74	0.000	0.134	89.44	0.00	89.44	0.051	0.600
26.09.25	67.19	58.34	8.85	491.53	0.00	491.52	0.000	0.697	501.96	0.00	501.96	0.000	0.000
27.09.25	64.15	54.91	9.24	417.76	0.00	417.75	0.000	0.685	425.84	0.00	425.84	0.027	0.167
28.09.25	66.99	56.99	10.00	417.36	0.00	417.35	0.000	0.682	426.11	0.00	426.11	0.003	0.017
29.09.25	66.02	56.40	9.62	424.33	0.00	424.32	0.000	0.682	432.99	0.00	432.99	0.020	0.117
30.09.25	66.46	56.15	10.31	392.53	0.00	392.53	0.000	0.689	400.67	0.00	400.67	3.511	21.283
01.10.25	64.90	55.05	9.85	392.41	0.00	392.40	0.000	0.729	400.21	0.00	400.21	2.450	16.167
02.10.25	66.47	57.38	9.09	441.69	0.00	441.68	0.000	0.742	450.82	0.00	450.82	0.000	0.000
03.10.25	67.30	58.20	9.10	442.00	0.00	442.00	0.000	0.742	451.35	0.00	451.35	0.000	0.000
04.10.25	67.88	58.79	9.09	452.31	0.00	452.31	0.000	0.740	462.03	0.00	462.03	0.000	0.000
05.10.25	66.87	58.12	8.75	447.69	0.00	447.69	0.000	0.740	457.05	0.00	457.05	0.000	0.000
06.10.25	66.40	57.63	8.77	436.39	0.00	436.38	0.000	0.738	445.39	0.00	445.39	0.000	0.000
07.10.25	66.69	57.66	9.03	418.99	0.00	418.98	0.000	0.725	427.70	0.00	427.70	0.000	0.000
08.10.25	67.10	58.38	8.72	432.55	0.00	432.55	0.000	0.695	441.65	0.00	441.65	0.000	0.000
09.10.25	67.04	58.43	8.61	444.75	0.00	444.74	0.000	0.694	454.09	0.00	454.09	0.000	0.000
10.10.25	66.68	58.78	7.90	472.24	0.00	472.23	0.000	0.699	482.06	0.00	482.06	0.000	0.000
11.10.25	66.44	58.61	7.83	473.81	0.00	473.80	0.000	0.701	483.59	0.00	483.59	0.004	0.033
12.10.25	66.52	58.47	8.05	471.58	0.00	471.58	0.000	0.696	481.35	0.00	481.35	0.000	0.000
13.10.25	67.35	59.04	8.31	461.61	0.00	461.60	0.000	0.691	471.39	0.00	471.39	0.000	0.000
14.10.25	66.57	58.58	7.99	463.18	0.00	463.17	0.000	0.694	472.78	0.00	472.78	0.000	0.000
15.10.25	67.02	58.53	8.49	448.37	0.00	448.36	0.000	0.684	457.78	0.00	457.78	0.000	0.000
16.10.25	66.91	58.23	8.68	448.51	0.00	448.51	0.000	0.689	457.90	0.00	457.90	0.000	0.000
17.10.25	66.67	57.80	8.87	443.87	0.00	443.87	0.000	0.704	453.10	0.00	453.10	0.000	0.000
18.10.25	67.02	57.90	9.12	435.10	0.00	435.09	0.000	0.673	444.23	0.00	444.23	0.000	0.000
19.10.25	67.31	58.30	9.01	435.68	0.00	435.67	0.000	0.695	444.89	0.00	444.89	0.000	0.000
20.10.25	66.72	58.01	8.71	441.70	0.00	441.70	0.000	0.699	450.90	0.00	450.90	0.002	0.017
Итого	---	---	---	11135.68	0.00	11135.67	---	---	11367.26	0.00	11367.26	6.068	38.567
Среднее	55.60	48.50	7.10	---	---	---	0.000	0.558	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Островского, 51
 Потребитель: АО "Жилуправление"
 Прибор: ТЭМ-106 Заводской номер: 3060470
 Формула: $Q = M1(h1 - h2)$
 Тип системы: Подача + расходомер

Система: 1

ТВ1

	ДУ, мм	Gmin, м3/ч	Gmax, м3/ч	Kv, л/имп	Fmax, КГц
1	80	9.78	163	8	---
2	80	9.6	160	10	---

Дата	Q, (Гкал)	M1, (т)	M2, (т)	dM, (т)	T1, (°C)	T2, (°C)	P1, (МПа)	P2, (МПа)	Время наработки, (ч)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-
28.09.25	-	-	-	-	-	-	-	-	-
29.09.25	-	-	-	-	-	-	-	-	-
30.09.25	-	-	-	-	-	-	-	-	-
01.10.25	-	-	-	-	-	-	-	-	-
02.10.25	3.133	193.71	191.16	2.5	66.383	50.233	0.6	0.5	24.00
03.10.25	3.096	191.55	189.17	2.4	66.628	50.488	0.6	0.5	24.00
04.10.25	3.128	188.48	186.38	2.1	67.655	51.084	0.6	0.5	24.00
05.10.25	3.101	196.08	193.70	2.4	66.631	50.839	0.6	0.5	24.00
06.10.25	2.995	193.22	190.85	2.4	66.045	50.568	0.6	0.5	24.00
07.10.25	2.851	174.35	172.25	2.1	66.150	49.833	0.6	0.5	24.00
08.10.25	2.979	187.68	185.36	2.3	66.862	51.051	0.6	0.5	24.00
09.10.25	2.959	192.16	189.73	2.4	66.524	51.151	0.6	0.5	24.00
10.10.25	3.006	204.62	201.98	2.6	66.340	51.671	0.6	0.5	24.00
11.10.25	2.992	206.40	203.73	2.7	66.370	51.898	0.6	0.5	24.00
12.10.25	2.983	204.85	202.22	2.6	66.077	51.539	0.6	0.5	24.00
13.10.25	3.066	200.19	197.82	2.4	66.710	51.420	0.6	0.5	24.00
14.10.25	3.009	202.48	200.06	2.4	66.490	51.650	0.6	0.5	24.00
15.10.25	3.030	194.69	192.44	2.3	66.664	51.125	0.6	0.5	24.00
16.10.25	3.063	194.73	192.51	2.2	66.477	50.768	0.6	0.5	24.00
17.10.25	3.049	192.24	190.03	2.2	66.309	50.472	0.6	0.5	24.00
18.10.25	3.072	188.19	186.05	2.1	66.571	50.270	0.6	0.5	24.00
19.10.25	3.084	188.81	186.61	2.2	66.845	50.532	0.6	0.5	24.00
20.10.25	3.046	190.51	188.14	2.4	66.438	50.473	0.6	0.5	24.00
Итого	57.64	3684.9	3640.2	44.7	---	---	---	---	456.00
Среднее	---	---	---	---	66.54	50.90	0.6	0.5	---

Показания интеграторов

Дата	Q, (Гкал)	M1, (т)	M2, (т)	Время наработки, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д
20.10.25 24:00	8502.3	626626.2	628691.6	66484.8
Итого за период	н/д	н/д	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Островского, 53
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BA715

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	15.79	0.00	16.91	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	15.74	0.00	16.83	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	15.73	0.00	16.76	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	15.71	0.00	16.73	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	15.95	0.00	16.99	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	16.12	0.00	17.11	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	16.37	0.00	17.20	0.00	0.00	24.00	0.00	0.00
26.09.25	0.30	26.97	21.40	24.62	21.54	2.03	24.00	0.00	0.00
27.09.25	0.00	20.53	0.00	20.86	0.00	0.00	24.00	0.00	0.00
28.09.25	0.00	15.89	0.00	16.61	0.00	0.00	24.00	0.00	0.00
29.09.25	0.00	14.54	0.00	15.13	0.00	0.00	24.00	0.00	0.00
30.09.25	1.32	39.78	90.27	32.65	90.92	12.10	24.00	0.00	0.00
01.10.25	2.55	66.50	168.70	51.36	170.00	24.00	24.00	0.00	0.00
02.10.25	2.54	66.03	171.50	51.19	172.79	24.00	24.00	0.00	0.00
03.10.25	2.63	67.13	208.70	54.41	210.07	24.00	24.00	0.00	0.00
04.10.25	2.69	68.32	233.95	56.80	235.39	24.00	24.00	0.00	0.00
05.10.25	2.68	68.58	236.86	57.25	238.29	24.00	24.00	0.00	0.00
06.10.25	2.53	67.53	234.43	56.74	235.76	24.00	24.00	0.00	0.00
07.10.25	2.44	67.20	224.75	56.32	226.03	24.00	24.00	0.00	0.00
08.10.25	2.37	67.65	214.10	56.60	215.35	23.28	24.00	0.00	0.00
09.10.25	2.35	67.67	223.23	57.14	224.48	24.00	24.00	0.00	0.00
10.10.25	2.39	68.04	222.32	57.28	223.59	24.00	24.00	0.00	0.00
11.10.25	2.33	67.67	228.75	57.48	229.98	24.00	24.00	0.00	0.00
12.10.25	2.31	67.28	228.62	57.15	229.85	24.00	24.00	0.00	0.00
13.10.25	2.35	67.42	226.18	57.00	227.43	24.00	24.00	0.00	0.00
14.10.25	2.42	68.50	223.41	57.64	224.71	24.00	24.00	0.00	0.00
15.10.25	2.31	67.45	219.42	56.89	220.64	24.00	24.00	0.00	0.00
16.10.25	2.40	68.00	211.33	56.62	212.60	24.00	24.00	0.00	0.00
17.10.25	2.45	67.89	211.83	56.32	213.13	24.00	24.00	0.00	0.00
18.10.25	2.43	67.71	209.31	56.08	210.59	24.00	24.00	0.00	0.00
19.10.25	2.47	68.06	205.74	56.04	207.05	24.00	24.00	0.00	0.00
20.10.25	2.47	68.40	206.26	56.40	207.58	24.00	24.00	0.00	0.00
Итого	50.73	---	4421.06	---	4447.77	493.41	768.00	0.00	0.00
Среднее	---	49.442	---	42.222	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	6495.44	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1 Пульсар ДУ-40, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Островского, 56
 Потребитель: АО "Жилуправление"
 Прибор: 350 Заводской номер: 02816576
 ТВ1

Дата	T1	T2	V1	Q	Время раб. (ч)
19.09.25	17.1	16.6	0.000	0.000	0.00
20.09.25	17.0	16.5	0.000	0.000	0.00
21.09.25	-	-	-	-	-
22.09.25	-	-	-	-	-
23.09.25	-	-	-	-	-
24.09.25	-	-	-	-	-
25.09.25	-	-	-	-	-
26.09.25	-	-	-	-	-
27.09.25	-	-	-	-	-
28.09.25	-	-	-	-	-
29.09.25	-	-	-	-	-
30.09.25	-	-	-	-	-
01.10.25	-	-	-	-	-
02.10.25	-	-	-	-	-
03.10.25	-	-	-	-	-
04.10.25	-	-	-	-	-
05.10.25	-	-	-	-	-
06.10.25	-	-	-	-	-
07.10.25	-	-	-	-	-
08.10.25	-	-	-	-	-
09.10.25	-	-	-	-	-
10.10.25	-	-	-	-	-
11.10.25	-	-	-	-	-
12.10.25	-	-	-	-	-
13.10.25	-	-	-	-	-
14.10.25	-	-	-	-	-
15.10.25	-	-	-	-	-
16.10.25	-	-	-	-	-
17.10.25	-	-	-	-	-
18.10.25	-	-	-	-	-
19.10.25	-	-	-	-	-
20.10.25	-	-	-	-	-
Итого	---	---	0.000	0.000	0.00
Среднее	17.0	16.6	---	---	---

Показания интеграторов

Дата	V1, м. куб	Q, Гкал	Время раб., ч
18.09.25 24:00	45619.453	1066.690	24740.000
20.10.25 24:00	н/д	н/д	н/д
Итого за период	н/д	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС2, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Островского, 5
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00166594

БД=1, ТВ2, СИ=3, КТЗ=1, ФРТ=3, КСН=0х7292

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	Qг, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	16.42	16.41	0.01	0.000	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	н/д	0.0	24.0
20.09.25	16.37	16.36	0.01	0.000	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	н/д	0.0	24.0
21.09.25	16.25	16.25	0.00	0.000	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	н/д	0.0	24.0
22.09.25	16.65	16.59	0.06	0.320	0.320	0.000	0.320	0.320	0.000	7.10	6.70	0.0000	н/д	0.0	24.0
23.09.25	16.96	17.00	-0.04	0.000	0.000	0.000	0.000	0.000	0.000	7.70	6.70	0.0000	н/д	0.0	24.0
24.09.25	17.24	17.29	-0.05	0.000	0.000	0.000	0.000	0.000	0.000	7.90	6.70	0.0000	н/д	0.0	24.0
25.09.25	16.92	16.96	-0.04	0.000	0.000	0.000	0.000	0.000	0.000	8.17	6.70	0.0000	н/д	0.0	24.0
26.09.25	40.25	36.54	3.71	153.180	153.700	0.000	152.430	152.260	0.170	8.48	6.70	0.5660	н/д	0.0	24.0
27.09.25	43.70	39.96	3.74	273.460	275.930	0.000	272.420	272.420	0.000	6.90	6.70	1.0190	н/д	0.0	24.0
28.09.25	42.96	38.73	4.23	280.940	284.160	0.000	280.360	280.320	0.040	6.90	6.70	1.1860	н/д	0.0	24.0
29.09.25	42.61	38.22	4.39	283.170	285.660	0.000	282.200	282.200	0.000	6.90	6.70	1.2380	н/д	0.0	24.0
30.09.25	43.89	38.25	5.64	242.460	242.300	0.000	240.610	240.120	0.490	6.90	6.70	1.3520	н/д	0.0	24.0
01.10.25	45.61	39.19	6.42	237.830	236.820	0.000	235.550	235.090	0.460	6.90	6.70	1.5090	н/д	0.0	24.0
02.10.25	47.76	40.96	6.80	249.690	247.260	0.000	247.020	245.300	1.720	6.90	6.70	1.6750	н/д	0.0	24.0
03.10.25	46.95	41.45	5.50	311.770	308.970	0.000	308.590	306.520	2.070	6.90	6.70	1.6970	н/д	0.0	24.0
04.10.25	46.75	41.28	5.47	311.970	309.060	0.000	308.850	306.660	2.190	6.90	6.70	1.6870	н/д	0.0	24.0
05.10.25	46.87	41.47	5.40	311.270	308.310	0.000	308.080	305.840	2.240	6.90	6.70	1.6620	н/д	0.0	24.0
06.10.25	45.45	40.46	4.99	307.200	304.170	0.000	304.270	301.870	2.400	6.90	6.70	1.5140	н/д	0.0	24.0
07.10.25	44.33	39.56	4.77	300.470	297.650	0.000	297.660	295.490	2.170	6.90	6.70	1.4190	н/д	0.0	24.0
08.10.25	44.41	39.46	4.95	284.710	281.900	0.000	282.020	279.890	2.130	6.90	6.70	1.3920	н/д	0.0	24.0
09.10.25	44.11	38.98	5.13	268.760	266.200	0.000	266.330	264.280	2.050	6.90	6.70	1.3670	н/д	0.0	24.0
10.10.25	43.27	38.33	4.94	260.800	258.290	0.000	258.490	256.590	1.900	6.90	6.70	1.2740	н/д	0.0	24.0
11.10.25	42.50	37.71	4.79	258.080	255.620	0.000	255.930	253.960	1.970	6.90	6.70	1.2230	н/д	0.0	24.0
12.10.25	42.90	37.85	5.05	257.500	254.930	0.000	255.340	253.250	2.090	6.90	6.70	1.2850	н/д	0.0	24.0
13.10.25	42.88	37.85	5.03	257.220	254.660	0.000	255.060	252.980	2.080	6.90	6.70	1.2800	н/д	0.0	24.0
14.10.25	44.58	39.06	5.52	254.380	251.670	0.000	252.040	249.870	2.170	6.90	6.70	1.3900	н/д	0.0	24.0
15.10.25	45.86	40.09	5.77	262.010	259.180	0.000	259.450	257.190	2.260	6.90	6.70	1.4980	н/д	0.0	24.0
16.10.25	46.28	40.74	5.54	286.820	283.750	0.000	283.940	281.590	2.350	6.90	6.70	1.5720	н/д	0.0	24.0
17.10.25	48.21	42.20	6.01	294.220	291.050	0.000	291.000	288.610	2.390	6.90	6.70	1.7460	н/д	0.0	24.0
18.10.25	51.83	45.01	6.82	296.030	292.590	0.000	292.350	289.760	2.590	6.90	6.70	1.9910	н/д	0.0	24.0
19.10.25	52.01	45.21	6.80	296.430	293.000	0.000	292.630	290.120	2.510	6.90	6.70	1.9860	н/д	0.0	24.0
20.10.25	50.81	44.08	6.73	193.560	191.770	0.000	191.220	190.000	1.220	6.83	6.70	1.2800	н/д	0.0	24.0
Итого	---	---	---	6734.250	6688.920	0.000	6674.160	6632.500	41.660	---	---	35.808	---	0.0	768.0
Среднее	39.17	34.98	4.19	---	---	---	---	---	---	7.05	6.70	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	Mг, (т)	Qo, (Гкал)	Qг, (Гкал)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	64829.900	71095.830	0.200	62458.440	62497.510	-39.070	468.7190	н/д	8270.0	6567.0
20.10.25 24:00	71269.930	77493.700	0.200	68841.600	68841.400	0.200	502.7810	н/д	9038.0	7335.0
Итого за период	6440.030	6397.870	0.000	6383.160	6343.890	---	34.0620	н/д	768.0	768.0

Представитель абонента _____/_____ Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Первомайская, 7а
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00169028

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0х1580

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	21.32	21.01	0.31	0.000	0.000	0.000	0.000	0.000	1.00	1.04	0.0000	0.0	24.0
20.09.25	21.34	21.04	0.30	0.000	0.000	0.000	0.000	0.000	1.01	1.04	0.0000	0.0	24.0
21.09.25	21.40	21.10	0.30	0.000	0.000	0.000	0.000	0.000	1.01	1.04	0.0000	0.0	24.0
22.09.25	21.75	21.40	0.35	0.000	0.000	0.000	0.000	0.000	1.02	1.04	0.0000	0.0	24.0
23.09.25	21.95	21.58	0.37	0.000	0.000	0.000	0.000	0.000	1.02	1.04	0.0000	0.0	24.0
24.09.25	22.39	22.00	0.39	0.000	0.000	0.000	0.000	0.000	1.03	1.04	0.0000	0.0	24.0
25.09.25	28.42	20.04	8.38	1.320	2.110	1.320	2.110	-0.790	2.58	2.14	0.0110	0.0	24.0
26.09.25	59.50	54.02	5.48	308.410	298.570	303.340	294.460	8.880	3.59	2.78	1.6690	0.0	24.0
27.09.25	60.47	54.76	5.71	588.950	569.350	579.040	561.380	17.660	5.10	3.85	3.3130	0.0	24.0
28.09.25	60.35	54.44	5.91	596.510	576.500	586.530	568.500	18.030	5.06	3.85	3.4760	0.0	24.0
29.09.25	53.80	48.71	5.09	568.290	549.110	560.360	542.760	17.600	5.02	3.92	2.8900	0.0	24.0
30.09.25	58.87	52.63	6.24	538.090	519.810	529.480	513.040	16.440	4.99	4.04	3.3100	0.0	24.0
01.10.25	58.70	53.04	5.66	551.730	533.210	542.960	526.180	16.780	4.79	3.84	3.0780	0.0	24.0
02.10.25	58.36	52.67	5.69	553.100	534.660	544.400	527.690	16.710	4.77	3.83	3.1000	0.0	24.0
03.10.25	57.97	52.16	5.81	560.210	541.140	551.460	534.220	17.240	4.71	3.74	3.2080	0.0	24.0
04.10.25	58.49	52.53	5.96	574.670	554.990	565.580	547.760	17.820	4.72	3.76	3.3750	0.0	24.0
05.10.25	58.17	52.22	5.95	575.550	555.760	566.540	548.650	17.890	4.74	3.78	3.3730	0.0	24.0
06.10.25	58.21	52.20	6.01	574.980	555.300	565.950	548.200	17.750	4.75	3.79	3.4030	0.0	24.0
07.10.25	57.90	52.05	5.85	575.620	555.890	566.700	548.830	17.870	4.71	3.76	3.3270	0.0	24.0
08.10.25	57.81	52.02	5.79	576.230	556.480	567.320	549.420	17.900	4.71	3.76	3.2950	0.0	24.0
09.10.25	57.94	52.08	5.86	577.110	557.120	568.140	550.020	18.120	4.75	3.80	3.3360	0.0	24.0
10.10.25	57.95	52.14	5.81	577.650	557.700	568.690	550.580	18.110	4.76	3.80	3.3080	0.0	24.0
11.10.25	58.42	52.43	5.99	577.860	558.000	568.730	550.760	17.970	4.75	3.80	3.4070	0.0	24.0
12.10.25	59.07	52.78	6.29	578.270	558.510	568.940	551.230	17.710	4.76	3.81	3.5790	0.0	24.0
13.10.25	57.73	51.76	5.97	577.250	557.380	568.330	550.340	17.990	4.75	3.80	3.3950	0.0	24.0
14.10.25	58.89	52.76	6.13	577.180	557.450	567.930	550.160	17.770	4.76	3.82	3.4910	0.0	24.0
15.10.25	56.54	50.79	5.75	576.250	556.300	567.630	549.480	18.150	4.75	3.80	3.2710	0.0	24.0
16.10.25	54.93	49.19	5.74	547.150	528.140	539.350	522.020	17.330	4.66	3.75	3.1000	0.0	24.0
17.10.25	60.85	54.13	6.72	576.690	557.100	566.890	549.460	17.430	4.72	3.78	3.8130	0.0	24.0
18.10.25	60.86	54.09	6.77	575.420	555.710	565.600	548.130	17.470	4.71	3.78	3.8330	0.0	24.0
19.10.25	60.54	53.88	6.66	575.120	555.470	565.430	547.950	17.480	4.73	3.80	3.7730	0.0	24.0
20.10.25	60.28	53.66	6.62	576.230	556.650	566.600	549.120	17.480	4.74	3.80	3.7580	0.0	24.0
Итого	---	---	---	14035.8	13558.4	13813.24	13382.45	430.790	---	---	82.8920	0.0	768.0
Среднее	50.66	45.66	4.99	---	---	---	---	---	3.97	3.21	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	61770.930	59728.120	60671.950	59001.410	692.2300	1670.540	905.0	9254.0
20.10.25 24:00	75806.769	73286.530	74485.190	72383.860	775.1220	2101.330	905.0	10022.0
Итого за период	14035.839	13558.409	13813.240	13382.449	82.8920	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Первомайская, 7а
 Потребитель: АО "Жилуправление"
 Прибор: ТЭМ-106 Заводской номер: 3060261
 Формула: $Q = M1(h1 - h2)$
 Тип системы: Подача + расходомер

Система: 1

ТВ1

	ДУ, мм	Gmin, м3/ч	Gmax, м3/ч	Kv, л/имп	Fmax, КГц
1	50	2.95	70.8	10	---
2	50	3.125	75	10	---

Дата	Q, (Гкал)	M1, (т)	M2, (т)	dM, (т)	T1, (°C)	T2, (°C)	P1, (МПа)	P2, (МПа)	Время наработки, (ч)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	н/д	н/д	н/д	н/д	17.368	17.561	0.6	0.5	н/д
23.09.25	0.000	0.39	0.09	0.3	17.803	17.975	0.6	0.5	24.00
24.09.25	0.000	0.39	0.13	0.3	18.449	18.567	0.6	0.5	24.00
25.09.25	0.011	1.30	0.25	1.1	29.595	22.315	0.6	0.5	24.00
26.09.25	0.784	158.42	161.10	-2.7	59.047	54.131	0.6	0.5	24.00
27.09.25	1.395	284.70	289.19	-4.5	60.277	55.398	0.6	0.5	24.00
28.09.25	1.445	284.53	288.92	-4.4	60.145	55.086	0.6	0.5	24.00
29.09.25	1.177	271.99	276.21	-4.2	53.651	49.394	0.6	0.5	24.00
30.09.25	1.389	250.42	254.15	-3.7	58.701	53.175	0.6	0.5	24.00
01.10.25	1.353	254.02	257.68	-3.7	58.526	53.219	0.6	0.5	24.00
02.10.25	1.333	254.29	258.14	-3.9	58.211	52.988	0.6	0.5	24.00
03.10.25	1.297	255.24	259.04	-3.8	57.736	52.674	0.6	0.5	24.00
04.10.25	1.350	260.32	263.84	-3.5	58.307	53.139	0.6	0.5	24.00
05.10.25	1.317	259.99	263.47	-3.5	58.008	52.963	0.6	0.5	24.00
06.10.25	1.315	259.43	262.93	-3.5	58.034	52.983	0.6	0.5	24.00
07.10.25	1.267	259.22	262.70	-3.5	57.741	52.873	0.6	0.5	24.00
08.10.25	1.245	259.04	262.51	-3.5	57.618	52.830	0.6	0.5	24.00
09.10.25	1.267	258.72	262.14	-3.4	57.773	52.896	0.6	0.5	24.00
10.10.25	1.245	258.68	262.13	-3.5	57.768	52.977	0.6	0.5	24.00
11.10.25	1.268	258.51	262.00	-3.5	58.235	53.351	0.6	0.5	24.00
12.10.25	1.337	258.62	262.12	-3.5	58.857	53.709	0.6	0.5	24.00
13.10.25	1.283	258.24	261.73	-3.5	57.585	52.637	0.6	0.5	24.00
14.10.25	1.321	257.97	261.47	-3.5	58.726	53.624	0.6	0.5	24.00
15.10.25	1.236	257.84	261.34	-3.5	56.355	51.582	0.6	0.5	24.00
16.10.25	1.181	245.28	248.60	-3.3	54.644	49.850	0.6	0.5	23.76
17.10.25	1.468	257.84	261.35	-3.5	60.663	54.990	0.6	0.5	24.00
18.10.25	1.469	257.18	260.72	-3.5	60.671	54.980	0.6	0.5	24.00
19.10.25	1.421	256.56	260.20	-3.6	60.391	54.874	0.6	0.5	24.00
20.10.25	1.405	256.87	260.64	-3.8	60.106	54.657	0.6	0.5	24.00
Итого	32.58	6396.0	6484.8	-88.8	---	---	---	---	671.76
Среднее	---	---	---	---	53.14	48.53	0.6	0.5	---

Показания интеграторов

Дата	Q, (Гкал)	M1, (т)	M2, (т)	Время наработки, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д
20.10.25 24:00	4274.5	588722.1	589729.9	78790.9
Итого за период	н/д	н/д	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 10
 Потребитель: АО "Жилуправление"
 Прибор: Взлёт ТСРВ-024 Заводской номер: 801161
 Тип системы: А32-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	20.22	19.74	0.48	0.00	0.00	0.00	0.235	0.300	0.00	0.00	0.00	0.000	24.000
20.09.25	20.17	19.70	0.47	0.00	0.00	0.00	0.196	0.253	0.00	0.00	0.00	0.000	24.000
21.09.25	20.18	19.67	0.51	0.00	0.00	0.00	0.172	0.222	0.00	0.00	0.00	0.000	24.000
22.09.25	20.48	19.93	0.55	0.00	0.00	0.00	0.158	0.204	0.00	0.00	0.00	0.000	24.000
23.09.25	20.69	20.15	0.54	0.00	0.00	0.00	0.147	0.190	0.00	0.00	0.00	0.000	24.000
24.09.25	20.85	20.26	0.59	0.00	0.00	0.00	0.140	0.177	0.00	0.00	0.00	0.000	24.000
25.09.25	20.80	20.20	0.60	0.00	0.00	0.00	0.107	0.132	0.00	0.00	0.00	0	24.000
26.09.25	19.58	18.59	0.99	0.00	0.00	0.00	0.001	0.004	0.00	0.00	0.00	0.000	24.000
27.09.25	42.53	37.22	5.31	245.88	242.04	3.83	0.629	0.632	248.13	243.71	4.42	1.557	24.000
28.09.25	43.89	38.43	5.46	256.90	253.48	3.41	0.677	0.679	259.24	255.24	4.00	1.531	24.000
29.09.25	43.63	38.23	5.40	254.31	251.90	2.40	0.663	0.665	256.60	253.64	2.96	1.462	24.000
30.09.25	43.77	37.55	6.22	221.73	218.87	2.85	0.653	0.657	223.74	220.33	3.41	1.470	24.000
01.10.25	45.66	38.56	7.10	205.50	202.69	2.81	0.634	0.639	207.54	204.11	3.43	1.564	24.000
02.10.25	48.79	40.41	8.38	194.84	191.96	2.87	0.721	0.726	197.02	193.44	3.58	1.728	24.000
03.10.25	48.05	41.63	6.42	256.50	253.99	2.51	0.532	0.534	259.31	256.09	3.22	1.725	24.000
04.10.25	47.47	41.44	6.03	262.47	259.89	2.58	0.521	0.523	265.29	262.01	3.27	1.687	24.000
05.10.25	47.59	41.56	6.03	262.40	259.80	2.59	0.519	0.521	265.23	261.94	3.29	1.686	24.000
06.10.25	47.47	41.58	5.89	262.21	259.58	2.62	0.520	0.522	265.03	261.72	3.30	1.651	24.000
07.10.25	44.90	39.73	5.17	260.67	258.02	2.64	0.521	0.523	263.17	259.96	3.21	1.449	24.000
08.10.25	45.08	39.86	5.22	258.19	255.53	2.66	0.521	0.523	260.70	257.46	3.24	1.450	24.000
09.10.25	45.00	39.79	5.21	254.40	251.77	2.62	0.515	0.517	256.86	253.67	3.19	1.427	24.000
10.10.25	44.40	39.31	5.09	248.77	246.16	2.61	0.509	0.511	251.11	247.97	3.14	1.367	24.000
11.10.25	44.01	38.99	5.02	247.50	244.96	2.54	0.507	0.509	249.79	246.73	3.07	1.340	24.000
12.10.25	43.10	38.24	4.86	247.31	244.70	2.61	0.503	0.505	249.50	246.40	3.10	1.300	24.000
13.10.25	43.55	38.42	5.13	247.28	244.65	2.63	0.507	0.509	249.52	246.36	3.16	1.366	24.000
14.10.25	44.29	38.94	5.35	246.27	243.68	2.59	0.508	0.511	248.58	245.44	3.14	1.414	24.000
15.10.25	46.42	40.43	5.99	243.08	240.54	2.53	0.500	0.503	245.58	242.42	3.16	1.555	24.000
16.10.25	46.49	40.86	5.63	270.69	267.89	2.80	0.534	0.535	273.48	270.02	3.46	1.634	24.000
17.10.25	46.35	40.98	5.37	284.66	281.77	2.89	0.545	0.545	287.58	284.02	3.55	1.643	24.000
18.10.25	51.87	44.94	6.93	282.59	279.77	2.81	0.550	0.550	286.19	282.46	3.73	2.081	24.000
19.10.25	52.02	45.18	6.84	282.45	279.67	2.77	0.551	0.551	286.07	282.39	3.68	2.053	24.000
20.10.25	51.67	45.03	6.64	283.24	280.45	2.79	0.551	0.551	286.83	283.16	3.67	2.001	24.000
Итого	---	---	---	6079.83	6013.74	66.08	---	---	6142.08	6060.70	81.38	38.140	768.000
Среднее	39.72	35.17	4.54	---	---	---	0.455	0.466	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 11
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВА730

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	1.66	19.86	832.91	17.85	0.00	23.04	24.00	0.00	0.00
20.09.25	1.71	20.20	827.64	18.09	0.00	22.35	24.00	0.00	0.00
21.09.25	1.23	20.05	897.84	18.68	0.00	24.00	24.00	0.00	0.00
22.09.25	1.28	20.14	911.40	18.73	60.95	23.60	24.00	0.00	0.00
23.09.25	1.94	19.53	943.23	17.48	99.37	23.52	24.00	0.00	0.00
24.09.25	1.46	19.60	974.25	18.08	0.02	24.00	24.00	0.00	0.00
25.09.25	0.19	19.51	1029.40	19.33	0.00	23.60	24.00	0.00	0.00
26.09.25	1.48	21.01	1027.79	19.57	0.00	24.00	24.00	0.00	0.00
27.09.25	1.56	32.39	595.32	28.66	166.44	23.49	24.00	0.00	0.00
28.09.25	0.78	35.37	132.45	32.35	131.23	9.35	24.00	0.00	0.00
29.09.25	0.00	20.56	0.00	21.93	0.00	0.00	24.00	0.00	0.00
30.09.25	0.67	26.85	84.44	24.84	83.68	6.57	24.00	0.00	0.00
01.10.25	1.94	45.73	266.64	38.42	264.08	24.00	24.00	0.00	0.00
02.10.25	2.04	47.61	261.99	39.80	259.79	24.00	24.00	0.00	0.00
03.10.25	2.15	49.85	275.76	41.72	274.20	24.00	24.00	0.00	0.00
04.10.25	1.98	48.67	335.50	42.77	334.95	24.00	24.00	0.00	0.00
05.10.25	1.97	48.48	334.86	42.59	334.62	24.00	24.00	0.00	0.00
06.10.25	2.09	48.62	338.70	42.43	338.13	24.00	24.00	0.00	0.00
07.10.25	1.94	47.02	338.52	41.28	338.25	24.00	24.00	0.00	0.00
08.10.25	1.82	45.95	336.21	40.51	335.94	24.00	24.00	0.00	0.00
09.10.25	1.80	46.02	331.23	40.58	330.77	24.00	24.00	0.00	0.00
10.10.25	1.77	45.72	324.76	40.27	324.16	24.00	24.00	0.00	0.00
11.10.25	1.66	44.89	319.50	39.67	318.84	24.00	24.00	0.00	0.00
12.10.25	1.59	44.08	318.30	39.06	317.47	24.00	24.00	0.00	0.00
13.10.25	1.67	44.52	318.09	39.25	317.06	24.00	24.00	0.00	0.00
14.10.25	1.67	44.49	318.09	39.24	317.34	24.00	24.00	0.00	0.00
15.10.25	1.82	46.37	315.17	40.57	314.33	24.00	24.00	0.00	0.00
16.10.25	1.93	47.29	325.97	41.36	325.37	24.00	24.00	0.00	0.00
17.10.25	1.99	47.38	357.42	41.79	357.47	24.00	24.00	0.00	0.00
18.10.25	2.23	49.50	366.47	43.41	366.67	24.00	24.00	0.00	0.00
19.10.25	2.52	53.03	368.58	46.19	368.86	24.00	24.00	0.00	0.00
20.10.25	2.50	53.23	368.81	46.44	369.12	24.00	24.00	0.00	0.00
Итого	53.04	---	14777.24	---	7049.11	707.52	768.00	0.00	0.00
Среднее	---	38.235	---	33.842	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	7362.69	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 12
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00169003

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0хА0Е8

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	21.73	22.36	-0.63	0.000	0.000	0.000	0.000	0.000	6.20	2.20	0.0000	0.0	24.0
20.09.25	21.65	21.53	0.12	0.000	0.000	0.000	0.000	0.000	6.20	1.53	0.0000	0.0	24.0
21.09.25	21.72	21.40	0.32	0.000	0.000	0.000	0.000	0.000	6.20	1.49	0.0000	0.0	24.0
22.09.25	22.17	21.67	0.50	0.000	0.000	0.000	0.000	0.000	6.20	1.51	0.0000	0.0	24.0
23.09.25	22.44	21.90	0.54	0.000	0.000	0.000	0.000	0.000	6.20	1.51	0.0000	0.0	24.0
24.09.25	22.51	21.86	0.65	0.000	0.000	0.000	0.000	0.000	6.20	1.50	0.0000	0.0	24.0
25.09.25	22.07	21.76	0.31	0.000	0.000	0.000	0.000	0.000	6.20	1.47	0.0000	0.0	24.0
26.09.25	40.98	36.89	4.09	207.470	207.470	205.820	206.150	-0.330	6.20	4.93	0.8370	0.0	24.0
27.09.25	44.38	39.96	4.42	336.360	336.360	333.240	333.860	-0.620	6.20	7.54	1.4580	0.0	24.0
28.09.25	43.60	39.26	4.34	331.630	331.630	328.750	329.230	-0.480	6.20	7.60	1.4120	0.0	24.0
29.09.25	43.23	38.76	4.47	322.370	322.370	319.580	320.090	-0.510	6.20	7.31	1.4190	0.0	24.0
30.09.25	44.61	38.90	5.71	271.590	271.590	269.060	269.670	-0.610	6.20	7.31	1.5280	0.0	24.0
01.10.25	46.41	40.07	6.34	268.420	268.420	265.670	266.420	-0.750	6.20	7.58	1.6720	0.0	24.0
02.10.25	48.56	41.92	6.64	280.290	280.290	277.210	278.010	-0.800	6.20	7.37	1.8330	0.0	24.0
03.10.25	47.58	42.36	5.22	345.280	345.280	341.630	342.400	-0.770	6.20	6.07	1.7790	0.0	24.0
04.10.25	47.38	42.18	5.20	343.820	343.820	340.220	340.940	-0.720	6.20	6.00	1.7670	0.0	24.0
05.10.25	47.51	42.36	5.15	344.370	344.370	340.770	341.490	-0.720	6.20	6.01	1.7520	0.0	24.0
06.10.25	46.01	41.25	4.76	343.040	343.040	339.680	340.300	-0.620	6.20	6.01	1.6120	0.0	24.0
07.10.25	44.89	40.41	4.48	340.590	340.590	337.430	337.950	-0.520	6.20	6.02	1.5040	0.0	24.0
08.10.25	44.98	40.49	4.49	335.940	335.940	332.750	333.340	-0.590	6.20	6.01	1.4900	0.0	24.0
09.10.25	44.69	40.19	4.50	330.070	330.070	326.950	327.620	-0.670	6.20	5.93	1.4670	0.0	24.0
10.10.25	43.86	39.57	4.29	324.820	324.820	321.940	322.420	-0.480	6.20	5.92	1.3820	0.0	24.0
11.10.25	43.08	38.93	4.15	323.890	323.890	321.080	321.560	-0.480	6.20	5.88	1.3310	0.0	24.0
12.10.25	43.49	39.15	4.34	323.550	323.550	320.670	321.150	-0.480	6.20	5.86	1.3920	0.0	24.0
13.10.25	43.46	39.12	4.34	323.410	323.410	320.530	321.010	-0.480	6.20	5.91	1.3900	0.0	24.0
14.10.25	45.22	40.40	4.82	320.600	320.600	317.540	318.130	-0.590	6.20	5.89	1.5320	0.0	24.0
15.10.25	46.19	41.15	5.04	333.050	333.050	329.750	330.370	-0.620	6.20	5.94	1.6580	0.0	24.0
16.10.25	46.30	41.49	4.81	364.400	364.400	360.800	361.520	-0.720	6.20	6.20	1.7300	0.0	24.0
17.10.25	48.18	43.09	5.09	386.730	386.730	382.520	383.370	-0.850	6.20	6.25	1.9420	0.0	24.0
18.10.25	51.83	45.86	5.97	374.910	374.910	370.250	371.230	-0.980	6.20	6.29	2.2030	0.0	24.0
19.10.25	52.01	46.10	5.91	375.080	375.080	370.280	371.270	-0.990	6.20	6.31	2.1840	0.0	24.0
20.10.25	50.59	45.11	5.48	377.390	377.390	372.860	373.750	-0.890	6.20	6.30	2.0370	0.0	24.0
Итого	---	---	---	8229.0	8229.0	8146.98	8163.25	-16.270	---	---	40.3110	0.0	768.0
Среднее	40.72	36.79	3.93	---	---	---	---	---	6.20	5.30	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	83162.530	83162.530	82050.349	82303.610	537.4490	-253.260	3698.0	7111.0
20.10.25 24:00	91391.600	91391.600	90197.330	90466.859	577.7600	-269.530	3698.0	7879.0
Итого за период	8229.070	8229.070	8146.981	8163.248	40.3110	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, проспект Ленина, 14
Потребитель: АО "Жилуправление"
Прибор: ТВ7-04.1 Заводской номер: 24213237

БД=1, ТВ1, СИ=6, КСН=0х4617

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
26.09.25	42.58	37.88	н/д	4.70	2.86	5.60	н/д	226.680	218.680	н/д	224.832	217.291	н/д	7.541	1.063	н/д	24	0
27.09.25	44.54	40.29	н/д	4.25	6.65	5.60	н/д	527.620	504.715	н/д	522.849	501.054	н/д	21.795	2.240	н/д	24	0
28.09.25	43.81	39.69	н/д	4.12	6.68	5.60	н/д	519.675	501.540	н/д	515.162	497.980	н/д	17.182	2.143	н/д	24	0
29.09.25	43.45	39.16	н/д	4.29	6.37	5.60	н/д	489.005	473.145	н/д	484.814	469.886	н/д	14.928	2.093	н/д	24	0
30.09.25	45.04	39.59	н/д	5.45	6.26	5.60	н/д	410.325	397.420	н/д	406.516	394.619	н/д	11.897	2.226	н/д	24	0
01.10.25	47.07	40.90	н/д	6.17	6.16	5.60	н/д	370.480	354.950	н/д	366.520	348.933	н/д	17.587	2.276	н/д	23	1
02.10.25	48.78	42.89	н/д	5.89	6.24	5.60	н/д	432.365	410.885	н/д	427.624	407.434	н/д	20.189	2.529	н/д	24	0
03.10.25	47.74	43.07	н/д	4.67	5.12	5.60	н/д	523.465	503.285	н/д	517.969	499.008	н/д	18.961	2.422	н/д	24	0
04.10.25	47.62	42.96	н/д	4.67	5.06	5.60	н/д	521.380	502.775	н/д	515.898	498.538	н/д	17.360	2.410	н/д	24	0
05.10.25	47.78	43.16	н/д	4.62	5.07	5.60	н/д	521.930	504.055	н/д	516.428	499.772	н/д	16.656	2.386	н/д	24	0
06.10.25	46.00	41.80	н/д	4.20	5.07	5.60	н/д	519.490	502.175	н/д	514.446	498.182	н/д	16.264	2.162	н/д	24	0
07.10.25	45.13	41.11	н/д	4.02	5.08	5.60	н/д	515.945	500.005	н/д	511.118	496.178	н/д	14.940	2.058	н/д	24	0
08.10.25	45.18	41.16	н/д	4.02	5.06	5.60	н/д	508.410	491.590	н/д	503.632	487.819	н/д	15.813	2.026	н/д	24	0
09.10.25	44.85	40.85	н/д	4.00	4.97	5.60	н/д	498.960	482.480	н/д	494.363	478.825	н/д	15.538	1.979	н/д	24	0
10.10.25	44.06	40.22	н/д	3.84	4.95	5.60	н/д	491.415	474.850	н/д	487.052	471.388	н/д	15.664	1.873	н/д	24	0
11.10.25	43.25	39.56	н/д	3.68	4.91	5.60	н/д	489.575	473.455	н/д	485.407	470.103	н/д	15.304	1.789	н/д	24	0
12.10.25	43.70	39.83	н/д	3.87	4.89	5.60	н/д	489.280	473.450	н/д	485.015	470.076	н/д	14.940	1.878	н/д	24	0
13.10.25	43.70	39.84	н/д	3.86	4.95	5.60	н/д	489.000	473.300	н/д	484.728	469.938	н/д	14.790	1.875	н/д	24	0
14.10.25	45.67	41.32	н/д	4.35	4.91	5.60	н/д	484.220	468.950	н/д	479.549	465.300	н/д	14.249	2.086	н/д	24	0
15.10.25	46.46	42.09	н/д	4.37	5.01	5.60	н/д	504.705	488.975	н/д	499.689	485.067	н/д	14.622	2.188	н/д	24	0
16.10.25	46.50	42.35	н/д	4.16	5.29	5.60	н/д	547.305	530.340	н/д	541.857	526.023	н/д	15.834	2.257	н/д	24	0
17.10.25	48.97	44.28	н/д	4.68	5.36	5.60	н/д	561.985	544.950	н/д	555.784	540.024	н/д	15.760	2.610	н/д	24	0
18.10.25	52.07	46.87	н/д	5.19	5.39	5.60	н/д	563.880	547.005	н/д	556.788	541.423	н/д	15.365	2.900	н/д	24	0
19.10.25	52.30	47.12	н/д	5.18	5.41	5.60	н/д	564.140	547.410	н/д	557.009	541.782	н/д	15.226	2.893	н/д	24	0
20.10.25	50.56	45.67	н/д	4.89	4.93	5.60	н/д	518.030	499.465	н/д	511.702	494.690	н/д	17.012	2.509	н/д	23	1
Итого	---	---	---	---	---	---	---	12289.265	11869.850	---	12166.751	11771.333	---	395.417	54.871	---	598	2
Среднее	46.43	41.93	---	4.50	5.31	5.60	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
20.10.25 24:00	12289.785	11872.345	0.000	12166.750	11771.355	0.000	395.395	54.872	0.000	680	583
Итого за период	н/д	н/д	н/д	н/д	н/д	н/д	---	н/д	н/д	н/д	н/д

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, проспект Ленина, 17
Потребитель: АО "Жилуправление"
Прибор: ТВ7-01 Заводской номер: 20133746

БД=1, ТВ1, СИ=7, КТЗ=0, ФРТ=0, КСН=0х0D56

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	15.61	15.50	н/д	0.11	5.20	5.00	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
20.09.25	15.57	15.46	н/д	0.10	5.20	5.00	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
21.09.25	15.50	15.39	н/д	0.11	5.20	5.00	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
22.09.25	15.77	15.66	н/д	0.11	5.20	5.00	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
23.09.25	15.90	15.76	н/д	0.14	5.20	5.00	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
24.09.25	16.06	15.89	н/д	0.17	5.20	5.00	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
25.09.25	15.74	15.61	н/д	0.13	5.20	5.00	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
26.09.25	43.08	38.98	н/д	4.10	5.20	5.00	н/д	34.966	н/д	н/д	34.672	н/д	н/д	н/д	0.142	н/д	24	0
27.09.25	44.50	41.17	н/д	3.33	5.20	5.00	н/д	146.016	н/д	н/д	144.687	н/д	н/д	н/д	0.481	н/д	24	0
28.09.25	43.70	40.47	н/д	3.23	5.20	5.00	н/д	143.173	н/д	н/д	141.915	н/д	н/д	н/д	0.458	н/д	24	0
29.09.25	44.02	39.97	н/д	4.06	5.20	5.00	н/д	133.863	н/д	н/д	132.665	н/д	н/д	н/д	0.538	н/д	24	0
30.09.25	44.73	40.21	н/д	4.52	5.20	5.00	н/д	105.764	н/д	н/д	104.793	н/д	н/д	н/д	0.473	н/д	24	0
01.10.25	46.53	41.62	н/д	4.91	5.20	5.00	н/д	103.980	н/д	н/д	102.938	н/д	н/д	н/д	0.505	н/д	24	0
02.10.25	48.72	43.71	н/д	5.02	5.20	5.00	н/д	108.706	н/д	н/д	107.509	н/д	н/д	н/д	0.540	н/д	24	0
03.10.25	47.72	43.85	н/д	3.87	5.20	5.00	н/д	135.292	н/д	н/д	133.864	н/д	н/д	н/д	0.518	н/д	24	0
04.10.25	47.50	43.60	н/д	3.91	5.20	5.00	н/д	135.425	н/д	н/д	134.010	н/д	н/д	н/д	0.524	н/д	24	0
05.10.25	47.63	43.80	н/д	3.83	5.20	5.00	н/д	135.478	н/д	н/д	134.055	н/д	н/д	н/д	0.514	н/д	24	0
06.10.25	46.15	42.75	н/д	3.40	5.20	5.00	н/д	139.021	н/д	н/д	137.650	н/д	н/д	н/д	0.468	н/д	24	0
07.10.25	45.00	41.68	н/д	3.32	5.20	5.00	н/д	133.376	н/д	н/д	132.132	н/д	н/д	н/д	0.438	н/д	24	0
08.10.25	45.09	41.75	н/д	3.34	5.20	5.00	н/д	130.704	н/д	н/д	129.482	н/д	н/д	н/д	0.432	н/д	24	0
09.10.25	44.76	40.60	н/д	4.16	5.20	5.00	н/д	95.830	н/д	н/д	94.949	н/д	н/д	н/д	0.395	н/д	24	0
10.10.25	43.91	38.22	н/д	5.69	5.20	5.00	н/д	63.851	н/д	н/д	63.287	н/д	н/д	н/д	0.360	н/д	24	0
11.10.25	43.14	37.58	н/д	5.56	5.20	5.00	н/д	63.594	н/д	н/д	63.054	н/д	н/д	н/д	0.351	н/д	24	0
12.10.25	43.55	37.67	н/д	5.88	5.20	5.00	н/д	63.544	н/д	н/д	62.992	н/д	н/д	н/д	0.370	н/д	24	0
13.10.25	43.51	37.64	н/д	5.88	5.20	5.00	н/д	63.534	н/д	н/д	62.980	н/д	н/д	н/д	0.370	н/д	24	0
14.10.25	45.27	38.82	н/д	6.44	5.20	5.00	н/д	63.028	н/д	н/д	62.431	н/д	н/д	н/д	0.402	н/д	24	0
15.10.25	46.26	39.63	н/д	6.62	5.20	5.00	н/д	64.963	н/д	н/д	64.322	н/д	н/д	н/д	0.426	н/д	24	0
16.10.25	46.37	40.06	н/д	6.31	5.20	5.00	н/д	71.187	н/д	н/д	70.482	н/д	н/д	н/д	0.444	н/д	24	0
17.10.25	48.24	41.43	н/д	6.81	5.20	5.00	н/д	72.848	н/д	н/д	72.055	н/д	н/д	н/д	0.491	н/д	24	0
18.10.25	51.92	44.24	н/д	7.69	5.20	5.00	н/д	73.417	н/д	н/д	72.500	н/д	н/д	н/д	0.557	н/д	24	0
19.10.25	52.09	44.49	н/д	7.60	5.20	5.00	н/д	73.458	н/д	н/д	72.536	н/д	н/д	н/д	0.551	н/д	24	0
20.10.25	50.71	43.63	н/д	7.08	5.20	5.00	н/д	73.387	н/д	н/д	72.511	н/д	н/д	н/д	0.513	н/д	24	0
Итого	---	---	---	---	---	---	---	2428.405	---	---	2404.471	---	---	---	11.261	---	768	0
Среднее	46.15	41.46	---	4.69	5.20	5.00	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	5199.853	0.000	0.000	5112.840	0.000	0.000	0.000	39.460	0.000	2400	2824
20.10.25 24:00	7628.258	0.000	0.000	7517.310	0.000	0.000	0.000	50.723	0.000	3168	2824
Итого за период	2428.405	0.000	0.000	2404.470	0.000	0.000	---	11.263	0.000	768	0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 23
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ631

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	17.29	0.00	17.00	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	17.13	0.00	16.93	0.01	0.00	24.00	0.00	0.00
21.09.25	0.00	17.14	0.00	16.83	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	17.20	0.00	16.85	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	17.37	0.00	17.00	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	17.57	0.00	17.26	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	19.00	0.00	21.85	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	19.16	0.00	21.28	0.00	0.00	24.00	0.00	0.00
27.09.25	0.16	24.84	25.23	23.46	26.24	6.65	24.00	0.00	0.00
28.09.25	0.56	44.40	100.90	38.85	104.88	24.00	24.00	0.00	0.00
29.09.25	0.25	33.29	46.06	30.31	47.55	10.93	24.00	0.00	0.00
30.09.25	0.20	26.38	24.48	24.09	25.52	7.52	24.00	0.00	0.00
01.10.25	0.61	44.59	70.11	35.88	74.18	24.00	24.00	0.00	0.00
02.10.25	0.64	46.37	68.78	37.03	71.60	24.00	24.00	0.00	0.00
03.10.25	0.69	48.66	71.92	38.75	73.37	24.00	24.00	0.00	0.00
04.10.25	0.68	47.58	89.68	39.92	91.62	24.00	24.00	0.00	0.00
05.10.25	0.67	47.37	89.48	39.85	91.16	24.00	24.00	0.00	0.00
06.10.25	0.67	47.50	89.50	40.01	91.20	24.00	24.00	0.00	0.00
07.10.25	0.62	46.02	89.51	39.13	91.04	24.00	24.00	0.00	0.00
08.10.25	0.57	44.90	84.81	38.19	87.30	24.00	24.00	0.00	0.00
09.10.25	0.55	45.01	80.46	38.13	83.18	24.00	24.00	0.00	0.00
10.10.25	0.54	44.73	79.89	37.92	82.29	24.00	24.00	0.00	0.00
11.10.25	0.51	43.90	79.65	37.48	81.94	24.00	24.00	0.00	0.00
12.10.25	0.48	43.12	79.36	37.00	82.23	24.00	24.00	0.00	0.00
13.10.25	0.51	43.53	79.25	37.10	82.70	24.00	24.00	0.00	0.00
14.10.25	0.51	43.50	79.23	37.09	81.51	24.00	24.00	0.00	0.00
15.10.25	0.55	45.27	78.78	38.27	81.10	24.00	24.00	0.00	0.00
16.10.25	0.58	46.23	81.73	39.04	84.27	24.00	24.00	0.00	0.00
17.10.25	0.62	46.35	89.74	39.48	92.27	24.00	24.00	0.00	0.00
18.10.25	0.68	48.26	91.61	40.78	94.56	24.00	24.00	0.00	0.00
19.10.25	0.77	51.88	91.81	43.43	95.09	24.00	24.00	0.00	0.00
20.10.25	0.77	52.05	91.81	43.63	94.67	24.00	24.00	0.00	0.00
Итого	13.39	---	1853.78	---	1911.48	529.10	768.00	0.00	0.00
Среднее	---	37.425	---	32.494	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	1011.24	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, проспект Ленина, 25
Потребитель: АО "Жилуправление"
Прибор: ТВ7-04.1 Заводской номер: 22180297

БД=1, ТВ1, СИ=6, КСН=0хВА07

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
28.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
29.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
30.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
01.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
02.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
03.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
04.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
05.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
07.10.25	44.79	38.32	н/д	6.47	4.65	4.60	н/д	97.478	95.125	н/д	96.579	94.505	н/д	2.074	0.624	н/д	24	0
08.10.25	44.87	38.26	н/д	6.62	4.65	4.60	н/д	93.460	91.165	н/д	92.595	90.570	н/д	2.025	0.612	н/д	24	0
09.10.25	44.59	38.03	н/д	6.56	4.57	4.53	н/д	92.853	90.573	н/д	92.004	89.988	н/д	2.016	0.603	н/д	24	0
10.10.25	43.77	37.59	н/д	6.18	4.55	4.51	н/д	92.552	90.313	н/д	91.740	89.747	н/д	1.992	0.566	н/д	24	0
11.10.25	43.00	37.06	н/д	5.93	4.52	4.48	н/д	92.180	89.972	н/д	91.400	89.428	н/д	1.972	0.542	н/д	24	0
12.10.25	43.39	37.24	н/д	6.15	4.49	4.46	н/д	92.115	89.915	н/д	91.322	89.367	н/д	1.954	0.561	н/д	24	0
13.10.25	43.35	37.18	н/д	6.17	4.54	4.51	н/д	92.098	89.905	н/д	91.306	89.360	н/д	1.946	0.563	н/д	24	0
14.10.25	45.09	38.30	н/д	6.79	4.50	4.47	н/д	91.537	89.313	н/д	90.682	88.728	н/д	1.954	0.615	н/д	24	0
15.10.25	46.08	39.15	н/д	6.93	4.55	4.52	н/д	94.497	92.215	н/д	93.573	91.581	н/д	1.992	0.648	н/д	24	0
16.10.25	46.21	39.63	н/д	6.58	4.85	4.80	н/д	103.160	100.737	н/д	102.147	100.026	н/д	2.121	0.671	н/д	24	0
17.10.25	48.10	40.96	н/д	7.14	4.89	4.84	н/д	105.463	102.965	н/д	104.335	102.182	н/д	2.153	0.744	н/д	24	0
18.10.25	51.72	43.65	н/д	8.07	4.91	4.86	н/д	106.255	103.648	н/д	104.943	102.745	н/д	2.198	0.846	н/д	24	0
19.10.25	51.89	43.90	н/д	7.99	4.92	4.87	н/д	106.352	103.710	н/д	105.026	102.795	н/д	2.232	0.838	н/д	24	0
20.10.25	50.50	43.00	н/д	7.50	4.93	4.87	н/д	106.253	103.637	н/д	104.995	102.764	н/д	2.231	0.787	н/д	24	0
Итого	---	---	---	---	---	---	---	1366.253	1333.193	---	1352.647	1323.786	---	28.860	9.220	---	336	0
Среднее	46.40	39.58	---	6.82	4.68	4.64	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
20.10.25 24:00	1420.575	1386.185	0.000	1406.474	1376.432	0.000	30.042	9.560	0.000	349	0
Итого за период	н/д	н/д	н/д	н/д	н/д	н/д	---	н/д	н/д	н/д	н/д

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 28
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ492

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	18.15	1.18	17.86	0.71	23.82	24.00	0.00	0.00
20.09.25	0.00	18.11	1.08	17.89	0.00	23.44	24.00	0.00	0.00
21.09.25	0	18.08	0.30	17.87	0.00	6.35	24.00	0.00	0.00
22.09.25	0.00	18.05	0.00	17.83	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	18.07	0.00	17.85	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	18.07	0.00	17.86	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	18.11	0.00	17.87	0.00	0.00	24.00	0.00	0.00
26.09.25	0.27	28.57	75.78	27.07	77.49	9.24	24.00	0.00	0.00
27.09.25	0.48	41.54	181.38	38.89	186.68	24.00	24.00	0.00	0.00
28.09.25	0.55	44.56	195.21	41.73	200.54	24.00	24.00	0.00	0.00
29.09.25	0.53	43.78	196.21	41.05	201.13	24.00	24.00	0.00	0.00
30.09.25	0.53	43.43	188.21	40.58	192.63	24.00	24.00	0.00	0.00
01.10.25	0.56	44.78	148.21	40.97	151.59	24.00	24.00	0.00	0.00
02.10.25	0.61	46.54	145.66	42.38	148.80	24.00	24.00	0.00	0.00
03.10.25	0.65	48.90	154.02	44.49	157.25	24.00	24.00	0.00	0.00
04.10.25	0.62	47.79	197.51	44.63	201.94	24.00	24.00	0.00	0.00
05.10.25	0.62	47.57	202.74	44.52	207.26	24.00	24.00	0.00	0.00
06.10.25	0.61	47.69	203.51	44.66	208.09	24.00	24.00	0.00	0.00
07.10.25	0.56	46.25	202.54	43.48	207.01	24.00	24.00	0.00	0.00
08.10.25	0.53	45.08	200.97	42.42	205.33	24.00	24.00	0.00	0.00
09.10.25	0.53	45.17	197.93	42.50	202.33	24.00	24.00	0.00	0.00
10.10.25	0.51	44.89	193.71	42.24	198.07	24.00	24.00	0.00	0.00
11.10.25	0.48	44.05	190.35	41.55	194.67	24.00	24.00	0.00	0.00
12.10.25	0.45	43.28	190.73	40.90	195.04	24.00	24.00	0.00	0.00
13.10.25	0.48	43.68	190.79	41.16	195.10	24.00	24.00	0.00	0.00
14.10.25	0.49	43.65	190.62	41.08	194.96	24.00	24.00	0.00	0.00
15.10.25	0.53	45.38	188.32	42.53	192.62	24.00	24.00	0.00	0.00
16.10.25	0.57	46.37	196.55	43.46	201.00	24.00	24.00	0.00	0.00
17.10.25	0.59	46.51	220.67	43.85	225.45	24.00	24.00	0.00	0.00
18.10.25	0.65	48.33	224.27	45.41	228.99	24.00	24.00	0.00	0.00
19.10.25	0.75	52.03	227.19	48.72	231.66	24.00	24.00	0.00	0.00
20.10.25	0.74	52.20	227.19	48.94	231.95	24.00	24.00	0.00	0.00
Итого	13.89	---	4732.83	---	4838.29	638.85	768.00	0.00	0.00
Среднее	---	39.333	---	37.008	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	1342.63	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 39
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: DD702

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	17.85	0.00	17.22	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	17.65	0.00	17.12	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	17.66	0.00	17.20	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	17.60	0.00	17.17	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	18.15	0.00	17.87	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	18.32	0.00	18.44	0.00	0.00	23.86	0.00	0.00
25.09.25	0.00	19.31	0.00	18.36	0.00	0.00	24.00	0.00	0.00
26.09.25	0.22	38.47	11.52	30.75	53.10	4.75	24.00	0.00	0.00
27.09.25	1.18	65.04	69.02	47.74	66.80	24.00	24.00	0.00	0.00
28.09.25	1.14	63.51	70.06	46.97	67.09	24.00	24.00	0.00	0.00
29.09.25	1.21	65.75	70.47	48.46	67.49	24.00	24.00	0.00	0.00
30.09.25	1.24	65.07	84.98	49.25	82.83	24.00	24.00	0.00	0.00
01.10.25	1.21	64.32	79.68	49.05	78.89	24.00	24.00	0.00	0.00
02.10.25	1.08	64.40	68.31	46.94	67.68	24.00	24.00	0.00	0.00
03.10.25	1.00	65.02	51.60	45.39	51.17	24.00	24.00	0.00	0.00
04.10.25	0.93	66.10	42.63	44.15	42.37	24.00	24.00	0.00	0.00
05.10.25	1.03	66.22	50.90	45.82	50.63	24.00	24.00	0.00	0.00
06.10.25	0.97	65.19	48.91	45.21	48.71	24.00	24.00	0.00	0.00
07.10.25	0.95	64.96	47.89	44.89	47.73	24.00	24.00	0.00	0.00
08.10.25	0.89	65.55	41.33	43.92	41.22	24.00	24.00	0.00	0.00
09.10.25	1.34	65.50	217.51	52.12	217.96	22.34	24.00	0.00	0.00
10.10.25	1.52	66.02	264.44	59.19	264.32	23.99	24.00	0.00	0.00
11.10.25	1.14	65.46	86.96	50.80	86.73	24.00	24.00	0.00	0.00
12.10.25	0.98	64.88	48.82	44.81	48.87	24.00	24.00	0.00	0.00
13.10.25	1.00	65.03	47.06	43.81	47.18	24.00	24.00	0.00	0.00
14.10.25	1.03	66.10	46.37	43.77	46.51	24.00	24.00	0.00	0.00
15.10.25	1.00	65.03	46.15	43.41	46.26	24.00	24.00	0.00	0.00
16.10.25	1.11	65.59	97.28	46.46	97.46	24.00	24.00	0.00	0.00
17.10.25	0.99	65.47	43.29	42.59	43.36	24.00	24.00	0.00	0.00
18.10.25	0.97	65.31	41.61	41.88	41.73	24.00	24.00	0.00	0.00
19.10.25	0.99	65.59	40.90	41.42	41.01	24.00	24.00	0.00	0.00
20.10.25	0.99	65.95	41.21	41.82	41.29	24.00	24.00	0.00	0.00
Итого	26.11	---	1758.90	---	1788.39	579.08	767.86	0.00	0.00
Среднее	---	54.127	---	39.500	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	1265.32	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 3
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВА706

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	14.31	0.00	13.74	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	14.29	0.00	13.75	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	14.29	0.00	13.76	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	14.22	0.00	13.64	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	14.83	0.00	14.47	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	15.03	0.00	14.63	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	15.40	0.00	15.00	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	14.57	0.00	13.97	0.00	0.00	24.00	0.00	0.00
27.09.25	0.09	20.61	27.70	18.74	27.29	2.49	24.00	0.00	0.00
28.09.25	0.00	21.03	0.00	21.20	0.00	0.00	24.00	0.00	0.00
29.09.25	0.00	19.69	0.00	20.46	0.00	0.00	24.00	0.00	0.00
30.09.25	0.00	18.68	0.00	19.44	0.00	0.00	24.00	0.00	0.00
01.10.25	0.63	30.94	92.11	28.06	84.56	11.14	24.00	0.00	0.00
02.10.25	1.35	46.60	195.73	39.67	170.67	24.00	24.00	0.00	0.00
03.10.25	1.42	48.80	206.08	41.59	178.07	24.00	24.00	0.00	0.00
04.10.25	1.37	47.64	251.55	42.19	217.58	24.00	24.00	0.00	0.00
05.10.25	1.35	47.46	249.37	42.04	215.53	24.00	24.00	0.00	0.00
06.10.25	1.33	47.59	248.66	42.25	214.89	24.00	24.00	0.00	0.00
07.10.25	1.20	46.01	246.49	41.12	213.11	24.00	24.00	0.00	0.00
08.10.25	1.14	44.97	243.02	40.27	210.25	24.00	24.00	0.00	0.00
09.10.25	1.11	45.04	225.99	40.09	195.51	24.00	24.00	0.00	0.00
10.10.25	1.09	44.74	212.83	39.60	184.06	24.00	24.00	0.00	0.00
11.10.25	1.03	43.92	207.85	38.97	179.84	24.00	24.00	0.00	0.00
12.10.25	0.98	43.13	205.46	38.34	177.88	24.00	24.00	0.00	0.00
13.10.25	1.02	43.55	204.94	38.56	177.44	24.00	24.00	0.00	0.00
14.10.25	1.03	43.53	205.00	38.51	177.31	24.00	24.00	0.00	0.00
15.10.25	1.11	45.38	201.53	39.85	174.13	24.00	24.00	0.00	0.00
16.10.25	1.17	46.29	204.58	40.56	177.09	24.00	24.00	0.00	0.00
17.10.25	1.22	46.36	223.98	40.91	193.92	24.00	24.00	0.00	0.00
18.10.25	1.36	48.46	226.76	42.44	196.33	24.00	24.00	0.00	0.00
19.10.25	1.54	51.92	227.81	45.15	197.07	24.00	24.00	0.00	0.00
20.10.25	1.54	52.12	228.19	45.37	197.17	24.00	24.00	0.00	0.00
Итого	24.08	---	4335.63	---	3759.70	469.63	768.00	0.00	0.00
Среднее	---	34.731	---	31.198	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	4563.85	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 3
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BB585

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	15.10	0.00	14.75	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	15.03	0.00	14.69	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	14.99	0.00	14.68	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	14.93	0.00	14.62	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	15.27	0.00	15.14	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	15.41	7.87	15.15	0.02	9.77	24.00	0.00	0.00
25.09.25	0.01	15.56	19.84	15.28	0.00	24.00	24.00	0.00	0.00
26.09.25	0.00	15.65	4.37	14.68	0.00	5.69	24.00	0.00	0.00
27.09.25	0.59	30.91	171.38	28.19	171.24	14.75	24.00	0.00	0.00
28.09.25	1.07	44.24	314.36	40.82	314.07	24.00	24.00	0.00	0.00
29.09.25	1.07	43.49	310.87	40.03	309.89	24.00	24.00	0.00	0.00
30.09.25	1.13	43.16	305.34	39.42	302.85	24.00	24.00	0.00	0.00
01.10.25	1.34	44.62	237.01	38.88	240.12	24.00	24.00	0.00	0.00
02.10.25	1.45	46.61	193.78	39.12	213.62	24.00	24.00	0.00	0.00
03.10.25	1.57	48.94	199.68	40.76	221.57	24.00	24.00	0.00	0.00
04.10.25	1.53	47.79	246.23	41.55	272.37	24.00	24.00	0.00	0.00
05.10.25	0.48	32.64	238.48	41.30	268.12	4.90	24.00	0.00	0.00
06.10.25	1.18	45.47	242.25	41.50	266.73	19.15	24.00	0.00	0.00
07.10.25	1.37	46.23	239.84	40.50	264.21	24.00	24.00	0.00	0.00
08.10.25	1.44	45.80	236.32	39.67	259.95	24.00	24.00	0.00	0.00
09.10.25	0.54	40.69	220.08	39.50	241.85	15.25	24.00	0.00	0.00
10.10.25	0.61	41.19	206.63	39.00	227.23	19.47	24.00	0.00	0.00
11.10.25	0.93	43.02	201.61	38.40	221.42	24.00	24.00	0.00	0.00
12.10.25	0.59	40.76	199.40	37.78	218.74	23.78	24.00	0.00	0.00
13.10.25	0.77	41.75	198.82	37.85	218.04	23.99	24.00	0.00	0.00
14.10.25	1.15	43.65	198.75	37.85	217.97	24.00	24.00	0.00	0.00
15.10.25	1.24	45.43	195.42	39.05	214.07	24.00	24.00	0.00	0.00
16.10.25	1.32	46.40	197.49	39.71	216.35	24.00	24.00	0.00	0.00
17.10.25	1.37	46.50	217.93	40.20	239.08	24.00	24.00	0.00	0.00
18.10.25	1.51	48.41	219.57	41.50	240.96	24.00	24.00	0.00	0.00
19.10.25	1.71	52.06	220.64	44.28	241.77	24.00	24.00	0.00	0.00
20.10.25	1.69	52.23	220.98	44.55	242.10	24.00	24.00	0.00	0.00
Итого	27.66	---	5464.94	---	5844.34	568.75	768.00	0.00	0.00
Среднее	---	36.998	---	33.450	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	2552.52	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 40
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00178847

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0x1E75

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	19.04	26.42	-7.38	3.100	1.810	3.100	1.810	1.290	2.64	1.15	0.0000	0.0	24.0
20.09.25	19.28	18.88	0.40	3.360	1.680	3.360	1.680	1.680	2.67	1.33	0.0000	0.0	24.0
21.09.25	19.15	18.61	0.54	3.840	2.880	3.840	2.880	0.960	2.20	1.83	0.0000	0.0	24.0
22.09.25	19.11	18.55	0.56	3.360	0.720	3.360	0.720	2.640	1.96	2.35	0.0000	0.0	24.0
23.09.25	19.12	18.57	0.55	3.600	0.720	3.600	0.720	2.880	1.81	3.04	0.0000	0.0	24.0
24.09.25	19.22	18.68	0.54	2.880	0.720	2.880	0.720	2.160	1.71	3.69	0.0000	0.0	24.0
25.09.25	19.31	18.75	0.56	8.540	3.360	8.540	3.360	5.180	1.62	4.07	0.0030	0.0	24.0
26.09.25	19.04	18.53	0.51	45.810	5.520	45.810	5.520	40.290	1.56	4.03	0.0240	0.0	24.0
27.09.25	18.78	18.30	0.48	47.220	5.760	47.220	5.760	41.460	1.51	4.09	0.0240	0.0	24.0
28.09.25	18.39	17.94	0.45	44.210	5.760	44.210	5.760	38.450	1.47	3.98	0.0240	0.0	24.0
29.09.25	56.03	54.84	1.19	112.860	95.530	111.120	94.180	16.940	4.58	5.47	0.8350	0.0	24.0
30.09.25	65.26	56.50	8.76	168.790	173.470	165.560	170.930	-5.370	7.87	7.24	1.4490	0.0	24.0
01.10.25	65.34	57.05	8.29	174.940	177.050	171.560	174.410	-2.850	8.23	7.57	1.4190	0.0	24.0
02.10.25	65.97	58.34	7.63	188.060	191.340	184.340	188.330	-3.990	8.34	7.58	1.4070	0.0	24.0
03.10.25	67.18	59.76	7.42	194.670	197.690	190.740	194.480	-3.740	8.37	7.55	1.4180	0.0	24.0
04.10.25	67.26	60.19	7.07	200.140	202.660	196.040	199.280	-3.240	8.38	7.49	1.3880	0.0	24.0
05.10.25	66.21	59.27	6.94	191.830	194.360	188.010	191.240	-3.230	8.36	7.53	1.3070	0.0	24.0
06.10.25	65.95	58.78	7.17	183.720	186.320	180.090	183.340	-3.250	8.31	7.54	1.2940	0.0	24.0
07.10.25	66.57	59.36	7.21	182.150	184.780	178.510	181.800	-3.290	8.12	7.37	1.2910	0.0	24.0
08.10.25	66.36	59.43	6.93	185.390	187.640	181.720	184.610	-2.890	7.88	7.10	1.2590	0.0	24.0
09.10.25	66.60	59.60	7.00	183.630	185.720	179.960	182.690	-2.730	7.89	7.12	1.2640	0.0	24.0
10.10.25	66.23	59.20	7.03	179.220	181.050	175.640	178.170	-2.530	7.94	7.21	1.2370	0.0	24.0
11.10.25	65.82	58.87	6.95	178.570	181.130	175.070	178.270	-3.200	7.95	7.22	1.2180	0.0	24.0
12.10.25	65.97	58.78	7.19	176.150	178.980	172.700	176.150	-3.450	7.88	7.17	1.2420	0.0	24.0
13.10.25	67.06	59.62	7.44	175.150	177.690	171.580	174.820	-3.240	7.87	7.16	1.2810	0.0	24.0
14.10.25	65.97	58.92	7.05	178.680	180.540	175.150	177.660	-2.510	7.87	7.14	1.2380	0.0	24.0
15.10.25	66.45	59.25	7.20	180.000	182.150	176.390	179.220	-2.830	7.80	7.06	1.2730	0.0	24.0
16.10.25	66.39	58.96	7.43	177.360	179.840	173.840	176.970	-3.130	7.87	7.17	1.2930	0.0	24.0
17.10.25	66.24	58.82	7.42	175.720	177.970	172.290	175.100	-2.810	7.92	7.23	1.2800	0.0	24.0
18.10.25	66.56	58.97	7.59	173.010	175.920	169.580	173.050	-3.470	7.72	7.05	1.2850	0.0	24.0
19.10.25	66.90	59.39	7.51	173.940	176.530	170.380	173.650	-3.270	7.89	7.21	1.2820	0.0	24.0
20.10.25	66.33	59.12	7.21	178.490	180.830	174.910	177.920	-3.010	7.94	7.23	1.2620	0.0	24.0
Итого	---	---	---	4078.3	3978.1	4001.10	3915.20	85.900	---	---	28.2970	0.0	768.0
Среднее	51.22	46.44	4.77	---	---	---	---	---	6.00	5.87	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	26364.820	26913.340	25815.450	26515.440	300.1860	-699.990	2422.0	7068.0
20.10.25 24:00	30443.210	30891.459	29816.550	30430.640	328.4830	-614.090	2422.0	7836.0
Итого за период	4078.389	3978.118	4001.099	3915.200	28.2970	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 41
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BA775

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.01	17.95	5.26	16.76	5.26	24.00	24.00	0.00	0.00
20.09.25	0.01	17.80	5.24	16.53	5.24	24.00	24.00	0.00	0.00
21.09.25	0.01	18.05	5.28	16.81	5.28	24.00	24.00	0.00	0.00
22.09.25	0.01	18.22	4.41	17.06	4.41	24.00	24.00	0.00	0.00
23.09.25	0.00	19.26	3.53	18.36	3.53	24.00	24.00	0.00	0.00
24.09.25	0.00	19.74	3.12	18.72	3.12	23.60	24.00	0.00	0.00
25.09.25	0.00	20.73	3.12	19.85	3.12	23.60	24.00	0.00	0.00
26.09.25	0.01	17.69	6.36	16.43	6.36	24.00	24.00	0.00	0.00
27.09.25	1.63	38.63	403.78	35.78	404.61	23.55	24.00	0.00	0.00
28.09.25	3.47	64.75	790.59	60.35	792.43	23.60	24.00	0.00	0.00
29.09.25	3.83	67.10	781.11	62.20	783.19	23.60	24.00	0.00	0.00
30.09.25	4.04	66.31	840.47	61.48	842.65	23.60	24.00	0.00	0.00
01.10.25	3.66	65.67	800.02	61.10	801.99	23.60	24.00	0.00	0.00
02.10.25	3.39	65.62	857.74	61.66	859.57	23.60	24.00	0.00	0.00
03.10.25	3.50	66.41	911.82	62.58	913.71	23.60	24.00	0.00	0.00
04.10.25	4.11	67.70	923.63	63.26	925.89	24.00	24.00	0.00	0.00
05.10.25	4.63	67.76	946.99	62.86	949.53	23.60	24.00	0.00	0.00
06.10.25	4.42	66.69	936.45	61.97	938.84	23.60	24.00	0.00	0.00
07.10.25	4.30	66.48	899.46	61.70	901.79	24.00	24.00	0.00	0.00
08.10.25	4.27	67.13	884.14	62.30	886.46	24.00	24.00	0.00	0.00
09.10.25	4.14	66.88	902.08	62.30	904.33	24.00	24.00	0.00	0.00
10.10.25	4.11	67.16	910.56	62.64	912.81	24.00	24.00	0.00	0.00
11.10.25	4.03	66.80	934.73	62.49	936.92	24.00	24.00	0.00	0.00
12.10.25	4.00	66.36	939.39	62.10	941.56	24.00	24.00	0.00	0.00
13.10.25	4.02	66.53	911.01	62.11	913.19	24.00	24.00	0.00	0.00
14.10.25	4.15	67.66	900.66	63.04	902.94	24.00	24.00	0.00	0.00
15.10.25	4.01	66.56	894.93	62.08	897.10	24.00	24.00	0.00	0.00
16.10.25	4.07	67.07	886.51	62.47	888.73	24.00	24.00	0.00	0.00
17.10.25	4.16	66.97	888.91	62.29	891.18	24.00	24.00	0.00	0.00
18.10.25	4.19	66.83	873.00	62.02	875.27	24.00	24.00	0.00	0.00
19.10.25	4.20	67.16	850.68	62.22	852.97	24.00	24.00	0.00	0.00
20.10.25	4.20	67.52	849.89	62.58	852.19	24.00	24.00	0.00	0.00
Итого	94.58	---	20754.87	---	20806.17	763.55	768.00	0.00	0.00
Среднее	---	53.850	---	50.191	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	13357.66	4876.10
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 42
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00236004

БД=1, ТВ1, СИ=3, КТЗ=1, КСН=0х9966

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	17.47	17.59	-0.12	17.490	23.940	17.490	23.940	-6.450	1.14	1.06	0.0000	0.0	24.0
20.09.25	17.46	17.55	-0.09	17.500	23.060	17.500	23.060	-5.560	1.14	1.06	0.0000	0.0	24.0
21.09.25	17.43	17.55	-0.12	17.490	22.370	17.490	22.370	-4.880	1.14	1.06	0.0000	0.0	24.0
22.09.25	18.16	18.17	-0.01	17.500	22.120	17.500	22.120	-4.620	1.14	1.06	0.0000	0.0	24.0
23.09.25	18.33	18.43	-0.10	17.490	21.650	17.490	21.650	-4.160	1.14	1.06	0.0000	0.0	24.0
24.09.25	18.95	19.14	-0.19	17.480	21.510	17.480	21.510	-4.030	1.14	1.06	0.0000	0.0	24.0
25.09.25	18.06	18.59	-0.53	17.500	21.120	17.500	21.120	-3.620	1.10	1.05	0.0000	0.0	24.0
26.09.25	16.81	23.18	-6.37	16.100	23.960	16.100	23.910	-7.810	3.02	2.72	0.0120	0.0	24.0
27.09.25	36.45	21.30	15.15	19.250	15.240	19.150	15.210	3.940	7.89	6.82	0.3100	0.0	24.0
28.09.25	37.05	17.18	19.87	19.320	11.520	19.150	11.520	7.630	7.85	6.90	0.3800	0.0	24.0
29.09.25	52.88	28.88	24.00	30.940	23.250	30.560	23.160	7.400	7.83	6.88	0.8020	0.0	24.0
30.09.25	63.89	39.40	24.49	61.160	62.450	60.400	61.600	-1.200	7.93	7.20	1.4780	0.0	24.0
01.10.25	63.35	40.32	23.03	63.190	70.750	62.050	70.160	-8.110	8.28	7.52	1.4240	0.0	24.0
02.10.25	64.29	39.07	25.22	54.920	63.910	53.870	63.430	-9.560	8.40	7.52	1.3550	0.0	24.0
03.10.25	65.12	38.19	26.93	50.700	59.400	49.730	58.920	-9.190	8.44	7.49	1.3410	0.0	24.0
04.10.25	65.60	40.01	25.59	55.950	63.590	54.850	63.060	-8.210	8.45	7.43	1.4010	0.0	24.0
05.10.25	64.52	39.26	25.26	54.460	61.760	53.420	61.260	-7.840	8.43	7.47	1.3450	0.0	24.0
06.10.25	64.28	39.39	24.89	54.550	61.780	53.520	61.290	-7.770	8.36	7.49	1.3300	0.0	24.0
07.10.25	64.39	37.92	26.47	47.310	54.270	46.380	53.860	-7.480	8.18	7.32	1.2210	0.0	24.0
08.10.25	64.19	37.62	26.57	47.730	54.680	46.820	54.330	-7.510	7.93	7.05	1.2420	0.0	24.0
09.10.25	64.34	37.50	26.84	46.860	54.050	46.030	53.750	-7.720	7.95	7.01	1.2340	0.0	24.0
10.10.25	63.44	36.28	27.16	43.730	50.930	43.020	50.690	-7.670	7.86	6.95	1.1690	0.0	24.0
11.10.25	63.29	35.54	27.75	43.340	50.710	42.620	50.470	-7.850	8.01	7.02	1.1800	0.0	24.0
12.10.25	63.60	36.06	27.54	45.520	52.870	44.730	52.580	-7.850	7.95	6.98	1.2300	0.0	24.0
13.10.25	64.62	36.54	28.08	45.760	53.050	44.870	52.740	-7.870	7.93	6.98	1.2590	0.0	24.0
14.10.25	63.66	36.48	27.18	46.340	53.630	45.420	53.390	-7.970	7.93	6.95	1.2340	0.0	24.0
15.10.25	64.34	37.07	27.27	47.840	55.100	46.880	54.790	-7.910	7.86	6.87	1.2790	0.0	24.0
16.10.25	64.70	38.75	25.95	53.430	60.610	52.390	60.160	-7.770	7.94	6.99	1.3570	0.0	24.0
17.10.25	64.32	37.65	26.67	50.680	57.840	49.720	57.440	-7.720	7.98	7.05	1.3240	0.0	24.0
18.10.25	64.65	37.73	26.92	50.690	57.830	49.710	57.460	-7.750	7.78	6.87	1.3350	0.0	24.0
19.10.25	64.49	35.76	28.73	45.450	52.570	44.610	52.330	-7.720	7.95	7.03	1.2810	0.0	24.0
20.10.25	64.15	36.29	27.86	47.530	54.660	46.580	54.420	-7.840	8.01	7.05	1.2940	0.0	24.0
Итого	---	---	---	1265.2	1436.1	1245.03	1427.70	-182.670	---	---	28.8170	0.0	768.0
Среднее	50.57	31.57	18.99	---	---	---	---	---	6.38	5.66	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	44038.379	49810.310	43539.539	48755.659	664.5500	-5216.120	1781.0	16762.0
20.10.25 24:00	45303.579	51246.490	44784.570	50183.360	693.3670	-5398.790	1781.0	17530.0
Итого за период	1265.199	1436.180	1245.031	1427.701	28.8170	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 43
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BA714

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.01	18.55	1042.40	20.28	0.00	0.40	24.00	0.00	0.00
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-
26.09.25	0.00	27.57	0.00	30.12	0.00	0.00	24.00	0.00	0.00
27.09.25	1.49	39.17	160.37	37.48	152.85	9.29	24.00	0.00	0.00
28.09.25	0.11	32.84	12.67	39.90	9.38	0.36	24.00	0.00	0.00
29.09.25	0.00	23.87	0.00	38.81	0.00	0.00	24.00	0.00	0.00
30.09.25	3.48	46.03	281.59	44.20	280.05	14.29	24.00	0.00	0.00
01.10.25	5.02	57.76	489.98	47.53	487.87	23.37	24.00	0.00	0.00
02.10.25	6.50	61.46	518.11	48.92	516.33	24.00	24.00	0.00	0.00
03.10.25	6.82	63.27	542.38	50.69	544.88	24.00	24.00	0.00	0.00
04.10.25	6.26	62.76	534.70	51.03	537.38	24.00	24.00	0.00	0.00
05.10.25	6.75	63.78	523.25	50.86	527.90	24.00	24.00	0.00	0.00
06.10.25	6.22	62.79	513.79	50.66	517.60	23.60	24.00	0.00	0.00
07.10.25	5.13	59.48	489.48	49.04	489.99	23.46	24.00	0.00	0.00
08.10.25	4.92	59.20	477.12	48.87	479.76	23.59	24.00	0.00	0.00
09.10.25	4.70	62.05	482.74	52.29	487.77	23.57	24.00	0.00	0.00
10.10.25	2.28	48.12	355.19	43.32	360.64	19.31	24.00	0.00	0.00
11.10.25	0.98	38.22	283.35	34.79	287.77	22.23	24.00	0.00	0.00
12.10.25	1.45	39.72	249.23	33.82	252.95	20.02	24.00	0.00	0.00
13.10.25	3.24	45.66	325.26	36.27	329.82	24.00	24.00	0.00	0.00
14.10.25	3.03	48.45	295.20	39.29	300.26	22.46	24.00	0.00	0.00
15.10.25	3.02	50.27	334.22	41.01	339.87	23.59	24.00	0.00	0.00
16.10.25	5.02	63.64	594.75	55.19	600.99	24.00	24.00	0.00	0.00
17.10.25	4.25	62.15	590.96	54.94	596.61	24.00	24.00	0.00	0.00
18.10.25	4.19	61.77	579.45	54.77	585.66	23.15	24.00	0.00	0.00
19.10.25	4.74	63.07	569.02	54.85	574.90	23.22	24.00	0.00	0.00
20.10.25	5.96	65.76	569.53	55.29	574.88	24.00	24.00	0.00	0.00
Итого	95.57	---	10814.74	---	9836.11	487.91	624.00	0.00	0.00
Среднее	---	51.054	---	44.778	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	5612.36	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 45
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BA711

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	23.25	0.00	25.09	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	23.05	0.00	24.80	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	22.90	0.00	24.63	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	22.89	0.00	24.65	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	23.00	0.00	24.76	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	23.12	0.00	24.86	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	23.17	0.00	24.85	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	23.84	0.00	25.65	0.00	0.00	24.00	0.00	0.00
27.09.25	0.83	37.48	128.71	35.91	130.88	9.55	24.00	0.00	0.00
28.09.25	1.68	57.17	306.21	51.66	311.54	24.00	24.00	0.00	0.00
29.09.25	1.74	58.86	288.21	52.82	293.44	24.00	24.00	0.00	0.00
30.09.25	1.69	58.15	278.37	52.05	283.11	24.00	24.00	0.00	0.00
01.10.25	1.60	57.05	262.53	50.95	266.91	24.00	24.00	0.00	0.00
02.10.25	1.64	57.58	269.15	51.47	273.56	24.00	24.00	0.00	0.00
03.10.25	1.70	59.08	277.45	52.93	282.31	24.00	24.00	0.00	0.00
04.10.25	1.83	60.85	277.20	54.24	282.14	24.00	24.00	0.00	0.00
05.10.25	1.89	61.49	276.94	54.65	281.88	24.00	24.00	0.00	0.00
06.10.25	1.81	60.67	276.80	54.13	281.58	24.00	24.00	0.00	0.00
07.10.25	1.79	60.46	269.38	53.81	274.13	24.00	24.00	0.00	0.00
08.10.25	1.71	59.25	292.96	53.35	298.21	24.00	24.00	0.00	0.00
09.10.25	1.42	54.53	315.43	50.03	320.98	24.00	24.00	0.00	0.00
10.10.25	0.99	48.04	227.72	43.75	231.32	23.45	24.00	0.00	0.00
11.10.25	0.75	43.44	177.27	39.20	179.69	24.00	24.00	0.00	0.00
12.10.25	0.76	45.30	158.55	38.31	160.60	23.53	24.00	0.00	0.00
13.10.25	1.09	46.70	205.85	41.67	208.91	24.00	24.00	0.00	0.00
14.10.25	1.20	51.68	185.51	45.28	188.47	24.00	24.00	0.00	0.00
15.10.25	0.97	48.85	131.30	41.42	133.18	24.00	24.00	0.00	0.00
16.10.25	1.00	48.28	146.95	41.48	149.01	24.00	24.00	0.00	0.00
17.10.25	1.01	47.88	146.69	40.98	148.75	24.00	24.00	0.00	0.00
18.10.25	0.99	47.56	146.19	40.74	147.56	24.00	24.00	0.00	0.00
19.10.25	0.99	47.31	145.11	40.45	146.66	24.00	24.00	0.00	0.00
20.10.25	1.00	47.57	145.42	40.69	147.00	24.00	24.00	0.00	0.00
Итого	32.08	---	5335.90	---	5421.82	560.53	768.00	0.00	0.00
Среднее	---	45.327	---	41.289	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	5277.13	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 47
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BA727

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	20.89	0.00	21.26	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	20.85	0.00	21.20	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	20.92	0.00	21.29	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	21.10	0.00	21.43	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	21.64	0.00	23.43	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	23.07	0.00	27.83	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	24.35	0.00	28.68	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	24.16	0.00	30.12	0.00	0.00	24.00	0.00	0.00
27.09.25	0.80	35.72	111.06	36.89	113.85	9.24	24.00	0.00	0.00
28.09.25	2.06	56.06	296.78	49.11	302.05	24.00	24.00	0.00	0.00
29.09.25	2.27	57.79	286.41	49.85	291.67	24.00	24.00	0.00	0.00
30.09.25	2.31	57.05	280.66	48.80	286.47	24.00	24.00	0.00	0.00
01.10.25	2.32	56.07	269.40	47.43	275.73	24.00	24.00	0.00	0.00
02.10.25	2.42	56.43	276.87	47.69	284.16	24.00	24.00	0.00	0.00
03.10.25	2.59	58.00	288.59	49.00	295.20	24.00	24.00	0.00	0.00
04.10.25	2.71	59.69	286.77	50.22	293.54	24.00	24.00	0.00	0.00
05.10.25	2.74	60.39	285.45	50.77	292.12	24.00	24.00	0.00	0.00
06.10.25	2.63	59.59	285.29	50.35	291.61	24.00	24.00	0.00	0.00
07.10.25	2.59	59.36	278.36	50.04	284.58	24.00	24.00	0.00	0.00
08.10.25	2.48	58.23	302.75	49.95	309.01	24.00	24.00	0.00	0.00
09.10.25	2.10	53.62	330.39	47.26	336.07	24.00	24.00	0.00	0.00
10.10.25	1.51	47.29	241.83	41.12	245.92	23.48	24.00	0.00	0.00
11.10.25	1.13	42.57	184.96	36.43	188.64	24.00	24.00	0.00	0.00
12.10.25	0.96	44.49	148.49	35.84	150.78	22.29	24.00	0.00	0.00
13.10.25	1.07	45.40	151.46	38.64	153.69	24.00	24.00	0.00	0.00
14.10.25	1.37	50.94	154.32	42.28	158.75	23.42	24.00	0.00	0.00
15.10.25	1.43	47.93	137.60	37.44	139.06	24.00	24.00	0.00	0.00
16.10.25	1.46	47.39	152.25	37.76	154.69	24.00	24.00	0.00	0.00
17.10.25	1.47	47.00	151.67	37.31	154.37	24.00	24.00	0.00	0.00
18.10.25	1.45	46.67	151.19	37.05	153.83	24.00	24.00	0.00	0.00
19.10.25	1.45	46.43	150.04	36.72	152.65	24.00	24.00	0.00	0.00
20.10.25	1.43	46.68	148.49	37.01	151.06	24.00	24.00	0.00	0.00
Итого	44.75	---	5351.08	---	5459.50	558.43	768.00	0.00	0.00
Среднее	---	44.305	---	38.756	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	7167.07	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 53
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BA728

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	21.43	0.00	19.64	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	21.28	0.00	19.63	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	20.99	0.00	19.57	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	20.99	0.00	19.63	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	21.44	0.00	19.97	0.00	0.00	23.52	0.00	0.00
24.09.25	0.00	21.81	0.00	20.43	0.00	0.00	24.00	0.00	0.00
25.09.25	0.11	32.23	7.09	25.03	6.93	0.15	24.00	0.00	0.00
26.09.25	1.11	39.65	173.28	32.50	174.24	6.39	24.00	0.00	0.00
27.09.25	1.91	57.72	289.68	48.18	291.48	13.49	24.00	0.00	0.00
28.09.25	2.73	59.03	434.85	52.73	438.97	24.00	24.00	0.00	0.00
29.09.25	2.77	59.48	414.04	52.78	417.77	24.00	24.00	0.00	0.00
30.09.25	2.74	58.16	410.34	51.48	413.60	24.00	24.00	0.00	0.00
01.10.25	2.59	56.61	396.90	50.08	399.69	24.00	24.00	0.00	0.00
02.10.25	2.61	56.36	399.90	49.84	402.24	24.00	24.00	0.00	0.00
03.10.25	2.73	58.40	410.61	51.73	412.52	24.00	24.00	0.00	0.00
04.10.25	2.85	59.88	411.90	52.95	413.29	24.00	24.00	0.00	0.00
05.10.25	2.92	60.84	410.44	53.72	411.84	24.00	24.00	0.00	0.00
06.10.25	2.81	60.07	410.24	53.20	411.60	24.00	24.00	0.00	0.00
07.10.25	2.75	59.58	406.84	52.82	408.02	24.00	24.00	0.00	0.00
08.10.25	2.72	59.24	434.07	52.95	435.44	24.00	24.00	0.00	0.00
09.10.25	2.42	56.46	449.47	51.08	450.93	24.00	24.00	0.00	0.00
10.10.25	1.70	49.21	354.39	44.52	355.55	23.20	24.00	0.00	0.00
11.10.25	1.30	44.03	300.45	39.70	300.64	24.00	24.00	0.00	0.00
12.10.25	1.36	46.53	268.35	39.31	268.42	23.48	24.00	0.00	0.00
13.10.25	1.76	46.63	329.32	41.51	329.76	24.00	24.00	0.00	0.00
14.10.25	2.00	51.32	326.93	45.51	327.50	24.00	24.00	0.00	0.00
15.10.25	1.54	47.98	213.90	40.77	213.76	24.00	24.00	0.00	0.00
16.10.25	1.73	49.88	222.83	42.10	222.87	24.00	24.00	0.00	0.00
17.10.25	1.74	49.49	222.48	41.66	222.53	24.00	24.00	0.00	0.00
18.10.25	1.71	49.16	221.89	41.42	221.86	24.00	24.00	0.00	0.00
19.10.25	1.72	48.92	220.41	41.11	220.39	24.00	24.00	0.00	0.00
20.10.25	1.73	49.21	220.70	41.37	220.67	24.00	24.00	0.00	0.00
Итого	54.06	---	8361.30	---	8392.51	570.71	767.52	0.00	0.00
Среднее	---	46.688	---	40.904	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	9119.78	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 55/1
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00178835

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0х798С

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	21.88	23.71	-1.83	11.520	0.000	11.520	0.000	11.520	1.12	1.37	0.0000	0.0	24.0
20.09.25	21.97	23.77	-1.80	11.520	0.000	11.520	0.000	11.520	1.12	1.37	0.0000	0.0	24.0
21.09.25	22.00	23.80	-1.80	11.520	0.000	11.520	0.000	11.520	1.12	1.37	0.0000	0.0	24.0
22.09.25	22.27	24.00	-1.73	11.520	0.000	11.520	0.000	11.520	1.12	1.37	0.0000	0.0	24.0
23.09.25	22.41	24.18	-1.77	11.520	0.000	11.520	0.000	11.520	1.12	1.37	0.0000	0.0	24.0
24.09.25	22.59	24.31	-1.72	11.520	0.000	11.520	0.000	11.520	1.12	1.37	0.0000	0.0	24.0
25.09.25	22.38	24.17	-1.79	11.520	0.000	11.520	0.000	11.520	1.12	1.37	0.0000	0.0	24.0
26.09.25	53.82	50.01	3.81	92.810	85.550	91.650	84.440	7.210	3.20	3.15	0.5510	0.0	24.0
27.09.25	57.76	50.72	7.04	265.080	264.640	261.320	261.030	0.290	6.95	6.36	1.8390	0.0	24.0
28.09.25	58.10	49.90	8.20	263.330	262.960	259.510	259.510	0.000	6.92	6.42	2.1290	0.0	24.0
29.09.25	56.85	48.88	7.97	259.840	258.940	256.000	255.890	0.110	6.96	6.48	2.0400	0.0	24.0
30.09.25	55.10	47.43	7.67	249.500	247.590	246.010	244.960	1.050	7.09	6.66	1.8870	0.0	24.0
01.10.25	55.43	47.66	7.77	251.790	248.950	248.250	246.300	1.950	7.49	7.05	1.9260	0.0	24.0
02.10.25	57.07	49.11	7.96	256.570	253.570	252.730	250.690	2.040	7.62	7.15	2.0110	0.0	24.0
03.10.25	58.70	50.30	8.40	257.680	255.040	253.590	252.030	1.560	7.68	7.20	2.1260	0.0	24.0
04.10.25	59.42	50.65	8.77	258.570	256.330	254.390	253.210	1.180	7.68	7.21	2.2310	0.0	24.0
05.10.25	58.66	50.25	8.41	257.470	255.540	253.390	252.480	0.910	7.69	7.22	2.1300	0.0	24.0
06.10.25	58.23	49.92	8.31	253.420	251.710	249.480	248.800	0.680	7.64	7.18	2.0700	0.0	24.0
07.10.25	57.90	50.23	7.67	272.330	270.700	268.170	267.550	0.620	7.42	6.85	2.0540	0.0	24.0
08.10.25	54.95	48.37	6.58	282.010	280.700	278.100	277.610	0.490	6.99	6.37	1.8310	0.0	24.0
09.10.25	48.44	42.69	5.75	218.090	216.990	215.670	215.140	0.530	7.28	6.96	1.2390	0.0	24.0
10.10.25	43.05	37.83	5.22	185.130	184.230	183.490	183.030	0.460	7.56	7.42	0.9560	0.0	24.0
11.10.25	43.72	37.82	5.90	165.490	164.720	163.960	163.650	0.310	7.57	7.48	0.9650	0.0	24.0
12.10.25	47.94	41.41	6.53	208.830	207.930	206.510	206.240	0.270	7.41	7.15	1.3460	0.0	24.0
13.10.25	52.57	45.33	7.24	192.950	191.860	190.410	189.940	0.470	7.46	7.24	1.3740	0.0	24.0
14.10.25	46.94	38.53	8.41	131.970	131.000	130.690	130.060	0.630	7.52	7.56	1.0980	0.0	24.0
15.10.25	48.64	39.73	8.91	137.260	136.200	135.790	135.240	0.550	7.37	7.39	1.2060	0.0	24.0
16.10.25	48.27	39.32	8.95	136.990	136.020	135.550	135.060	0.490	7.56	7.59	1.2110	0.0	24.0
17.10.25	47.95	39.09	8.86	136.410	135.560	134.970	134.600	0.370	7.65	7.68	1.1960	0.0	24.0
18.10.25	47.73	38.85	8.88	135.360	134.540	133.920	133.580	0.340	7.41	7.44	1.1860	0.0	24.0
19.10.25	48.02	39.08	8.94	135.560	134.700	134.120	133.740	0.380	7.58	7.62	1.1950	0.0	24.0
20.10.25	47.75	38.91	8.84	135.750	134.960	134.320	134.000	0.320	7.63	7.66	1.1850	0.0	24.0
Итого	---	---	---	5220.8	5100.9	5152.63	5048.78	103.850	---	---	38.9820	0.0	768.0
Среднее	45.89	40.31	5.57	---	---	---	---	---	5.91	5.75	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	30489.730	30304.620	30077.300	29952.800	261.9350	124.500	2188.0	4234.0
20.10.25 24:00	35710.560	35405.549	35229.930	35001.579	300.9170	228.350	2188.0	5002.0
Итого за период	5220.829	5100.929	5152.630	5048.778	38.9820	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 55/1
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00179191

БД=1, ТВ1, СИ=1, КТЗ=1, ФРТ=0, КСН=0xФВЕ0

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Мг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	21.87	21.61	0.26	0.000	16.490	0.000	16.490	-16.490	7.00	7.00	0.0000	0.0	24.0
20.09.25	21.73	21.49	0.24	0.000	14.320	0.000	14.320	-14.320	7.00	7.00	0.0000	0.0	24.0
21.09.25	21.66	21.41	0.25	0.000	12.490	0.000	12.490	-12.490	7.00	7.00	0.0000	0.0	24.0
22.09.25	21.82	21.63	0.19	0.000	10.380	0.000	10.380	-10.380	7.00	7.00	0.0000	0.0	24.0
23.09.25	21.98	21.79	0.19	0.000	8.640	0.000	8.640	-8.640	7.00	7.00	0.0000	0.0	24.0
24.09.25	22.07	21.89	0.18	0.000	7.300	0.000	7.300	-7.300	7.00	7.00	0.0000	0.0	24.0
25.09.25	22.04	21.67	0.37	0.000	6.410	0.000	6.410	-6.410	7.00	7.00	0.0000	0.0	24.0
26.09.25	55.53	47.34	8.19	38.310	41.270	37.760	40.840	-3.080	7.00	7.00	0.2070	0.0	24.0
27.09.25	56.73	49.71	7.02	123.610	119.210	121.750	117.820	3.930	7.00	7.00	0.8550	0.0	24.0
28.09.25	57.08	49.71	7.37	117.480	113.670	115.750	112.400	3.350	7.00	7.00	0.8550	0.0	24.0
29.09.25	55.85	48.61	7.24	116.450	113.100	114.800	111.830	2.970	7.00	7.00	0.8310	0.0	24.0
30.09.25	54.15	46.62	7.53	117.480	113.920	115.920	112.810	3.110	7.00	7.00	0.8720	0.0	24.0
01.10.25	54.46	46.89	7.57	118.570	115.100	116.940	113.950	2.990	7.00	7.00	0.8830	0.0	24.0
02.10.25	56.08	48.34	7.74	121.420	117.500	119.740	116.300	3.440	7.00	7.00	0.9240	0.0	24.0
03.10.25	57.67	49.53	8.14	121.620	117.570	119.800	116.240	3.560	7.00	7.00	0.9710	0.0	24.0
04.10.25	58.38	50.02	8.36	121.120	116.880	119.200	115.440	3.760	7.00	7.00	0.9930	0.0	24.0
05.10.25	57.63	49.60	8.03	121.000	116.760	119.080	115.320	3.760	7.00	7.00	0.9570	0.0	24.0
06.10.25	57.21	49.35	7.86	119.900	115.590	118.100	114.290	3.810	7.00	7.00	0.9280	0.0	24.0
07.10.25	56.91	49.79	7.12	127.430	122.910	125.550	121.530	4.020	7.00	7.00	0.8920	0.0	24.0
08.10.25	54.74	48.20	6.54	90.140	87.240	88.920	86.320	2.600	7.00	7.00	0.5820	0.0	24.0
09.10.25	42.75	37.15	5.60	47.620	49.170	47.230	48.890	-1.660	7.00	7.00	0.2700	0.0	24.0
10.10.25	42.32	36.86	5.46	88.870	86.120	88.150	85.640	2.510	7.00	7.00	0.4810	0.0	24.0
11.10.25	42.91	36.89	6.02	79.520	76.650	78.860	76.220	2.640	7.00	7.00	0.4740	0.0	24.0
12.10.25	47.11	40.33	6.78	99.720	96.250	98.700	95.560	3.140	7.00	7.00	0.6710	0.0	24.0
13.10.25	51.65	44.22	7.43	92.750	89.360	91.570	88.480	3.090	7.00	7.00	0.6790	0.0	24.0
14.10.25	46.07	37.62	8.45	63.870	60.840	63.210	60.360	2.850	7.00	7.00	0.5350	0.0	24.0
15.10.25	47.76	38.73	9.03	66.440	63.310	65.720	62.830	2.890	7.00	7.00	0.5940	0.0	24.0
16.10.25	47.39	38.37	9.02	66.090	62.930	65.370	62.450	2.920	7.00	7.00	0.5870	0.0	24.0
17.10.25	47.08	38.07	9.01	65.880	62.730	65.160	62.250	2.910	7.00	7.00	0.5880	0.0	24.0
18.10.25	46.86	37.77	9.09	65.520	62.260	64.800	61.780	3.020	7.00	7.00	0.5850	0.0	24.0
19.10.25	47.15	37.99	9.16	65.620	62.420	64.900	61.940	2.960	7.00	7.00	0.5940	0.0	24.0
20.10.25	46.89	37.82	9.07	65.820	62.500	65.100	62.020	3.080	7.00	7.00	0.5890	0.0	24.0
Итого	---	---	---	2322.2	2321.2	2292.08	2299.54	-7.460	---	---	17.3970	0.0	768.0
Среднее	45.04	38.96	6.07	---	---	---	---	---	7.00	7.00	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Мг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	25811.910	26490.779	25451.010	26233.250	212.4770	-782.240	2494.0	6807.0
20.10.25 24:00	28134.159	28812.069	27743.089	28532.790	229.8740	-789.700	2494.0	7575.0
Итого за период	2322.249	2321.290	2292.079	2299.540	17.3970	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 55
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00179183

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0х7272

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	22.43	23.63	-1.20	0.000	0.000	0.000	0.000	0.000	1.02	6.00	0.0000	0.0	24.0
20.09.25	22.34	23.53	-1.19	0.000	0.000	0.000	0.000	0.000	1.02	6.00	0.0000	0.0	24.0
21.09.25	22.32	23.53	-1.21	0.000	0.000	0.000	0.000	0.000	1.02	6.00	0.0000	0.0	24.0
22.09.25	22.52	23.73	-1.21	0.000	0.000	0.000	0.000	0.000	1.02	6.00	0.0000	0.0	24.0
23.09.25	22.66	23.85	-1.19	0.000	0.000	0.000	0.000	0.000	1.02	6.00	0.0000	0.0	24.0
24.09.25	22.84	23.79	-0.95	0.000	0.000	0.000	0.000	0.000	1.02	6.00	0.0000	0.0	24.0
25.09.25	23.09	23.88	-0.79	0.000	0.000	0.000	0.000	0.000	1.02	6.00	0.0000	0.0	24.0
26.09.25	56.72	48.94	7.78	94.240	95.320	92.840	94.250	-1.410	3.07	5.90	0.7110	0.0	24.0
27.09.25	57.93	50.43	7.50	265.220	262.950	261.140	259.870	1.270	6.64	5.72	1.9560	0.0	24.0
28.09.25	58.26	50.43	7.83	254.950	252.410	250.940	249.380	1.560	6.61	5.78	1.9680	0.0	24.0
29.09.25	57.01	49.16	7.85	252.800	250.030	248.990	247.170	1.820	6.65	5.84	1.9560	0.0	24.0
30.09.25	55.22	47.20	8.02	252.600	249.200	249.020	246.580	2.440	6.78	6.03	1.9950	0.0	24.0
01.10.25	55.63	47.43	8.20	259.270	255.650	255.540	252.950	2.590	7.18	6.41	2.0920	0.0	24.0
02.10.25	57.25	48.91	8.34	265.590	261.440	261.510	258.560	2.950	7.31	6.51	2.1810	0.0	24.0
03.10.25	58.88	50.21	8.67	266.940	262.590	262.710	259.560	3.150	7.37	6.56	2.2810	0.0	24.0
04.10.25	59.58	50.69	8.89	267.270	263.010	262.950	259.890	3.060	7.37	6.57	2.3390	0.0	24.0
05.10.25	58.82	50.17	8.65	268.290	264.240	263.990	261.120	2.870	7.37	6.57	2.2830	0.0	24.0
06.10.25	58.40	49.81	8.59	265.620	261.750	261.460	258.710	2.750	7.33	6.54	2.2460	0.0	24.0
07.10.25	58.07	50.11	7.96	285.910	281.670	281.520	278.320	3.200	7.11	6.20	2.2440	0.0	24.0
08.10.25	55.12	48.30	6.82	294.280	290.070	290.140	286.860	3.280	6.69	5.73	1.9790	0.0	24.0
09.10.25	48.53	42.51	6.02	225.620	222.660	223.130	220.780	2.350	6.95	6.33	1.3380	0.0	24.0
10.10.25	43.21	37.74	5.47	193.230	191.220	191.550	190.020	1.530	7.22	6.79	1.0470	0.0	24.0
11.10.25	43.89	37.80	6.09	172.540	171.180	171.010	170.090	0.920	7.23	6.84	1.0400	0.0	24.0
12.10.25	48.22	41.42	6.80	218.400	216.060	216.020	214.360	1.660	7.08	6.51	1.4600	0.0	24.0
13.10.25	52.70	45.14	7.56	201.030	199.020	198.350	197.060	1.290	7.13	6.62	1.4900	0.0	24.0
14.10.25	47.13	38.12	9.01	137.670	137.180	136.180	136.220	-0.040	7.17	6.94	1.2250	0.0	24.0
15.10.25	48.82	39.34	9.48	143.270	142.630	141.640	141.670	-0.030	7.02	6.77	1.3410	0.0	24.0
16.10.25	48.44	38.91	9.53	142.950	142.370	141.370	141.410	-0.040	7.21	6.96	1.3460	0.0	24.0
17.10.25	48.12	38.62	9.50	142.470	141.980	140.960	141.020	-0.060	7.30	7.05	1.3400	0.0	24.0
18.10.25	47.91	38.31	9.60	141.490	141.010	140.050	140.050	0.000	7.06	6.82	1.3440	0.0	24.0
19.10.25	48.20	38.55	9.65	141.720	141.260	140.280	140.300	-0.020	7.24	6.99	1.3540	0.0	24.0
20.10.25	47.94	38.40	9.54	141.820	141.420	140.340	140.460	-0.120	7.28	7.03	1.3360	0.0	24.0
Итого	---	---	---	5295.1	5238.3	5223.63	5186.66	36.970	---	---	41.8920	0.0	768.0
Среднее	46.19	40.08	6.11	---	---	---	---	---	5.64	6.38	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	54977.840	53913.250	54182.979	53355.110	472.5360	827.870	2971.0	7260.0
20.10.25 24:00	60273.030	59151.570	59406.609	58541.769	514.4280	864.840	2971.0	8028.0
Итого за период	5295.190	5238.320	5223.629	5186.659	41.8920	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 57
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00182349

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0х4А0А

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	23.23	23.27	-0.04	4.860	38.880	4.860	38.880	-34.020	6.00	5.80	0.0000	0.0	24.0
20.09.25	22.47	22.93	-0.46	0.000	38.880	0.000	38.880	-38.880	6.00	5.80	0.0000	0.0	24.0
21.09.25	22.55	22.99	-0.44	0.000	38.880	0.000	38.880	-38.880	6.00	5.80	0.0000	0.0	24.0
22.09.25	23.13	23.75	-0.62	0.000	38.880	0.000	38.880	-38.880	6.00	5.80	0.0000	0.0	24.0
23.09.25	23.48	24.46	-0.98	0.000	38.880	0.000	38.880	-38.880	6.00	5.80	0.0000	0.0	24.0
24.09.25	23.78	24.71	-0.93	0.000	38.880	0.000	38.880	-38.880	6.00	5.80	0.0000	0.0	24.0
25.09.25	22.99	23.60	-0.61	0.000	38.880	0.000	38.880	-38.880	6.00	5.80	0.0000	0.0	24.0
26.09.25	46.83	42.80	4.03	589.780	549.660	583.680	544.930	38.750	6.00	5.80	2.1970	0.0	24.0
27.09.25	47.73	43.68	4.05	1120.320	1112.670	1108.330	1102.710	5.620	6.00	5.80	4.4860	0.0	24.0
28.09.25	48.11	43.73	4.38	1169.030	1151.080	1156.340	1140.690	15.650	6.00	5.80	5.0590	0.0	24.0
29.09.25	46.31	41.85	4.46	1159.720	1134.050	1148.040	1124.720	23.320	6.00	5.80	5.1200	0.0	24.0
30.09.25	56.85	50.21	6.64	1352.300	1343.220	1331.750	1327.090	4.660	6.00	5.80	8.9200	0.0	24.0
01.10.25	65.83	58.34	7.49	1667.500	1662.080	1634.750	1635.960	-1.210	6.00	5.80	12.2500	0.0	24.0
02.10.25	66.52	59.19	7.33	1707.230	1688.870	1673.080	1661.600	11.480	6.00	5.80	12.2590	0.0	24.0
03.10.25	58.53	52.46	6.07	1389.520	1358.950	1367.170	1341.180	25.990	6.00	5.80	8.4190	0.0	24.0
04.10.25	51.01	45.31	5.70	1198.100	1166.400	1183.570	1155.120	28.450	6.00	5.80	6.7410	0.0	24.0
05.10.25	50.40	44.83	5.57	1196.430	1167.030	1182.220	1156.010	26.210	6.00	5.80	6.5760	0.0	24.0
06.10.25	48.16	43.05	5.11	1173.900	1144.800	1161.120	1134.770	26.350	6.00	5.80	5.9290	0.0	24.0
07.10.25	46.21	41.55	4.66	1142.170	1114.650	1130.700	1105.560	25.140	6.00	5.80	5.2590	0.0	24.0
08.10.25	45.25	40.86	4.39	1115.980	1092.170	1105.230	1083.590	21.640	6.00	5.80	4.8460	0.0	24.0
09.10.25	46.14	41.48	4.66	1110.020	1088.080	1098.910	1079.270	19.640	6.00	5.80	5.1200	0.0	24.0
10.10.25	46.34	41.68	4.66	1116.130	1093.620	1104.870	1084.670	20.200	6.00	5.80	5.1440	0.0	24.0
11.10.25	46.86	41.78	5.08	991.820	973.600	981.590	965.600	15.990	6.00	5.80	4.9790	0.0	24.0
12.10.25	45.69	41.06	4.63	1109.300	1094.030	1098.420	1085.340	13.080	6.00	5.80	5.0780	0.0	24.0
13.10.25	45.91	41.05	4.86	1119.280	1104.470	1108.170	1095.690	12.480	6.00	5.80	5.3780	0.0	24.0
14.10.25	47.14	41.94	5.20	1148.850	1132.530	1136.820	1123.160	13.660	6.00	5.80	5.8930	0.0	24.0
15.10.25	50.52	44.29	6.23	1110.470	1092.750	1097.210	1082.640	14.570	6.00	5.80	6.8290	0.0	24.0
16.10.25	51.10	44.80	6.30	1184.680	1164.800	1170.220	1153.790	16.430	6.00	5.80	7.3690	0.0	24.0
17.10.25	51.17	45.28	5.89	1308.670	1285.550	1292.650	1273.150	19.500	6.00	5.80	7.6010	0.0	24.0
18.10.25	50.84	44.95	5.89	1312.650	1290.370	1296.790	1278.080	18.710	6.00	5.80	7.6290	0.0	24.0
19.10.25	51.16	45.25	5.91	1330.130	1306.880	1313.850	1294.270	19.580	6.00	5.80	7.7540	0.0	24.0
20.10.25	50.83	45.06	5.77	1329.600	1306.200	1313.520	1293.730	19.790	6.00	5.80	7.5670	0.0	24.0
Итого	---	---	---	30158.4	29890.6	29783.86	29595.48	188.380	---	---	164.4020	0.0	768.0
Среднее	44.47	40.38	4.09	---	---	---	---	---	6.00	5.80	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	290690.010	287076.670	285827.740	283478.990	2370.0100	2348.750	1846.0	7090.0
20.10.25 24:00	320848.449	316967.340	315611.600	313074.470	2534.4120	2537.130	1846.0	7858.0
Итого за период	30158.439	29890.670	29783.859	29595.479	164.4020	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 5
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ145

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	13.97	0.00	15.43	1.75	0.00	24.00	0.00	0.00
20.09.25	0.00	13.93	0.00	14.44	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	13.92	0.00	14.89	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	13.79	0.00	13.81	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	14.24	0.00	14.28	0.00	0.00	24.00	0.00	0.00
24.09.25	0	14.79	0.01	14.52	237.05	0.00	24.00	0.00	0.00
25.09.25	0.00	14.74	0.00	14.74	542.22	0.00	24.00	0.00	0.00
26.09.25	1.05	29.54	248.75	27.54	429.90	11.30	24.00	0.00	0.00
27.09.25	0.63	30.37	185.51	28.22	188.07	9.62	24.00	0.00	0.00
28.09.25	0.00	14.36	0.00	13.91	0.00	0.00	24.00	0.00	0.00
29.09.25	0.00	12.66	0.00	12.20	0.00	0.00	24.00	0.00	0.00
30.09.25	0.00	11.57	0.00	11.12	0.00	0.00	24.00	0.00	0.00
01.10.25	0.47	18.42	73.74	17.03	38.59	5.78	24.00	0.00	0.00
02.10.25	2.09	45.65	339.65	39.48	289.05	23.61	24.00	0.00	0.00
03.10.25	2.44	48.15	363.86	41.17	364.73	24.00	24.00	0.00	0.00
04.10.25	2.32	47.05	449.33	41.88	450.87	24.00	24.00	0.00	0.00
05.10.25	2.23	46.82	439.07	41.72	439.96	24.00	24.00	0.00	0.00
06.10.25	2.22	46.93	438.04	41.85	438.27	23.79	24.00	0.00	0.00
07.10.25	2.08	45.62	444.91	40.93	444.56	24.00	24.00	0.00	0.00
08.10.25	1.94	44.36	439.50	39.95	439.04	24.00	24.00	0.00	0.00
09.10.25	1.89	44.46	411.19	39.84	410.29	24.00	24.00	0.00	0.00
10.10.25	1.84	44.19	385.48	39.40	384.31	24.00	24.00	0.00	0.00
11.10.25	1.73	43.36	376.51	38.76	374.95	24.00	24.00	0.00	0.00
12.10.25	1.68	42.61	372.07	38.09	370.54	24.00	24.00	0.00	0.00
13.10.25	1.74	42.98	370.85	38.27	369.27	24.00	24.00	0.00	0.00
14.10.25	1.74	42.94	371.00	38.25	369.34	24.00	24.00	0.00	0.00
15.10.25	1.85	44.60	365.33	39.51	364.13	24.00	24.00	0.00	0.00
16.10.25	1.99	45.62	367.71	40.19	366.15	24.00	24.00	0.00	0.00
17.10.25	1.87	44.74	355.80	39.83	354.63	21.50	24.00	0.00	0.00
18.10.25	2.22	47.39	408.05	41.94	406.74	24.00	24.00	0.00	0.00
19.10.25	2.56	51.23	410.18	44.99	408.99	24.00	24.00	0.00	0.00
20.10.25	2.54	51.37	410.48	45.18	409.63	24.00	24.00	0.00	0.00
Итого	41.12	---	8027.02	---	8893.03	479.60	768.00	0.00	0.00
Среднее	---	33.949	---	30.730	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	5128.67	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 61
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00178760

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0х0С4Е

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	23.16	24.09	-0.93	0.000	0.000	0.000	0.000	0.000	6.20	2.65	0.0000	0.0	24.0
20.09.25	23.18	24.11	-0.93	0.000	0.000	0.000	0.000	0.000	6.20	2.65	0.0000	0.0	24.0
21.09.25	23.23	24.15	-0.92	0.000	0.000	0.000	0.000	0.000	6.20	2.66	0.0000	0.0	24.0
22.09.25	23.35	24.24	-0.89	0.000	0.000	0.000	0.000	0.000	6.20	2.66	0.0000	0.0	24.0
23.09.25	23.56	24.42	-0.86	0.000	0.000	0.000	0.000	0.000	6.20	2.58	0.0000	0.0	24.0
24.09.25	24.00	24.85	-0.85	0.000	0.000	0.000	0.000	0.000	6.20	2.37	0.0000	0.0	24.0
25.09.25	65.76	59.54	6.22	131.370	130.510	128.780	128.350	0.430	4.43	2.01	0.8130	0.0	24.0
26.09.25	65.75	59.97	5.78	359.420	360.270	352.320	354.300	-1.980	3.84	5.22	2.0230	0.0	24.0
27.09.25	64.78	59.16	5.62	352.850	354.350	346.130	348.640	-2.510	4.16	4.93	1.9390	0.0	24.0
28.09.25	65.24	59.63	5.61	358.040	359.580	351.120	353.710	-2.590	4.54	5.35	1.9650	0.0	24.0
29.09.25	65.50	59.66	5.84	346.210	348.480	339.460	342.750	-3.290	4.40	5.14	1.9750	0.0	24.0
30.09.25	66.58	60.20	6.38	325.640	328.070	319.060	322.630	-3.570	4.26	4.87	2.0280	0.0	24.0
01.10.25	67.83	61.75	6.08	352.450	355.220	345.100	349.010	-3.910	4.35	5.08	2.0910	0.0	24.0
02.10.25	68.07	62.71	5.36	406.360	406.790	397.820	399.470	-1.650	4.51	5.23	2.1260	0.0	24.0
03.10.25	66.94	61.13	5.81	342.900	343.360	335.940	337.480	-1.540	4.16	4.83	1.9480	0.0	24.0
04.10.25	66.26	57.35	8.91	211.920	212.110	207.670	208.840	-1.170	2.44	2.63	1.8500	0.0	24.0
05.10.25	66.33	57.69	8.64	214.690	215.420	210.360	212.040	-1.680	1.65	1.41	1.8170	0.0	24.0
06.10.25	66.51	58.21	8.30	225.490	225.920	220.960	222.360	-1.400	2.94	3.26	1.8300	0.0	24.0
07.10.25	65.96	57.93	8.03	225.750	226.840	221.290	223.330	-2.040	4.16	4.78	1.7730	0.0	24.0
08.10.25	66.23	57.71	8.52	209.320	210.010	205.150	206.760	-1.610	4.11	4.60	1.7460	0.0	24.0
09.10.25	65.76	57.36	8.40	208.730	209.960	204.590	206.730	-2.140	2.60	2.77	1.7150	0.0	24.0
10.10.25	65.28	56.00	9.28	178.330	178.770	174.860	176.140	-1.280	2.35	2.32	1.6200	0.0	24.0
11.10.25	65.16	54.12	11.04	146.490	146.900	143.650	144.890	-1.240	2.85	2.88	1.5830	0.0	24.0
12.10.25	64.96	53.82	11.14	145.670	146.320	142.920	144.320	-1.400	3.27	3.57	1.5870	0.0	24.0
13.10.25	65.06	53.79	11.27	145.190	145.480	142.370	143.510	-1.140	3.00	3.31	1.6020	0.0	24.0
14.10.25	65.09	53.90	11.19	144.300	144.370	141.510	142.380	-0.870	2.90	3.10	1.5820	0.0	24.0
15.10.25	65.39	54.00	11.39	146.160	146.250	143.310	144.250	-0.940	2.51	2.63	1.6300	0.0	24.0
16.10.25	65.38	54.75	10.63	162.180	162.290	159.020	159.990	-0.970	1.59	1.44	1.6860	0.0	24.0
17.10.25	65.60	55.17	10.43	167.590	167.740	164.310	165.340	-1.030	1.55	1.50	1.7140	0.0	24.0
18.10.25	65.89	55.05	10.84	159.620	160.570	156.480	158.280	-1.800	1.61	1.47	1.6920	0.0	24.0
19.10.25	65.12	54.40	10.72	158.990	159.290	155.880	157.070	-1.190	1.57	1.52	1.6700	0.0	24.0
20.10.25	65.51	54.92	10.59	161.820	162.230	158.680	159.920	-1.240	1.60	1.47	1.6800	0.0	24.0
Итого	---	---	---	5987.4	6007.0	5868.74	5912.49	-43.750	---	---	45.6850	0.0	768.0
Среднее	57.88	51.11	6.77	---	---	---	---	---	3.70	3.22	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	17462.190	17456.180	17113.090	17271.080	318.0300	-157.990	2690.0	6804.0
20.10.25 24:00	23449.670	23463.280	22981.829	23183.569	363.7150	-201.740	2690.0	7572.0
Итого за период	5987.480	6007.099	5868.739	5912.488	45.6850	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 63а
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ859

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	0.00	21.04	0.00	20.68	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	21.47	0.00	21.02	0.00	0.00	24.00	0.00	0.00
26.09.25	0.60	37.23	83.11	34.38	80.91	8.85	24.00	0.00	0.00
27.09.25	1.42	65.19	219.95	58.73	220.37	24.00	24.00	0.00	0.00
28.09.25	1.38	64.21	218.27	57.87	219.19	24.00	24.00	0.00	0.00
29.09.25	1.39	64.65	221.07	58.35	222.04	24.00	24.00	0.00	0.00
30.09.25	1.46	64.83	217.78	58.10	218.61	24.00	24.00	0.00	0.00
01.10.25	1.61	66.00	215.69	58.53	216.03	24.00	24.00	0.00	0.00
02.10.25	1.67	67.17	233.07	59.98	233.58	24.00	24.00	0.00	0.00
03.10.25	1.69	67.42	266.60	61.09	267.40	24.00	24.00	0.00	0.00
04.10.25	1.63	66.21	282.45	60.44	283.21	24.00	24.00	0.00	0.00
05.10.25	1.65	65.89	289.92	60.18	290.41	24.00	24.00	0.00	0.00
06.10.25	1.63	65.93	294.23	60.38	294.79	24.00	24.00	0.00	0.00
07.10.25	1.55	66.08	250.56	59.52	251.40	24.00	24.00	0.00	0.00
08.10.25	1.42	65.56	166.07	56.99	166.65	24.00	24.00	0.00	0.00
09.10.25	1.41	65.82	164.96	57.23	165.57	24.00	24.00	0.00	0.00
10.10.25	1.40	65.34	165.02	56.86	165.61	24.00	24.00	0.00	0.00
11.10.25	1.36	64.97	159.26	56.43	159.84	24.00	24.00	0.00	0.00
12.10.25	1.36	64.98	153.97	56.14	154.46	24.00	24.00	0.00	0.00
13.10.25	1.37	64.76	153.43	55.79	153.91	24.00	24.00	0.00	0.00
14.10.25	1.38	64.87	152.56	55.82	153.04	24.00	24.00	0.00	0.00
15.10.25	1.38	64.92	151.42	55.82	151.88	24.00	24.00	0.00	0.00
16.10.25	1.40	65.22	153.35	56.07	153.85	24.00	24.00	0.00	0.00
17.10.25	1.44	65.13	169.86	56.62	170.46	24.00	24.00	0.00	0.00
18.10.25	1.47	65.35	175.37	56.96	176.00	24.00	24.00	0.00	0.00
19.10.25	1.47	65.66	168.00	56.88	168.57	24.00	24.00	0.00	0.00
20.10.25	1.42	64.89	166.80	56.35	167.27	24.00	24.00	0.00	0.00
Итого	35.96	---	4892.77	---	4905.05	584.85	648.00	0.00	0.00
Среднее	---	61.140	---	54.193	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	105.00	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 65
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ552

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	0.00	20.75	0.00	22.98	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	20.99	0.00	23.21	0.00	0.00	24.00	0.00	0.00
26.09.25	1.03	37.93	153.99	36.77	153.30	8.98	24.00	0.00	0.00
27.09.25	2.39	66.13	400.66	60.16	404.70	24.00	24.00	0.00	0.00
28.09.25	2.35	65.15	401.72	59.29	405.25	24.00	24.00	0.00	0.00
29.09.25	2.42	65.60	409.47	59.68	412.74	24.00	24.00	0.00	0.00
30.09.25	2.42	65.80	370.91	59.22	374.01	24.00	24.00	0.00	0.00
01.10.25	2.46	67.01	330.43	59.55	333.58	24.00	24.00	0.00	0.00
02.10.25	2.58	68.20	360.06	60.99	363.12	24.00	24.00	0.00	0.00
03.10.25	2.60	68.46	413.71	62.17	417.14	24.00	24.00	0.00	0.00
04.10.25	2.49	67.24	435.67	61.52	437.35	24.00	24.00	0.00	0.00
05.10.25	2.51	66.93	444.79	61.29	443.00	24.00	24.00	0.00	0.00
06.10.25	2.48	66.97	451.53	61.47	449.04	24.00	24.00	0.00	0.00
07.10.25	2.48	67.14	485.20	61.99	482.25	24.00	24.00	0.00	0.00
08.10.25	2.44	66.66	525.15	62.00	522.26	24.00	24.00	0.00	0.00
09.10.25	2.42	66.93	520.61	62.27	518.11	24.00	24.00	0.00	0.00
10.10.25	2.39	66.45	519.35	61.84	517.25	24.00	24.00	0.00	0.00
11.10.25	2.33	66.08	500.28	61.42	498.41	24.00	24.00	0.00	0.00
12.10.25	2.34	66.10	483.18	61.26	480.92	24.00	24.00	0.00	0.00
13.10.25	2.37	65.87	481.47	60.95	479.43	24.00	24.00	0.00	0.00
14.10.25	2.37	66.00	479.04	61.06	476.51	24.00	24.00	0.00	0.00
15.10.25	2.35	66.05	475.90	61.10	473.28	24.00	24.00	0.00	0.00
16.10.25	2.41	66.36	481.56	61.35	478.95	24.00	24.00	0.00	0.00
17.10.25	2.46	66.27	532.74	61.63	530.17	23.94	24.00	0.00	0.00
18.10.25	2.49	66.49	550.42	61.96	547.98	24.00	24.00	0.00	0.00
19.10.25	2.49	66.82	527.06	62.09	524.53	24.00	24.00	0.00	0.00
20.10.25	2.41	66.03	523.37	61.42	520.68	24.00	24.00	0.00	0.00
Итого	59.48	---	11258.27	---	11243.96	584.92	648.00	0.00	0.00
Среднее	---	62.089	---	57.431	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	2901.49	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 67
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ410

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	20.50	0.00	21.02	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	20.52	0.00	21.06	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	20.82	0.00	21.35	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	21.10	0.00	21.63	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	21.67	0.00	22.19	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	22.14	0.00	22.63	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	22.81	0.00	23.29	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	23.11	0.00	23.28	0.00	0.00	24.00	0.00	0.00
27.09.25	0.00	26.74	0.00	26.29	0.00	0.00	24.00	0.00	0.00
28.09.25	0.00	26.81	0.00	26.34	0.00	0.00	24.00	0.00	0.00
29.09.25	0.00	25.83	0.00	25.33	0.00	0.00	24.00	0.00	0.00
30.09.25	3.29	50.58	293.81	43.03	293.59	15.46	24.00	0.00	0.00
01.10.25	4.97	66.07	469.62	55.47	473.60	24.00	24.00	0.00	0.00
02.10.25	5.06	67.34	511.44	57.38	515.23	24.00	24.00	0.00	0.00
03.10.25	5.08	67.49	585.17	58.79	588.81	24.00	24.00	0.00	0.00
04.10.25	4.79	66.22	610.40	58.36	613.99	24.00	24.00	0.00	0.00
05.10.25	4.64	65.98	601.31	58.26	604.35	24.00	24.00	0.00	0.00
06.10.25	4.58	66.00	615.13	58.55	617.94	24.00	24.00	0.00	0.00
07.10.25	4.29	66.12	505.94	56.93	509.47	24.00	24.00	0.00	0.00
08.10.25	3.88	65.74	314.80	53.38	319.43	24.00	24.00	0.00	0.00
09.10.25	3.89	65.91	312.87	53.46	317.49	24.00	24.00	0.00	0.00
10.10.25	3.79	65.42	311.34	53.23	315.96	24.00	24.00	0.00	0.00
11.10.25	3.69	65.10	299.21	52.75	303.68	24.00	24.00	0.00	0.00
12.10.25	3.69	65.17	289.58	52.40	293.96	24.00	24.00	0.00	0.00
13.10.25	3.76	64.88	288.01	51.79	292.40	24.00	24.00	0.00	0.00
14.10.25	3.76	65.03	286.96	51.91	291.42	24.00	24.00	0.00	0.00
15.10.25	3.75	65.07	284.95	51.90	289.14	24.00	24.00	0.00	0.00
16.10.25	3.84	65.43	289.17	52.12	293.36	24.00	24.00	0.00	0.00
17.10.25	4.00	65.26	321.59	52.78	325.90	24.00	24.00	0.00	0.00
18.10.25	4.08	65.51	331.18	53.16	335.31	24.00	24.00	0.00	0.00
19.10.25	4.09	65.83	317.57	52.92	321.63	24.00	24.00	0.00	0.00
20.10.25	3.93	65.06	314.46	52.53	318.41	24.00	24.00	0.00	0.00
Итого	86.85	---	8154.51	---	8235.07	495.46	768.00	0.00	0.00
Среднее	---	50.539	---	43.297	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	6611.87	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 69
 Потребитель: АО "Жилуправление"
 Прибор: ТЭМ-106 Заводской номер: 3060268
 Формула: $Q = M1(h1 - h2)$
 Тип системы: Подача + расходомер

Система: 1

ТВ1

	ДУ, мм	Gmin, м3/ч	Gmax, м3/ч	Kv, л/имп	Fmax, КГц
1	80	8	192	10	---
2	80	8.1	194.4	10	---

Дата	Q, (Гкал)	M1, (т)	M2, (т)	dM, (т)	T1, (°C)	T2, (°C)	P1, (МПа)	P2, (МПа)	Время наработки, (ч)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-
28.09.25	-	-	-	-	-	-	-	-	-
29.09.25	-	-	-	-	-	-	-	-	-
30.09.25	н/д	н/д	н/д	н/д	50.812	45.961	0.5	0.5	н/д
01.10.25	3.025	535.90	531.84	4.1	53.576	47.930	0.5	0.5	24.00
02.10.25	3.671	552.08	548.02	4.1	60.605	53.958	0.5	0.5	24.00
03.10.25	2.793	539.26	535.19	4.1	53.252	48.076	0.5	0.5	24.00
04.10.25	2.668	538.20	534.14	4.1	51.510	46.550	0.5	0.5	24.00
05.10.25	2.651	538.12	534.08	4.0	51.869	46.941	0.5	0.5	24.00
06.10.25	2.160	527.00	522.93	4.1	47.945	43.844	0.5	0.5	24.00
07.10.25	1.935	528.64	524.38	4.3	45.388	41.724	0.5	0.5	24.00
08.10.25	1.897	525.42	521.19	4.2	45.383	41.769	0.5	0.5	24.00
09.10.25	1.775	488.31	484.28	4.0	44.924	41.287	0.5	0.5	24.00
10.10.25	2.033	520.74	516.14	4.6	46.710	42.803	0.5	0.5	24.00
11.10.25	2.174	468.60	464.77	3.8	48.458	43.825	0.5	0.5	24.00
12.10.25	2.240	526.27	522.17	4.1	48.117	43.858	0.5	0.5	24.00
13.10.25	2.224	525.28	521.11	4.2	48.049	43.812	0.5	0.5	24.00
14.10.25	2.225	525.29	521.20	4.1	48.271	44.032	0.5	0.5	24.00
15.10.25	2.314	525.46	521.38	4.1	48.571	44.163	0.5	0.5	24.00
16.10.25	2.421	526.23	522.18	4.1	49.112	44.509	0.5	0.5	24.00
17.10.25	2.474	526.73	522.69	4.0	49.547	44.847	0.5	0.5	24.00
18.10.25	2.438	526.78	522.73	4.1	49.226	44.595	0.5	0.5	24.00
19.10.25	2.387	526.70	522.65	4.0	48.805	44.270	0.5	0.5	24.00
20.10.25	2.435	526.76	522.72	4.0	49.245	44.618	0.5	0.5	24.00
Итого	47.94	10497.8	10415.8	82.1	---	---	---	---	480.00
Среднее	---	---	---	---	49.49	44.92	0.5	0.5	---

Показания интеграторов

Дата	Q, (Гкал)	M1, (т)	M2, (т)	Время наработки, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д
20.10.25 24:00	10926.6	959995.4	956754.0	77458.8
Итого за период	н/д	н/д	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 71
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BA722

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	0.07	20.33	63.89	19.21	91.89	24.00	24.00	0.00	0.00
21.09.25	0.04	20.32	35.30	19.24	103.04	24.00	24.00	0.00	0.00
22.09.25	0.02	20.56	22.02	19.53	95.35	21.56	24.00	0.00	0.00
23.09.25	0.01	20.85	12.75	19.93	81.10	14.41	24.00	0.00	0.00
24.09.25	0.02	21.39	24.95	20.40	59.35	23.37	24.00	0.00	0.00
25.09.25	0.02	22.11	20.20	21.08	30.70	21.03	24.00	0.00	0.00
26.09.25	1.67	41.16	217.67	37.18	160.97	10.37	24.00	0.00	0.00
27.09.25	3.11	62.46	405.08	56.89	403.49	19.42	24.00	0.00	0.00
28.09.25	1.20	34.96	259.10	34.08	258.55	12.03	24.00	0.00	0.00
29.09.25	2.56	49.71	522.88	44.80	522.41	24.00	24.00	0.00	0.00
30.09.25	2.92	53.26	518.07	47.59	517.75	24.00	24.00	0.00	0.00
01.10.25	3.05	54.59	496.44	48.45	495.82	24.00	24.00	0.00	0.00
02.10.25	2.95	52.47	498.57	46.62	498.20	24.00	24.00	0.00	0.00
03.10.25	3.94	62.22	543.75	55.00	542.92	24.00	24.00	0.00	0.00
04.10.25	3.05	54.80	534.60	49.10	534.13	24.00	24.00	0.00	0.00
05.10.25	2.83	52.28	532.63	46.95	532.77	24.00	24.00	0.00	0.00
06.10.25	2.83	52.67	532.76	47.34	533.19	24.00	24.00	0.00	0.00
07.10.25	2.41	49.62	525.04	45.03	525.65	24.00	24.00	0.00	0.00
08.10.25	1.85	45.51	480.86	41.66	479.41	22.57	24.00	0.00	0.00
09.10.25	1.88	46.15	510.59	42.46	511.04	24.00	24.00	0.00	0.00
10.10.25	1.94	45.87	521.21	42.14	521.46	23.51	24.00	0.00	0.00
11.10.25	2.10	47.01	524.78	43.00	524.66	24.00	24.00	0.00	0.00
12.10.25	2.12	47.90	460.45	43.65	460.21	21.06	24.00	0.00	0.00
13.10.25	2.42	49.01	526.19	44.41	526.52	24.00	24.00	0.00	0.00
14.10.25	2.49	48.79	532.76	44.10	532.70	24.00	24.00	0.00	0.00
15.10.25	2.48	49.01	533.71	44.35	533.53	24.00	24.00	0.00	0.00
16.10.25	2.51	49.27	534.07	44.57	534.13	24.00	24.00	0.00	0.00
17.10.25	2.62	49.80	534.74	44.88	535.14	24.00	24.00	0.00	0.00
18.10.25	2.68	50.36	535.43	45.35	535.91	24.00	24.00	0.00	0.00
19.10.25	2.66	49.95	534.94	44.97	535.49	24.00	24.00	0.00	0.00
20.10.25	2.60	49.66	534.74	44.80	535.39	24.00	24.00	0.00	0.00
Итого	63.05	---	12530.17	---	12752.87	693.33	744.00	0.00	0.00
Среднее	---	44.324	---	40.283	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	10315.23	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 77
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ582

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	20.18	0.00	21.65	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	20.16	0.00	21.62	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	20.17	0.00	21.61	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	20.20	0.00	21.63	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	20.32	0.00	21.76	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	20.71	0.00	22.19	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	21.13	0.00	22.63	0.00	0.00	24.00	0.00	0.00
26.09.25	0.10	28.42	21.82	27.87	6.64	7.99	24.00	0.00	0.00
27.09.25	0.55	46.01	99.41	40.74	30.54	24.00	24.00	0.00	0.00
28.09.25	0.88	48.61	127.98	41.72	39.42	24.00	24.00	0.00	0.00
29.09.25	0.89	49.02	124.96	41.87	38.60	24.00	24.00	0.00	0.00
30.09.25	1.03	48.75	130.53	40.86	40.63	24.00	24.00	0.00	0.00
01.10.25	1.19	49.59	136.81	40.86	42.71	24.00	24.00	0.00	0.00
02.10.25	1.33	51.97	144.59	42.93	44.96	24.00	24.00	0.00	0.00
03.10.25	1.08	49.06	110.20	39.27	34.49	24.00	24.00	0.00	0.00
04.10.25	-	-	-	-	-	-	-	-	-
05.10.25	-	-	-	-	-	-	-	-	-
06.10.25	-	-	-	-	-	-	-	-	-
07.10.25	-	-	-	-	-	-	-	-	-
08.10.25	-	-	-	-	-	-	-	-	-
09.10.25	-	-	-	-	-	-	-	-	-
10.10.25	1.07	46.04	272.75	42.03	83.78	24.00	24.00	0.00	0.00
11.10.25	1.02	46.18	212.36	41.36	65.53	24.00	24.00	0.00	0.00
12.10.25	0.98	48.32	183.13	40.49	56.26	24.00	24.00	0.00	0.00
13.10.25	1.01	45.76	211.31	40.96	65.48	24.00	24.00	0.00	0.00
14.10.25	1.00	45.52	210.88	40.75	65.35	24.00	24.00	0.00	0.00
15.10.25	1.10	47.20	215.47	42.11	66.71	24.00	24.00	0.00	0.00
16.10.25	1.18	48.62	219.32	43.24	68.01	24.00	24.00	0.00	0.00
17.10.25	1.22	49.10	221.03	43.58	68.57	23.99	24.00	0.00	0.00
18.10.25	1.23	49.50	221.58	43.92	68.67	24.00	24.00	0.00	0.00
19.10.25	1.20	49.27	219.86	43.81	68.08	24.00	24.00	0.00	0.00
20.10.25	1.19	48.46	219.37	43.04	67.92	24.00	24.00	0.00	0.00
Итого	19.25	---	3303.36	---	1022.35	439.98	624.00	0.00	0.00
Среднее	---	39.933	---	35.942	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	336.05	0.00
20.10.25 24:00	357.53	0.00
Итого за период	21.48	0.00

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 79
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00179020

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0x586В

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	18.08	18.35	-0.27	0.000	0.000	0.000	0.000	0.000	1.00	5.08	0.0000	0.0	24.0
20.09.25	18.22	18.47	-0.25	0.000	0.000	0.000	0.000	0.000	1.00	5.06	0.0000	0.0	24.0
21.09.25	18.32	18.56	-0.24	0.000	0.000	0.000	0.000	0.000	1.00	5.05	0.0000	0.0	24.0
22.09.25	18.84	19.07	-0.23	0.000	0.000	0.000	0.000	0.000	1.00	5.05	0.0000	0.0	24.0
23.09.25	19.29	19.54	-0.25	0.000	0.000	0.000	0.000	0.000	1.00	5.05	0.0000	0.0	24.0
24.09.25	20.00	20.26	-0.26	0.000	0.000	0.000	0.000	0.000	1.00	5.07	0.0000	0.0	24.0
25.09.25	44.71	37.87	6.84	30.290	29.210	29.990	29.010	0.980	2.95	5.68	0.2070	0.0	24.0
26.09.25	46.70	38.52	8.18	103.110	101.610	102.080	100.900	1.180	6.90	6.86	0.8340	0.0	24.0
27.09.25	49.03	38.89	10.14	118.450	116.920	117.110	116.130	0.980	7.04	6.96	1.1860	0.0	24.0
28.09.25	49.43	38.81	10.62	117.890	116.470	116.490	115.720	0.770	7.07	6.98	1.2360	0.0	24.0
29.09.25	49.13	38.38	10.75	116.730	113.490	115.390	112.720	2.670	7.06	6.96	1.2370	0.0	24.0
30.09.25	49.94	38.17	11.77	114.700	112.940	113.360	112.220	1.140	7.47	7.36	1.3300	0.0	24.0
01.10.25	54.74	41.78	12.96	124.360	122.450	122.610	121.450	1.160	7.53	7.40	1.5870	0.0	24.0
02.10.25	49.54	36.18	13.36	96.860	95.230	95.820	94.680	1.140	7.46	7.38	1.2770	0.0	24.0
03.10.25	50.71	36.86	13.85	97.520	96.550	96.350	95.990	0.360	7.48	7.40	1.3340	0.0	24.0
04.10.25	50.41	36.44	13.97	95.920	95.080	94.720	94.580	0.140	7.49	7.40	1.3220	0.0	24.0
05.10.25	50.62	36.73	13.89	96.310	95.660	95.110	95.090	0.020	7.53	7.44	1.3180	0.0	24.0
06.10.25	46.14	39.13	7.01	199.840	198.790	197.830	197.370	0.460	7.74	7.45	1.3840	0.0	24.0
07.10.25	45.69	40.14	5.55	264.610	263.120	262.050	261.110	0.940	7.88	7.46	1.4550	0.0	24.0
08.10.25	46.40	40.85	5.55	265.200	263.640	262.530	261.590	0.940	7.87	7.44	1.4590	0.0	24.0
09.10.25	46.12	40.69	5.43	269.070	267.390	266.410	265.310	1.100	7.88	7.44	1.4460	0.0	24.0
10.10.25	46.30	40.99	5.31	275.770	273.960	273.010	271.800	1.210	7.82	7.37	1.4480	0.0	24.0
11.10.25	47.08	40.90	6.18	240.950	239.280	238.450	237.420	1.030	7.81	7.43	1.4690	0.0	24.0
12.10.25	45.86	40.58	5.28	275.130	273.200	272.410	271.110	1.300	7.90	7.45	1.4380	0.0	24.0
13.10.25	45.62	40.30	5.32	274.570	272.680	271.890	270.620	1.270	7.88	7.44	1.4450	0.0	24.0
14.10.25	47.35	41.69	5.66	280.590	278.470	277.660	276.190	1.470	7.94	7.49	1.5690	0.0	24.0
15.10.25	48.78	42.79	5.99	285.340	283.170	282.190	280.790	1.400	8.02	7.55	1.6870	0.0	24.0
16.10.25	49.26	43.10	6.16	287.750	285.500	284.510	283.060	1.450	8.17	7.70	1.7550	0.0	24.0
17.10.25	49.65	43.36	6.29	288.990	286.730	285.680	284.220	1.460	8.14	7.67	1.7970	0.0	24.0
18.10.25	49.42	43.13	6.29	287.600	285.430	284.330	282.960	1.370	7.93	7.46	1.7870	0.0	24.0
19.10.25	48.60	42.53	6.07	285.720	283.560	282.550	281.160	1.390	7.93	7.47	1.7130	0.0	24.0
20.10.25	49.34	43.10	6.24	287.970	285.700	284.700	283.240	1.460	7.95	7.48	1.7730	0.0	24.0
Итого	---	---	---	5181.2	5136.2	5125.23	5096.44	28.790	---	---	36.4930	0.0	768.0
Среднее	42.79	36.13	6.66	---	---	---	---	---	6.28	6.89	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	59728.720	59840.340	58852.880	59196.650	489.6510	-343.770	2833.0	6658.0
20.10.25 24:00	64909.959	64976.570	63978.110	64293.090	526.1440	-314.980	2833.0	7426.0
Итого за период	5181.239	5136.230	5125.230	5096.439	36.4930	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 7
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ395

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.36	16.46	752.42	15.98	0.00	24.00	24.00	0.00	0.00
20.09.25	0.49	16.50	1012.34	16.02	0.00	24.00	24.00	0.00	0.00
21.09.25	0.50	16.57	1059.47	16.09	0.00	24.00	24.00	0.00	0.00
22.09.25	0.48	16.61	1024.79	16.14	0.00	24.00	24.00	0.00	0.00
23.09.25	0.47	16.81	1008.59	16.35	0.00	24.00	24.00	0.00	0.00
24.09.25	0.48	16.90	981.96	16.41	0.00	24.00	24.00	0.00	0.00
25.09.25	0.35	16.96	979.54	16.62	0.00	21.84	24.00	0.00	0.00
26.09.25	0.40	16.69	911.03	16.25	0.00	24.00	24.00	0.00	0.00
27.09.25	0.47	16.16	799.43	15.56	0.00	24.00	24.00	0.00	0.00
28.09.25	0.43	16.11	727.92	15.51	0.00	24.00	24.00	0.00	0.00
29.09.25	0.41	15.79	643.66	15.16	0.00	24.00	24.00	0.00	0.00
30.09.25	1.28	32.52	416.15	28.78	197.80	23.77	24.00	0.00	0.00
01.10.25	1.92	44.92	273.66	37.89	274.08	24.00	24.00	0.00	0.00
02.10.25	2.09	46.74	271.20	39.02	270.31	24.00	24.00	0.00	0.00
03.10.25	2.26	49.00	286.58	40.80	284.65	24.00	24.00	0.00	0.00
04.10.25	2.19	47.86	352.67	41.64	349.92	24.00	24.00	0.00	0.00
05.10.25	2.17	47.66	352.31	41.48	349.24	24.00	24.00	0.00	0.00
06.10.25	2.14	47.79	352.09	41.69	349.07	24.00	24.00	0.00	0.00
07.10.25	1.95	46.27	350.62	40.69	347.76	24.00	24.00	0.00	0.00
08.10.25	1.83	45.17	348.29	39.90	345.28	24.00	24.00	0.00	0.00
09.10.25	1.80	45.25	342.13	39.96	339.22	23.92	24.00	0.00	0.00
10.10.25	1.77	44.96	337.25	39.70	334.26	24.00	24.00	0.00	0.00
11.10.25	1.67	44.13	331.90	39.10	328.91	24.00	24.00	0.00	0.00
12.10.25	1.60	43.35	330.71	38.50	327.77	24.00	24.00	0.00	0.00
13.10.25	1.68	43.77	330.56	38.68	327.52	24.00	24.00	0.00	0.00
14.10.25	1.68	43.74	330.63	38.65	327.45	24.00	24.00	0.00	0.00
15.10.25	1.83	45.55	327.68	39.96	324.43	24.00	24.00	0.00	0.00
16.10.25	1.92	46.49	338.17	40.78	334.79	24.00	24.00	0.00	0.00
17.10.25	1.99	46.58	375.91	41.26	372.13	24.00	24.00	0.00	0.00
18.10.25	2.23	48.56	388.81	42.80	384.69	24.00	24.00	0.00	0.00
19.10.25	2.55	52.13	391.07	45.60	386.74	24.00	24.00	0.00	0.00
20.10.25	2.53	52.31	391.30	45.82	386.91	24.00	24.00	0.00	0.00
Итого	45.92	---	17120.84	---	6942.93	765.53	768.00	0.00	0.00
Среднее	---	35.822	---	31.837	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	5607.49	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 81
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BA652

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0	26.01	0.01	23.97	0.00	24.00	24.00	0.00	0.00
20.09.25	0	25.88	0.04	23.92	0.00	24.00	24.00	0.00	0.00
21.09.25	0	25.82	0.03	23.92	0.00	24.00	24.00	0.00	0.00
22.09.25	0	25.74	0.02	23.82	0.00	24.00	24.00	0.00	0.00
23.09.25	0	25.62	0.06	23.92	0.00	23.43	24.00	0.00	0.00
24.09.25	0	25.58	0.06	24.20	0.00	23.50	24.00	0.00	0.00
25.09.25	0	25.76	0.01	24.58	0.00	24.00	24.00	0.00	0.00
26.09.25	0.41	32.09	43.99	28.08	0.00	23.38	24.00	0.00	0.00
27.09.25	1.16	46.58	127.46	37.45	0.00	24.00	24.00	0.00	0.00
28.09.25	1.55	49.01	141.06	38.04	0.00	24.00	24.00	0.00	0.00
29.09.25	1.81	49.45	152.06	37.51	0.00	24.00	24.00	0.00	0.00
30.09.25	1.90	49.14	156.68	36.98	0.00	24.00	24.00	0.00	0.00
01.10.25	2.13	49.98	164.63	36.99	90.23	24.00	24.00	0.00	0.00
02.10.25	2.44	52.34	172.91	38.61	168.25	24.00	24.00	0.00	0.00
03.10.25	1.94	49.52	132.23	34.80	130.11	24.00	24.00	0.00	0.00
04.10.25	1.99	50.69	132.20	35.64	130.06	24.00	24.00	0.00	0.00
05.10.25	1.96	50.41	129.86	35.27	127.83	24.00	24.00	0.00	0.00
06.10.25	1.96	50.63	130.54	35.59	128.50	24.00	24.00	0.00	0.00
07.10.25	2.07	47.19	274.50	38.01	271.04	24.00	24.00	0.00	0.00
08.10.25	2.18	45.82	361.17	39.76	356.88	24.00	24.00	0.00	0.00
09.10.25	2.18	46.50	361.48	40.45	357.19	24.00	24.00	0.00	0.00
10.10.25	2.16	46.22	368.00	40.34	363.85	24.00	24.00	0.00	0.00
11.10.25	2.17	46.40	379.18	40.68	375.23	24.00	24.00	0.00	0.00
12.10.25	2.15	49.31	329.60	39.75	326.18	24.00	24.00	0.00	0.00
13.10.25	2.17	45.95	377.59	40.18	373.68	24.00	24.00	0.00	0.00
14.10.25	2.19	45.73	377.26	39.92	373.33	24.00	24.00	0.00	0.00
15.10.25	2.35	47.44	385.17	41.32	381.33	24.00	24.00	0.00	0.00
16.10.25	2.56	48.90	391.96	42.36	388.12	24.00	24.00	0.00	0.00
17.10.25	2.64	49.36	394.93	42.68	391.11	24.00	24.00	0.00	0.00
18.10.25	2.69	49.75	396.49	42.97	392.71	24.00	24.00	0.00	0.00
19.10.25	2.67	49.53	394.40	42.74	390.58	24.00	24.00	0.00	0.00
20.10.25	2.54	48.70	391.85	42.22	387.99	24.00	24.00	0.00	0.00
Итого	51.97	---	6667.43	---	5904.20	766.31	768.00	0.00	0.00
Среднее	---	43.033	---	35.521	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	11275.91	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 85
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВА709

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.09	67.19	151.10	66.58	149.37	24.00	24.00	0.00	0.00
20.09.25	0.09	67.54	151.95	66.98	150.22	24.00	24.00	0.00	0.00
21.09.25	0.09	67.41	152.45	66.84	150.71	24.00	24.00	0.00	0.00
22.09.25	0.09	66.57	151.18	66.00	149.44	24.00	24.00	0.00	0.00
23.09.25	0.10	65.95	146.43	65.24	144.70	24.00	24.00	0.00	0.00
24.09.25	0.09	66.67	147.23	66.05	145.57	24.00	24.00	0.00	0.00
25.09.25	0.11	67.19	173.03	66.53	170.94	24.00	24.00	0.00	0.00
26.09.25	0.78	66.58	267.49	64.63	263.09	24.00	24.00	0.00	0.00
27.09.25	1.82	66.24	427.02	61.98	419.99	24.00	24.00	0.00	0.00
28.09.25	1.79	66.55	410.97	62.19	404.18	24.00	24.00	0.00	0.00
29.09.25	1.87	67.85	409.41	63.27	403.04	24.00	24.00	0.00	0.00
30.09.25	1.94	68.34	403.42	63.50	397.91	24.00	24.00	0.00	0.00
01.10.25	2.09	69.85	413.06	64.84	407.60	24.00	24.00	0.00	0.00
02.10.25	2.25	69.34	435.44	64.17	428.27	24.00	24.00	0.00	0.00
03.10.25	2.16	68.53	458.10	63.81	449.19	24.00	24.00	0.00	0.00
04.10.25	2.11	68.20	469.34	63.70	459.89	24.00	24.00	0.00	0.00
05.10.25	2.15	68.69	476.48	64.17	466.63	24.00	24.00	0.00	0.00
06.10.25	2.13	68.66	480.16	64.21	470.24	24.00	24.00	0.00	0.00
07.10.25	2.11	68.48	496.92	64.23	486.90	24.00	24.00	0.00	0.00
08.10.25	2.07	68.05	507.67	63.98	496.97	24.00	24.00	0.00	0.00
09.10.25	2.04	68.23	505.82	64.19	494.39	24.00	24.00	0.00	0.00
10.10.25	2.04	67.70	504.24	63.66	492.71	24.00	24.00	0.00	0.00
11.10.25	1.99	67.66	506.47	63.73	494.85	24.00	24.00	0.00	0.00
12.10.25	2.03	67.85	507.59	63.84	496.11	24.00	24.00	0.00	0.00
13.10.25	2.08	67.68	504.08	63.54	492.70	24.00	24.00	0.00	0.00
14.10.25	2.12	67.84	501.44	63.61	490.24	24.00	24.00	0.00	0.00
15.10.25	2.08	67.81	489.59	63.55	478.81	24.00	24.00	0.00	0.00
16.10.25	2.08	68.21	484.25	63.91	473.66	24.00	24.00	0.00	0.00
17.10.25	2.13	68.00	501.89	63.76	490.73	24.00	24.00	0.00	0.00
18.10.25	2.16	68.26	501.56	63.94	490.56	24.00	24.00	0.00	0.00
19.10.25	2.19	68.65	483.72	64.12	473.44	24.00	24.00	0.00	0.00
20.10.25	2.11	67.83	478.17	63.41	467.97	24.00	24.00	0.00	0.00
Итого	50.98	---	12697.67	---	12451.02	768.00	768.00	0.00	0.00
Среднее	---	67.800	---	64.317	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	3801.13	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

ИМ2300, Суточный с 19.09.25 по 20.10.25

Объект: None
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BA717

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	23.32	0.00	22.70	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	23.23	0.00	22.91	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	23.11	0.00	22.87	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	23.14	0.00	22.87	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	23.20	0.00	22.90	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	23.31	0.00	22.94	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	22.93	0.00	22.59	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	22.89	0.00	22.66	0.00	0.00	23.59	0.00	0.00
27.09.25	0.23	32.60	73.92	30.75	75.39	13.15	24.00	0.00	0.00
28.09.25	0.48	44.39	139.82	40.93	143.34	24.00	24.00	0.00	0.00
29.09.25	0.50	43.63	146.03	40.22	150.11	24.00	24.00	0.00	0.00
30.09.25	0.53	43.27	143.60	39.54	147.20	24.00	24.00	0.00	0.00
01.10.25	0.64	44.46	118.48	39.05	121.57	24.00	24.00	0.00	0.00
02.10.25	0.68	46.10	116.09	40.25	119.10	24.00	24.00	0.00	0.00
03.10.25	0.73	48.70	117.46	42.12	120.51	24.00	24.00	0.00	0.00
04.10.25	0.72	47.65	154.08	42.98	158.57	24.00	24.00	0.00	0.00
05.10.25	0.43	47.37	92.36	42.69	158.01	12.46	24.00	0.00	0.00
06.10.25	0.05	47.49	10.33	42.88	158.50	0.54	24.00	0.00	0.00
07.10.25	0.01	46.25	3.43	41.99	158.15	0.33	24.00	0.00	0.00
08.10.25	0.13	44.89	32.33	40.97	157.10	2.34	24.00	0.00	0.00
09.10.25	0.58	45.00	147.56	41.09	154.85	22.22	24.00	0.00	0.00
10.10.25	0.59	44.75	147.50	40.78	151.92	24.00	24.00	0.00	0.00
11.10.25	0.54	43.93	144.88	40.21	149.13	24.00	24.00	0.00	0.00
12.10.25	0.52	43.18	144.43	39.55	148.62	24.00	24.00	0.00	0.00
13.10.25	0.55	43.52	144.17	39.70	148.41	24.00	24.00	0.00	0.00
14.10.25	0.55	43.48	144.15	39.62	148.41	24.00	24.00	0.00	0.00
15.10.25	0.60	45.09	142.66	40.91	146.94	24.00	24.00	0.00	0.00
16.10.25	0.64	46.17	146.09	41.77	150.49	24.00	24.00	0.00	0.00
17.10.25	0.67	46.36	162.40	42.23	167.12	24.00	24.00	0.00	0.00
18.10.25	0.73	47.82	170.67	43.52	175.59	24.00	24.00	0.00	0.00
19.10.25	0.86	51.86	168.43	46.76	173.37	24.00	24.00	0.00	0.00
20.10.25	0.84	51.98	168.50	46.96	173.48	24.00	24.00	0.00	0.00
Итого	12.80	---	2979.37	---	3555.88	483.04	767.59	0.00	0.00
Среднее	---	39.846	---	36.560	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	2522.75	5051.46
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 8
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BA729

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	22.18	0.00	20.18	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	22.36	0.00	20.39	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	22.26	0.00	20.42	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	22.11	0.00	20.33	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	22.05	0.00	20.49	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	22.10	0.00	20.55	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	22.40	0.00	20.83	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	22.47	0.00	20.78	0.00	0.00	24.00	0.00	0.00
27.09.25	0.33	32.86	96.37	30.09	97.92	14.36	24.00	0.00	0.00
28.09.25	0.58	43.90	153.87	40.11	156.49	24.00	24.00	0.00	0.00
29.09.25	0.60	43.14	150.27	39.16	152.85	24.00	24.00	0.00	0.00
30.09.25	0.59	42.78	145.49	38.67	148.01	24.00	24.00	0.00	0.00
01.10.25	0.63	44.05	121.31	38.85	123.61	24.00	24.00	0.00	0.00
02.10.25	0.67	45.78	119.35	40.17	121.60	24.00	24.00	0.00	0.00
03.10.25	0.72	48.13	124.05	42.07	126.25	24.00	24.00	0.00	0.00
04.10.25	0.71	47.12	153.42	42.49	155.76	24.00	24.00	0.00	0.00
05.10.25	0.71	46.89	151.94	42.24	154.34	24.00	24.00	0.00	0.00
06.10.25	0.71	47.02	151.17	42.33	153.48	24.00	24.00	0.00	0.00
07.10.25	0.65	45.61	150.74	41.32	153.01	24.00	24.00	0.00	0.00
08.10.25	0.60	44.44	149.49	40.40	151.65	24.00	24.00	0.00	0.00
09.10.25	0.59	44.53	147.13	40.50	149.26	24.00	24.00	0.00	0.00
10.10.25	0.59	44.25	143.94	40.18	146.20	24.00	24.00	0.00	0.00
11.10.25	0.55	43.43	141.01	39.51	143.33	24.00	24.00	0.00	0.00
12.10.25	0.53	42.66	140.33	38.86	142.63	24.00	24.00	0.00	0.00
13.10.25	0.56	43.04	140.66	39.06	142.92	24.00	24.00	0.00	0.00
14.10.25	0.55	43.01	140.76	39.07	142.91	24.00	24.00	0.00	0.00
15.10.25	0.60	44.71	139.35	40.41	141.54	24.00	24.00	0.00	0.00
16.10.25	0.63	45.71	143.63	41.27	145.97	24.00	24.00	0.00	0.00
17.10.25	0.67	45.86	157.04	41.62	159.34	24.00	24.00	0.00	0.00
18.10.25	0.74	47.65	163.74	43.14	165.88	24.00	24.00	0.00	0.00
19.10.25	0.84	51.34	160.16	46.07	162.36	24.00	24.00	0.00	0.00
20.10.25	0.84	51.50	159.52	46.23	161.64	24.00	24.00	0.00	0.00
Итого	15.19	---	3444.74	---	3498.95	566.36	768.00	0.00	0.00
Среднее	---	39.292	---	35.556	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	2658.37	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 9
 Потребитель: АО "Жилуправление"
 Прибор: ТЭМ-106 Заводской номер: 3060274
 Формула: $Q = M1(h1 - h2)$
 Тип системы: Подача + расходомер

Система: 1

ТВ1

	ДУ, мм	Gmin, м3/ч	Gmax, м3/ч	Kv, л/имп	Fmax, КГц
1	80	8	160	10	---
2	80	8	160	10	---

Дата	Q, (Гкал)	M1, (т)	M2, (т)	dM, (т)	T1, (°C)	T2, (°C)	P1, (МПа)	P2, (МПа)	Время наработки, (ч)
19.09.25	0.000	0.00	0.00	0.0	14.908	14.840	0.9	0.6	24.00
20.09.25	0.000	0.00	0.00	0.0	14.887	14.819	0.9	0.6	24.00
21.09.25	0.000	0.00	0.00	0.0	14.864	14.775	0.9	0.6	24.00
22.09.25	0.000	0.00	0.00	0.0	15.130	15.027	0.9	0.6	24.00
23.09.25	0.000	0.00	0.00	0.0	15.262	15.151	0.9	0.6	24.00
24.09.25	0.000	0.00	0.00	0.0	19.525	17.519	0.9	0.6	24.00
25.09.25	0.000	0.00	0.00	0.0	18.721	15.621	0.9	0.6	24.00
26.09.25	0.000	0.00	0.00	0.0	16.418	14.681	0.9	0.6	24.00
27.09.25	0.000	0.00	0.00	0.0	16.443	14.515	0.9	0.6	24.00
28.09.25	0.000	0.00	0.00	0.0	15.770	13.952	0.9	0.6	24.00
29.09.25	0.581	79.77	77.44	2.3	42.945	35.733	0.9	0.6	24.00
30.09.25	1.712	216.18	211.52	4.7	44.573	36.706	0.9	0.6	24.00
01.10.25	1.801	211.71	207.69	4.0	46.341	37.885	0.9	0.6	24.00
02.10.25	1.912	217.30	213.47	3.8	48.621	39.874	0.9	0.6	24.00
03.10.25	1.877	275.31	270.38	4.9	47.612	40.851	0.9	0.6	24.00
04.10.25	1.853	275.21	270.07	5.1	47.377	40.700	0.9	0.6	24.00
05.10.25	1.824	275.27	270.02	5.2	47.495	40.923	0.9	0.6	24.00
06.10.25	1.704	275.68	270.40	5.3	46.102	39.978	0.9	0.6	24.00
07.10.25	1.636	277.06	271.79	5.3	44.865	39.017	0.9	0.6	24.00
08.10.25	1.600	273.03	267.92	5.1	44.967	39.162	0.9	0.6	24.00
09.10.25	1.565	267.61	262.71	4.9	44.697	38.906	0.9	0.6	24.00
10.10.25	1.471	262.97	258.18	4.8	43.856	38.319	0.9	0.6	24.00
11.10.25	1.416	261.90	257.09	4.8	43.082	37.734	0.9	0.6	24.00
12.10.25	1.480	261.70	256.99	4.7	43.475	37.874	0.9	0.6	24.00
13.10.25	1.479	261.62	256.86	4.8	43.431	37.833	0.9	0.6	24.00
14.10.25	1.610	259.54	254.79	4.7	45.150	39.001	0.9	0.6	24.00
15.10.25	1.711	266.60	261.68	4.9	46.181	39.819	0.9	0.6	24.00
16.10.25	1.778	295.82	290.31	5.5	46.299	40.347	0.9	0.6	24.00
17.10.25	1.983	305.04	299.19	5.9	48.033	41.590	0.9	0.6	24.00
18.10.25	2.280	307.60	301.47	6.1	51.869	44.512	0.9	0.6	24.00
19.10.25	2.266	307.80	301.67	6.1	52.015	44.710	0.9	0.6	24.00
20.10.25	2.120	308.24	302.19	6.1	50.705	43.885	0.9	0.6	24.00
Итого	37.66	5743.0	5633.8	109.0	---	---	---	---	768.00
Среднее	---	---	---	---	36.93	32.07	0.9	0.6	---

Показания интеграторов

Дата	Q, (Гкал)	M1, (т)	M2, (т)	Время наработки, (ч)
18.09.25 24:00	4927.1	489655.0	488589.0	50747.1
20.10.25 24:00	4964.8	495398.0	494222.8	51515.1
Итого за период	37.7	5743.0	5633.8	768.0

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Садовое кольцо, 12а
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00166946

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0хВ242

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	15.31	15.25	0.06	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
22.09.25	15.34	15.27	0.07	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
23.09.25	15.41	15.33	0.08	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
24.09.25	15.56	15.44	0.12	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
25.09.25	15.59	15.46	0.13	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
26.09.25	38.90	34.21	4.69	77.970	74.610	77.420	74.210	3.210	5.92	5.88	0.3640	0.0	24.0
27.09.25	40.04	35.44	4.60	193.230	189.040	191.790	187.860	3.930	5.41	5.42	0.8810	0.0	24.0
28.09.25	40.28	35.73	4.55	215.960	212.000	214.340	210.670	3.670	5.42	5.44	0.9730	0.0	24.0
29.09.25	42.81	37.44	5.37	225.000	221.490	223.000	220.010	2.990	5.41	5.44	1.1930	0.0	24.0
30.09.25	47.25	39.58	7.67	189.460	186.670	187.450	185.300	2.150	5.33	5.31	1.4340	0.0	24.0
01.10.25	47.20	39.58	7.62	200.030	196.880	197.890	195.440	2.450	5.38	5.36	1.5020	0.0	24.0
02.10.25	47.26	39.83	7.43	202.680	199.390	200.520	197.950	2.570	5.32	5.31	1.4860	0.0	24.0
03.10.25	47.96	40.41	7.55	204.920	201.250	202.700	199.730	2.970	5.33	5.31	1.5270	0.0	24.0
04.10.25	47.96	40.31	7.65	203.560	199.830	201.400	198.330	3.070	5.38	5.35	1.5400	0.0	24.0
05.10.25	47.89	40.41	7.48	204.650	200.750	202.480	199.210	3.270	5.46	5.40	1.5110	0.0	24.0
06.10.25	46.96	39.85	7.11	203.970	200.130	201.840	198.680	3.160	5.37	5.36	1.4310	0.0	24.0
07.10.25	44.83	38.53	6.30	206.130	202.320	204.180	200.860	3.320	5.35	5.33	1.2800	0.0	24.0
08.10.25	44.92	38.60	6.32	203.260	199.420	201.340	197.980	3.360	5.43	5.46	1.2690	0.0	24.0
09.10.25	44.73	38.42	6.31	202.950	199.210	201.030	197.770	3.260	5.46	5.42	1.2680	0.0	24.0
10.10.25	44.53	38.40	6.13	202.970	199.240	201.050	197.800	3.250	5.37	5.38	1.2280	0.0	24.0
11.10.25	44.28	38.25	6.03	205.570	201.670	203.670	200.240	3.430	5.38	5.39	1.2260	0.0	24.0
12.10.25	44.89	38.41	6.48	202.860	199.020	200.940	197.580	3.360	5.61	5.61	1.2990	0.0	24.0
13.10.25	46.59	39.66	6.93	206.310	202.380	204.160	200.930	3.230	5.43	5.42	1.4160	0.0	24.0
14.10.25	46.19	39.63	6.56	209.030	205.110	206.920	203.640	3.280	5.38	5.42	1.3540	0.0	24.0
15.10.25	46.84	39.77	7.07	203.490	199.550	201.330	198.110	3.220	5.49	5.44	1.4240	0.0	24.0
16.10.25	46.70	39.49	7.21	202.960	199.290	200.800	197.850	2.950	5.32	5.34	1.4430	0.0	24.0
17.10.25	48.03	40.25	7.78	201.410	197.810	199.170	196.290	2.880	5.30	5.26	1.5470	0.0	24.0
18.10.25	50.59	42.07	8.52	202.270	198.380	199.870	196.720	3.150	5.48	5.43	1.7010	0.0	24.0
19.10.25	51.68	43.14	8.54	209.820	205.780	207.180	203.960	3.220	5.49	5.45	1.7640	0.0	24.0
20.10.25	50.46	42.40	8.06	207.650	203.670	205.180	201.870	3.310	5.31	5.29	1.6510	0.0	24.0
Итого	---	---	---	4988.1	4894.8	4937.65	4858.99	78.660	---	---	33.7120	0.0	720.0
Среднее	40.89	35.21	5.68	---	---	---	---	---	5.67	5.62	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
19.09.25 24:00	0	0	0	0	0	0	0	0
20.10.25 24:00	50307.590	49353.059	49647.420	48914.050	462.0090	733.370	0.0	9827.0
Итого за период	50307.590	49353.059	49647.420	48914.050	462.0090	---	0.0	9827.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Садовое кольцо, 14а
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00169005

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0хD931

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	16.30	15.85	0.45	0.000	0.000	0.000	0.000	0.000	1.00	1.24	0.0000	0.0	24.0
20.09.25	16.27	15.81	0.46	0.000	0.000	0.000	0.000	0.000	1.00	1.22	0.0000	0.0	24.0
21.09.25	16.24	15.78	0.46	0.000	0.000	0.000	0.000	0.000	1.00	1.22	0.0000	0.0	24.0
22.09.25	16.34	15.84	0.50	0.000	0.000	0.000	0.000	0.000	1.00	1.21	0.0000	0.0	24.0
23.09.25	16.44	15.92	0.52	0.000	0.000	0.000	0.000	0.000	1.00	1.20	0.0000	0.0	24.0
24.09.25	16.54	15.95	0.59	0.000	0.000	0.000	0.000	0.000	1.00	1.20	0.0000	0.0	24.0
25.09.25	45.61	42.16	3.45	238.980	242.930	236.630	240.900	-4.270	2.79	2.73	0.8180	0.0	24.0
26.09.25	42.89	39.97	2.92	455.040	461.280	451.110	457.760	-6.650	5.35	5.08	1.3200	0.0	24.0
27.09.25	40.14	36.73	3.41	355.910	360.470	353.200	358.190	-4.990	5.88	5.69	1.2080	0.0	24.0
28.09.25	40.03	36.76	3.27	228.380	231.000	226.640	229.530	-2.890	4.76	4.44	0.7410	0.0	24.0
29.09.25	44.61	39.06	5.55	192.490	197.280	190.700	195.860	-5.160	4.35	3.94	1.0330	0.0	24.0
30.09.25	47.36	41.47	5.89	318.150	321.880	314.810	319.290	-4.480	5.83	5.66	1.8500	0.0	24.0
01.10.25	47.30	41.46	5.84	308.890	311.460	305.600	308.960	-3.360	5.84	5.69	1.7840	0.0	24.0
02.10.25	47.36	41.66	5.70	297.330	299.950	294.210	297.550	-3.340	5.83	5.67	1.6730	0.0	24.0
03.10.25	48.06	42.29	5.77	294.500	296.760	291.310	294.280	-2.970	5.83	5.67	1.6770	0.0	24.0
04.10.25	48.06	42.25	5.81	303.360	306.140	300.030	303.520	-3.490	5.89	5.74	1.7380	0.0	24.0
05.10.25	47.99	42.27	5.72	310.440	313.390	307.070	310.740	-3.670	5.89	5.75	1.7550	0.0	24.0
06.10.25	47.03	41.53	5.50	309.400	312.460	306.170	309.910	-3.740	5.88	5.74	1.6810	0.0	24.0
07.10.25	44.92	40.12	4.80	319.920	323.580	316.910	321.150	-4.240	5.91	5.77	1.5150	0.0	24.0
08.10.25	45.02	40.22	4.80	318.090	321.670	315.020	319.240	-4.220	5.90	5.77	1.5110	0.0	24.0
09.10.25	44.82	40.05	4.77	317.090	320.590	314.100	318.190	-4.090	5.97	5.85	1.4960	0.0	24.0
10.10.25	44.63	39.99	4.64	317.310	320.200	314.380	317.800	-3.420	6.05	5.92	1.4550	0.0	24.0
11.10.25	44.37	39.79	4.58	320.800	323.870	317.800	321.480	-3.680	6.08	5.95	1.4520	0.0	24.0
12.10.25	44.99	40.11	4.88	318.340	321.850	315.350	319.430	-4.080	6.09	5.97	1.5350	0.0	24.0
13.10.25	46.69	41.43	5.26	321.940	325.190	318.640	322.550	-3.910	6.10	5.98	1.6730	0.0	24.0
14.10.25	46.28	41.26	5.02	324.980	327.700	321.700	325.100	-3.400	6.09	5.97	1.6150	0.0	24.0
15.10.25	46.95	41.58	5.37	319.270	322.530	315.910	319.890	-3.980	6.10	5.98	1.6910	0.0	24.0
16.10.25	46.79	41.37	5.42	319.050	322.140	315.730	319.500	-3.770	6.07	5.95	1.7100	0.0	24.0
17.10.25	48.15	42.25	5.90	316.470	319.300	312.990	316.580	-3.590	6.07	5.96	1.8430	0.0	24.0
18.10.25	50.71	44.22	6.49	316.490	319.350	312.710	316.450	-3.740	6.03	5.92	2.0240	0.0	24.0
19.10.25	51.79	45.29	6.50	325.130	327.840	321.050	324.710	-3.660	6.04	5.92	2.0840	0.0	24.0
20.10.25	50.55	44.44	6.11	323.040	325.840	319.200	322.830	-3.630	6.00	5.89	1.9460	0.0	24.0
Итого	---	---	---	8090.7	8176.6	8008.97	8111.39	-102.420	---	---	40.8280	0.0	768.0
Среднее	40.66	36.40	4.26	---	---	---	---	---	4.83	4.75	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	69114.730	69792.870	68185.440	69099.980	512.1790	-914.540	836.0	8655.0
20.10.25 24:00	77205.520	77969.520	76194.410	77211.370	553.0070	-1016.960	836.0	9423.0
Итого за период	8090.790	8176.650	8008.970	8111.389	40.8280	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Садовое кольцо, 16
Потребитель: АО "Жилуправление"
Прибор: ТВ7-04.1 Заводской номер: 20123889

БД=1, ТВ1, СИ=6, КТЗ=0, ФРТ=0, КСН=0х0F07

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	16.07	15.85	н/д	0.22	6.12	4.12	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
22.09.25	16.19	15.92	н/д	0.27	6.12	4.12	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
23.09.25	16.27	15.99	н/д	0.28	6.12	4.12	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
24.09.25	16.40	16.08	н/д	0.32	6.12	4.12	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
25.09.25	17.23	17.29	н/д	-0.06	6.12	4.12	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	0	24
26.09.25	38.69	33.17	н/д	5.52	4.81	3.86	н/д	75.753	76.775	н/д	75.250	76.417	н/д	-1.167	0.415	н/д	12	12
27.09.25	39.68	34.49	н/д	5.19	4.91	4.82	н/д	187.477	188.080	н/д	186.159	187.127	н/д	-0.968	0.965	н/д	24	0
28.09.25	39.87	34.73	н/д	5.14	4.91	4.80	н/д	192.908	193.205	н/д	191.522	192.207	н/д	-0.686	0.983	н/д	24	0
29.09.25	42.37	36.46	н/д	5.91	4.82	4.70	н/д	192.647	192.770	н/д	191.065	191.657	н/д	-0.593	1.128	н/д	24	0
30.09.25	46.78	39.11	н/д	7.67	4.81	4.76	н/д	172.557	172.615	н/д	170.817	171.427	н/д	-0.609	1.309	н/д	24	0
01.10.25	46.71	39.00	н/д	7.71	4.80	4.77	н/д	167.385	167.768	н/д	165.706	166.630	н/д	-0.924	1.276	н/д	24	0
02.10.25	46.79	39.09	н/д	7.69	4.77	4.74	н/д	166.542	167.030	н/д	164.862	165.887	н/д	-1.025	1.267	н/д	24	0
03.10.25	47.46	39.55	н/д	7.91	4.77	4.74	н/д	164.357	164.773	н/д	162.657	163.619	н/д	-0.962	1.285	н/д	24	0
04.10.25	47.48	39.45	н/д	8.02	4.83	4.80	н/д	163.628	164.003	н/д	161.927	162.858	н/д	-0.931	1.298	н/д	24	0
05.10.25	47.39	39.44	н/д	7.96	4.83	4.80	н/д	161.345	161.650	н/д	159.674	160.532	н/д	-0.857	1.269	н/д	24	0
06.10.25	46.57	38.97	н/д	7.60	4.80	4.77	н/д	160.893	161.190	н/д	159.279	160.091	н/д	-0.812	1.209	н/д	24	0
07.10.25	44.37	37.41	н/д	6.96	4.83	4.79	н/д	146.777	147.113	н/д	145.456	146.205	н/д	-0.749	1.011	н/д	24	0
08.10.25	44.49	37.69	н/д	6.80	4.80	4.78	н/д	161.883	162.195	н/д	160.412	161.174	н/д	-0.762	1.089	н/д	24	0
09.10.25	44.30	37.64	н/д	6.66	4.87	4.85	н/д	161.840	162.133	н/д	160.393	161.116	н/д	-0.723	1.067	н/д	24	0
10.10.25	44.11	37.66	н/д	6.45	4.96	4.93	н/д	161.827	162.150	н/д	160.388	161.138	н/д	-0.750	1.033	н/д	24	0
11.10.25	43.87	37.53	н/д	6.34	4.97	4.94	н/д	162.553	162.928	н/д	161.122	161.915	н/д	-0.793	1.021	н/д	24	0
12.10.25	44.44	37.60	н/д	6.84	4.99	4.96	н/д	161.375	161.740	н/д	159.916	160.729	н/д	-0.813	1.092	н/д	24	0
13.10.25	46.12	38.69	н/д	7.43	5.00	4.97	н/д	160.390	160.693	н/д	158.814	159.622	н/д	-0.808	1.178	н/д	24	0
14.10.25	45.75	38.47	н/д	7.29	5.00	4.96	н/д	152.490	152.852	н/д	151.018	151.859	н/д	-0.842	1.099	н/д	24	0
15.10.25	46.37	38.86	н/д	7.51	5.00	4.98	н/д	161.410	161.762	н/д	159.815	160.674	н/д	-0.859	1.199	н/д	24	0
16.10.25	46.25	38.70	н/д	7.55	4.97	4.94	н/д	161.345	161.697	н/д	159.754	160.620	н/д	-0.866	1.204	н/д	24	0
17.10.25	47.47	39.37	н/д	8.10	4.98	4.95	н/д	160.890	161.170	н/д	159.213	160.059	н/д	-0.846	1.289	н/д	24	0
18.10.25	50.08	41.08	н/д	8.99	4.93	4.91	н/д	161.408	161.548	н/д	159.529	160.312	н/д	-0.782	1.433	н/д	24	0
19.10.25	51.13	41.87	н/д	9.26	4.96	4.92	н/д	161.530	161.615	н/д	159.576	160.336	н/д	-0.760	1.477	н/д	24	0
20.10.25	50.00	41.33	н/д	8.67	4.91	4.88	н/д	163.202	163.348	н/д	161.314	162.086	н/д	-0.772	1.398	н/д	24	0
Итого	---	---	---	---	---	---	---	4044.412	4052.803	---	4005.638	4026.297	---	-20.659	28.994	---	588	132
Среднее	38.92	33.36	---	5.56	5.09	4.70	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
20.10.25 24:00	36636.715	36556.643	0.000	36158.333	36246.087	0.000	-87.754	353.892	0.000	5410	3267
Итого за период	н/д	н/д	н/д	н/д	н/д	н/д	---	н/д	н/д	н/д	н/д

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Садовое кольцо, 19
 Потребитель: АО "Жилуправление"
 Прибор: Взлёт ТСРВ-024М Заводской номер: 901534
 Тип системы: А32-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	16.42	16.10	0.32	0.00	0.00	0.00	0.0	0.0	0.00	0.00	0.00	0.000	24.00
20.09.25	16.39	16.08	0.31	0.00	0.00	0.00	0.0	0.0	0.00	0.00	0.00	0.000	24.00
21.09.25	16.26	15.94	0.32	0.00	0.00	0.00	0.0	0.0	0.00	0.00	0.00	0.000	24.00
22.09.25	16.29	15.96	0.33	0.00	0.00	0.00	0.0	0.0	0.00	0.00	0.00	0.000	24.00
23.09.25	16.30	15.96	0.34	0.00	0.00	0.00	0.0	0.0	0.00	0.00	0.00	0.000	21.97
24.09.25	16.38	16.01	0.37	0.00	0.00	0.00	0.0	0.0	0.00	0.00	0.00	0.000	24.00
25.09.25	16.42	16.06	0.36	0.00	0.00	0.00	0.0	0.0	0.00	0.00	0.00	0.000	24.00
26.09.25	28.36	25.85	2.51	97.62	96.95	0.68	0.0	0.0	98.37	97.54	0.83	0.444	24.00
27.09.25	40.28	35.75	4.53	206.52	207.54	-1.02	0.0	0.0	208.16	208.84	-0.68	0.898	24.00
28.09.25	40.46	35.51	4.95	208.40	209.58	-1.17	0.0	0.0	210.08	210.88	-0.80	0.988	24.00
29.09.25	43.27	36.98	6.29	207.26	208.02	-0.76	0.0	0.0	209.17	209.42	-0.25	1.271	24.00
30.09.25	47.52	39.34	8.18	202.15	203.17	-1.02	0.0	0.0	204.37	204.72	-0.35	1.610	24.00
01.10.25	47.45	39.35	8.10	200.05	201.15	-1.11	0.0	0.0	202.24	202.69	-0.45	1.559	24.00
02.10.25	47.51	39.61	7.90	199.49	200.75	-1.26	0.0	0.0	201.68	202.32	-0.64	1.492	24.00
03.10.25	48.20	40.11	8.09	199.24	199.48	-0.25	0.0	0.0	201.49	201.06	0.43	1.594	24.00
04.10.25	48.21	40.09	8.12	198.96	198.77	0.19	0.0	0.0	201.20	200.33	0.87	1.620	24.00
05.10.25	48.14	40.16	7.98	199.02	198.69	0.33	0.0	0.0	201.26	200.27	1.00	1.592	24.00
06.10.25	47.22	39.74	7.48	199.08	198.84	0.23	0.0	0.0	201.24	200.39	0.85	1.484	24.00
07.10.25	45.06	38.37	6.69	199.10	198.75	0.35	0.0	0.0	201.08	200.20	0.88	1.339	24.00
08.10.25	45.16	38.70	6.46	199.59	200.06	-0.47	0.0	0.0	201.58	201.56	0.02	1.228	24.00
09.10.25	44.97	38.35	6.62	199.06	198.52	0.54	0.0	0.0	201.03	199.95	1.08	1.335	24.00
10.10.25	44.77	38.33	6.44	199.19	199.01	0.19	0.0	0.0	201.15	200.45	0.69	1.277	24.00
11.10.25	44.52	38.19	6.33	201.39	201.18	0.21	0.0	0.0	203.34	202.63	0.72	1.274	24.00
12.10.25	45.12	38.78	6.34	201.47	202.93	-1.46	0.0	0.0	203.47	204.49	-1.01	1.132	24.00
13.10.25	46.83	39.56	7.27	201.28	201.22	0.06	0.0	0.0	203.43	202.77	0.66	1.457	24.00
14.10.25	46.44	39.55	6.89	201.55	202.07	-0.52	0.0	0.0	203.67	203.65	0.02	1.327	24.00
15.10.25	47.09	39.77	7.32	201.51	201.69	-0.18	0.0	0.0	203.69	203.27	0.42	1.455	24.00
16.10.25	46.94	39.49	7.45	201.10	201.00	0.10	0.0	0.0	203.26	202.54	0.72	1.501	24.00
17.10.25	48.28	40.19	8.09	200.09	200.03	0.07	0.0	0.0	202.36	201.61	0.75	1.618	24.00
18.10.25	50.87	41.88	8.99	198.70	198.92	-0.22	0.0	0.0	201.18	200.64	0.55	1.763	24.00
19.10.25	51.94	42.91	9.03	201.42	202.33	-0.91	0.0	0.0	204.05	204.21	-0.16	1.714	24.00
20.10.25	50.71	42.31	8.40	201.28	202.32	-1.04	0.0	0.0	203.79	204.17	-0.38	1.557	24.00
Итого	---	---	---	4924.53	4932.97	-8.44	---	---	4976.35	4970.58	5.77	34.531	765.97
Среднее	39.37	33.78	5.59	---	---	---	0.0	0.0	---	---	---	---	---

Показания интеграторов

Дата	Мтс	Q, (Гкал)
18.09.25 24:00	-239985.63	7952.096
20.10.25 24:00	-239994.07	7986.627
Итого за период	---	34.531

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Садовое кольцо, 21
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00167000

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0хЕ5DB

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	16.72	16.82	-0.10	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
22.09.25	16.76	16.57	0.19	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
23.09.25	16.91	16.73	0.18	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
24.09.25	17.13	16.84	0.29	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
25.09.25	17.26	17.65	-0.39	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
26.09.25	39.41	35.70	3.71	155.710	156.620	154.550	155.680	-1.130	5.67	6.00	0.5740	0.0	24.0
27.09.25	40.31	36.52	3.79	359.850	360.850	357.090	358.620	-1.530	6.22	6.00	1.3560	0.0	24.0
28.09.25	40.51	36.12	4.39	377.280	379.440	374.350	377.130	-2.780	6.20	6.00	1.6390	0.0	24.0
29.09.25	43.34	37.95	5.39	371.260	373.440	367.940	370.910	-2.970	5.99	6.00	1.9780	0.0	24.0
30.09.25	47.60	40.92	6.68	358.100	358.770	354.280	355.910	-1.630	6.03	6.00	2.3620	0.0	24.0
01.10.25	47.55	40.89	6.66	355.100	355.080	351.290	352.240	-0.950	6.07	6.00	2.3330	0.0	24.0
02.10.25	47.61	40.94	6.67	356.120	355.540	352.280	352.660	-0.380	6.07	6.00	2.3450	0.0	24.0
03.10.25	48.30	41.50	6.80	357.570	356.510	353.680	353.630	0.050	6.08	6.00	2.4020	0.0	24.0
04.10.25	48.30	41.49	6.81	356.750	355.730	352.910	352.850	0.060	6.13	6.00	2.3970	0.0	24.0
05.10.25	48.23	41.52	6.71	356.240	355.200	352.400	352.320	0.080	6.14	6.00	2.3600	0.0	24.0
06.10.25	47.27	40.94	6.33	355.600	354.820	351.900	352.020	-0.120	6.11	6.00	2.2230	0.0	24.0
07.10.25	45.14	39.48	5.66	354.090	353.880	350.730	351.240	-0.510	6.14	6.00	1.9870	0.0	24.0
08.10.25	45.24	39.66	5.58	355.130	354.730	351.750	352.080	-0.330	6.12	6.00	1.9600	0.0	24.0
09.10.25	45.04	39.46	5.58	352.440	352.350	349.080	349.710	-0.630	6.18	6.00	1.9470	0.0	24.0
10.10.25	44.85	39.37	5.48	352.180	351.960	348.860	349.370	-0.510	6.25	6.00	1.9090	0.0	24.0
11.10.25	44.59	39.22	5.37	355.290	355.950	351.980	353.360	-1.380	6.27	6.00	1.8870	0.0	24.0
12.10.25	45.22	39.50	5.72	354.980	355.780	351.580	353.140	-1.560	6.29	6.00	2.0070	0.0	24.0
13.10.25	46.92	40.71	6.21	353.770	355.160	350.170	352.350	-2.180	6.30	6.00	2.1740	0.0	24.0
14.10.25	46.51	40.49	6.02	353.860	355.360	350.320	352.590	-2.270	6.30	6.00	2.1060	0.0	24.0
15.10.25	47.18	40.84	6.34	353.540	354.860	349.940	351.980	-2.040	6.30	6.00	2.2160	0.0	24.0
16.10.25	47.02	40.59	6.43	351.210	353.780	347.590	351.070	-3.480	6.26	6.00	2.2340	0.0	24.0
17.10.25	48.42	41.42	7.00	348.870	351.760	345.030	348.950	-3.920	6.27	6.00	2.4110	0.0	24.0
18.10.25	50.97	43.17	7.80	348.170	349.840	343.950	346.770	-2.820	6.22	6.00	2.6780	0.0	24.0
19.10.25	52.05	44.12	7.93	354.420	355.460	349.920	352.200	-2.280	6.25	6.00	2.7700	0.0	24.0
20.10.25	50.78	43.38	7.40	353.700	354.880	349.410	351.750	-2.340	6.21	6.00	2.5800	0.0	24.0
Итого	---	---	---	8701.2	8717.7	8612.98	8650.53	-37.550	---	---	52.8350	0.0	720.0
Среднее	41.43	36.35	5.08	---	---	---	---	---	6.17	6.00	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
19.09.25 24:00	0	0	0	0	0	0	0	0
20.10.25 24:00	90976.540	90483.660	89765.759	89622.930	748.2440	142.830	2278.0	7983.0
Итого за период	90976.540	90483.660	89765.759	89622.930	748.2440	---	2278.0	7983.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Садовое кольцо, 29
Потребитель: АО "Жилуправление"
Прибор ТВ7-04.1 Заводской номер: 20123943

БД=1, ТВ1, СИ=6, КТ3=0, ФРТ=0, КСН=0х936А

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	17.92	17.11	н/д	0.81	5.20	5.00	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
22.09.25	18.70	17.98	н/д	0.72	5.20	5.00	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
23.09.25	19.00	18.22	н/д	0.78	5.20	5.00	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
24.09.25	19.50	18.73	н/д	0.77	5.20	5.00	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
25.09.25	18.84	18.05	н/д	0.79	5.20	5.00	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
26.09.25	39.43	34.22	н/д	5.21	4.51	4.41	н/д	23.913	0.009	н/д	23.747	0.009	н/д	23.738	0.124	н/д	24	0
27.09.25	39.92	35.16	н/д	4.76	4.66	4.64	н/д	43.502	0.000	н/д	43.190	0.000	н/д	43.190	0.205	н/д	24	0
28.09.25	40.11	35.26	н/д	4.85	4.64	4.63	н/д	43.655	0.000	н/д	43.336	0.000	н/д	43.336	0.210	н/д	24	0
29.09.25	42.76	36.93	н/д	5.83	4.56	4.55	н/д	43.187	0.000	н/д	42.826	0.000	н/д	42.826	0.250	н/д	24	0
30.09.25	47.08	39.52	н/д	7.56	4.60	4.60	н/д	39.212	0.000	н/д	38.811	0.000	н/д	38.811	0.293	н/д	24	0
01.10.25	46.99	39.22	н/д	7.77	4.62	4.63	н/д	36.719	0.000	н/д	36.344	0.000	н/д	36.344	0.282	н/д	24	0
02.10.25	47.07	39.37	н/д	7.70	4.59	4.60	н/д	36.419	0.000	н/д	36.046	0.000	н/д	36.046	0.277	н/д	24	0
03.10.25	47.75	40.14	н/д	7.61	4.59	4.60	н/д	36.321	0.000	н/д	35.937	0.000	н/д	35.937	0.273	н/д	24	0
04.10.25	47.77	40.03	н/д	7.74	4.65	4.66	н/д	36.271	0.000	н/д	35.888	0.000	н/д	35.888	0.278	н/д	24	0
05.10.25	47.69	40.08	н/д	7.62	4.65	4.66	н/д	36.309	0.000	н/д	35.925	0.000	н/д	35.925	0.274	н/д	24	0
06.10.25	46.84	39.48	н/д	7.35	4.62	4.63	н/д	36.350	0.000	н/д	35.981	0.000	н/д	35.981	0.265	н/д	24	0
07.10.25	44.69	38.21	н/д	6.48	4.64	4.66	н/д	36.362	0.000	н/д	36.029	0.000	н/д	36.029	0.233	н/д	24	0
08.10.25	44.78	38.39	н/д	6.40	4.63	4.64	н/д	36.387	0.000	н/д	36.052	0.000	н/д	36.052	0.230	н/д	24	0
09.10.25	44.60	38.24	н/д	6.35	4.70	4.71	н/д	36.347	0.000	н/д	36.013	0.000	н/д	36.013	0.229	н/д	24	0
10.10.25	44.40	38.14	н/д	6.26	4.78	4.79	н/д	36.488	0.000	н/д	36.156	0.000	н/д	36.156	0.226	н/д	24	0
11.10.25	44.16	37.99	н/д	6.17	4.79	4.80	н/д	36.888	0.000	н/д	36.556	0.000	н/д	36.556	0.226	н/д	24	0
12.10.25	44.74	38.24	н/д	6.50	4.81	4.82	н/д	36.886	0.000	н/д	36.546	0.000	н/д	36.546	0.237	н/д	24	0
13.10.25	46.43	39.43	н/д	7.01	4.82	4.83	н/д	36.911	0.000	н/д	36.542	0.000	н/д	36.542	0.256	н/д	24	0
14.10.25	46.04	39.19	н/д	6.84	4.81	4.82	н/д	36.980	0.000	н/д	36.619	0.000	н/д	36.619	0.251	н/д	24	0
15.10.25	46.66	39.45	н/д	7.21	4.82	4.83	н/д	36.928	0.000	н/д	36.556	0.000	н/д	36.556	0.264	н/д	24	0
16.10.25	46.54	39.14	н/д	7.41	4.78	4.79	н/д	36.899	0.000	н/д	36.530	0.000	н/д	36.530	0.270	н/д	24	0
17.10.25	47.77	39.84	н/д	7.93	4.80	4.81	н/д	36.668	0.000	н/д	36.280	0.000	н/д	36.280	0.288	н/д	24	0
18.10.25	50.38	41.59	н/д	8.79	4.75	4.77	н/д	36.434	0.000	н/д	36.006	0.000	н/д	36.006	0.316	н/д	24	0
19.10.25	51.44	42.46	н/д	8.98	4.77	4.78	н/д	36.938	0.000	н/д	36.483	0.000	н/д	36.483	0.328	н/д	24	0
20.10.25	50.29	41.80	н/д	8.49	4.73	4.74	н/д	36.890	0.000	н/д	36.455	0.000	н/д	36.455	0.309	н/д	24	0
Итого	---	---	---	---	---	---	---	925.864	0.009	---	916.854	0.009	---	916.845	6.394	---	720	0
Среднее	45.83	38.86	---	6.98	4.78	4.75	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
20.10.25 24:00	8610.404	5451.557	0.000	8522.972	5376.808	0.000	3146.164	82.916	0.000	7740	2089
Итого за период	н/д	н/д	н/д	н/д	н/д	н/д	---	н/д	н/д	н/д	н/д

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Садовое кольцо, 2а
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВА707

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	0.00	16.73	0.00	16.43	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	16.67	0.00	16.37	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	16.63	0.00	16.31	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	16.66	0.00	16.34	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	16.78	0.00	16.43	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	16.99	0.00	16.54	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	16.88	0.00	16.42	0.00	0.00	24.00	0.00	0.00
27.09.25	0.50	29.64	175.41	27.71	173.26	12.59	24.00	0.00	0.00
28.09.25	0.96	41.08	368.63	38.47	364.81	24.00	24.00	0.00	0.00
29.09.25	1.02	41.25	369.97	38.50	365.60	24.00	24.00	0.00	0.00
30.09.25	1.24	44.08	368.32	40.71	363.52	24.00	24.00	0.00	0.00
01.10.25	1.54	48.50	366.09	44.30	361.87	24.00	24.00	0.00	0.00
02.10.25	1.53	48.43	369.03	44.29	364.67	24.00	24.00	0.00	0.00
03.10.25	1.55	48.50	370.43	44.32	366.27	24.00	24.00	0.00	0.00
04.10.25	1.57	49.21	371.86	44.99	367.89	24.00	24.00	0.00	0.00
05.10.25	1.57	49.22	371.79	45.00	367.77	24.00	24.00	0.00	0.00
06.10.25	1.56	49.14	371.91	44.93	367.96	24.00	24.00	0.00	0.00
07.10.25	1.49	48.23	372.38	44.23	368.77	24.00	24.00	0.00	0.00
08.10.25	1.36	46.00	373.00	42.34	369.40	24.00	24.00	0.00	0.00
09.10.25	1.37	46.09	373.44	42.42	369.95	24.00	24.00	0.00	0.00
10.10.25	1.37	45.90	373.43	42.23	369.99	24.00	24.00	0.00	0.00
11.10.25	1.35	45.70	373.80	42.09	370.41	24.00	24.00	0.00	0.00
12.10.25	1.34	45.44	378.11	41.88	374.72	24.00	24.00	0.00	0.00
13.10.25	1.40	46.04	378.47	42.34	375.20	24.00	24.00	0.00	0.00
14.10.25	1.53	47.80	378.24	43.76	374.94	24.00	24.00	0.00	0.00
15.10.25	1.48	47.41	378.59	43.50	375.36	24.00	24.00	0.00	0.00
16.10.25	1.55	48.07	378.69	43.97	375.40	24.00	24.00	0.00	0.00
17.10.25	1.56	47.93	377.78	43.80	374.50	24.00	24.00	0.00	0.00
18.10.25	1.68	49.25	376.82	44.78	373.52	24.00	24.00	0.00	0.00
19.10.25	1.86	51.94	375.31	46.97	372.14	24.00	24.00	0.00	0.00
20.10.25	1.93	53.03	378.33	47.93	374.86	24.00	24.00	0.00	0.00
Итого	34.31	---	8769.83	---	8682.78	564.59	744.00	0.00	0.00
Среднее	---	39.846	---	36.784	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	5728.17	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Садовое кольцо, 33
Потребитель: АО "Жилуправление"
Прибор: ТВ7-04.1 Заводской номер: 20123767

БД=1, ТВ1, СИ=6, КТ3=0, ФРТ=0, КСН=0хD59F

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	18.14	17.90	н/д	0.24	5.20	5.00	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
22.09.25	18.47	18.24	н/д	0.23	5.20	5.00	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
23.09.25	18.93	18.63	н/д	0.31	5.20	5.00	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
24.09.25	19.53	19.19	н/д	0.34	5.20	5.00	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
25.09.25	19.35	18.96	н/д	0.40	5.20	5.00	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
26.09.25	39.13	35.66	н/д	3.47	4.36	5.00	н/д	36.607	36.607	н/д	36.381	36.381	н/д	0.000	0.126	н/д	24	0
27.09.25	39.61	36.60	н/д	3.01	4.64	5.00	н/д	70.693	70.809	н/д	70.291	70.291	н/д	0.000	0.212	н/д	24	0
28.09.25	39.79	36.77	н/д	3.02	4.63	5.00	н/д	70.976	71.467	н/д	70.757	70.757	н/д	0.000	0.214	н/д	24	0
29.09.25	42.42	38.77	н/д	3.65	4.55	5.00	н/д	70.380	71.381	н/д	70.351	70.351	н/д	0.000	0.257	н/д	24	0
30.09.25	46.75	41.95	н/д	4.80	4.60	5.00	н/д	63.480	64.236	н/д	63.279	63.279	н/д	0.000	0.304	н/д	24	0
01.10.25	46.69	41.66	н/д	5.03	4.61	5.00	н/д	58.933	59.450	н/д	58.657	58.657	н/д	0.000	0.295	н/д	24	0
02.10.25	46.77	41.77	н/д	4.99	4.58	5.00	н/д	58.454	58.771	н/д	58.083	58.083	н/д	0.000	0.290	н/д	24	0
03.10.25	47.44	42.39	н/д	5.05	2.27	5.00	н/д	58.276	58.410	н/д	57.802	57.802	н/д	0.000	0.292	н/д	24	0
04.10.25	47.46	42.35	н/д	5.11	0.02	5.00	н/д	58.148	58.162	н/д	57.613	57.613	н/д	0.000	0.295	н/д	24	0
05.10.25	47.39	42.35	н/д	5.04	0.24	5.00	н/д	58.114	58.084	н/д	57.558	57.558	н/д	0.000	0.290	н/д	24	0
06.10.25	46.53	41.75	н/д	4.78	1.54	5.00	н/д	58.086	58.060	н/д	57.553	57.553	н/д	0.000	0.275	н/д	24	0
07.10.25	44.37	40.12	н/д	4.25	5.20	5.00	н/д	58.040	58.047	н/д	57.570	57.570	н/д	0.000	0.245	н/д	24	0
08.10.25	44.46	40.17	н/д	4.29	3.90	5.00	н/д	58.065	58.080	н/д	57.598	57.598	н/д	0.000	0.247	н/д	24	0
09.10.25	44.22	39.40	н/д	4.82	5.20	5.00	н/д	48.954	48.931	н/д	48.554	48.551	н/д	0.003	0.234	н/д	24	0
10.10.25	44.00	37.86	н/д	6.13	5.20	5.00	н/д	35.791	35.698	н/д	35.476	35.467	н/д	0.009	0.218	н/д	24	0
11.10.25	43.76	37.70	н/д	6.05	5.20	5.00	н/д	36.186	36.097	н/д	35.870	35.865	н/д	0.004	0.217	н/д	24	0
12.10.25	44.32	38.03	н/д	6.29	5.20	5.00	н/д	36.184	36.092	н/д	35.859	35.856	н/д	0.004	0.226	н/д	24	0
13.10.25	46.00	39.08	н/д	6.92	4.77	5.00	н/д	36.214	36.112	н/д	35.864	35.860	н/д	0.004	0.248	н/д	24	0
14.10.25	45.61	39.00	н/д	6.61	1.54	5.00	н/д	36.287	36.195	н/д	35.945	35.943	н/д	0.003	0.237	н/д	24	0
15.10.25	46.24	39.17	н/д	7.08	0.04	5.00	н/д	36.245	36.146	н/д	35.894	35.892	н/д	0.002	0.254	н/д	24	0
16.10.25	46.12	38.99	н/д	7.13	0.09	5.00	н/д	36.223	36.125	н/д	35.874	35.872	н/д	0.001	0.256	н/д	24	0
17.10.25	47.34	39.67	н/д	7.67	0.14	5.00	н/д	35.993	35.880	н/д	35.625	35.621	н/д	0.004	0.273	н/д	24	0
18.10.25	49.94	41.43	н/д	8.51	0.04	5.00	н/д	35.763	35.627	н/д	35.352	35.346	н/д	0.006	0.301	н/д	24	0
19.10.25	51.00	42.42	н/д	8.58	0.06	5.00	н/д	36.272	36.136	н/д	35.838	35.835	н/д	0.003	0.307	н/д	24	0
20.10.25	49.86	41.74	н/д	8.12	0.03	5.00	н/д	36.224	36.100	н/д	35.811	35.809	н/д	0.002	0.291	н/д	24	0
Итого	---	---	---	---	---	---	---	1224.588	1226.703	---	1215.455	1215.410	---	0.045	6.404	---	720	0
Среднее	45.21	39.94	---	5.27	3.29	5.00	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
20.10.25 24:00	9080.278	9039.320	0.000	8970.400	8958.171	0.000	12.230	80.978	0.000	7572	2090
Итого за период	н/д	н/д	н/д	н/д	н/д	н/д	---	н/д	н/д	н/д	н/д

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Садовое кольцо, 34
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00179015

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0x2C0E

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Мг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	19.29	20.29	-1.00	0.000	20.710	0.000	20.710	-20.710	6.90	6.70	0.0000	0.0	24.0
20.09.25	20.70	28.62	-7.92	0.000	38.800	0.000	38.680	-38.680	6.90	6.70	0.0000	0.0	24.0
21.09.25	20.40	27.85	-7.45	0.000	21.990	0.000	21.930	-21.930	6.90	6.70	0.0000	0.0	24.0
22.09.25	23.19	31.02	-7.83	0.000	11.660	0.000	11.660	-11.660	6.90	6.70	0.0000	0.0	24.0
23.09.25	22.14	28.68	-6.54	0.000	10.950	0.000	10.950	-10.950	6.90	6.70	0.0000	0.0	24.0
24.09.25	23.61	30.93	-7.32	0.000	15.850	0.000	15.830	-15.830	6.90	6.70	0.0000	0.0	24.0
25.09.25	21.07	26.56	-5.49	0.000	17.130	0.000	17.110	-17.110	6.90	6.70	0.0000	0.0	24.0
26.09.25	56.87	40.61	16.26	15.520	20.680	15.290	20.530	-5.240	6.90	6.70	0.1540	0.0	24.0
27.09.25	21.68	24.87	-3.19	2.560	0.000	2.560	0.000	2.560	6.90	6.70	0.0000	0.0	24.0
28.09.25	20.84	24.29	-3.45	0.320	0.000	0.320	0.000	0.320	6.90	6.70	0.0000	0.0	24.0
29.09.25	64.87	51.29	13.58	91.000	85.980	89.270	84.910	4.360	6.90	6.70	1.2710	0.0	24.0
30.09.25	65.66	50.76	14.90	139.640	136.600	136.900	134.950	1.950	6.90	6.70	2.0370	0.0	24.0
01.10.25	65.26	50.71	14.55	160.690	157.680	157.620	155.740	1.880	6.90	6.70	2.2920	0.0	24.0
02.10.25	57.69	47.76	9.93	199.530	196.300	196.440	194.170	2.270	6.90	6.70	1.9410	0.0	24.0
03.10.25	47.91	42.92	4.99	276.430	271.570	273.480	269.200	4.280	6.90	6.70	1.3620	0.0	24.0
04.10.25	47.70	42.68	5.02	285.490	279.880	282.410	277.480	4.930	6.90	6.70	1.4170	0.0	24.0
05.10.25	47.82	42.85	4.97	285.350	279.670	282.260	277.270	4.990	6.90	6.70	1.4030	0.0	24.0
06.10.25	46.34	41.71	4.63	284.250	278.680	281.390	276.420	4.970	6.90	6.70	1.2990	0.0	24.0
07.10.25	45.20	40.80	4.40	282.750	277.220	280.110	275.060	5.050	6.90	6.70	1.2300	0.0	24.0
08.10.25	45.28	40.87	4.41	278.880	273.430	276.240	271.270	4.970	6.90	6.70	1.2140	0.0	24.0
09.10.25	45.00	40.64	4.36	276.530	271.180	273.890	269.030	4.860	6.90	6.70	1.1930	0.0	24.0
10.10.25	44.18	39.97	4.21	268.220	263.040	265.810	261.120	4.690	6.90	6.70	1.1190	0.0	24.0
11.10.25	43.40	39.31	4.09	265.530	260.420	263.200	258.540	4.660	6.90	6.70	1.0730	0.0	24.0
12.10.25	43.80	39.45	4.35	265.420	260.260	263.020	258.340	4.680	6.90	6.70	1.1400	0.0	24.0
13.10.25	43.76	39.39	4.37	266.050	260.840	263.650	258.920	4.730	6.90	6.70	1.1510	0.0	24.0
14.10.25	45.43	40.62	4.81	264.280	259.190	261.710	257.150	4.560	6.90	6.70	1.2580	0.0	24.0
15.10.25	46.47	41.46	5.01	270.440	265.190	267.740	263.010	4.730	6.90	6.70	1.3390	0.0	24.0
16.10.25	46.57	41.78	4.79	294.740	289.000	291.800	286.600	5.200	6.90	6.70	1.3950	0.0	24.0
17.10.25	53.76	44.56	9.20	301.260	387.800	260.130	356.110	-95.980	6.90	5.80	2.3420	3.0	21.0
18.10.25	52.12	45.88	6.24	303.500	660.620	299.660	654.080	-354.420	6.90	6.70	1.8690	0.0	24.0
19.10.25	52.27	46.38	5.89	303.640	840.180	299.800	831.710	-531.910	6.90	6.22	1.7690	0.0	24.0
20.10.25	50.88	45.31	5.57	303.690	1129.940	300.050	1118.970	-818.920	6.90	4.80	1.6540	0.0	24.0
Итого	---	---	---	5685.7	7542.4	5584.75	7447.45	-1862.700	---	---	32.9220	3.0	765.0
Среднее	42.22	38.77	3.44	---	---	---	---	---	6.90	6.60	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Мг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	45295.420	44464.300	44583.930	43980.880	449.7230	603.050	4369.0	6974.0
20.10.25 24:00	50981.129	52006.740	50168.680	51428.329	482.6450	-1259.650	4372.0	7739.0
Итого за период	5685.709	7542.439	5584.750	7447.449	32.9220	---	3.0	765.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Садовое кольцо, 37
Потребитель: АО "Жилуправление"
Прибор: ТВ7-04.1 Заводской номер: 20119355

БД=1, ТВ1, СИ=7, КТ3=0, ФРТ=0, КСН=0х0В00

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	17.94	17.27	н/д	0.68	9.80	5.20	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
20.09.25	17.06	16.35	н/д	0.71	9.80	5.20	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
21.09.25	17.73	16.99	н/д	0.73	9.80	5.20	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
22.09.25	18.87	18.10	н/д	0.76	9.80	5.20	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
23.09.25	18.70	17.73	н/д	0.97	9.80	5.20	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
24.09.25	20.48	19.45	н/д	1.04	9.80	5.20	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
25.09.25	17.66	16.76	н/д	0.90	9.80	5.20	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
26.09.25	39.32	35.10	н/д	4.22	9.80	5.20	н/д	36.627	н/д	н/д	36.380	н/д	н/д	н/д	0.157	н/д	24	0
27.09.25	39.81	36.15	н/д	3.66	9.80	5.20	н/д	63.821	н/д	н/д	63.379	н/д	н/д	н/д	0.238	н/д	24	0
28.09.25	40.02	36.34	н/д	3.68	9.80	5.20	н/д	64.583	н/д	н/д	64.128	н/д	н/д	н/д	0.242	н/д	24	0
29.09.25	42.69	38.19	н/д	4.50	9.80	5.20	н/д	63.928	н/д	н/д	63.406	н/д	н/д	н/д	0.291	н/д	24	0
30.09.25	46.91	41.11	н/д	5.80	9.80	5.20	н/д	57.954	н/д	н/д	57.377	н/д	н/д	н/д	0.338	н/д	24	0
01.10.25	46.82	40.96	н/д	5.86	9.80	5.20	н/д	54.198	н/д	н/д	53.660	н/д	н/д	н/д	0.319	н/д	24	0
02.10.25	46.88	41.01	н/д	5.86	9.80	5.20	н/д	49.045	н/д	н/д	48.557	н/д	н/д	н/д	0.289	н/д	22	2
03.10.25	47.57	41.75	н/д	5.83	9.80	5.20	н/д	53.345	н/д	н/д	52.797	н/д	н/д	н/д	0.312	н/д	24	0
04.10.25	47.59	41.76	н/д	5.83	9.80	5.20	н/д	53.095	н/д	н/д	52.552	н/д	н/д	н/д	0.311	н/д	24	0
05.10.25	47.52	41.75	н/д	5.77	9.80	5.20	н/д	53.012	н/д	н/д	52.471	н/д	н/д	н/д	0.308	н/д	24	0
06.10.25	46.64	41.15	н/д	5.50	9.80	5.20	н/д	52.959	н/д	н/д	52.435	н/д	н/д	н/д	0.293	н/д	24	0
07.10.25	44.54	39.71	н/д	4.83	9.80	5.20	н/д	52.893	н/д	н/д	52.422	н/д	н/д	н/д	0.258	н/д	24	0
08.10.25	44.62	39.74	н/д	4.88	9.80	5.20	н/д	52.918	н/д	н/д	52.447	н/д	н/д	н/д	0.261	н/д	24	0
09.10.25	44.44	39.56	н/д	4.88	9.80	5.20	н/д	52.869	н/д	н/д	52.402	н/д	н/д	н/д	0.260	н/д	24	0
10.10.25	44.25	39.52	н/д	4.73	9.80	5.20	н/д	53.079	н/д	н/д	52.612	н/д	н/д	н/д	0.254	н/д	24	0
11.10.25	44.01	39.39	н/д	4.62	9.80	5.20	н/д	53.665	н/д	н/д	53.199	н/д	н/д	н/д	0.251	н/д	24	0
12.10.25	44.59	39.72	н/д	4.87	9.80	5.20	н/д	53.680	н/д	н/д	53.201	н/д	н/д	н/д	0.264	н/д	24	0
13.10.25	46.26	40.95	н/д	5.31	9.80	5.20	н/д	53.736	н/д	н/д	53.216	н/д	н/д	н/д	0.287	н/д	24	0
14.10.25	45.84	40.72	н/д	5.11	9.80	5.20	н/д	53.853	н/д	н/д	53.344	н/д	н/д	н/д	0.278	н/д	24	0
15.10.25	46.47	41.03	н/д	5.44	9.80	5.20	н/д	53.810	н/д	н/д	53.281	н/д	н/д	н/д	0.295	н/д	24	0
16.10.25	46.35	40.78	н/д	5.57	9.80	5.20	н/д	53.793	н/д	н/д	53.270	н/д	н/д	н/д	0.302	н/д	24	0
17.10.25	47.61	41.58	н/д	6.03	9.80	5.20	н/д	53.425	н/д	н/д	52.873	н/д	н/д	н/д	0.324	н/д	24	0
18.10.25	50.16	43.51	н/д	6.65	9.80	5.20	н/д	53.091	н/д	н/д	52.482	н/д	н/д	н/д	0.354	н/д	24	0
19.10.25	51.23	44.48	н/д	6.75	9.80	5.20	н/д	53.844	н/д	н/д	53.201	н/д	н/д	н/д	0.364	н/д	24	0
20.10.25	50.07	43.71	н/д	6.36	9.80	5.20	н/д	53.772	н/д	н/д	53.157	н/д	н/д	н/д	0.343	н/д	24	0
Итого	---	---	---	---	---	---	---	1350.995	---	---	1338.249	---	---	---	7.193	---	766	2
Среднее	45.65	40.37	---	5.28	9.80	5.20	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	179	413
20.10.25 24:00	1350.995	0.000	0.000	1338.252	0.000	0.000	0.000	7.190	0.000	945	415
Итого за период	1350.995	0.000	0.000	1338.252	0.000	0.000	---	7.190	0.000	766	2

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Садовое кольцо, 38
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00179107

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0xF70E

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	24.99	23.03	1.96	0.000	0.000	0.000	0.000	0.000	1.00	1.15	0.0000	0.0	24.0
20.09.25	25.04	23.01	2.03	0.000	0.000	0.000	0.000	0.000	1.00	1.15	0.0000	0.0	24.0
21.09.25	25.07	23.07	2.00	0.000	0.000	0.000	0.000	0.000	1.00	1.15	0.0000	0.0	24.0
22.09.25	25.43	23.32	2.11	0.000	0.000	0.000	0.000	0.000	1.00	1.16	0.0000	0.0	24.0
23.09.25	25.82	23.56	2.26	0.000	0.000	0.000	0.000	0.000	1.00	1.19	0.0000	0.0	24.0
24.09.25	26.13	23.88	2.25	0.000	0.000	0.000	0.000	0.000	1.00	1.23	0.0000	0.0	24.0
25.09.25	25.03	23.40	1.63	0.000	0.000	0.000	0.000	0.000	1.00	1.25	0.0000	0.0	24.0
26.09.25	63.06	54.32	8.74	78.130	80.800	76.720	79.670	-2.950	3.60	3.73	0.6680	0.0	24.0
27.09.25	63.93	55.65	8.28	179.000	179.560	175.680	177.000	-1.320	6.68	6.59	1.4690	0.0	24.0
28.09.25	33.73	29.71	4.02	5.280	0.000	5.280	0.000	5.280	1.14	1.10	0.0220	0.0	24.0
29.09.25	65.04	54.61	10.43	54.030	54.380	52.990	53.630	-0.640	3.11	3.11	0.6140	0.0	24.0
30.09.25	65.82	54.62	11.20	150.990	150.020	148.040	147.970	0.070	7.87	7.86	1.6540	0.0	24.0
01.10.25	65.52	54.67	10.85	173.110	172.000	169.760	169.660	0.100	8.33	8.34	1.8390	0.0	24.0
02.10.25	66.15	56.40	9.75	193.190	192.190	189.370	189.360	0.010	8.42	8.38	1.8470	0.0	24.0
03.10.25	67.28	58.17	9.11	209.380	208.510	205.120	205.280	-0.160	8.45	8.37	1.8690	0.0	24.0
04.10.25	67.38	58.42	8.96	211.680	211.390	207.340	208.090	-0.750	8.42	8.34	1.8570	0.0	24.0
05.10.25	66.34	57.73	8.61	208.860	209.570	204.730	206.370	-1.640	8.44	8.36	1.7630	0.0	24.0
06.10.25	66.06	57.49	8.57	203.810	204.820	199.800	201.730	-1.930	8.40	8.33	1.7140	0.0	24.0
07.10.25	66.72	57.34	9.38	182.570	183.790	178.900	181.000	-2.100	8.21	8.18	1.6760	0.0	24.0
08.10.25	66.44	57.93	8.51	199.240	200.580	195.300	197.480	-2.180	7.97	7.91	1.6640	0.0	24.0
09.10.25	66.74	58.68	8.06	217.440	218.720	213.100	215.260	-2.160	7.98	7.87	1.7160	0.0	24.0
10.10.25	66.42	58.94	7.48	228.790	230.360	224.230	226.690	-2.460	8.02	7.88	1.6760	0.0	24.0
11.10.25	66.00	58.69	7.31	227.940	229.580	223.440	225.950	-2.510	8.03	7.89	1.6350	0.0	24.0
12.10.25	66.16	58.59	7.57	220.180	222.300	215.840	218.790	-2.950	7.97	7.84	1.6360	0.0	24.0
13.10.25	67.25	59.43	7.82	211.760	213.700	207.450	210.250	-2.800	7.96	7.83	1.6200	0.0	24.0
14.10.25	66.17	58.62	7.55	214.290	216.130	210.040	212.720	-2.680	7.95	7.82	1.5880	0.0	24.0
15.10.25	66.66	58.66	8.00	212.410	213.950	208.160	210.580	-2.420	7.86	7.76	1.6680	0.0	24.0
16.10.25	66.57	58.37	8.20	209.990	212.230	205.810	208.910	-3.100	7.95	7.86	1.6870	0.0	24.0
17.10.25	66.42	58.06	8.36	206.820	208.650	202.690	205.440	-2.750	8.00	7.92	1.6940	0.0	24.0
18.10.25	66.73	58.11	8.62	204.310	206.410	200.220	203.200	-2.980	7.81	7.73	1.7240	0.0	24.0
19.10.25	67.09	58.47	8.62	205.780	208.100	201.630	204.850	-3.220	7.97	7.89	1.7350	0.0	24.0
20.10.25	66.50	58.17	8.33	208.470	210.520	204.320	207.260	-2.940	8.02	7.93	1.7010	0.0	24.0
Итого	---	---	---	4617.4	4638.2	4525.96	4567.14	-41.180	---	---	38.7360	0.0	768.0
Среднее	56.24	49.15	7.08	---	---	---	---	---	5.99	5.97	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	29835.700	29750.620	29210.000	29336.670	395.4800	-126.670	2788.0	8578.0
20.10.25 24:00	34453.150	34388.880	33735.960	33903.810	434.2160	-167.850	2788.0	9346.0
Итого за период	4617.450	4638.259	4525.959	4567.139	38.7360	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Садовое кольцо, 39
 Потребитель: АО "Жилуправление"
 Прибор: ИМ2300 Заводской номер: DC638

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.09	15.66	603.56	15.50	0.00	24.00	24.00	0.00	0.00
20.09.25	0.07	15.67	536.34	15.53	0.00	24.00	24.00	0.00	0.00
21.09.25	0.06	15.60	465.37	15.46	0.00	24.00	24.00	0.00	0.00
22.09.25	0.05	15.38	397.63	15.25	0.00	24.00	24.00	0.00	0.00
23.09.25	0.06	15.56	381.19	15.40	0.00	24.00	24.00	0.00	0.00
24.09.25	0.07	15.70	364.28	15.51	0.00	24.00	24.00	0.00	0.00
25.09.25	0.09	15.84	357.73	15.61	0.00	24.00	24.00	0.00	0.00
26.09.25	0.16	16.35	340.02	15.89	0.00	24.00	24.00	0.00	0.00
27.09.25	0.40	31.00	220.27	28.92	117.89	23.86	24.00	0.00	0.00
28.09.25	0.51	40.32	178.10	37.47	184.91	24.00	24.00	0.00	0.00
29.09.25	0.46	40.50	170.72	37.78	177.34	24.00	24.00	0.00	0.00
30.09.25	0.47	43.41	165.18	40.52	171.96	24.00	24.00	0.00	0.00
01.10.25	0.52	47.51	151.77	44.06	158.53	24.00	24.00	0.00	0.00
02.10.25	0.68	47.44	156.66	43.11	163.73	23.71	24.00	0.00	0.00
03.10.25	0.74	47.53	154.70	42.75	162.08	24.00	24.00	0.00	0.00
04.10.25	0.73	48.23	154.02	43.51	161.60	24.00	24.00	0.00	0.00
05.10.25	0.72	48.22	153.43	43.51	161.04	24.00	24.00	0.00	0.00
06.10.25	0.71	48.15	153.31	43.52	160.89	24.00	24.00	0.00	0.00
07.10.25	0.66	47.17	153.16	42.83	160.96	24.00	24.00	0.00	0.00
08.10.25	0.59	45.09	153.36	41.23	161.16	24.00	24.00	0.00	0.00
09.10.25	0.59	45.18	153.45	41.36	161.21	24.00	24.00	0.00	0.00
10.10.25	0.58	44.99	153.15	41.21	160.89	24.00	24.00	0.00	0.00
11.10.25	0.56	44.80	153.90	41.15	161.72	24.00	24.00	0.00	0.00
12.10.25	0.56	44.54	155.32	40.93	163.12	23.96	24.00	0.00	0.00
13.10.25	0.60	45.18	155.30	41.30	163.08	24.00	24.00	0.00	0.00
14.10.25	0.65	46.87	156.00	42.70	162.91	24.00	24.00	0.00	0.00
15.10.25	0.63	46.44	158.74	42.45	163.25	24.00	24.00	0.00	0.00
16.10.25	0.67	47.12	158.97	42.90	163.02	24.00	24.00	0.00	0.00
17.10.25	0.67	46.95	156.95	42.69	163.21	24.00	24.00	0.00	0.00
18.10.25	0.73	48.38	157.34	43.73	161.49	24.00	24.00	0.00	0.00
19.10.25	0.80	50.88	156.13	45.71	160.10	24.00	24.00	0.00	0.00
20.10.25	0.83	51.96	157.37	46.70	162.06	24.00	24.00	0.00	0.00
Итого	15.71	---	7283.42	---	3888.15	767.53	768.00	0.00	0.00
Среднее	---	38.238	---	35.193	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	1348.20	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Садовое кольцо, 40
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00175273

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0x669A

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	29.29	27.76	1.53	65.880	12.560	65.640	12.560	53.080	1.00	6.00	0.0950	0.0	24.0
20.09.25	29.21	27.71	1.50	68.360	13.960	68.120	13.960	54.160	1.00	6.00	0.0960	0.0	24.0
21.09.25	29.29	27.75	1.54	73.020	15.040	72.780	15.040	57.740	1.00	6.00	0.1050	0.0	24.0
22.09.25	29.31	27.87	1.44	78.410	16.160	78.170	16.160	62.010	1.00	6.00	0.0990	0.0	24.0
23.09.25	29.32	27.97	1.35	81.580	17.140	81.340	17.140	64.200	1.00	6.00	0.1040	0.0	24.0
24.09.25	29.24	27.93	1.31	86.090	17.110	85.820	17.110	68.710	1.00	6.00	0.1030	0.0	24.0
25.09.25	53.17	56.51	-3.34	164.920	118.060	162.510	116.340	46.170	3.21	7.45	0.7770	0.0	24.0
26.09.25	67.64	60.24	7.40	278.250	278.620	272.540	274.040	-1.500	7.92	10.34	1.9990	0.0	24.0
27.09.25	65.46	57.49	7.97	237.840	238.280	233.220	234.660	-1.440	7.83	10.37	1.8470	0.0	24.0
28.09.25	67.80	59.53	8.27	246.570	247.090	241.490	243.100	-1.610	7.81	10.30	1.9850	0.0	24.0
29.09.25	66.96	58.37	8.59	232.370	233.150	227.670	229.520	-1.850	7.81	10.35	1.9400	0.0	24.0
30.09.25	66.48	55.99	10.49	179.210	179.880	175.640	177.300	-1.660	7.93	10.77	1.8280	0.0	24.0
01.10.25	66.55	55.93	10.62	177.200	177.960	173.650	175.410	-1.760	8.26	11.35	1.8300	0.0	24.0
02.10.25	67.22	57.42	9.80	197.100	198.380	193.090	195.450	-2.360	8.34	11.42	1.8760	0.0	24.0
03.10.25	68.45	59.07	9.38	211.940	213.630	207.470	210.260	-2.790	8.36	11.40	1.9290	0.0	24.0
04.10.25	68.51	59.26	9.25	215.020	216.390	210.520	212.960	-2.440	8.34	11.34	1.9340	0.0	24.0
05.10.25	67.46	58.59	8.87	214.360	215.060	209.980	211.700	-1.720	8.35	11.36	1.8480	0.0	24.0
06.10.25	67.20	58.33	8.87	210.800	210.850	206.510	207.610	-1.100	8.32	11.32	1.8210	0.0	24.0
07.10.25	67.86	58.25	9.61	192.910	192.550	188.910	189.570	-0.660	8.13	11.04	1.8020	0.0	24.0
08.10.25	67.57	58.81	8.76	209.990	209.340	205.680	206.060	-0.380	7.89	10.55	1.7910	0.0	24.0
09.10.25	67.89	59.62	8.27	228.930	227.700	224.180	224.030	0.150	7.90	10.49	1.8410	0.0	24.0
10.10.25	67.57	59.86	7.71	241.230	239.860	236.280	235.970	0.310	7.94	10.50	1.8080	0.0	24.0
11.10.25	67.14	59.49	7.65	241.060	239.670	236.190	235.820	0.370	7.94	10.51	1.7940	0.0	24.0
12.10.25	67.29	59.29	8.00	236.130	234.670	231.300	230.930	0.370	7.88	10.43	1.8390	0.0	24.0
13.10.25	68.40	60.15	8.25	236.040	234.520	231.070	230.670	0.400	7.87	10.41	1.8960	0.0	24.0
14.10.25	67.30	59.33	7.97	234.010	232.730	229.270	229.010	0.260	7.86	10.40	1.8150	0.0	24.0
15.10.25	67.80	59.44	8.36	226.100	224.800	221.440	221.180	0.260	7.78	10.28	1.8380	0.0	24.0
16.10.25	67.70	59.21	8.49	224.340	223.030	219.700	219.470	0.230	7.87	10.46	1.8510	0.0	24.0
17.10.25	67.55	58.86	8.69	220.660	219.540	216.110	216.100	0.010	7.92	10.56	1.8680	0.0	24.0
18.10.25	67.87	59.00	8.87	217.870	216.490	213.360	213.080	0.280	7.73	10.23	1.8800	0.0	24.0
19.10.25	68.23	59.43	8.80	219.350	218.090	214.780	214.590	0.190	7.90	10.52	1.8800	0.0	24.0
20.10.25	67.65	59.05	8.60	221.630	220.380	217.080	216.880	0.200	7.94	10.58	1.8540	0.0	24.0
Итого	---	---	---	6169.1	5752.6	6051.51	5663.68	387.830	---	---	47.9730	0.0	768.0
Среднее	59.88	52.92	6.96	---	---	---	---	---	6.53	9.71	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	24365.760	24004.150	23840.489	23703.270	406.3450	137.220	257.0	9230.0
20.10.25 24:00	30534.929	29756.840	29892.000	29366.950	454.3180	525.050	257.0	9998.0
Итого за период	6169.169	5752.689	6051.510	5663.680	47.9730	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Садовое кольцо, 42
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВА779

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	26.58	3.63	25.68	3.99	24.00	24.00	0.00	0.00
20.09.25	0.00	26.39	3.71	25.41	4.02	24.00	24.00	0.00	0.00
21.09.25	0.00	26.25	3.75	25.29	4.01	24.00	24.00	0.00	0.00
22.09.25	0.00	26.24	3.70	25.23	3.97	24.00	24.00	0.00	0.00
23.09.25	0.00	25.44	3.54	24.83	3.92	24.00	24.00	0.00	0.00
24.09.25	0.00	25.28	3.60	24.78	3.92	24.00	24.00	0.00	0.00
25.09.25	0.00	25.02	3.68	24.30	3.94	23.99	24.00	0.00	0.00
26.09.25	1.14	38.50	134.63	35.03	130.38	23.99	24.00	0.00	0.00
27.09.25	3.21	66.28	381.33	57.86	373.55	24.00	24.00	0.00	0.00
28.09.25	2.93	64.35	332.72	55.53	325.48	24.00	24.00	0.00	0.00
29.09.25	3.06	66.77	333.90	57.59	326.15	24.00	24.00	0.00	0.00
30.09.25	3.02	65.94	339.07	57.00	331.28	23.93	24.00	0.00	0.00
01.10.25	2.87	65.43	303.20	55.96	296.57	24.00	24.00	0.00	0.00
02.10.25	2.87	65.29	314.73	56.14	307.72	24.00	24.00	0.00	0.00
03.10.25	2.95	66.11	345.08	57.56	337.03	24.00	24.00	0.00	0.00
04.10.25	3.01	67.27	352.06	58.73	343.25	24.00	24.00	0.00	0.00
05.10.25	2.98	67.41	356.32	59.04	346.68	24.00	24.00	0.00	0.00
06.10.25	2.85	66.36	354.52	58.31	343.99	24.00	24.00	0.00	0.00
07.10.25	2.80	66.08	343.49	57.93	332.66	24.00	24.00	0.00	0.00
08.10.25	2.80	66.69	333.80	58.30	322.67	24.00	24.00	0.00	0.00
09.10.25	2.63	66.50	287.48	56.85	277.20	24.00	24.00	0.00	0.00
10.10.25	2.36	66.69	170.41	52.00	163.61	24.00	24.00	0.00	0.00
11.10.25	1.94	66.24	91.04	44.85	86.43	24.00	24.00	0.00	0.00
12.10.25	1.95	65.83	91.24	44.45	86.38	24.00	24.00	0.00	0.00
13.10.25	1.98	65.97	90.21	43.94	85.58	24.00	24.00	0.00	0.00
14.10.25	2.05	67.07	88.89	43.99	84.26	24.00	24.00	0.00	0.00
15.10.25	1.97	65.98	88.40	43.67	83.85	24.00	24.00	0.00	0.00
16.10.25	2.01	66.49	86.10	43.09	81.50	24.00	24.00	0.00	0.00
17.10.25	2.05	66.40	85.64	42.41	81.22	24.00	24.00	0.00	0.00
18.10.25	2.02	66.24	84.25	42.17	80.00	24.00	24.00	0.00	0.00
19.10.25	2.04	66.57	83.05	42.00	78.93	24.00	24.00	0.00	0.00
20.10.25	2.06	66.92	83.31	42.18	79.30	24.00	24.00	0.00	0.00
Итого	61.55	---	5580.48	---	5413.44	767.91	768.00	0.00	0.00
Среднее	---	56.581	---	45.066	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	4453.28	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Садовое кольцо, 42
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВА780

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	23.08	0.00	24.84	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	22.91	0.00	24.59	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	22.83	0.00	24.51	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	22.75	0.00	24.48	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	22.62	0.00	24.34	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	22.60	0.00	24.27	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	22.32	0.00	23.77	0.00	0.00	24.00	0.00	0.00
26.09.25	1.20	39.86	134.34	37.25	130.23	9.31	24.00	0.00	0.00
27.09.25	2.70	66.20	297.81	57.12	293.59	24.00	24.00	0.00	0.00
28.09.25	1.25	49.71	129.21	43.84	127.45	21.94	24.00	0.00	0.00
29.09.25	0.00	24.13	0.00	24.74	0.00	0.00	24.00	0.00	0.00
30.09.25	0.94	37.81	76.71	34.00	73.81	12.20	24.00	0.00	0.00
01.10.25	2.65	65.36	225.48	53.61	222.55	24.00	24.00	0.00	0.00
02.10.25	2.74	65.96	240.45	54.51	236.96	24.00	24.00	0.00	0.00
03.10.25	2.74	66.56	260.18	56.01	255.72	24.00	24.00	0.00	0.00
04.10.25	2.85	67.81	271.33	57.30	266.31	24.00	24.00	0.00	0.00
05.10.25	2.82	67.70	274.18	57.41	268.93	24.00	24.00	0.00	0.00
06.10.25	2.69	66.68	272.59	56.79	267.46	24.00	24.00	0.00	0.00
07.10.25	2.11	63.44	216.82	55.34	211.94	23.12	23.99	0.00	0.00
08.10.25	2.35	67.23	241.78	57.52	237.42	24.00	24.00	0.00	0.00
09.10.25	2.30	66.77	210.44	55.46	205.75	24.00	24.00	0.00	0.00
10.10.25	2.13	67.07	142.85	51.64	138.70	24.00	24.00	0.00	0.00
11.10.25	1.89	66.68	99.03	47.61	95.50	24.00	24.00	0.00	0.00
12.10.25	1.87	66.23	98.84	47.26	95.43	24.00	24.00	0.00	0.00
13.10.25	1.90	66.38	97.06	46.75	93.78	24.00	24.00	0.00	0.00
14.10.25	1.96	67.54	96.87	47.24	93.89	24.00	24.00	0.00	0.00
15.10.25	1.88	66.40	95.55	46.69	92.64	24.00	24.00	0.00	0.00
16.10.25	1.92	66.86	93.30	46.30	89.98	24.00	24.00	0.00	0.00
17.10.25	1.94	66.80	92.79	45.83	89.65	24.00	24.00	0.00	0.00
18.10.25	1.94	66.69	91.22	45.38	88.09	24.00	24.00	0.00	0.00
19.10.25	1.96	66.99	90.20	45.22	87.62	24.00	24.00	0.00	0.00
20.10.25	1.96	67.38	90.53	45.69	87.62	24.00	24.00	0.00	0.00
Итого	50.69	---	3939.56	---	3851.02	546.57	767.99	0.00	0.00
Среднее	---	53.417	---	43.353	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	6747.81	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Садовое кольцо, 58
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ149

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	18.04	62.08	19.60	42.34	0.00	24.00	0.00	0.00
20.09.25	0.00	18.05	49.09	19.63	37.43	0.00	24.00	0.00	0.00
21.09.25	0.00	18.38	45.23	19.81	45.91	0.00	24.00	0.00	0.00
22.09.25	0.00	18.42	44.15	19.81	59.99	0.00	24.00	0.00	0.00
23.09.25	0.00	18.47	19.66	19.78	64.78	0.00	24.00	0.00	0.00
24.09.25	0.00	18.67	13.99	19.91	67.99	0.00	24.00	0.00	0.00
25.09.25	0.00	18.74	4.48	19.87	71.16	0.00	24.00	0.00	0.00
26.09.25	0.47	34.58	37.99	30.85	42.96	4.36	24.00	0.00	0.00
27.09.25	1.29	51.75	92.21	41.77	0.00	13.34	24.00	0.00	0.00
28.09.25	1.99	65.95	158.07	53.32	0.00	24.00	24.00	0.00	0.00
29.09.25	2.11	68.24	157.13	54.80	0.00	24.00	24.00	0.00	0.00
30.09.25	2.11	67.48	159.65	54.19	0.00	24.00	24.00	0.00	0.00
01.10.25	2.11	66.60	147.00	52.22	0.00	24.00	24.00	0.00	0.00
02.10.25	2.31	66.90	157.49	52.17	0.00	24.00	24.00	0.00	0.00
03.10.25	2.40	67.61	169.18	53.39	0.00	24.00	24.00	0.00	0.00
04.10.25	2.52	68.83	168.53	53.83	0.00	23.79	24.00	0.00	0.00
05.10.25	2.54	68.83	171.57	54.04	0.00	24.00	24.00	0.00	0.00
06.10.25	2.42	67.77	169.91	53.53	0.00	24.00	24.00	0.00	0.00
07.10.25	2.36	67.53	162.48	52.99	0.00	24.00	24.00	0.00	0.00
08.10.25	2.37	68.24	160.09	53.44	0.00	24.00	24.00	0.00	0.00
09.10.25	2.32	67.91	162.93	53.68	91.71	24.00	24.00	0.00	0.00
10.10.25	2.37	68.22	169.56	54.23	169.11	24.00	24.00	0.00	0.00
11.10.25	2.34	67.86	176.64	54.61	176.33	24.00	24.00	0.00	0.00
12.10.25	2.30	67.42	176.17	54.34	175.88	24.00	24.00	0.00	0.00
13.10.25	2.35	67.57	173.55	53.99	173.27	24.00	24.00	0.00	0.00
14.10.25	2.42	68.73	172.21	54.68	172.02	24.00	24.00	0.00	0.00
15.10.25	2.31	67.60	170.39	54.01	170.17	24.00	24.00	0.00	0.00
16.10.25	2.36	68.10	166.24	53.91	166.02	24.00	24.00	0.00	0.00
17.10.25	2.39	68.01	165.61	53.58	165.36	24.00	24.00	0.00	0.00
18.10.25	2.37	67.89	162.64	53.29	162.32	24.00	24.00	0.00	0.00
19.10.25	2.39	68.20	160.39	53.29	159.96	24.00	24.00	0.00	0.00
20.10.25	2.39	68.58	160.81	53.70	160.47	24.00	24.00	0.00	0.00
Итого	55.31	---	4167.12	---	2375.18	569.49	768.00	0.00	0.00
Среднее	---	55.474	---	45.196	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	6595.62	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Садовое кольцо, 60
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00177107

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0хЕАВВ

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Мг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	19.05	15.88	3.17	0.000	0.000	0.000	0.000	0.000	1.00	1.83	0.0000	0.0	24.0
20.09.25	19.03	15.89	3.14	0.000	0.000	0.000	0.000	0.000	1.00	1.82	0.0000	0.0	24.0
21.09.25	19.10	15.88	3.22	0.000	0.000	0.000	0.000	0.000	1.00	1.81	0.0000	0.0	24.0
22.09.25	19.62	16.48	3.14	0.000	0.000	0.000	0.000	0.000	1.00	1.81	0.0000	0.0	24.0
23.09.25	20.00	16.76	3.24	0.000	0.000	0.000	0.000	0.000	1.00	1.80	0.0000	0.0	24.0
24.09.25	20.12	17.06	3.06	0.000	0.000	0.000	0.000	0.000	1.00	1.79	0.0000	0.0	24.0
25.09.25	66.81	55.54	11.27	102.810	95.430	100.750	94.070	6.680	3.43	3.83	1.1470	0.0	24.0
26.09.25	67.98	56.37	11.61	231.710	216.800	226.910	213.640	13.270	7.15	7.07	2.6310	0.0	24.0
27.09.25	65.87	53.23	12.64	208.000	194.670	203.950	192.070	11.880	7.17	7.13	2.5750	0.0	24.0
28.09.25	68.29	54.87	13.42	206.510	193.320	202.210	190.680	11.530	7.15	7.11	2.7100	0.0	24.0
29.09.25	67.42	54.38	13.04	210.710	197.620	206.410	194.970	11.440	7.14	7.11	2.6880	0.0	24.0
30.09.25	66.91	53.14	13.77	195.690	183.960	191.730	181.580	10.150	7.35	7.33	2.6370	0.0	24.0
01.10.25	66.99	53.76	13.23	205.030	193.950	200.900	191.350	9.550	7.66	7.63	2.6580	0.0	24.0
02.10.25	67.62	55.11	12.51	221.900	211.030	217.330	208.090	9.240	7.67	7.63	2.7140	0.0	24.0
03.10.25	68.84	56.08	12.76	226.510	215.130	221.710	212.030	9.680	7.66	7.62	2.8280	0.0	24.0
04.10.25	68.92	56.25	12.67	230.360	218.220	225.470	215.090	10.380	7.63	7.58	2.8540	0.0	24.0
05.10.25	67.85	55.62	12.23	229.140	216.790	224.370	213.670	10.700	7.64	7.60	2.7450	0.0	24.0
06.10.25	67.59	55.11	12.48	220.570	208.480	216.050	205.520	10.530	7.64	7.61	2.6930	0.0	24.0
07.10.25	68.25	55.41	12.84	217.770	205.780	213.210	202.840	10.370	7.48	7.45	2.7370	0.0	24.0
08.10.25	68.00	55.76	12.24	221.630	209.490	217.030	206.490	10.540	7.21	7.18	2.6570	0.0	24.0
09.10.25	68.27	56.13	12.14	228.240	215.770	223.480	212.630	10.850	7.18	7.14	2.7100	0.0	24.0
10.10.25	67.90	56.34	11.56	237.550	224.590	232.610	221.270	11.340	7.17	7.13	2.6890	0.0	24.0
11.10.25	67.47	55.80	11.67	237.930	224.980	233.040	221.730	11.310	7.18	7.13	2.7180	0.0	24.0
12.10.25	67.63	55.67	11.96	235.290	222.410	230.440	219.220	11.220	7.13	7.09	2.7540	0.0	24.0
13.10.25	68.76	56.36	12.40	233.480	220.600	228.520	217.360	11.160	7.12	7.09	2.8330	0.0	24.0
14.10.25	67.65	55.72	11.93	231.590	218.850	226.800	215.660	11.140	7.12	7.09	2.7040	0.0	24.0
15.10.25	68.17	55.66	12.51	226.050	213.540	221.360	210.470	10.890	7.06	7.03	2.7690	0.0	24.0
16.10.25	68.08	55.32	12.76	225.370	212.840	220.700	209.850	10.850	7.16	7.13	2.8150	0.0	24.0
17.10.25	67.94	55.02	12.92	221.690	209.340	217.070	206.400	10.670	7.23	7.21	2.8010	0.0	24.0
18.10.25	68.26	54.98	13.28	218.740	206.460	214.190	203.580	10.610	7.04	7.02	2.8430	0.0	24.0
19.10.25	68.63	55.33	13.30	219.680	207.340	215.080	204.460	10.620	7.21	7.19	2.8590	0.0	24.0
20.10.25	68.01	54.98	13.03	224.880	212.350	220.180	209.410	10.770	7.23	7.20	2.8630	0.0	24.0
Итого	---	---	---	5668.8	5349.7	5551.50	5274.13	277.370	---	---	69.6320	0.0	768.0
Среднее	58.78	47.99	10.78	---	---	---	---	---	5.99	6.13	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Мг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	34811.860	32582.220	34044.020	32179.610	633.0960	1864.410	258.0	9229.0
20.10.25 24:00	40480.690	37931.959	39595.520	37453.739	702.7280	2141.780	258.0	9997.0
Итого за период	5668.830	5349.739	5551.500	5274.129	69.6320	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Садовое кольцо, 60а
 Потребитель: АО "Жилуправление"
 Прибор: ИМ2300 Заводской номер: ВВ412

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	18.45	0.00	19.63	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	18.25	0.00	19.39	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	18.17	0.00	19.33	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	18.17	0.00	19.36	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	18.27	0.00	19.43	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	18.36	0.00	19.50	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	18.38	0.00	19.41	0.00	0.00	24.00	0.00	0.00
26.09.25	2.06	40.04	247.98	36.62	248.92	11.11	24.00	0.00	0.00
27.09.25	4.01	65.31	471.27	56.80	476.08	24.00	24.00	0.00	0.00
28.09.25	3.76	64.12	421.51	55.19	425.02	24.00	24.00	0.00	0.00
29.09.25	3.93	66.24	414.78	56.77	417.99	24.00	24.00	0.00	0.00
30.09.25	3.80	65.54	419.78	56.44	423.16	23.97	24.00	0.00	0.00
01.10.25	3.54	64.49	381.91	55.23	385.16	24.00	24.00	0.00	0.00
02.10.25	3.69	65.03	411.59	56.03	415.13	24.00	24.00	0.00	0.00
03.10.25	3.74	65.63	443.63	57.19	447.37	24.00	24.00	0.00	0.00
04.10.25	3.82	66.86	451.91	58.38	456.91	24.00	24.00	0.00	0.00
05.10.25	3.77	66.77	454.39	58.47	460.17	24.00	24.00	0.00	0.00
06.10.25	3.57	65.76	449.41	57.80	455.61	24.00	24.00	0.00	0.00
07.10.25	3.55	65.55	430.71	57.29	436.51	24.00	24.00	0.00	0.00
08.10.25	3.57	66.30	426.71	57.91	432.51	24.00	24.00	0.00	0.00
09.10.25	3.46	65.89	431.26	57.85	437.56	24.00	24.00	0.00	0.00
10.10.25	3.55	66.21	447.96	58.27	454.80	24.00	24.00	0.00	0.00
11.10.25	3.48	65.87	464.95	58.38	472.84	24.00	24.00	0.00	0.00
12.10.25	3.46	65.43	464.58	57.98	472.33	24.00	24.00	0.00	0.00
13.10.25	3.52	65.59	457.60	57.89	465.20	24.00	24.00	0.00	0.00
14.10.25	3.63	66.74	455.59	58.76	463.83	24.00	24.00	0.00	0.00
15.10.25	3.48	65.62	449.99	57.87	458.17	24.00	24.00	0.00	0.00
16.10.25	3.55	66.09	439.52	58.01	447.59	24.00	24.00	0.00	0.00
17.10.25	3.59	66.03	437.96	57.82	445.85	24.00	24.00	0.00	0.00
18.10.25	3.65	65.92	432.39	57.48	439.99	24.00	24.00	0.00	0.00
19.10.25	3.69	66.22	427.91	57.59	435.44	24.00	24.00	0.00	0.00
20.10.25	3.72	66.61	429.52	57.94	437.27	24.00	24.00	0.00	0.00
Итого	89.59	---	10764.81	---	10911.41	587.08	768.00	0.00	0.00
Среднее	---	54.622	---	48.500	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	6819.88	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Садовое кольцо, 61
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00182110

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0x0991

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	15.33	16.95	-1.62	0.000	0.000	0.000	0.000	0.000	7.81	4.03	0.0000	0.0	24.0
20.09.25	15.43	17.01	-1.58	0.000	0.000	0.000	0.000	0.000	8.77	2.86	0.0000	0.0	24.0
21.09.25	15.44	17.05	-1.61	0.000	0.000	0.000	0.000	0.000	8.75	2.86	0.0000	0.0	24.0
22.09.25	15.64	17.36	-1.72	0.000	0.000	0.000	0.000	0.000	5.76	2.87	0.0000	0.0	24.0
23.09.25	15.92	17.11	-1.19	0.000	0.000	0.000	0.000	0.000	2.21	2.86	0.0000	0.0	24.0
24.09.25	16.10	16.66	-0.56	0.000	0.000	0.000	0.000	0.000	1.68	2.85	0.0000	0.0	24.0
25.09.25	15.49	15.63	-0.14	0.000	0.000	0.000	0.000	0.000	6.37	2.81	0.0000	0.0	24.0
26.09.25	14.06	14.62	-0.56	0.000	0.000	0.000	0.000	0.000	9.11	2.74	0.0000	0.0	24.0
27.09.25	65.03	58.98	6.05	419.220	432.500	411.210	425.590	-14.380	8.39	5.74	2.5390	0.0	24.0
28.09.25	66.74	60.49	6.25	633.720	656.580	621.040	645.640	-24.600	8.27	7.60	3.8850	0.0	24.0
29.09.25	65.90	59.73	6.17	617.910	639.820	605.810	629.350	-23.540	8.31	7.64	3.7430	0.0	24.0
30.09.25	65.58	59.30	6.28	514.280	532.050	504.300	523.490	-19.190	8.26	7.68	3.1730	0.0	24.0
01.10.25	65.34	59.47	5.87	602.700	623.650	591.070	613.560	-22.490	8.87	8.20	3.4780	0.0	24.0
02.10.25	66.14	60.39	5.75	600.300	621.810	588.500	611.490	-22.990	8.93	8.25	3.3940	0.0	24.0
03.10.25	67.34	61.54	5.80	607.560	629.750	595.210	618.910	-23.700	8.93	8.22	3.4570	0.0	24.0
04.10.25	67.40	61.58	5.82	608.780	630.270	596.400	619.390	-22.990	8.90	8.19	3.4740	0.0	24.0
05.10.25	66.36	60.84	5.52	610.760	632.150	598.630	621.480	-22.850	8.91	8.19	3.3110	0.0	24.0
06.10.25	66.11	60.41	5.70	582.690	602.670	571.220	592.620	-21.400	8.87	8.22	3.2680	0.0	24.0
07.10.25	66.74	60.79	5.95	548.110	566.840	537.130	557.300	-20.170	8.71	8.13	3.2020	0.0	24.0
08.10.25	66.48	60.63	5.85	539.470	557.880	528.740	548.500	-19.760	8.50	7.93	3.0980	0.0	24.0
09.10.25	66.71	60.71	6.00	532.960	550.960	522.300	541.710	-19.410	8.54	7.98	3.1390	0.0	24.0
10.10.25	66.39	60.46	5.93	525.600	543.110	515.160	534.060	-18.900	8.59	8.04	3.0630	0.0	24.0
11.10.25	65.96	60.23	5.73	539.140	556.860	528.570	547.640	-19.070	8.60	8.02	3.0300	0.0	24.0
12.10.25	66.08	60.12	5.96	532.990	550.340	522.530	541.240	-18.710	8.53	7.97	3.1150	0.0	24.0
13.10.25	67.21	61.10	6.11	532.430	549.770	521.620	540.420	-18.800	8.52	7.95	3.1900	0.0	24.0
14.10.25	66.05	60.08	5.97	520.640	537.530	510.390	528.650	-18.260	8.51	7.97	3.0500	0.0	24.0
15.10.25	66.60	60.26	6.34	502.230	517.760	492.200	509.160	-16.960	8.43	7.93	3.1240	0.0	24.0
16.10.25	66.48	59.91	6.57	497.260	510.970	487.360	502.570	-15.210	8.63	8.16	3.2040	0.0	24.0
17.10.25	66.38	59.36	7.02	254.740	257.220	249.730	253.050	-3.320	5.10	5.04	1.7830	0.0	24.0
18.10.25	66.62	59.57	7.05	450.470	423.410	441.450	416.530	24.920	8.53	8.15	3.1120	0.0	24.0
19.10.25	66.89	59.61	7.28	273.460	272.800	267.990	268.370	-0.380	5.54	5.82	1.9370	0.0	24.0
20.10.25	66.41	59.78	6.63	493.300	507.500	483.490	499.230	-15.740	8.77	8.30	3.2150	0.0	24.0
Итого	---	---	---	12540.7	12904.2	12292.05	12689.95	-397.900	---	---	74.9840	0.0	768.0
Среднее	53.63	49.30	4.33	---	---	---	---	---	7.83	6.54	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	68719.210	68973.240	67272.130	67912.820	729.9500	-640.690	3142.0	7933.0
20.10.25 24:00	81259.930	81877.440	79564.180	80602.770	804.9340	-1038.590	3142.0	8701.0
Итого за период	12540.719	12904.199	12292.049	12689.949	74.9840	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Садовое кольцо, 61
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00182274

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0х31Е0

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	15.41	15.41	0.00	0.000	3.600	0.000	3.600	-3.600	4.62	4.67	0.0000	0.0	24.0
20.09.25	15.50	15.43	0.07	0.000	5.760	0.000	5.760	-5.760	4.01	4.02	0.0000	0.0	24.0
21.09.25	15.48	15.41	0.07	0.000	5.760	0.000	5.760	-5.760	3.96	3.94	0.0000	0.0	24.0
22.09.25	15.36	15.25	0.11	0.000	0.000	0.000	0.000	0.000	3.79	3.91	0.0000	0.0	24.0
23.09.25	15.63	15.52	0.11	0.000	0.000	0.000	0.000	0.000	3.97	3.99	0.0000	0.0	24.0
24.09.25	15.53	15.39	0.14	0.240	0.000	0.240	0.000	0.240	4.01	3.89	0.0000	0.0	24.0
25.09.25	15.90	15.78	0.12	0.000	0.000	0.000	0.000	0.000	3.82	3.93	0.0000	0.0	24.0
26.09.25	15.86	15.78	0.08	0.000	0.000	0.000	0.000	0.000	3.77	3.79	0.0000	0.0	24.0
27.09.25	65.22	57.43	7.79	174.420	167.570	171.050	165.020	6.030	4.08	3.86	1.3710	0.0	24.0
28.09.25	66.67	59.05	7.62	372.730	359.040	365.230	353.240	11.990	4.22	3.57	2.7890	0.0	24.0
29.09.25	65.83	58.19	7.64	367.040	354.450	359.770	348.850	10.920	4.21	3.66	2.7510	0.0	24.0
30.09.25	65.55	57.62	7.93	299.380	289.250	293.530	284.760	8.770	4.48	3.98	2.3270	0.0	24.0
01.10.25	65.28	57.52	7.76	343.110	331.240	336.420	326.120	10.300	4.13	3.57	2.6090	0.0	24.0
02.10.25	66.06	58.17	7.89	338.620	325.620	331.890	320.500	11.390	4.01	3.31	2.6180	0.0	24.0
03.10.25	67.24	59.07	8.17	332.590	317.980	325.750	312.840	12.910	4.15	3.48	2.6690	0.0	24.0
04.10.25	67.31	58.95	8.36	323.750	308.870	317.160	303.890	13.270	4.03	3.50	2.6560	0.0	24.0
05.10.25	66.28	58.13	8.15	317.920	303.480	311.560	298.690	12.870	4.24	3.65	2.5430	0.0	24.0
06.10.25	66.02	57.22	8.80	288.550	275.070	282.830	270.880	11.950	4.22	3.67	2.4930	0.0	24.0
07.10.25	66.62	56.92	9.70	261.990	249.320	256.720	245.520	11.200	4.04	3.40	2.4950	0.0	24.0
08.10.25	66.37	56.68	9.69	256.060	243.720	250.950	240.070	10.880	4.04	3.55	2.4350	0.0	24.0
09.10.25	66.57	56.73	9.84	260.050	247.640	254.820	243.930	10.890	4.23	3.63	2.5080	0.0	24.0
10.10.25	66.28	56.43	9.85	251.010	239.000	246.010	235.480	10.530	4.11	3.59	2.4230	0.0	24.0
11.10.25	65.85	56.33	9.52	256.290	244.240	251.220	240.650	10.570	4.09	3.45	2.3910	0.0	24.0
12.10.25	65.96	56.07	9.89	249.510	237.570	244.600	234.080	10.520	4.15	3.49	2.4210	0.0	24.0
13.10.25	67.09	56.86	10.23	247.210	235.280	242.120	231.760	10.360	4.12	3.52	2.4780	0.0	24.0
14.10.25	65.94	55.79	10.15	238.350	226.920	233.610	223.610	10.000	4.24	3.61	2.3720	0.0	24.0
15.10.25	66.47	55.42	11.05	221.890	210.790	217.410	207.780	9.630	4.11	3.45	2.4030	0.0	24.0
16.10.25	66.33	54.82	11.51	212.850	202.020	208.580	199.150	9.430	3.99	3.53	2.4000	0.0	24.0
17.10.25	65.98	55.19	10.79	227.980	216.880	223.480	213.780	9.700	4.08	3.51	2.4110	0.0	24.0
18.10.25	66.46	54.27	12.19	199.190	188.760	195.180	186.120	9.060	4.01	3.52	2.3800	0.0	24.0
19.10.25	66.67	54.93	11.74	207.950	197.320	203.760	194.530	9.230	4.07	3.54	2.3910	0.0	24.0
20.10.25	66.24	53.18	13.06	178.170	168.270	174.630	166.040	8.590	4.16	3.63	2.2790	0.0	24.0
Итого	---	---	---	6426.8	6155.4	6298.52	6062.41	236.110	---	---	58.6130	0.0	768.0
Среднее	53.59	46.40	7.18	---	---	---	---	---	4.10	3.68	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	0.000	0.000	0.000	0.000	0.0000	0.000	580.0	1066.0
20.10.25 24:00	6426.850	6155.420	6298.519	6062.409	58.6130	236.110	580.0	1834.0
Итого за период	6426.850	6155.420	6298.519	6062.409	58.6130	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Садовое кольцо, 79
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00169042

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0х7500

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Мг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	20.31	21.10	-0.79	0.750	0.750	0.750	0.750	0.000	5.60	5.40	0.0000	0.0	24.0
20.09.25	20.70	21.46	-0.76	0.000	0.000	0.000	0.000	0.000	5.60	5.40	0.0000	0.0	24.0
21.09.25	20.81	21.58	-0.77	0.000	0.000	0.000	0.000	0.000	5.60	5.40	0.0000	0.0	24.0
22.09.25	21.04	21.79	-0.75	0.000	0.000	0.000	0.000	0.000	5.60	5.40	0.0000	0.0	24.0
23.09.25	21.42	22.17	-0.75	0.000	0.000	0.000	0.000	0.000	5.60	5.40	0.0000	0.0	24.0
24.09.25	21.92	22.52	-0.60	0.750	0.000	0.750	0.000	0.750	5.60	5.40	0.0000	0.0	24.0
25.09.25	21.37	22.05	-0.68	0.000	0.000	0.000	0.000	0.000	5.60	5.40	0.0000	0.0	24.0
26.09.25	59.72	45.10	14.62	177.700	172.400	174.770	170.740	4.030	5.60	5.40	2.5210	0.0	24.0
27.09.25	57.94	43.74	14.20	257.940	247.640	253.890	245.460	8.430	5.60	5.40	3.5980	0.0	24.0
28.09.25	59.54	44.19	15.35	254.970	245.710	250.800	243.460	7.340	5.60	5.40	3.8430	0.0	24.0
29.09.25	59.95	43.94	16.01	262.090	254.930	257.730	252.630	5.100	5.60	5.40	4.1180	0.0	24.0
30.09.25	59.94	42.77	17.17	239.940	234.960	235.990	232.930	3.060	5.60	5.40	4.0450	0.0	24.0
01.10.25	55.31	41.15	14.16	252.820	249.380	249.220	247.370	1.850	5.60	5.40	3.5230	0.0	24.0
02.10.25	53.69	40.44	13.25	264.500	259.670	260.940	257.690	3.250	5.60	5.40	3.4540	0.0	24.0
03.10.25	54.80	41.38	13.42	266.830	260.940	263.070	258.770	4.300	5.60	5.40	3.5250	0.0	24.0
04.10.25	52.54	39.43	13.11	250.030	244.250	246.820	242.500	4.320	5.60	5.40	3.2340	0.0	24.0
05.10.25	51.90	39.22	12.68	251.120	245.440	247.990	243.700	4.290	5.60	5.40	3.1380	0.0	24.0
06.10.25	57.15	44.10	13.05	313.920	307.790	309.160	304.900	4.260	5.60	5.40	4.0250	0.0	24.0
07.10.25	56.43	44.27	12.16	288.240	282.670	283.930	280.050	3.880	5.60	5.40	3.4500	0.0	24.0
08.10.25	45.47	35.15	10.32	211.580	206.930	209.510	205.740	3.770	5.60	5.40	2.1580	0.0	24.0
09.10.25	46.69	35.76	10.93	215.020	210.160	212.860	208.960	3.900	5.60	5.40	2.3230	0.0	24.0
10.10.25	46.95	36.04	10.91	216.340	211.410	214.160	210.210	3.950	5.60	5.40	2.3320	0.0	24.0
11.10.25	46.65	35.77	10.88	216.330	211.350	214.170	210.150	4.020	5.60	5.40	2.3290	0.0	24.0
12.10.25	47.50	35.99	11.51	223.620	218.440	221.290	217.140	4.150	5.60	5.40	2.5430	0.0	24.0
13.10.25	51.50	38.82	12.68	242.290	236.670	239.310	234.990	4.320	5.60	5.40	3.0270	0.0	24.0
14.10.25	50.36	38.26	12.10	238.240	232.720	235.420	231.090	4.330	5.60	5.40	2.8420	0.0	24.0
15.10.25	50.28	38.05	12.23	236.090	230.700	233.320	229.140	4.180	5.60	5.40	2.8480	0.0	24.0
16.10.25	50.69	39.13	11.56	269.790	264.300	266.510	262.380	4.130	5.60	5.40	3.0750	0.0	24.0
17.10.25	53.43	41.83	11.60	315.560	309.800	311.380	307.240	4.140	5.60	5.40	3.6050	0.0	24.0
18.10.25	55.05	43.08	11.97	327.060	321.100	322.460	318.220	4.240	5.60	5.40	3.8580	0.0	24.0
19.10.25	55.43	43.40	12.03	327.240	321.230	322.580	318.350	4.230	5.60	5.40	3.8750	0.0	24.0
20.10.25	55.01	42.54	12.47	299.020	293.100	294.790	290.620	4.170	5.60	5.40	3.6720	0.0	24.0
Итого	---	---	---	6419.7	6274.4	6333.57	6225.18	108.390	---	---	80.9610	0.0	768.0
Среднее	46.29	36.44	9.85	---	---	---	---	---	5.60	5.40	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Мг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	71872.120	67154.320	70764.560	66528.330	926.6370	4236.230	2474.0	7694.0
20.10.25 24:00	78291.900	73428.760	77098.130	72753.510	1007.5980	4344.620	2474.0	8462.0
Итого за период	6419.779	6274.439	6333.570	6225.179	80.9610	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Садовое кольцо, 7
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00166279

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0хСВЕВ

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	16.44	16.16	0.28	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
20.09.25	16.50	16.21	0.29	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
21.09.25	16.63	16.30	0.33	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
22.09.25	17.03	16.62	0.41	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
23.09.25	17.28	16.87	0.41	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
24.09.25	17.57	17.09	0.48	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
25.09.25	17.54	32.51	-14.97	0.000	1.560	0.000	1.560	-1.560	6.20	6.00	0.0000	0.0	24.0
26.09.25	39.44	33.79	5.65	110.750	109.450	109.970	108.860	1.110	6.20	6.00	0.6220	0.0	24.0
27.09.25	40.24	36.08	4.16	233.160	230.760	231.480	229.320	2.160	6.20	6.00	0.9620	0.0	24.0
28.09.25	40.43	36.72	3.71	227.310	224.890	225.600	223.450	2.150	6.20	6.00	0.8350	0.0	24.0
29.09.25	43.34	37.89	5.45	222.860	220.620	220.840	219.140	1.700	6.20	6.00	1.2030	0.0	24.0
30.09.25	47.50	40.85	6.65	225.130	222.350	222.730	220.670	2.060	6.20	6.00	1.4780	0.0	24.0
01.10.25	47.44	40.47	6.97	222.790	220.100	220.420	218.430	1.990	6.20	6.00	1.5360	0.0	24.0
02.10.25	47.51	40.69	6.82	224.980	221.990	222.580	220.310	2.270	6.20	6.00	1.5190	0.0	24.0
03.10.25	48.21	41.00	7.21	220.820	218.160	218.430	216.490	1.940	6.20	6.00	1.5720	0.0	24.0
04.10.25	48.21	40.82	7.39	226.240	223.300	223.840	221.620	2.220	6.20	6.00	1.6520	0.0	24.0
05.10.25	48.14	41.08	7.06	225.620	222.720	223.220	221.000	2.220	6.20	6.00	1.5750	0.0	24.0
06.10.25	47.17	40.57	6.60	225.430	222.630	223.090	220.950	2.140	6.20	6.00	1.4700	0.0	24.0
07.10.25	45.06	38.92	6.14	225.950	223.170	223.790	221.490	2.300	6.20	6.00	1.3720	0.0	24.0
08.10.25	45.15	38.99	6.16	226.490	223.600	224.330	221.920	2.410	6.20	6.00	1.3790	0.0	24.0
09.10.25	44.96	38.83	6.13	226.400	223.540	224.240	221.910	2.330	6.20	6.00	1.3740	0.0	24.0
10.10.25	44.78	38.83	5.95	226.730	223.890	224.590	222.260	2.330	6.20	6.00	1.3340	0.0	24.0
11.10.25	44.51	38.66	5.85	229.300	226.490	227.170	224.860	2.310	6.20	6.00	1.3270	0.0	24.0
12.10.25	45.14	38.95	6.19	229.580	226.720	227.390	225.040	2.350	6.20	6.00	1.4080	0.0	24.0
13.10.25	46.84	40.11	6.73	229.630	226.800	227.230	225.120	2.110	6.20	6.00	1.5270	0.0	24.0
14.10.25	46.43	39.95	6.48	229.880	227.070	227.540	225.400	2.140	6.20	6.00	1.4720	0.0	24.0
15.10.25	47.09	40.31	6.78	230.060	227.150	227.660	225.470	2.190	6.20	6.00	1.5400	0.0	24.0
16.10.25	46.92	40.03	6.89	229.720	226.670	227.320	224.990	2.330	6.20	6.00	1.5640	0.0	24.0
17.10.25	48.31	40.81	7.50	227.650	224.510	225.160	222.750	2.410	6.20	6.00	1.6860	0.0	24.0
18.10.25	50.87	42.48	8.39	224.850	221.620	222.060	219.740	2.320	6.20	6.00	1.8620	0.0	24.0
19.10.25	51.96	43.34	8.62	227.020	223.760	224.140	221.840	2.300	6.20	6.00	1.9280	0.0	24.0
20.10.25	50.67	42.63	8.04	226.840	223.550	224.090	221.630	2.460	6.20	6.00	1.8000	0.0	24.0
Итого	---	---	---	5555.1	5487.0	5498.91	5446.22	52.690	---	---	35.9970	0.0	768.0
Среднее	39.85	35.14	4.71	---	---	---	---	---	6.20	6.00	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	50974.260	47243.610	47418.270	46803.310	464.1120	614.960	3482.0	6009.0
20.10.25 24:00	56529.450	52730.680	52917.180	52249.529	500.1090	667.650	3482.0	6777.0
Итого за период	5555.189	5487.070	5498.910	5446.219	35.9970	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Салавата батыра, 5
 Потребитель: АО "Жилуправление"
 Прибор: Вzlёт ТСРВ-024 Заводской номер: 800762
 Тип системы: А32-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
28.09.25	43.69	38.00	5.69	136.32	137.53	-1.20	0.590	0.549	137.55	138.53	-0.97	0.650	24.000
29.09.25	43.42	37.17	6.25	136.05	135.58	0.46	0.590	0.549	137.24	136.50	0.74	0.867	24.000
30.09.25	43.33	35.35	7.98	121.28	120.75	0.52	0.590	0.549	122.33	121.49	0.84	0.976	24.000
01.10.25	45.32	35.96	9.36	111.86	111.45	0.41	0.590	0.549	112.94	112.15	0.79	1.061	24.000
02.10.25	48.01	37.35	10.66	108.12	107.70	0.42	0.590	0.549	109.30	108.41	0.89	1.162	24.000
03.10.25	47.98	39.02	8.96	135.53	135.23	0.29	0.590	0.549	137.00	136.22	0.77	1.193	24.000
04.10.25	47.20	39.10	8.10	142.96	142.68	0.27	0.590	0.549	144.47	143.72	0.75	1.168	24.000
05.10.25	47.32	39.26	8.06	142.79	142.51	0.27	0.590	0.549	144.31	143.55	0.75	1.161	24.000
06.10.25	47.40	39.45	7.95	142.75	142.57	0.18	0.590	0.549	144.27	143.62	0.65	1.136	24.000
07.10.25	44.72	37.73	6.99	141.97	141.92	0.04	0.590	0.549	143.32	142.88	0.44	0.982	24.000
08.10.25	44.86	37.79	7.07	140.73	140.40	0.32	0.590	0.549	142.07	141.36	0.72	1.006	24.000
09.10.25	44.79	37.72	7.07	138.62	138.40	0.22	0.590	0.549	139.94	139.33	0.61	0.984	24.000
10.10.25	44.25	37.30	6.95	135.48	135.24	0.24	0.590	0.549	136.75	136.14	0.61	0.946	24.000
11.10.25	43.81	36.98	6.83	134.82	134.58	0.24	0.590	0.549	136.05	135.45	0.60	0.925	24.000
12.10.25	42.91	36.39	6.52	134.68	134.42	0.26	0.590	0.549	135.86	135.26	0.60	0.884	24.000
13.10.25	43.35	36.64	6.71	134.68	134.78	-0.10	0.590	0.549	135.88	135.65	0.23	0.883	24.000
14.10.25	43.75	36.80	6.95	134.32	134.07	0.25	0.590	0.549	135.54	134.93	0.62	0.939	24.000
15.10.25	46.29	38.40	7.89	132.48	132.23	0.24	0.590	0.549	133.83	133.16	0.67	1.051	24.000
16.10.25	46.26	38.76	7.50	145.83	145.64	0.19	0.590	0.549	147.31	146.68	0.63	1.095	24.000
17.10.25	46.10	38.99	7.11	156.37	156.30	0.06	0.590	0.549	157.95	157.44	0.51	1.100	24.000
18.10.25	51.24	42.53	8.71	156.00	156.44	-0.43	0.590	0.549	157.94	157.81	0.12	1.294	24.000
19.10.25	51.73	42.89	8.84	153.37	153.60	-0.23	0.590	0.549	155.31	154.96	0.35	1.322	24.000
20.10.25	51.68	42.93	8.75	153.87	153.69	0.17	0.590	0.549	155.81	155.05	0.77	1.347	24.000
Итого	---	---	---	3170.86	3167.70	3.16	---	---	3202.98	3190.29	12.69	24.130	552.000
Среднее	46.06	38.37	7.69	---	---	---	0.590	0.549	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

**ТС Пульсар ДУ-32, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Салавата батыра, 9
 Потребитель: АО "Жилуправление"
 Прибор: 378 Заводской номер: 04299129
 ТВ1

Дата	T1	T2	V1	Q	Время раб. (ч)
19.09.25	15.4	15.0	0.000	0.000	0.00
20.09.25	15.3	15.0	0.000	0.000	0.00
21.09.25	15.3	15.0	0.000	0.000	0.00
22.09.25	15.4	15.2	0.000	0.000	0.00
23.09.25	15.6	15.2	0.000	0.000	0.00
24.09.25	15.7	15.4	0.000	0.000	0.00
25.09.25	27.7	25.4	23.010	0.110	10.00
26.09.25	41.2	36.9	43.988	0.182	23.00
27.09.25	44.1	38.8	40.234	0.208	24.00
28.09.25	43.3	38.2	39.459	0.202	24.00
29.09.25	42.9	37.0	33.723	0.193	24.00
30.09.25	43.9	35.6	24.059	0.197	24.00
01.10.25	45.6	36.4	23.387	0.212	24.00
02.10.25	47.8	38.0	24.672	0.230	24.00
03.10.25	47.0	39.5	30.789	0.231	24.00
04.10.25	46.9	39.4	30.879	0.228	24.00
05.10.25	47.0	39.6	31.258	0.227	24.00
06.10.25	45.6	38.8	31.461	0.210	24.00
07.10.25	44.5	38.1	31.227	0.198	24.00
08.10.25	44.6	38.1	30.727	0.195	24.00
09.10.25	44.3	37.8	30.148	0.192	24.00
10.10.25	43.5	37.3	29.691	0.181	24.00
11.10.25	42.7	36.7	29.604	0.175	24.00
12.10.25	43.1	36.9	29.574	0.182	24.00
13.10.25	43.1	36.8	29.557	0.183	24.00
14.10.25	44.7	37.9	29.303	0.199	24.00
15.10.25	45.7	38.7	30.373	0.210	24.00
16.10.25	45.9	39.2	33.340	0.219	24.00
17.10.25	47.8	40.6	34.168	0.243	24.00
18.10.25	51.3	43.1	34.438	0.276	24.00
19.10.25	51.5	43.3	34.453	0.276	24.00
20.10.25	50.1	42.5	34.594	0.258	24.00
Итого	---	---	818.113	5.417	609.00
Среднее	39.3	33.8	---	---	---

Показания интеграторов

Дата	V1, м. куб	Q, Гкал	Время раб., ч
18.09.25 24:00	30993.564	283.353	19462.000
20.10.25 24:00	31811.678	288.770	20071.000
Итого за период	818.114	5.417	609.000

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Свердловла, 12
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00179188

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0x5F0D

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	18.69	18.72	-0.03	0.000	0.000	0.000	0.000	0.000	1.19	1.21	0.0000	0.0	24.0
20.09.25	18.65	18.68	-0.03	0.000	0.000	0.000	0.000	0.000	1.18	1.20	0.0000	0.0	24.0
21.09.25	18.61	18.62	-0.01	0.000	0.000	0.000	0.000	0.000	1.18	1.19	0.0000	0.0	24.0
22.09.25	18.63	18.65	-0.02	0.000	0.000	0.000	0.000	0.000	1.17	1.18	0.0000	0.0	24.0
23.09.25	18.68	18.71	-0.03	0.000	0.000	0.000	0.000	0.000	1.16	1.16	0.0000	0.0	24.0
24.09.25	18.74	18.77	-0.03	0.000	0.000	0.000	0.000	0.000	1.16	1.15	0.0000	0.0	24.0
25.09.25	18.74	18.77	-0.03	0.000	0.000	0.000	0.000	0.000	1.15	1.14	0.0000	0.0	24.0
26.09.25	39.87	33.79	6.08	80.590	80.240	79.980	79.780	0.200	2.47	1.19	0.4890	0.0	24.0
27.09.25	44.52	37.80	6.72	140.290	140.120	138.970	139.160	-0.190	3.89	1.30	0.9380	0.0	24.0
28.09.25	43.73	36.98	6.75	132.130	132.810	130.930	131.850	-0.920	3.90	1.32	0.8890	0.0	24.0
29.09.25	43.36	36.65	6.71	130.020	131.440	128.870	130.530	-1.660	3.89	1.32	0.8710	0.0	24.0
30.09.25	44.75	36.44	8.31	109.280	111.240	108.320	110.520	-2.200	3.90	1.32	0.9040	0.0	24.0
01.10.25	46.53	37.34	9.19	105.000	107.080	103.970	106.360	-2.390	3.91	1.33	0.9610	0.0	24.0
02.10.25	48.73	39.14	9.59	108.410	110.430	107.180	109.670	-2.490	3.93	1.34	1.0280	0.0	24.0
03.10.25	47.74	40.09	7.65	134.840	136.710	133.400	135.740	-2.340	3.92	1.34	1.0240	0.0	24.0
04.10.25	47.52	39.92	7.60	134.640	136.580	133.200	135.620	-2.420	3.91	1.33	1.0180	0.0	24.0
05.10.25	47.65	40.13	7.52	134.430	136.470	132.990	135.470	-2.480	3.93	1.34	1.0030	0.0	24.0
06.10.25	46.18	39.22	6.96	133.060	135.220	131.740	134.260	-2.520	3.91	1.34	0.9230	0.0	24.0
07.10.25	45.03	38.46	6.57	120.870	122.930	119.770	122.050	-2.280	3.99	1.53	0.7930	0.0	24.0
08.10.25	44.97	39.24	5.73	154.470	156.690	152.990	155.510	-2.520	3.89	1.34	0.8800	0.0	24.0
09.10.25	44.75	39.48	5.27	169.770	171.910	168.090	170.710	-2.620	3.89	1.35	0.8950	0.0	24.0
10.10.25	43.91	38.88	5.03	167.070	169.250	165.620	168.050	-2.430	3.88	1.35	0.8400	0.0	24.0
11.10.25	43.14	38.24	4.90	165.220	167.430	163.800	166.250	-2.450	3.88	1.35	0.8080	0.0	24.0
12.10.25	43.54	38.39	5.15	164.900	167.070	163.460	165.870	-2.410	3.89	1.36	0.8480	0.0	24.0
13.10.25	43.51	38.37	5.14	164.760	166.960	163.320	165.760	-2.440	3.89	1.36	0.8400	0.0	24.0
14.10.25	45.21	39.57	5.64	162.900	165.070	161.330	163.830	-2.500	3.90	1.36	0.9140	0.0	24.0
15.10.25	46.25	40.43	5.82	167.190	169.410	165.440	168.130	-2.690	3.90	1.36	0.9680	0.0	24.0
16.10.25	46.37	40.82	5.55	182.530	184.720	180.610	183.280	-2.670	3.91	1.37	1.0080	0.0	24.0
17.10.25	48.25	42.23	6.02	186.910	189.130	184.830	187.520	-2.690	3.93	1.37	1.1160	0.0	24.0
18.10.25	51.91	45.04	6.87	188.040	190.210	185.640	188.290	-2.650	3.98	1.40	1.2820	0.0	24.0
19.10.25	52.08	45.27	6.81	188.200	190.410	185.800	188.490	-2.690	3.98	1.40	1.2720	0.0	24.0
20.10.25	50.67	44.53	6.14	194.620	196.910	192.290	195.050	-2.760	3.96	1.38	1.1880	0.0	24.0
Итого	---	---	---	3720.1	3766.4	3682.54	3737.75	-55.210	---	---	23.7000	0.0	768.0
Среднее	40.02	34.91	5.11	---	---	---	---	---	3.27	1.31	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	211.790	217.590	208.910	215.430	1.4650	-6.520	24.0	336.0
20.10.25 24:00	3720.619	3769.530	3683.020	3740.840	23.7000	-57.820	0.0	1118.0
Итого за период	3508.829	3551.940	3474.110	3525.410	22.2350	---	-24.0	782.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ИМ2300, Суточный с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Свердлова, 14
 Потребитель: АО "Жилуправление"
 Прибор: ИМ2300 Заводской номер: ВВ587

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	18.33	0.00	18.04	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	18.31	0.00	18.01	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	18.27	0.00	17.97	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	18.26	0.00	17.95	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	18.33	0.00	18.02	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	18.38	0.00	18.08	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	18.45	0.00	18.14	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	18.48	0.00	18.16	0.00	0.00	24.00	0.00	0.00
27.09.25	0.32	27.07	64.90	24.98	65.07	9.05	24.00	0.00	0.00
28.09.25	0.79	44.53	149.62	39.25	151.54	24.00	24.00	0.00	0.00
29.09.25	0.75	43.76	141.35	38.46	144.58	24.00	24.00	0.00	0.00
30.09.25	0.75	43.40	139.95	38.01	143.41	24.00	24.00	0.00	0.00
01.10.25	0.79	44.73	118.22	38.06	122.33	24.00	24.00	0.00	0.00
02.10.25	0.83	46.47	113.34	39.16	118.31	24.00	24.00	0.00	0.00
03.10.25	0.88	48.83	116.30	41.00	121.59	24.00	24.00	0.00	0.00
04.10.25	0.90	47.74	146.79	41.62	147.47	24.00	24.00	0.00	0.00
05.10.25	0.88	47.52	146.66	41.49	147.29	24.00	24.00	0.00	0.00
06.10.25	0.88	47.65	146.54	41.64	147.17	24.00	24.00	0.00	0.00
07.10.25	0.80	46.22	145.18	40.69	145.86	24.00	24.00	0.00	0.00
08.10.25	0.74	45.04	143.72	39.87	144.51	24.00	24.00	0.00	0.00
09.10.25	0.76	45.08	169.82	40.59	170.26	23.88	24.00	0.00	0.00
10.10.25	0.75	44.90	187.80	40.91	188.21	24.00	24.00	0.00	0.00
11.10.25	0.70	44.06	184.81	40.26	185.38	24.00	24.00	0.00	0.00
12.10.25	0.67	43.29	182.79	39.61	183.43	24.00	24.00	0.00	0.00
13.10.25	0.71	43.70	182.19	39.80	182.97	24.00	24.00	0.00	0.00
14.10.25	0.71	43.66	182.23	39.75	183.02	24.00	24.00	0.00	0.00
15.10.25	0.77	45.36	180.18	41.07	180.99	24.00	24.00	0.00	0.00
16.10.25	0.81	46.40	184.61	41.97	185.54	24.00	24.00	0.00	0.00
17.10.25	0.85	46.53	201.16	42.30	202.32	24.00	24.00	0.00	0.00
18.10.25	0.94	48.36	205.57	43.80	206.74	24.00	24.00	0.00	0.00
19.10.25	1.07	52.06	206.24	46.84	207.44	24.00	24.00	0.00	0.00
20.10.25	1.06	52.23	206.47	47.08	207.65	24.00	24.00	0.00	0.00
Итого	19.11	---	3846.44	---	3883.08	560.93	768.00	0.00	0.00
Среднее	---	38.606	---	34.768	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	1542.78	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

ИМ2300, Суточный с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Свердлова, 16
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВА705

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	19.07	0.00	18.71	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	19.01	0.00	18.71	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	18.93	0.00	18.65	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	18.83	0.00	18.53	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	18.83	0.00	18.58	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	18.89	0.00	18.67	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	18.93	0.00	18.70	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	19.02	0.00	18.78	0.00	0.00	24.00	0.00	0.00
27.09.25	0.50	29.23	67.73	25.42	67.54	11.45	24.00	0.00	0.00
28.09.25	1.07	44.52	131.82	36.38	131.25	24.00	24.00	0.00	0.00
29.09.25	1.02	43.74	124.87	35.57	124.54	24.00	24.00	0.00	0.00
30.09.25	1.01	43.38	123.99	35.18	123.77	24.00	24.00	0.00	0.00
01.10.25	1.05	44.66	104.58	34.63	104.45	24.00	24.00	0.00	0.00
02.10.25	1.11	46.36	100.57	35.33	100.49	24.00	24.00	0.00	0.00
03.10.25	1.21	48.86	102.51	36.72	102.50	24.00	24.00	0.00	0.00
04.10.25	1.21	47.75	128.05	38.28	128.03	24.00	24.00	0.00	0.00
05.10.25	1.20	47.51	127.99	38.11	127.99	24.00	24.00	0.00	0.00
06.10.25	1.19	47.62	127.86	38.31	127.86	24.00	24.00	0.00	0.00
07.10.25	1.10	46.29	126.43	37.58	126.39	24.00	24.00	0.00	0.00
08.10.25	1.03	45.02	124.68	36.76	124.67	23.51	24.00	0.00	0.00
09.10.25	1.07	45.06	147.39	37.71	147.36	23.54	24.00	0.00	0.00
10.10.25	1.07	44.89	164.08	38.35	163.73	24.00	24.00	0.00	0.00
11.10.25	0.99	44.05	161.32	37.88	161.50	24.00	24.00	0.00	0.00
12.10.25	0.95	43.29	159.54	37.33	159.72	24.00	24.00	0.00	0.00
13.10.25	0.99	43.68	159.06	37.47	159.23	24.00	24.00	0.00	0.00
14.10.25	0.99	43.63	159.08	37.41	159.25	24.00	24.00	0.00	0.00
15.10.25	1.07	45.28	157.26	38.43	157.38	24.00	24.00	0.00	0.00
16.10.25	1.15	46.36	160.98	39.16	161.17	24.00	24.00	0.00	0.00
17.10.25	1.20	46.51	176.13	39.68	176.53	24.00	24.00	0.00	0.00
18.10.25	1.33	48.18	180.08	40.80	180.50	24.00	24.00	0.00	0.00
19.10.25	1.53	52.05	180.79	43.59	181.18	24.00	24.00	0.00	0.00
20.10.25	1.51	52.20	180.96	43.82	181.33	24.00	24.00	0.00	0.00
Итого	26.55	---	3377.75	---	3378.36	562.50	768.00	0.00	0.00
Среднее	---	38.801	---	32.788	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	4840.55	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Свердлова, 20
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00177294

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0xE4B7

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	18.39	18.38	0.01	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
20.09.25	18.30	18.32	-0.02	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
21.09.25	18.26	18.28	-0.02	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
22.09.25	18.23	18.26	-0.03	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
23.09.25	18.15	18.21	-0.06	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
24.09.25	18.15	18.19	-0.04	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
25.09.25	18.24	18.20	0.04	0.000	0.000	0.000	0.000	0.000	6.20	6.00	0.0000	0.0	24.0
26.09.25	41.27	35.35	5.92	82.710	81.770	82.050	81.270	0.780	6.20	6.00	0.4790	0.0	24.0
27.09.25	44.59	38.80	5.79	169.380	167.270	167.820	166.070	1.750	6.20	6.00	0.9710	0.0	24.0
28.09.25	43.80	38.12	5.68	166.710	165.010	165.270	163.810	1.460	6.20	6.00	0.9360	0.0	24.0
29.09.25	43.43	37.70	5.73	163.770	162.510	162.340	161.380	0.960	6.20	6.00	0.9290	0.0	24.0
30.09.25	44.89	37.48	7.41	132.390	131.090	131.190	130.130	1.060	6.20	6.00	0.9700	0.0	24.0
01.10.25	46.73	38.44	8.29	124.420	123.200	123.160	122.400	0.760	6.20	6.00	1.0190	0.0	24.0
02.10.25	48.86	40.37	8.49	129.950	128.730	128.490	127.730	0.760	6.20	6.00	1.0910	0.0	24.0
03.10.25	47.82	41.08	6.74	160.370	159.210	158.690	158.010	0.680	6.20	6.00	1.0670	0.0	24.0
04.10.25	47.63	40.93	6.70	159.920	158.720	158.240	157.520	0.720	6.20	6.00	1.0590	0.0	24.0
05.10.25	47.76	41.13	6.63	159.370	158.150	157.690	156.950	0.740	6.20	6.00	1.0460	0.0	24.0
06.10.25	46.24	40.10	6.14	157.850	156.670	156.290	155.470	0.820	6.20	6.00	0.9610	0.0	24.0
07.10.25	45.12	39.32	5.80	155.790	154.630	154.350	153.430	0.920	6.20	6.00	0.8990	0.0	24.0
08.10.25	45.21	39.16	6.05	145.480	144.160	144.060	143.120	0.940	6.20	6.00	0.8700	0.0	24.0
09.10.25	44.92	38.63	6.29	136.680	135.390	135.460	134.430	1.030	6.20	6.00	0.8500	0.0	24.0
10.10.25	44.08	38.08	6.00	133.320	132.130	132.120	131.170	0.950	6.20	6.00	0.7920	0.0	24.0
11.10.25	43.30	37.47	5.83	131.710	130.550	130.540	129.650	0.890	6.20	6.00	0.7590	0.0	24.0
12.10.25	43.72	37.61	6.11	131.310	130.140	130.110	129.180	0.930	6.20	6.00	0.7910	0.0	24.0
13.10.25	43.69	37.50	6.19	131.350	130.170	130.150	129.210	0.940	6.20	6.00	0.8030	0.0	24.0
14.10.25	45.49	38.72	6.77	129.600	128.400	128.350	127.440	0.910	6.20	6.00	0.8640	0.0	24.0
15.10.25	46.45	39.44	7.01	132.160	130.960	130.880	130.000	0.880	6.20	6.00	0.9190	0.0	24.0
16.10.25	46.54	39.87	6.67	144.190	143.010	142.750	142.020	0.730	6.20	6.00	0.9500	0.0	24.0
17.10.25	48.54	41.24	7.30	147.100	145.930	145.490	144.760	0.730	6.20	6.00	1.0570	0.0	24.0
18.10.25	52.12	43.84	8.28	147.880	146.640	145.960	145.250	0.710	6.20	6.00	1.2050	0.0	24.0
19.10.25	52.30	44.10	8.20	148.050	146.830	146.130	145.390	0.740	6.20	6.00	1.1960	0.0	24.0
20.10.25	50.82	43.39	7.43	152.680	151.480	150.830	150.100	0.730	6.20	6.00	1.1200	0.0	24.0
Итого	---	---	---	3574.1	3542.7	3538.41	3515.89	22.520	---	---	23.6030	0.0	768.0
Среднее	40.09	34.86	5.22	---	---	---	---	---	6.20	6.00	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	35456.720	34786.369	34989.299	34460.890	291.5190	528.410	3184.0	8296.0
20.10.25 24:00	39030.859	38329.120	38527.710	37976.779	315.1220	550.930	3184.0	9064.0
Итого за период	3574.138	3542.751	3538.411	3515.889	23.6030	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ИМ2300, Суточный с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Свердлова, 22
 Потребитель: АО "Жилуправление"
 Прибор: ИМ2300 Заводской номер: ВВ316

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.09	15.99	258.89	15.63	0.00	24.00	24.00	0.00	0.00
20.09.25	0.05	15.93	140.27	15.57	0.00	24.00	24.00	0.00	0.00
21.09.25	0.01	15.87	15.92	15.53	0.00	24.00	24.00	0.00	0.00
22.09.25	0.00	15.84	8.30	15.49	0.00	24.00	24.00	0.00	0.00
23.09.25	0.00	15.83	6.02	15.56	0.02	23.05	24.00	0.00	0.00
24.09.25	0.00	15.80	4.20	15.50	0.00	24.00	24.00	0.00	0.00
25.09.25	0.00	15.85	3.47	15.51	0.00	24.00	24.00	0.00	0.00
26.09.25	0.00	15.87	2.67	15.54	0.00	24.00	24.00	0.00	0.00
27.09.25	0.19	15.99	558.27	15.62	0.00	24.00	24.00	0.00	0.00
28.09.25	0.44	15.63	1579.55	16.27	133.03	17.43	24.00	0.00	0.00
29.09.25	0.12	15.47	1559.98	15.91	390.19	9.41	24.00	0.00	0.00
30.09.25	1.16	25.18	1159.30	23.25	200.42	23.50	24.00	0.00	0.00
01.10.25	1.94	44.90	335.62	39.10	329.82	24.00	24.00	0.00	0.00
02.10.25	2.02	46.66	320.62	40.35	315.34	24.00	24.00	0.00	0.00
03.10.25	2.15	49.17	330.33	42.38	325.11	24.00	24.00	0.00	0.00
04.10.25	2.07	47.94	414.00	42.93	407.92	24.00	24.00	0.00	0.00
05.10.25	2.05	47.69	413.11	42.72	407.19	24.00	24.00	0.00	0.00
06.10.25	2.02	47.81	412.59	42.89	406.73	24.00	24.00	0.00	0.00
07.10.25	1.86	46.44	409.65	41.89	403.79	24.00	24.00	0.00	0.00
08.10.25	1.74	45.17	403.96	40.86	398.13	24.00	24.00	0.00	0.00
09.10.25	1.49	45.28	364.27	41.21	360.43	24.00	24.00	0.00	0.00
10.10.25	1.54	45.02	341.68	40.50	338.83	24.00	24.00	0.00	0.00
11.10.25	1.51	44.18	336.61	39.68	333.73	24.00	24.00	0.00	0.00
12.10.25	1.51	43.40	337.33	38.93	334.38	24.00	24.00	0.00	0.00
13.10.25	1.58	43.79	335.97	39.09	333.20	24.00	24.00	0.00	0.00
14.10.25	1.58	43.75	336.15	39.04	333.34	24.00	24.00	0.00	0.00
15.10.25	1.71	45.47	332.55	40.30	329.76	24.00	24.00	0.00	0.00
16.10.25	1.82	46.51	338.34	41.12	335.67	24.00	24.00	0.00	0.00
17.10.25	1.88	46.63	370.53	41.54	367.64	24.00	24.00	0.00	0.00
18.10.25	2.07	48.31	378.62	42.83	375.82	24.00	24.00	0.00	0.00
19.10.25	2.39	52.21	380.03	45.92	378.84	24.00	24.00	0.00	0.00
20.10.25	2.36	52.36	380.09	46.13	379.63	24.00	24.00	0.00	0.00
Итого	39.35	---	12568.89	---	7918.96	745.39	768.00	0.00	0.00
Среднее	---	35.373	---	32.025	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	5681.95	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Свердлова, 24
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВА734

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	17.44	0.00	17.29	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	17.41	0.00	17.26	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	17.39	0.00	17.24	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	17.36	0.00	17.22	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	17.69	0.00	17.65	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	17.84	0.00	17.78	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	17.99	0.00	17.96	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	17.73	0.00	17.54	0.00	0.00	24.00	0.00	0.00
27.09.25	0.32	25.20	73.98	23.78	73.57	8.12	24.00	0.00	0.00
28.09.25	0.93	44.68	224.21	40.51	223.91	24.00	24.00	0.00	0.00
29.09.25	0.91	43.91	220.19	39.75	220.30	24.00	24.00	0.00	0.00
30.09.25	0.91	43.56	219.08	39.37	218.71	24.00	24.00	0.00	0.00
01.10.25	0.97	44.90	180.21	39.51	179.82	24.00	24.00	0.00	0.00
02.10.25	1.02	46.65	171.94	40.68	171.51	24.00	24.00	0.00	0.00
03.10.25	1.10	49.14	177.17	42.65	176.66	24.00	24.00	0.00	0.00
04.10.25	1.06	47.95	221.53	43.15	220.77	24.00	24.00	0.00	0.00
05.10.25	1.05	47.71	221.05	42.94	220.35	24.00	24.00	0.00	0.00
06.10.25	1.04	47.83	220.79	43.12	220.09	24.00	24.00	0.00	0.00
07.10.25	0.97	46.46	219.45	42.06	218.78	24.00	24.00	0.00	0.00
08.10.25	0.90	45.20	216.48	41.05	215.78	24.00	24.00	0.00	0.00
09.10.25	0.90	45.40	203.98	40.98	203.41	23.60	24.00	0.00	0.00
10.10.25	1.04	45.93	190.98	40.48	190.57	24.00	24.00	0.00	0.00
11.10.25	1.00	45.21	185.63	39.80	185.15	24.00	24.00	0.00	0.00
12.10.25	0.94	44.31	183.04	39.15	182.50	24.00	24.00	0.00	0.00
13.10.25	1.17	45.72	182.32	39.31	181.77	24.00	24.00	0.00	0.00
14.10.25	1.35	46.70	182.32	39.26	181.84	24.00	24.00	0.00	0.00
15.10.25	1.06	46.48	180.44	40.58	179.79	24.00	24.00	0.00	0.00
16.10.25	1.10	47.42	182.78	41.40	182.16	24.00	24.00	0.00	0.00
17.10.25	1.25	48.03	198.43	41.75	197.80	23.59	24.00	0.00	0.00
18.10.25	1.45	50.22	202.61	43.06	202.04	24.00	24.00	0.00	0.00
19.10.25	1.75	54.74	203.45	46.18	203.01	23.57	24.00	0.00	0.00
20.10.25	1.69	54.72	203.71	46.40	203.09	24.00	24.00	0.00	0.00
Итого	25.88	---	4665.77	---	4653.38	558.88	768.00	0.00	0.00
Среднее	---	39.029	---	34.902	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	3793.58	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Свердловка, 26
 Потребитель: АО "Жилуправление"
 Прибор: 378 Заводской номер: 04015637
 ТВ1

Дата	T1	T2	V1	Q	Время раб. (ч)
19.09.25	13.9	13.6	0.000	0.000	0.00
20.09.25	14.0	13.8	0.000	0.000	0.00
21.09.25	14.2	13.9	0.000	0.000	0.00
22.09.25	14.9	14.7	0.000	0.000	0.00
23.09.25	15.4	15.1	0.000	0.000	0.00
24.09.25	15.8	15.4	0.000	0.000	0.00
25.09.25	13.7	13.4	0.000	0.000	0.00
26.09.25	25.6	22.8	69.859	0.443	10.00
27.09.25	34.2	31.5	93.258	0.509	16.00
28.09.25	43.7	38.2	149.344	0.814	24.00
29.09.25	43.4	37.5	144.680	0.827	24.00
30.09.25	45.0	37.4	121.359	0.909	24.00
01.10.25	47.0	38.5	117.195	0.976	24.00
02.10.25	48.8	40.2	128.305	1.035	24.00
03.10.25	47.6	40.9	153.883	1.022	24.00
04.10.25	47.6	40.8	153.711	1.028	24.00
05.10.25	47.7	41.0	153.469	1.016	24.00
06.10.25	45.8	39.6	148.672	0.915	24.00
07.10.25	45.1	39.1	149.320	0.894	24.00
08.10.25	45.1	38.7	137.367	0.870	24.00
09.10.25	44.7	38.1	130.062	0.850	24.00
10.10.25	44.0	37.6	126.523	0.801	24.00
11.10.25	43.2	36.9	124.734	0.772	24.00
12.10.25	43.6	37.1	124.531	0.809	24.00
13.10.25	43.7	37.1	124.430	0.805	24.00
14.10.25	45.7	38.4	122.492	0.878	24.00
15.10.25	45.5	38.2	111.680	0.841	22.00
16.10.25	46.5	39.3	133.086	0.947	24.00
17.10.25	49.3	41.2	136.320	1.085	24.00
18.10.25	52.1	43.3	136.523	1.182	24.00
19.10.25	52.3	43.6	136.758	1.181	24.00
20.10.25	50.5	42.6	141.188	1.095	24.00
Итого	---	---	3268.750	22.505	576.00
Среднее	38.4	33.1	---	---	---

Показания интеграторов

Дата	V1, м. куб	Q, Гкал	Время раб., ч
18.09.25 24:00	126010.898	1143.231	19863.000
20.10.25 24:00	129279.648	1165.736	20439.000
Итого за период	3268.750	22.505	576.000

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1 Пульсар ДУ-40, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Свердлова, 29
 Потребитель: АО "Жилуправление"
 Прибор: 378 Заводской номер: 02816728
 ТВ1

Дата	T1	T2	V1	Q	Время раб. (ч)
19.09.25	-	-	-	-	-
20.09.25	-	-	-	-	-
21.09.25	-	-	-	-	-
22.09.25	-	-	-	-	-
23.09.25	-	-	-	-	-
24.09.25	-	-	-	-	-
25.09.25	-	-	-	-	-
26.09.25	-	-	-	-	-
27.09.25	-	-	-	-	-
28.09.25	-	-	-	-	-
29.09.25	-	-	-	-	-
30.09.25	-	-	-	-	-
01.10.25	-	-	-	-	-
02.10.25	48.9	43.9	142.672	0.671	24.00
03.10.25	47.7	43.9	170.219	0.644	24.00
04.10.25	47.7	43.8	170.078	0.647	24.00
05.10.25	47.8	44.0	169.984	0.646	24.00
06.10.25	45.9	42.4	167.875	0.576	24.00
07.10.25	45.2	41.8	165.359	0.547	24.00
08.10.25	45.2	42.0	169.156	0.535	23.00
09.10.25	44.9	41.6	165.172	0.534	23.00
10.10.25	44.1	40.9	160.906	0.496	24.00
11.10.25	43.3	40.2	159.500	0.407	18.00
12.10.25	43.8	40.5	159.375	0.512	24.00
13.10.25	43.8	40.5	159.047	0.510	24.00
14.10.25	45.9	42.2	156.906	0.561	24.00
15.10.25	46.5	42.9	164.281	0.582	24.00
16.10.25	46.6	43.1	177.297	0.607	24.00
17.10.25	49.3	45.5	181.703	0.694	24.00
18.10.25	52.1	47.9	182.141	0.754	24.00
19.10.25	52.4	48.2	182.312	0.750	24.00
20.10.25	50.5	46.9	194.344	0.672	23.00
Итого	---	---	3198.328	11.344	447.00
Среднее	46.9	43.3	---	---	---

Показания интеграторов

Дата	V1, м. куб	Q, Гкал	Время раб., ч
18.09.25 24:00	н/д	н/д	н/д
20.10.25 24:00	146622.219	954.909	23149.000
Итого за период	н/д	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Свердловла, 34
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00178954

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0хFB1E

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Мг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	18.20	18.20	0.00	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
20.09.25	18.44	18.52	-0.08	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
21.09.25	18.61	18.65	-0.04	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
22.09.25	18.86	18.84	0.02	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
23.09.25	19.03	18.98	0.05	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
24.09.25	19.38	19.19	0.19	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
25.09.25	19.31	19.22	0.09	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
26.09.25	18.60	18.76	-0.16	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
27.09.25	43.88	34.89	8.99	48.860	50.920	48.480	50.670	-2.190	6.90	6.70	0.4360	0.0	24.0
28.09.25	43.75	35.57	8.18	92.000	96.110	91.280	95.630	-4.350	6.90	6.70	0.7410	0.0	24.0
29.09.25	43.38	35.27	8.11	93.310	97.590	92.520	97.050	-4.530	6.90	6.70	0.7500	0.0	24.0
30.09.25	44.78	35.07	9.71	81.610	85.500	80.890	85.020	-4.130	6.90	6.70	0.7840	0.0	24.0
01.10.25	46.58	36.09	10.49	79.840	83.730	79.060	83.250	-4.190	6.90	6.70	0.8310	0.0	24.0
02.10.25	48.83	38.06	10.77	83.130	87.110	82.150	86.560	-4.410	6.90	6.70	0.8810	0.0	24.0
03.10.25	47.79	39.09	8.70	103.710	108.330	102.510	107.610	-5.100	6.90	6.70	0.8900	0.0	24.0
04.10.25	47.57	38.79	8.78	103.730	108.270	102.530	107.550	-5.020	6.90	6.70	0.9010	0.0	24.0
05.10.25	47.69	39.04	8.65	103.720	108.260	102.520	107.540	-5.020	6.90	6.70	0.8840	0.0	24.0
06.10.25	46.27	38.29	7.98	103.310	107.860	102.250	107.140	-4.890	6.90	6.70	0.8140	0.0	24.0
07.10.25	45.06	37.54	7.52	102.500	107.160	101.540	106.440	-4.900	6.90	6.70	0.7620	0.0	24.0
08.10.25	45.16	37.53	7.63	99.280	103.750	98.340	103.050	-4.710	6.90	6.70	0.7500	0.0	24.0
09.10.25	44.89	37.30	7.59	99.080	103.500	98.120	102.780	-4.660	6.90	6.70	0.7450	0.0	24.0
10.10.25	44.04	36.75	7.29	97.390	101.690	96.430	100.970	-4.540	6.90	6.70	0.7000	0.0	24.0
11.10.25	43.26	36.21	7.05	96.980	101.240	96.080	100.570	-4.490	6.90	6.70	0.6770	0.0	24.0
12.10.25	43.67	36.33	7.34	96.890	101.130	95.930	100.410	-4.480	6.90	6.70	0.6990	0.0	24.0
13.10.25	43.63	36.24	7.39	96.890	101.120	95.930	100.400	-4.470	6.90	6.70	0.7080	0.0	24.0
14.10.25	45.38	37.33	8.05	96.100	100.310	95.140	99.590	-4.450	6.90	6.70	0.7640	0.0	24.0
15.10.25	46.39	38.10	8.29	98.770	103.130	97.790	102.410	-4.620	6.90	6.70	0.8070	0.0	24.0
16.10.25	46.50	38.55	7.95	108.140	112.870	106.940	112.150	-5.210	6.90	6.70	0.8470	0.0	24.0
17.10.25	48.31	39.72	8.59	110.470	115.310	109.200	114.500	-5.300	6.90	6.70	0.9360	0.0	24.0
18.10.25	52.07	42.35	9.72	111.220	116.150	109.780	115.190	-5.410	6.90	6.70	1.0660	0.0	24.0
19.10.25	52.22	42.63	9.59	111.300	116.160	109.860	115.200	-5.340	6.90	6.70	1.0540	0.0	24.0
20.10.25	50.87	41.95	8.92	111.420	116.300	110.050	115.350	-5.300	6.90	6.70	0.9820	0.0	24.0
Итого	---	---	---	2329.6	2433.5	2305.32	2417.03	-111.710	---	---	19.4090	0.0	768.0
Среднее	39.44	33.09	6.35	---	---	---	---	---	6.90	6.70	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Мг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	23811.210	24701.649	23491.219	24490.250	252.9250	-999.030	2681.0	8773.0
20.10.25 24:00	26140.860	27135.150	25796.540	26907.280	272.3340	-1110.740	2681.0	9565.0
Итого за период	2329.650	2433.501	2305.321	2417.029	19.4090	---	0.0	792.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Свердлова, 39
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00182565

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0x619E

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	16.50	14.61	1.89	58.770	7.120	58.770	7.120	51.650	6.20	1.29	0.0640	0.0	24.0
20.09.25	16.62	15.99	0.63	59.000	4.080	59.000	4.080	54.920	6.20	1.06	0.0480	0.0	24.0
21.09.25	16.61	15.99	0.62	58.960	2.400	58.960	2.400	56.560	6.20	1.06	0.0480	0.0	24.0
22.09.25	16.77	16.08	0.69	58.740	2.640	58.740	2.640	56.100	6.20	1.05	0.0480	0.0	24.0
23.09.25	16.90	16.19	0.71	58.340	2.880	58.340	2.880	55.460	6.20	1.05	0.0480	0.0	24.0
24.09.25	17.07	16.33	0.74	58.130	2.640	58.130	2.640	55.490	6.20	1.05	0.0480	0.0	24.0
25.09.25	16.95	16.28	0.67	57.890	2.640	57.890	2.640	55.250	6.20	1.05	0.0480	0.0	24.0
26.09.25	16.55	15.96	0.59	58.050	3.840	58.050	3.840	54.210	6.20	1.05	0.0480	0.0	24.0
27.09.25	37.39	35.56	1.83	109.060	83.080	108.300	82.590	25.710	6.20	4.08	0.6960	0.0	24.0
28.09.25	43.77	36.51	7.26	156.360	155.540	154.920	154.580	0.340	7.91	6.63	1.1260	0.0	24.0
29.09.25	43.43	36.31	7.12	158.310	159.840	156.920	158.850	-1.930	13.53	6.32	1.1380	0.0	24.0
30.09.25	44.95	36.46	8.49	140.120	141.990	138.790	141.040	-2.250	10.75	6.51	1.1900	0.0	24.0
01.10.25	46.79	37.70	9.09	138.360	139.980	136.870	139.020	-2.150	6.56	6.78	1.2380	0.0	24.0
02.10.25	48.93	39.53	9.40	140.920	143.250	139.390	142.210	-2.820	10.76	6.41	1.3190	0.0	24.0
03.10.25	47.83	40.66	7.17	178.300	179.600	176.410	178.160	-1.750	16.04	4.82	1.3020	0.0	24.0
04.10.25	47.63	40.75	6.88	177.680	179.120	175.870	177.680	-1.810	16.71	4.75	1.2510	0.0	24.0
05.10.25	47.76	40.83	6.93	180.000	181.280	178.080	179.840	-1.760	16.23	4.76	1.2740	0.0	24.0
06.10.25	46.22	39.78	6.44	179.680	181.020	177.910	179.690	-1.780	15.89	4.79	1.1840	0.0	24.0
07.10.25	45.11	39.00	6.11	178.680	179.970	177.000	178.770	-1.770	15.11	4.81	1.1160	0.0	24.0
08.10.25	45.20	39.12	6.08	175.940	177.340	174.280	176.140	-1.860	16.07	4.84	1.0970	0.0	24.0
09.10.25	44.91	38.81	6.10	172.200	173.820	170.660	172.620	-1.960	16.14	4.80	1.0770	0.0	24.0
10.10.25	44.08	38.22	5.86	168.080	169.740	166.650	168.550	-1.900	16.41	4.82	1.0140	0.0	24.0
11.10.25	43.28	37.63	5.65	168.240	170.070	166.830	168.900	-2.070	16.01	4.80	0.9800	0.0	24.0
12.10.25	43.71	37.71	6.00	168.320	169.790	166.880	168.590	-1.710	16.21	4.78	1.0370	0.0	24.0
13.10.25	43.69	37.65	6.04	168.130	169.610	166.690	168.410	-1.720	15.46	4.83	1.0380	0.0	24.0
14.10.25	45.50	38.88	6.62	167.020	168.130	165.450	166.930	-1.480	15.89	4.81	1.1310	0.0	24.0
15.10.25	46.45	39.61	6.84	172.430	173.840	170.680	172.560	-1.880	10.29	4.78	1.1820	0.0	24.0
16.10.25	46.53	39.99	6.54	188.540	189.820	186.620	188.380	-1.760	6.20	4.87	1.2230	0.0	24.0
17.10.25	48.54	41.41	7.13	192.580	194.110	190.480	192.540	-2.060	6.20	4.86	1.3610	0.0	24.0
18.10.25	52.12	44.04	8.08	194.060	195.290	191.660	193.550	-1.890	6.20	4.87	1.5490	0.0	24.0
19.10.25	52.30	44.28	8.02	194.270	195.300	191.870	193.450	-1.580	6.20	4.88	1.5380	0.0	24.0
20.10.25	50.83	43.40	7.43	194.330	195.840	192.010	194.090	-2.080	6.20	4.88	1.4280	0.0	24.0
Итого	---	---	---	4529.4	4095.6	4489.10	4065.38	423.720	---	---	28.8890	0.0	768.0
Среднее	38.77	33.47	5.30	---	---	---	---	---	10.59	4.13	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	43045.059	42100.840	42477.659	41700.909	370.3380	776.750	1823.0	6782.0
20.10.25 24:00	47574.549	46196.449	46966.760	45766.289	399.2270	1200.470	1823.0	7550.0
Итого за период	4529.489	4095.609	4489.101	4065.379	28.8890	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС Пульсар ДУ-32, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Свердлова, 42
 Потребитель: АО "Жилуправление"
 Прибор: 378 Заводской номер: 04298960
 ТВ1

Дата	T1	T2	V1	Q	Время раб. (ч)
19.09.25	18.4	17.9	0.000	0.000	0.00
20.09.25	18.4	17.9	0.000	0.000	0.00
21.09.25	18.4	17.9	0.000	0.000	0.00
22.09.25	18.5	18.0	0.000	0.000	0.00
23.09.25	18.6	18.1	0.000	0.000	0.00
24.09.25	18.7	18.3	0.000	0.000	0.00
25.09.25	18.8	18.3	0.000	0.000	0.00
26.09.25	33.5	29.5	32.195	0.176	17.00
27.09.25	43.8	38.2	49.078	0.274	24.00
28.09.25	43.2	37.7	49.129	0.266	24.00
29.09.25	43.1	37.0	43.426	0.258	24.00
30.09.25	44.7	36.9	35.414	0.275	24.00
01.10.25	46.6	38.1	34.914	0.294	24.00
02.10.25	48.5	39.8	37.785	0.314	24.00
03.10.25	47.5	40.7	45.375	0.304	24.00
04.10.25	47.4	40.6	45.336	0.304	24.00
05.10.25	47.5	40.9	45.363	0.298	24.00
06.10.25	45.7	39.6	45.199	0.272	24.00
07.10.25	44.9	39.1	44.805	0.258	24.00
08.10.25	44.9	39.1	44.066	0.254	24.00
09.10.25	44.6	38.8	43.328	0.249	24.00
10.10.25	43.9	38.3	42.766	0.234	24.00
11.10.25	43.0	37.7	42.621	0.224	24.00
12.10.25	43.5	37.9	42.594	0.236	24.00
13.10.25	43.5	37.8	42.578	0.238	24.00
14.10.25	45.4	39.2	42.188	0.260	24.00
15.10.25	46.2	39.9	44.141	0.275	24.00
16.10.25	46.3	40.2	47.762	0.287	24.00
17.10.25	48.8	42.0	48.906	0.329	24.00
18.10.25	51.8	44.3	49.172	0.360	24.00
19.10.25	52.0	44.7	49.227	0.357	24.00
20.10.25	50.3	43.4	49.121	0.334	24.00
Итого	---	---	1096.488	6.931	593.00
Среднее	39.7	34.6	---	---	---

Показания интеграторов

Дата	V1, м. куб	Q, Гкал	Время раб., ч
18.09.25 24:00	39565.266	366.386	20255.000
20.10.25 24:00	40661.754	373.317	20848.000
Итого за период	1096.488	6.931	593.000

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1 Пульсар ДУ-40, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Свердловла, 66
 Потребитель: АО "Жилуправление"
 Прибор: 378 Заводской номер: 05578584
 ТВ1

Дата	T1	T2	V1	Q	Время раб. (ч)
19.09.25	15.5	15.4	0.000	0.000	0.00
20.09.25	15.4	15.3	0.000	0.000	0.00
21.09.25	15.3	15.2	0.000	0.000	0.00
22.09.25	15.4	15.3	0.000	0.000	0.00
23.09.25	15.5	15.4	0.000	0.000	0.00
24.09.25	15.6	15.5	0.000	0.000	0.00
25.09.25	15.6	15.4	0.000	0.000	0.00
26.09.25	23.8	22.2	20.355	0.096	8.00
27.09.25	44.6	40.7	71.449	0.270	24.00
28.09.25	43.8	40.1	71.598	0.259	24.00
29.09.25	43.4	39.6	68.434	0.256	24.00
30.09.25	44.8	39.8	56.000	0.278	24.00
01.10.25	46.6	40.8	56.844	0.327	24.00
02.10.25	48.4	42.3	61.852	0.357	23.00
03.10.25	47.7	43.4	83.145	0.358	24.00
04.10.25	47.6	43.2	82.750	0.354	24.00
05.10.25	47.7	43.4	82.520	0.350	24.00
06.10.25	46.1	42.1	80.457	0.323	24.00
07.10.25	45.1	41.2	79.863	0.304	24.00
08.10.25	45.2	41.3	79.242	0.302	24.00
09.10.25	44.9	41.0	77.086	0.299	24.00
10.10.25	44.0	39.9	71.570	0.276	24.00
11.10.25	43.1	35.3	29.387	0.227	24.00
12.10.25	43.5	35.2	29.461	0.241	24.00
13.10.25	43.5	36.6	42.453	0.255	24.00
14.10.25	45.5	41.1	71.789	0.307	24.00
15.10.25	46.4	41.9	74.090	0.328	24.00
16.10.25	46.5	42.2	80.488	0.338	24.00
17.10.25	48.5	43.9	82.680	0.378	24.00
18.10.25	52.0	46.9	84.008	0.421	24.00
19.10.25	52.2	47.1	83.527	0.421	24.00
20.10.25	50.7	46.0	85.512	0.390	24.00
Итого	---	---	1706.559	7.715	583.00
Среднее	38.9	35.2	---	---	---

Показания интеграторов

Дата	V1, м. куб	Q, Гкал	Время раб., ч
18.09.25 24:00	35733.027	369.177	19060.000
20.10.25 24:00	37439.586	376.892	19643.000
Итого за период	1706.559	7.715	583.000

Представитель абонента _____/_____

Представитель поставщика _____/_____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Свердловла, 74
Потребитель: АО "Жилуправление"
Прибор: ТВ7-04.1 Заводской номер: 24213248

БД=1, ТВ1, СИ=7, КСН=0х0Е5А

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
28.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
29.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
30.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
01.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
02.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
03.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
04.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
05.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
07.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
08.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
09.10.25	44.75	37.16	н/д	7.60	4.35	4.35	н/д	74.150	н/д	н/д	73.465	н/д	н/д	н/д	0.558	н/д	24	0
10.10.25	43.87	34.87	н/д	9.00	4.20	4.21	н/д	54.732	н/д	н/д	54.249	н/д	н/д	н/д	0.488	н/д	24	0
11.10.25	43.10	34.38	н/д	8.72	4.16	4.18	н/д	54.555	н/д	н/д	54.090	н/д	н/д	н/д	0.471	н/д	24	0
12.10.25	43.51	34.42	н/д	9.09	4.13	4.15	н/д	54.533	н/д	н/д	54.060	н/д	н/д	н/д	0.491	н/д	24	0
13.10.25	43.47	34.28	н/д	9.19	4.19	4.21	н/д	54.525	н/д	н/д	54.053	н/д	н/д	н/д	0.496	н/д	24	0
14.10.25	45.20	35.14	н/д	10.07	4.17	4.19	н/д	54.052	н/д	н/д	53.543	н/д	н/д	н/д	0.538	н/д	24	0
15.10.25	46.20	35.73	н/д	10.47	4.21	4.23	н/д	55.768	н/д	н/д	55.219	н/д	н/д	н/д	0.577	н/д	24	0
16.10.25	46.33	36.36	н/д	9.98	4.47	4.49	н/д	60.952	н/д	н/д	60.348	н/д	н/д	н/д	0.601	н/д	24	0
17.10.25	48.21	37.30	н/д	10.91	4.52	4.53	н/д	62.388	н/д	н/д	61.715	н/д	н/д	н/д	0.673	н/д	24	0
18.10.25	51.84	39.46	н/д	12.38	4.56	4.57	н/д	62.833	н/д	н/д	62.052	н/д	н/д	н/д	0.767	н/д	24	0
19.10.25	52.01	39.69	н/д	12.32	4.58	4.59	н/д	62.847	н/д	н/д	62.058	н/д	н/д	н/д	0.764	н/д	24	0
20.10.25	50.64	39.14	н/д	11.49	4.57	4.58	н/д	63.030	н/д	н/д	62.282	н/д	н/д	н/д	0.715	н/д	24	0
Итого	---	---	---	---	---	---	---	714.365	---	---	707.134	---	---	---	7.139	---	288	0
Среднее	46.73	36.62	---	10.11	4.34	4.36	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
20.10.25 24:00	1414.395	0.000	0.000	1400.269	0.000	0.000	0.000	10.267	0.000	392	0
Итого за период	н/д	н/д	н/д	н/д	н/д	н/д	---	н/д	н/д	н/д	н/д

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ИМ2300, Суточный с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Свердлова, 78
 Потребитель: АО "Жилуправление"
 Прибор: ИМ2300 Заводской номер: ВВ679

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	14.27	2.52	14.03	0.00	8.31	24.00	0.00	0.00
20.09.25	0.00	14.28	1.41	14.05	0.00	4.65	24.00	0.00	0.00
21.09.25	0.00	14.26	0.52	14.02	0.00	1.72	24.00	0.00	0.00
22.09.25	0	14.26	0.03	13.99	0.00	0.10	24.00	0.00	0.00
23.09.25	0.00	14.65	4.49	14.28	0.00	14.47	24.00	0.00	0.00
24.09.25	0.00	14.95	8.01	14.53	0.00	24.00	24.00	0.00	0.00
25.09.25	0.00	15.21	8.55	14.74	0.00	24.00	24.00	0.00	0.00
26.09.25	0.00	14.79	6.43	14.55	0.00	19.72	24.00	0.00	0.00
27.09.25	0.17	27.64	29.28	23.34	0.00	11.92	24.00	0.00	0.00
28.09.25	0.48	43.41	74.95	37.02	0.00	24.00	24.00	0.00	0.00
29.09.25	0.55	42.68	77.80	35.61	0.00	24.00	24.00	0.00	0.00
30.09.25	0.59	42.32	76.69	34.60	0.00	24.00	24.00	0.00	0.00
01.10.25	0.63	43.57	63.74	33.68	0.00	24.00	24.00	0.00	0.00
02.10.25	0.71	45.29	64.32	34.20	0.00	24.00	24.00	0.00	0.00
03.10.25	0.80	47.55	68.28	35.46	0.00	24.00	24.00	0.00	0.00
04.10.25	0.80	46.59	85.23	37.16	0.00	24.00	24.00	0.00	0.00
05.10.25	0.80	46.39	84.93	36.99	0.00	24.00	24.00	0.00	0.00
06.10.25	0.78	46.51	85.00	37.30	0.00	24.00	24.00	0.00	0.00
07.10.25	0.72	45.10	84.78	36.55	0.00	24.00	24.00	0.00	0.00
08.10.25	0.67	43.98	84.06	35.94	0.00	24.00	24.00	0.00	0.00
09.10.25	0.66	44.06	82.74	36.06	0.00	24.00	24.00	0.00	0.00
10.10.25	0.65	43.78	81.23	35.82	0.00	24.00	24.00	0.00	0.00
11.10.25	0.61	42.97	79.83	35.34	0.00	24.00	24.00	0.00	0.00
12.10.25	0.58	42.22	79.73	34.88	0.00	24.00	24.00	0.00	0.00
13.10.25	0.61	42.61	79.70	34.98	0.00	24.00	24.00	0.00	0.00
14.10.25	0.61	42.57	79.71	34.89	0.00	24.00	24.00	0.00	0.00
15.10.25	0.66	44.28	78.60	35.91	0.00	24.00	24.00	0.00	0.00
16.10.25	0.71	45.23	81.52	36.52	0.00	24.00	24.00	0.00	0.00
17.10.25	0.75	45.38	89.42	37.02	0.00	24.00	24.00	0.00	0.00
18.10.25	0.83	47.20	91.43	38.15	0.00	24.00	24.00	0.00	0.00
19.10.25	0.94	50.77	91.26	40.48	0.00	24.00	24.00	0.00	0.00
20.10.25	0.93	50.94	91.26	40.69	0.00	24.00	24.00	0.00	0.00
Итого	16.24	---	1917.45	---	0.00	660.89	768.00	0.00	0.00
Среднее	---	36.866	---	30.399	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	1201.79	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Свердлова, 91
Потребитель: АО "Жилуправление"
Прибор: ТВ7-04.1 Заводской номер: 20127926

БД=1, ТВ1, СИ=7, КТ3=0, ФРТ=0, КСН=0х0377

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	18.20	17.87	н/д	0.32	1.33	1.50	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
21.09.25	18.53	17.98	н/д	0.55	1.32	1.49	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
22.09.25	18.95	18.98	н/д	-0.04	1.32	1.52	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
23.09.25	19.77	19.92	н/д	-0.15	1.32	1.54	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
24.09.25	20.79	20.76	н/д	0.03	1.33	1.57	н/д	0.000	н/д	н/д	0.000	н/д	н/д	н/д	0.000	н/д	24	0
25.09.25	44.39	40.86	н/д	3.53	1.36	3.38	н/д	81.753	н/д	н/д	81.004	н/д	н/д	н/д	0.278	н/д	24	0
26.09.25	40.83	37.64	н/д	3.19	1.43	5.55	н/д	165.227	н/д	н/д	163.953	н/д	н/д	н/д	0.507	н/д	24	0
27.09.25	43.69	39.80	н/д	3.89	1.45	5.49	н/д	152.335	н/д	н/д	150.991	н/д	н/д	н/д	0.574	н/д	24	0
28.09.25	42.91	39.02	н/д	3.89	1.46	5.55	н/д	149.465	н/д	н/д	148.185	н/д	н/д	н/д	0.563	н/д	24	0
29.09.25	42.54	38.53	н/д	4.01	1.48	5.26	н/д	142.575	н/д	н/д	141.373	н/д	н/д	н/д	0.556	н/д	24	0
30.09.25	43.88	38.41	н/д	5.46	1.49	5.30	н/д	112.525	н/д	н/д	111.511	н/д	н/д	н/д	0.600	н/д	24	0
01.10.25	45.65	39.77	н/д	5.88	1.51	5.56	н/д	109.540	н/д	н/д	108.475	н/д	н/д	н/д	0.628	н/д	24	0
02.10.25	47.77	41.73	н/д	6.03	1.53	5.36	н/д	114.997	н/д	н/д	113.772	н/д	н/д	н/д	0.677	н/д	24	0
03.10.25	46.81	42.08	н/д	4.73	1.53	4.02	н/д	142.920	н/д	н/д	141.449	н/д	н/д	н/д	0.661	н/д	24	0
04.10.25	46.61	41.90	н/д	4.71	1.53	3.95	н/д	143.242	н/д	н/д	141.787	н/д	н/д	н/д	0.661	н/д	24	0
05.10.25	46.74	42.13	н/д	4.61	1.53	3.96	н/д	144.840	н/д	н/д	143.363	н/д	н/д	н/д	0.654	н/д	24	0
06.10.25	45.28	41.09	н/д	4.18	1.52	3.96	н/д	145.745	н/д	н/д	144.346	н/д	н/д	н/д	0.596	н/д	24	0
07.10.25	44.16	40.20	н/д	3.96	1.51	3.97	н/д	144.530	н/д	н/д	143.219	н/д	н/д	н/д	0.559	н/д	24	0
08.10.25	44.25	40.30	н/д	3.95	1.51	3.97	н/д	142.443	н/д	н/д	141.138	н/д	н/д	н/д	0.549	н/д	24	0
09.10.25	43.97	40.00	н/д	3.97	1.50	3.89	н/д	139.768	н/д	н/д	138.508	н/д	н/д	н/д	0.542	н/д	24	0
10.10.25	43.15	39.39	н/д	3.76	1.50	3.87	н/д	137.462	н/д	н/д	136.273	н/д	н/д	н/д	0.505	н/д	24	0
11.10.25	42.39	38.73	н/д	3.66	1.49	3.84	н/д	137.020	н/д	н/д	135.880	н/д	н/д	н/д	0.490	н/д	24	0
12.10.25	42.79	38.90	н/д	3.88	1.49	3.81	н/д	136.897	н/д	н/д	135.731	н/д	н/д	н/д	0.520	н/д	24	0
13.10.25	42.75	38.92	н/д	3.83	1.49	3.87	н/д	136.807	н/д	н/д	135.651	н/д	н/д	н/д	0.513	н/д	24	0
14.10.25	44.50	40.27	н/д	4.23	1.50	3.85	н/д	135.610	н/д	н/д	134.353	н/д	н/д	н/д	0.561	н/д	24	0
15.10.25	45.45	41.08	н/д	4.37	1.51	3.89	н/д	140.227	н/д	н/д	138.871	н/д	н/д	н/д	0.599	н/д	24	0
16.10.25	45.56	41.39	н/д	4.17	1.51	4.14	н/д	153.943	н/д	н/д	152.451	н/д	н/д	н/д	0.627	н/д	24	0
17.10.25	47.46	42.95	н/д	4.50	1.52	4.19	н/д	157.735	н/д	н/д	156.066	н/д	н/д	н/д	0.694	н/д	24	0
18.10.25	51.01	45.92	н/д	5.09	1.55	4.23	н/д	159.000	н/д	н/д	157.060	н/д	н/д	н/д	0.790	н/д	24	0
19.10.25	51.18	46.17	н/д	5.01	1.55	4.25	н/д	159.057	н/д	н/д	157.100	н/д	н/д	н/д	0.778	н/д	24	0
20.10.25	49.79	45.14	н/д	4.65	1.54	4.24	н/д	159.815	н/д	н/д	157.956	н/д	н/д	н/д	0.725	н/д	24	0
Итого	---	---	---	---	---	---	---	3645.478	---	---	3610.466	---	---	---	15.407	---	744	0
Среднее	45.28	40.94	---	4.33	1.47	3.90	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
20.10.25 24:00	3645.685	0.000	0.000	3610.671	0.000	0.000	0.000	15.404	0.000	1360	0
Итого за период	н/д	н/д	н/д	н/д	н/д	н/д	---	н/д	н/д	н/д	н/д

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Свердлова, 99
Потребитель: АО "Жилуправление"
Прибор: ТВ7-04.1 Заводской номер: 20110286

БД=1, ТВ1, СИ=6, КТЗ=0, ФРТ=0, КСН=0хD477

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	16.33	16.28	н/д	0.05	0.16	2.24	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
20.09.25	16.30	16.25	н/д	0.05	0.16	2.24	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
21.09.25	16.26	16.21	н/д	0.06	0.17	2.23	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
22.09.25	16.36	16.30	н/д	0.06	0.16	2.23	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
23.09.25	16.47	16.39	н/д	0.08	0.16	2.23	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
24.09.25	16.62	16.50	н/д	0.12	0.16	2.23	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
25.09.25	44.55	41.20	н/д	3.34	2.95	4.16	н/д	41.908	41.643	н/д	41.531	41.325	н/д	0.206	0.139	н/д	24	0
26.09.25	41.19	38.18	н/д	3.01	6.40	6.38	н/д	82.643	82.330	н/д	82.017	81.800	н/д	0.217	0.247	н/д	24	0
27.09.25	44.02	40.19	н/д	3.83	6.30	6.30	н/д	75.220	75.118	н/д	74.556	74.579	н/д	-0.023	0.285	н/д	24	0
28.09.25	43.26	39.42	н/д	3.85	6.36	6.36	н/д	73.598	73.698	н/д	72.971	73.191	н/д	-0.220	0.280	н/д	24	0
29.09.25	42.88	38.52	н/д	4.36	6.05	6.07	н/д	62.803	63.010	н/д	62.280	62.598	н/д	-0.318	0.271	н/д	24	0
30.09.25	43.89	37.46	н/д	6.43	6.03	6.08	н/д	44.423	44.757	н/д	44.034	44.482	н/д	-0.448	0.283	н/д	24	0
01.10.25	45.55	38.59	н/д	6.96	6.29	6.34	н/д	43.220	43.545	н/д	42.810	43.258	н/д	-0.448	0.298	н/д	24	0
02.10.25	47.76	40.61	н/д	7.15	6.10	6.15	н/д	45.390	45.670	н/д	44.913	45.335	н/д	-0.421	0.321	н/д	24	0
03.10.25	47.05	41.43	н/д	5.62	4.77	4.80	н/д	57.130	57.278	н/д	56.546	56.833	н/д	-0.287	0.318	н/д	24	0
04.10.25	46.85	41.19	н/д	5.67	4.70	4.73	н/д	57.375	57.487	н/д	56.794	57.045	н/д	-0.251	0.322	н/д	24	0
05.10.25	46.99	41.38	н/д	5.61	4.71	4.74	н/д	58.105	58.185	н/д	57.510	57.734	н/д	-0.224	0.323	н/д	24	0
06.10.25	45.62	40.52	н/д	5.09	4.72	4.75	н/д	58.560	58.630	н/д	57.999	58.195	н/д	-0.196	0.295	н/д	24	0
07.10.25	44.46	39.63	н/д	4.82	4.72	4.75	н/д	57.272	57.350	н/д	56.755	56.946	н/д	-0.191	0.273	н/д	24	0
08.10.25	44.54	39.74	н/д	4.80	4.72	4.75	н/д	57.140	57.210	н/д	56.619	56.806	н/д	-0.187	0.271	н/д	24	0
09.10.25	44.26	39.50	н/д	4.77	4.63	4.67	н/д	56.138	56.215	н/д	55.633	55.821	н/д	-0.188	0.265	н/д	24	0
10.10.25	43.45	38.91	н/д	4.54	4.61	4.65	н/д	55.182	55.272	н/д	54.706	54.897	н/д	-0.191	0.248	н/д	24	0
11.10.25	42.70	38.24	н/д	4.46	4.58	4.61	н/д	55.000	55.097	н/д	54.541	54.739	н/д	-0.198	0.243	н/д	24	0
12.10.25	43.08	38.34	н/д	4.73	4.55	4.59	н/д	54.965	55.058	н/д	54.499	54.698	н/д	-0.200	0.258	н/д	24	0
13.10.25	43.03	38.32	н/д	4.71	4.60	4.64	н/д	54.930	55.015	н/д	54.466	54.656	н/д	-0.190	0.256	н/д	24	0
14.10.25	44.66	39.53	н/д	5.13	4.58	4.62	н/д	54.433	54.505	н/д	53.934	54.120	н/д	-0.186	0.276	н/д	24	0
15.10.25	45.70	40.47	н/д	5.23	4.63	4.66	н/д	56.322	56.368	н/д	55.779	55.950	н/д	-0.171	0.291	н/д	24	0
16.10.25	45.89	40.90	н/д	4.99	4.91	4.94	н/д	61.995	62.007	н/д	61.395	61.535	н/д	-0.140	0.306	н/д	24	0
17.10.25	47.68	42.23	н/д	5.44	4.97	4.99	н/д	63.580	63.565	н/д	62.911	63.051	н/д	-0.141	0.342	н/д	24	0
18.10.25	51.30	45.11	н/д	6.19	5.01	5.03	н/д	64.158	64.118	н/д	63.376	63.519	н/д	-0.143	0.392	н/д	24	0
19.10.25	51.47	45.40	н/д	6.07	5.03	5.05	н/д	64.225	64.177	н/д	63.437	63.572	н/д	-0.135	0.385	н/д	24	0
20.10.25	50.16	44.51	н/д	5.65	5.02	5.04	н/д	64.503	64.457	н/д	63.751	63.874	н/д	-0.122	0.360	н/д	24	0
Итого	---	---	---	---	---	---	---	1520.218	1521.765	---	1505.763	1510.559	---	-4.796	7.548	---	768	0
Среднее	45.44	40.43	---	5.02	4.15	4.60	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	39	0
20.10.25 24:00	1520.215	1521.765	0.000	1505.764	1510.561	0.000	-4.797	7.546	0.000	807	0
Итого за период	1520.215	1521.765	0.000	1505.764	1510.561	0.000	---	7.546	0.000	768	0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Свердлова, 99
Потребитель: АО "Жилуправление"
Прибор: ТВ7-04.1 Заводской номер: 20140260

БД=1, ТВ1, СИ=6, КТ3=0, ФРТ=0, КСН=0х7АF9

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	17.70	17.67	н/д	0.03	0.02	2.80	н/д	11.597	0.000	н/д	11.589	0.000	н/д	11.589	0	н/д	24	0
20.09.25	17.64	17.61	н/д	0.03	0.02	2.73	н/д	12.405	0.000	н/д	12.396	0.000	н/д	12.396	0.000	н/д	24	0
21.09.25	17.67	17.61	н/д	0.05	0.02	2.67	н/д	13.220	0.000	н/д	13.210	0.000	н/д	13.210	0.000	н/д	24	0
22.09.25	17.84	17.76	н/д	0.08	0.02	2.62	н/д	14.090	0.000	н/д	14.079	0.000	н/д	14.079	0.000	н/д	24	0
23.09.25	17.92	17.83	н/д	0.09	0.02	2.56	н/д	14.865	0.000	н/д	14.854	0.000	н/д	14.854	0.001	н/д	24	0
24.09.25	18.17	18.00	н/д	0.18	0.02	2.52	н/д	15.705	0.000	н/д	15.691	0.000	н/д	15.691	0.002	н/д	24	0
25.09.25	41.54	38.12	н/д	3.41	2.83	4.29	н/д	76.145	66.433	н/д	75.526	65.933	н/д	9.593	0.257	н/д	24	0
26.09.25	41.35	37.71	н/д	3.64	6.34	6.33	н/д	127.490	127.192	н/д	126.514	126.405	н/д	0.109	0.460	н/д	24	0
27.09.25	44.20	39.51	н/д	4.69	6.24	6.24	н/д	112.878	112.110	н/д	111.877	111.335	н/д	0.541	0.524	н/д	24	0
28.09.25	43.43	38.77	н/д	4.66	6.30	6.30	н/д	110.577	109.603	н/д	109.636	108.871	н/д	0.765	0.510	н/д	24	0
29.09.25	43.07	37.76	н/д	5.31	5.99	6.01	н/д	94.580	93.882	н/д	93.785	93.294	н/д	0.492	0.497	н/д	24	0
30.09.25	44.20	36.49	н/д	7.72	5.98	6.02	н/д	66.283	65.810	н/д	65.692	65.430	н/д	0.263	0.506	н/д	24	0
01.10.25	45.91	37.40	н/д	8.51	6.24	6.28	н/д	64.387	63.928	н/д	63.766	63.537	н/д	0.229	0.542	н/д	24	0
02.10.25	48.10	39.31	н/д	8.79	6.05	6.08	н/д	67.613	67.143	н/д	66.894	66.680	н/д	0.214	0.587	н/д	24	0
03.10.25	47.29	40.23	н/д	7.06	4.71	4.74	н/д	84.110	83.580	н/д	83.241	82.972	н/д	0.268	0.587	н/д	24	0
04.10.25	47.09	40.06	н/д	7.03	4.65	4.67	н/д	84.192	83.650	н/д	83.333	83.048	н/д	0.284	0.585	н/д	24	0
05.10.25	47.22	40.38	н/д	6.84	4.66	4.68	н/д	85.215	84.667	н/д	84.336	84.043	н/д	0.294	0.576	н/д	24	0
06.10.25	45.82	39.49	н/д	6.33	4.66	4.68	н/д	85.875	85.345	н/д	85.043	84.748	н/д	0.295	0.538	н/д	24	0
07.10.25	44.66	38.75	н/д	5.91	4.66	4.69	н/д	85.370	84.840	н/д	84.587	84.275	н/д	0.313	0.499	н/д	24	0
08.10.25	44.74	38.77	н/д	5.97	4.66	4.69	н/д	83.772	83.240	н/д	83.004	82.680	н/д	0.324	0.495	н/д	24	0
09.10.25	44.46	38.49	н/д	5.97	4.58	4.60	н/д	82.048	81.522	н/д	81.302	80.980	н/д	0.322	0.485	н/д	24	0
10.10.25	43.64	37.95	н/д	5.69	4.56	4.58	н/д	80.698	80.177	н/д	79.994	79.664	н/д	0.331	0.454	н/д	24	0
11.10.25	42.88	37.37	н/д	5.50	4.53	4.55	н/д	80.465	79.948	н/д	79.785	79.454	н/д	0.331	0.439	н/д	24	0
12.10.25	43.26	37.44	н/д	5.82	4.50	4.52	н/д	80.432	79.900	н/д	79.744	79.404	н/д	0.341	0.464	н/д	24	0
13.10.25	43.21	37.40	н/д	5.82	4.55	4.57	н/д	80.370	79.838	н/д	79.683	79.344	н/д	0.339	0.463	н/д	24	0
14.10.25	44.87	38.55	н/д	6.32	4.53	4.56	н/д	79.643	79.095	н/д	78.906	78.573	н/д	0.333	0.498	н/д	24	0
15.10.25	45.92	39.41	н/д	6.51	4.58	4.60	н/д	82.575	81.995	н/д	81.774	81.424	н/д	0.350	0.531	н/д	24	0
16.10.25	46.08	39.91	н/д	6.17	4.86	4.88	н/д	91.073	90.433	н/д	90.183	89.788	н/д	0.395	0.556	н/д	24	0
17.10.25	47.90	41.24	н/д	6.66	4.91	4.93	н/д	93.355	92.700	н/д	92.363	91.988	н/д	0.375	0.614	н/д	24	0
18.10.25	51.53	43.93	н/д	7.60	4.95	4.97	н/д	94.085	93.390	н/д	92.923	92.564	н/д	0.359	0.706	н/д	24	0
19.10.25	51.71	44.21	н/д	7.49	4.97	4.99	н/д	94.088	93.390	н/д	92.926	92.560	н/д	0.366	0.696	н/д	24	0
20.10.25	50.36	43.47	н/д	6.89	4.96	4.98	н/д	94.817	94.135	н/д	93.708	93.322	н/д	0.386	0.645	н/д	24	0
Итого	---	---	---	---	---	---	---	2344.018	2237.946	---	2322.344	2222.316	---	100.031	13.717	---	768	0
Среднее	44.55	38.63	---	5.92	4.08	4.64	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	80.628	0.950	0.000	80.560	0.948	0.000	79.612	0.007	0.000	350	0
20.10.25 24:00	2424.645	2238.895	0.000	2402.904	2223.262	0.000	179.642	13.723	0.000	1118	0
Итого за период	2344.017	2237.945	0.000	2322.344	2222.314	0.000	---	13.716	0.000	768	0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ИМ2300, Суточный с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Северная, 12
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BA721

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	14.81	0.00	14.39	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	14.77	0.00	14.35	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	14.74	0.00	14.33	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	14.73	0.00	14.32	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	14.72	0.00	14.32	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	14.77	0.00	14.35	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	14.87	0.00	14.41	0.00	0.00	24.00	0.00	0.00
26.09.25	0.99	33.16	208.11	29.82	211.23	14.65	24.00	0.00	0.00
27.09.25	1.16	40.96	269.68	36.64	273.95	24.00	24.00	0.00	0.00
28.09.25	1.03	38.89	237.76	34.56	241.86	24.00	24.00	0.00	0.00
29.09.25	1.08	39.06	241.83	34.58	246.10	24.00	24.00	0.00	0.00
30.09.25	1.33	41.80	237.82	36.14	241.79	24.00	24.00	0.00	0.00
01.10.25	1.65	45.97	221.59	38.48	224.43	24.00	24.00	0.00	0.00
02.10.25	1.58	45.93	196.21	37.88	198.87	24.00	24.00	0.00	0.00
03.10.25	1.55	45.99	195.07	38.01	197.65	24.00	24.00	0.00	0.00
04.10.25	1.58	46.67	194.73	38.56	197.14	24.00	24.00	0.00	0.00
05.10.25	1.59	46.69	194.52	38.50	197.05	24.00	24.00	0.00	0.00
06.10.25	1.56	46.62	194.41	38.60	196.88	24.00	24.00	0.00	0.00
07.10.25	1.46	45.72	195.08	38.22	197.66	24.00	24.00	0.00	0.00
08.10.25	1.31	43.61	194.62	36.87	197.08	24.00	24.00	0.00	0.00
09.10.25	1.30	43.70	194.61	37.00	197.12	24.00	24.00	0.00	0.00
10.10.25	1.29	43.51	194.22	36.86	196.79	24.00	24.00	0.00	0.00
11.10.25	1.26	43.32	194.53	36.82	197.14	24.00	24.00	0.00	0.00
12.10.25	1.26	43.09	196.84	36.69	199.50	24.00	24.00	0.00	0.00
13.10.25	1.32	43.68	197.10	36.95	199.80	24.00	24.00	0.00	0.00
14.10.25	1.44	45.35	197.02	38.02	199.87	24.00	24.00	0.00	0.00
15.10.25	1.39	44.96	197.39	37.89	200.20	24.00	24.00	0.00	0.00
16.10.25	1.46	45.60	197.52	38.19	200.25	24.00	24.00	0.00	0.00
17.10.25	1.47	45.47	197.22	38.01	199.98	24.00	24.00	0.00	0.00
18.10.25	1.58	46.77	196.23	38.69	198.97	24.00	24.00	0.00	0.00
19.10.25	1.75	49.30	194.77	40.27	197.34	24.00	24.00	0.00	0.00
20.10.25	1.81	50.36	197.46	41.16	199.77	24.00	24.00	0.00	0.00
Итого	35.20	---	5136.34	---	5208.42	590.65	768.00	0.00	0.00
Среднее	---	37.800	---	32.309	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	5074.84	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Северная, 14
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00166734

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0хАЕ6А

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	15.27	15.11	0.16	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
23.09.25	15.49	15.36	0.13	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
24.09.25	16.20	16.00	0.20	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
25.09.25	27.61	26.18	1.43	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
26.09.25	39.80	36.40	3.40	127.870	124.680	125.370	125.370	0.000	6.90	6.81	0.4250	0.0	24.0
27.09.25	40.29	36.31	3.98	231.850	226.520	227.560	227.560	0.000	6.90	7.12	0.9020	0.0	24.0
28.09.25	40.46	36.27	4.19	236.040	230.540	231.700	231.700	0.000	6.90	16.35	0.9260	0.0	24.0
29.09.25	43.16	37.93	5.23	233.860	228.100	229.180	229.180	0.000	6.90	14.73	1.1590	0.0	24.0
30.09.25	47.52	40.67	6.85	237.850	235.490	233.610	235.220	-1.610	6.90	11.01	1.5670	0.0	24.0
01.10.25	47.48	41.88	5.60	375.930	369.930	369.350	369.350	0.000	6.90	7.59	2.0610	0.0	24.0
02.10.25	47.55	42.04	5.51	373.740	367.580	367.080	367.080	0.000	6.90	6.70	2.0210	0.0	24.0
03.10.25	48.24	42.69	5.55	371.750	365.440	364.920	364.920	0.000	6.90	6.70	2.0230	0.0	24.0
04.10.25	48.25	42.65	5.60	369.610	363.290	362.790	362.790	0.000	6.90	6.70	2.0250	0.0	24.0
05.10.25	48.17	42.73	5.44	368.190	361.940	361.430	361.430	0.000	6.90	6.70	1.9680	0.0	24.0
06.10.25	47.27	42.26	5.01	364.520	358.570	358.070	358.070	0.000	6.90	6.70	1.7910	0.0	24.0
07.10.25	45.12	40.55	4.57	369.760	363.170	363.170	363.170	0.000	6.90	6.70	1.6560	0.0	24.0
08.10.25	45.21	40.65	4.56	369.800	363.180	363.170	363.170	0.000	6.90	6.70	1.6500	0.0	24.0
09.10.25	45.02	40.50	4.52	368.070	361.640	361.640	361.640	0.000	6.90	6.70	1.6300	0.0	24.0
10.10.25	44.82	40.44	4.38	367.770	361.420	361.380	361.380	0.000	6.90	6.70	1.5800	0.0	24.0
11.10.25	44.57	40.23	4.34	371.060	364.090	364.370	364.370	0.000	6.90	6.70	1.5790	0.0	24.0
12.10.25	45.17	40.62	4.55	370.630	363.200	363.590	363.590	0.000	6.90	6.70	1.6510	0.0	24.0
13.10.25	46.88	41.95	4.93	369.900	362.210	362.600	362.600	0.000	6.90	6.70	1.7830	0.0	24.0
14.10.25	46.48	41.76	4.72	369.780	362.440	362.670	362.670	0.000	6.90	6.70	1.7090	0.0	24.0
15.10.25	47.13	42.14	4.99	369.510	362.440	362.470	362.470	0.000	6.90	6.70	1.8080	0.0	24.0
16.10.25	46.99	41.92	5.07	368.420	361.700	361.600	361.600	0.000	6.90	6.70	1.8330	0.0	24.0
17.10.25	48.30	42.75	5.55	366.450	359.850	359.550	359.550	0.000	6.90	7.12	1.9910	0.0	24.0
18.10.25	50.90	44.71	6.19	363.710	357.310	356.560	356.560	0.000	6.90	6.70	2.2080	0.0	24.0
19.10.25	51.97	45.68	6.29	368.530	362.250	361.220	361.220	0.000	6.90	6.70	2.2730	0.0	24.0
20.10.25	50.77	44.91	5.86	367.800	361.480	360.660	360.660	0.000	6.90	6.70	2.1130	0.0	24.0
Итого	---	---	---	8452.4	8298.4	8295.71	8297.32	-1.610	---	---	42.3320	0.0	696.0
Среднее	42.48	38.04	4.44	---	---	---	---	---	6.90	7.52	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
20.09.25 24:00	0	0	0	0	0	0	0	0
20.10.25 24:00	69450.950	67257.519	67593.129	67545.790	527.5770	47.340	255.0	10000.0
Итого за период	69450.950	67257.519	67593.129	67545.790	527.5770	---	255.0	10000.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Северная, 20
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00177469

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0x7E58

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	17.43	17.34	0.09	0.000	0.000	0.000	0.000	0.000	7.00	7.00	0.0000	0.0	24.0
22.09.25	17.44	17.39	0.05	0.000	0.000	0.000	0.000	0.000	7.00	7.00	0.0000	0.0	24.0
23.09.25	17.48	17.44	0.04	0.000	0.000	0.000	0.000	0.000	7.00	7.00	0.0000	0.0	24.0
24.09.25	17.53	17.50	0.03	0.000	0.000	0.000	0.000	0.000	7.00	7.00	0.0000	0.0	24.0
25.09.25	17.52	17.45	0.07	0.000	0.000	0.000	0.000	0.000	7.00	7.00	0.0000	0.0	24.0
26.09.25	39.49	34.61	4.88	86.260	85.190	85.630	84.700	0.930	5.54	5.28	0.4160	0.0	24.0
27.09.25	40.33	36.12	4.21	297.120	292.700	294.810	290.890	3.920	6.61	5.84	1.2410	0.0	24.0
28.09.25	40.52	36.06	4.46	309.160	304.560	306.720	302.730	3.990	6.59	5.85	1.3680	0.0	24.0
29.09.25	43.30	37.88	5.42	310.890	306.510	308.130	304.460	3.670	6.49	5.77	1.6740	0.0	24.0
30.09.25	47.58	40.90	6.68	299.810	295.100	296.660	292.750	3.910	6.49	5.79	1.9820	0.0	24.0
01.10.25	47.52	40.86	6.66	292.310	287.250	289.190	285.070	4.120	6.49	5.80	1.9240	0.0	24.0
02.10.25	47.58	41.01	6.57	291.420	286.050	288.300	283.860	4.440	6.46	5.77	1.8930	0.0	24.0
03.10.25	48.28	41.63	6.65	291.300	285.630	288.140	283.230	4.910	6.47	5.78	1.9160	0.0	24.0
04.10.25	48.28	41.63	6.65	290.930	285.020	287.810	282.620	5.190	6.53	5.83	1.9160	0.0	24.0
05.10.25	48.21	41.64	6.57	291.080	285.020	287.960	282.620	5.340	6.52	5.83	1.8920	0.0	24.0
06.10.25	47.27	41.09	6.18	291.350	285.190	288.320	282.910	5.410	6.49	5.79	1.7810	0.0	24.0
07.10.25	45.13	39.63	5.50	291.400	285.280	288.530	283.120	5.410	6.51	5.82	1.5840	0.0	24.0
08.10.25	45.22	39.71	5.51	291.850	285.770	288.990	283.610	5.380	6.50	5.80	1.5930	0.0	24.0
09.10.25	45.03	39.53	5.50	291.390	285.190	288.620	283.030	5.590	6.57	5.87	1.5860	0.0	24.0
10.10.25	44.84	39.50	5.34	291.780	285.620	288.980	283.490	5.490	6.64	5.95	1.5400	0.0	24.0
11.10.25	44.58	39.39	5.19	295.080	288.930	292.300	286.810	5.490	6.66	5.96	1.5170	0.0	24.0
12.10.25	45.20	39.74	5.46	295.390	289.180	292.510	287.020	5.490	6.67	5.97	1.5980	0.0	24.0
13.10.25	46.90	40.97	5.93	295.490	289.190	292.380	286.880	5.500	6.68	5.98	1.7310	0.0	24.0
14.10.25	46.50	40.77	5.73	295.940	289.690	292.910	287.380	5.530	6.68	5.98	1.6770	0.0	24.0
15.10.25	47.16	41.14	6.02	296.090	289.940	292.970	287.540	5.430	6.68	5.98	1.7640	0.0	24.0
16.10.25	47.01	40.90	6.11	295.610	289.400	292.490	287.160	5.330	6.65	5.95	1.7880	0.0	24.0
17.10.25	48.37	41.74	6.63	294.230	287.970	290.950	285.650	5.300	6.66	5.96	1.9260	0.0	24.0
18.10.25	50.94	43.58	7.36	292.600	286.290	289.080	283.700	5.380	6.61	5.92	2.1260	0.0	24.0
19.10.25	52.02	44.59	7.43	296.660	290.360	292.920	287.720	5.200	6.64	5.93	2.1740	0.0	24.0
20.10.25	50.77	43.77	7.00	296.370	290.110	292.770	287.560	5.210	6.60	5.90	2.0490	0.0	24.0
Итого	---	---	---	7171.5	7031.1	7098.07	6976.51	121.560	---	---	42.6560	0.0	720.0
Среднее	41.51	36.51	4.99	---	---	---	---	---	6.61	6.04	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
19.09.25 24:00	0	0	0	0	0	0	0	0
20.10.25 24:00	67231.500	65620.230	66339.630	65006.730	573.9000	1332.900	256.0	10000.0
Итого за период	67231.500	65620.230	66339.630	65006.730	573.9000	---	256.0	10000.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Северная, 22
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВА708

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-
28.09.25	-	-	-	-	-	-	-	-	-
29.09.25	-	-	-	-	-	-	-	-	-
30.09.25	-	-	-	-	-	-	-	-	-
01.10.25	-	-	-	-	-	-	-	-	-
02.10.25	1.71	48.14	240.01	40.98	247.75	24.00	24.00	0.00	0.00
03.10.25	1.70	48.23	239.04	41.11	246.94	24.00	24.00	0.00	0.00
04.10.25	1.71	48.89	238.41	41.72	246.22	24.00	24.00	0.00	0.00
05.10.25	1.72	48.94	237.58	41.71	245.51	24.00	24.00	0.00	0.00
06.10.25	1.68	48.85	237.36	41.77	245.18	24.00	24.00	0.00	0.00
07.10.25	1.60	48.13	237.46	41.38	245.17	24.00	24.00	0.00	0.00
08.10.25	1.41	45.75	237.50	39.80	245.23	24.00	24.00	0.00	0.00
09.10.25	1.41	45.85	237.68	39.92	245.37	24.00	24.00	0.00	0.00
10.10.25	1.41	45.66	236.91	39.70	244.86	24.00	24.00	0.00	0.00
11.10.25	1.36	45.45	237.01	39.69	244.89	24.00	24.00	0.00	0.00
12.10.25	1.34	45.21	239.78	39.61	247.54	24.00	24.00	0.00	0.00
13.10.25	1.40	45.70	240.03	39.84	247.80	24.00	24.00	0.00	0.00
14.10.25	1.54	47.50	239.90	41.06	247.60	24.00	24.00	0.00	0.00
15.10.25	1.48	47.17	240.26	40.99	247.81	24.00	24.00	0.00	0.00
16.10.25	1.55	47.76	240.37	41.30	247.83	24.00	24.00	0.00	0.00
17.10.25	1.58	47.69	240.08	41.11	247.44	24.00	24.00	0.00	0.00
18.10.25	1.67	48.73	239.00	41.71	246.34	24.00	24.00	0.00	0.00
19.10.25	1.88	51.63	237.05	43.70	244.34	24.00	24.00	0.00	0.00
20.10.25	1.94	52.69	240.37	44.61	247.51	24.00	24.00	0.00	0.00
Итого	30.09	---	4535.80	---	4681.33	456.00	456.00	0.00	0.00
Среднее	---	47.788	---	41.143	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	5596.58	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

ИМ2300, Суточный с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Северная, 26
 Потребитель: АО "Жилуправление"
 Прибор: ИМ2300 Заводской номер: ВВ420

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0	16.74	0.00	16.04	0.00	0.00	24.00	0.00	0.00
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-
25.09.25	0.00	16.81	0.00	16.32	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	16.85	0.00	16.37	0.00	0.00	24.00	0.00	0.00
27.09.25	0.52	28.29	197.52	26.68	0.00	12.23	24.00	0.00	0.00
28.09.25	0.92	40.27	390.10	37.91	0.00	24.00	24.00	0.00	0.00
29.09.25	0.94	40.47	387.39	38.04	0.00	24.00	24.00	0.00	0.00
30.09.25	1.11	43.36	381.23	40.43	0.00	24.00	24.00	0.00	0.00
01.10.25	1.31	47.48	368.11	43.92	0.00	24.00	24.00	0.00	0.00
02.10.25	1.26	47.43	361.73	43.93	0.00	24.00	24.00	0.00	0.00
03.10.25	1.23	47.49	360.47	44.07	0.00	24.00	24.00	0.00	0.00
04.10.25	1.24	48.19	358.57	44.74	0.00	24.00	24.00	0.00	0.00
05.10.25	1.23	48.18	356.71	44.73	0.00	24.00	24.00	0.00	0.00
06.10.25	1.20	48.12	356.16	44.73	0.00	24.00	24.00	0.00	0.00
07.10.25	1.13	47.14	356.98	43.97	0.00	24.00	24.00	0.00	0.00
08.10.25	1.00	45.06	357.35	42.25	0.00	24.00	24.00	0.00	0.00
09.10.25	1.00	45.15	363.19	42.40	0.00	24.00	24.00	0.00	0.00
10.10.25	0.99	44.96	357.55	42.18	0.00	24.00	24.00	0.00	0.00
11.10.25	0.96	44.77	358.26	42.07	0.00	24.00	24.00	0.00	0.00
12.10.25	0.96	44.51	362.91	41.87	0.00	23.90	24.00	0.00	0.00
13.10.25	1.02	45.15	363.45	42.32	0.00	24.00	24.00	0.00	0.00
14.10.25	1.10	46.83	363.19	43.79	0.00	24.00	24.00	0.00	0.00
15.10.25	1.06	46.42	363.37	43.49	0.00	24.00	24.00	0.00	0.00
16.10.25	1.11	47.09	363.15	44.02	0.00	24.00	24.00	0.00	0.00
17.10.25	1.12	46.93	362.34	43.82	0.00	24.00	24.00	0.00	0.00
18.10.25	1.21	48.35	360.21	44.97	0.00	24.00	24.00	0.00	0.00
19.10.25	1.34	50.85	357.65	47.09	0.00	24.00	24.00	0.00	0.00
20.10.25	1.39	51.93	362.46	48.09	0.00	24.00	24.00	0.00	0.00
Итого	26.35	---	8570.05	---	0.00	564.13	648.00	0.00	0.00
Среднее	---	42.401	---	39.639	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	2809.97	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Фрунзе, 11
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00169033

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0х195А

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	16.00	15.82	0.18	0.000	0.000	0.000	0.000	0.000	1.09	6.00	0.0000	0.0	24.0
20.09.25	15.96	15.76	0.20	0.000	0.000	0.000	0.000	0.000	1.10	6.00	0.0000	0.0	24.0
21.09.25	15.98	15.84	0.14	0.000	0.000	0.000	0.000	0.000	1.12	6.00	0.0000	0.0	24.0
22.09.25	16.46	16.41	0.05	0.000	0.000	0.000	0.000	0.000	1.13	6.00	0.0000	0.0	24.0
23.09.25	16.40	16.24	0.16	0.000	0.000	0.000	0.000	0.000	1.12	6.00	0.0000	0.0	24.0
24.09.25	16.47	16.33	0.14	0.000	0.000	0.000	0.000	0.000	1.12	6.00	0.0000	0.0	24.0
25.09.25	16.52	16.38	0.14	0.000	0.000	0.000	0.000	0.000	1.12	6.00	0.0000	0.0	24.0
26.09.25	39.90	35.29	4.61	230.440	229.320	228.660	227.970	0.690	1.42	6.00	1.0100	0.0	24.0
27.09.25	40.30	35.97	4.33	447.540	441.990	444.090	439.350	4.740	3.21	6.00	1.8900	0.0	24.0
28.09.25	40.48	35.79	4.69	454.800	448.920	451.240	446.250	4.990	4.19	6.00	2.0980	0.0	24.0
29.09.25	43.21	37.16	6.05	435.860	432.760	431.940	429.940	2.000	3.36	6.00	2.5900	0.0	24.0
30.09.25	47.56	39.87	7.69	410.400	407.090	405.960	404.010	1.950	3.18	6.00	3.0910	0.0	24.0
01.10.25	47.54	40.03	7.51	414.990	413.210	410.530	410.090	0.440	3.37	6.00	3.0520	0.0	24.0
02.10.25	47.60	40.16	7.44	417.610	416.890	413.060	413.760	-0.700	3.12	6.00	3.0430	0.0	24.0
03.10.25	48.30	40.72	7.58	418.440	419.370	413.820	416.100	-2.280	3.27	6.00	3.1030	0.0	24.0
04.10.25	48.30	40.69	7.61	415.080	417.630	410.520	414.330	-3.810	3.23	6.00	3.0930	0.0	24.0
05.10.25	48.23	40.71	7.52	413.670	416.950	409.110	413.730	-4.620	3.08	6.00	3.0450	0.0	24.0
06.10.25	47.28	40.17	7.11	413.730	419.150	409.350	415.950	-6.600	3.08	6.00	2.8760	0.0	24.0
07.10.25	45.14	38.79	6.35	413.450	429.310	409.370	426.230	-16.860	3.14	6.00	2.5700	0.0	24.0
08.10.25	45.24	38.91	6.33	412.180	429.630	408.120	426.510	-18.390	3.24	6.00	2.5540	0.0	24.0
09.10.25	45.05	38.76	6.29	413.290	428.000	409.260	424.980	-15.720	3.03	6.00	2.5430	0.0	24.0
10.10.25	44.85	38.72	6.13	413.510	428.190	409.510	425.140	-15.630	2.74	6.00	2.4830	0.0	24.0
11.10.25	44.59	38.59	6.00	418.560	431.910	414.580	428.870	-14.290	2.89	6.00	2.4610	0.0	24.0
12.10.25	45.22	38.85	6.37	418.950	432.950	414.840	429.830	-14.990	2.91	6.00	2.6100	0.0	24.0
13.10.25	46.93	40.03	6.90	419.250	423.160	414.930	420.040	-5.110	2.95	6.00	2.8340	0.0	24.0
14.10.25	46.47	39.78	6.69	404.870	408.330	400.640	405.280	-4.640	1.85	6.00	2.6420	0.0	24.0
15.10.25	47.18	40.34	6.84	427.670	429.470	423.110	426.160	-3.050	1.13	6.00	2.8480	0.0	24.0
16.10.25	47.03	40.08	6.95	422.490	423.030	418.010	419.850	-1.840	1.15	6.00	2.8580	0.0	24.0
17.10.25	48.42	40.88	7.54	422.020	422.340	417.270	419.050	-1.780	1.18	6.00	3.0970	0.0	24.0
18.10.25	50.98	42.65	8.33	421.220	422.770	416.050	419.210	-3.160	1.46	6.00	3.4200	0.0	24.0
19.10.25	52.06	43.55	8.51	424.610	426.220	419.120	422.380	-3.260	2.48	6.00	3.5290	0.0	24.0
20.10.25	50.79	42.84	7.95	424.670	425.960	419.480	422.260	-2.780	2.68	6.00	3.3000	0.0	24.0
Итого	---	---	---	10329.3	10424.5	10222.57	10347.27	-124.700	---	---	68.6400	0.0	768.0
Среднее	39.76	34.44	5.32	---	---	---	---	---	2.35	6.00	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	89894.840	88484.820	88674.390	87663.359	811.2980	1011.030	2496.0	5605.0
20.10.25 24:00	100224.139	98909.370	98896.959	98010.629	879.9380	100886.330	2496.0	6373.0
Итого за период	10329.298	10424.549	10222.569	10347.270	68.6400	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Фрунзе, 1
 Потребитель: АО "Жилуправление"
 Прибор: Взлёт ТСРВ-024 Заводской номер: 902520
 Тип системы: А42-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
28.09.25	40.72	38.91	1.81	354.08	354.13	-0.05	0.461	0.432	356.86	356.67	0.18	0.013	0.467
29.09.25	43.77	40.84	2.93	346.28	347.06	-0.78	0.457	0.426	349.41	349.79	-0.38	0.732	13.617
30.09.25	47.82	44.21	3.61	350.83	347.71	3.12	0.447	0.429	354.64	350.94	3.70	1.258	23.650
01.10.25	47.63	44.13	3.50	354.59	354.22	0.36	0.441	0.429	358.43	357.52	0.91	1.245	23.533
02.10.25	47.57	44.07	3.50	351.68	346.95	4.73	0.438	0.426	355.50	350.18	5.32	1.219	22.750
03.10.25	48.33	44.80	3.53	360.66	352.35	8.31	0.433	0.426	364.69	355.74	8.95	1.271	23.817
04.10.25	48.34	44.81	3.53	362.63	360.37	2.26	0.438	0.432	366.68	363.83	2.85	1.277	24.000
05.10.25	48.30	44.93	3.37	363.26	361.03	2.22	0.438	0.433	367.30	364.52	2.78	1.221	23.983
06.10.25	47.30	43.94	3.36	358.79	359.87	-1.07	0.436	0.429	362.63	363.20	-0.57	1.198	23.667
07.10.25	45.17	42.10	3.07	365.07	368.44	-3.36	0.436	0.433	368.64	371.57	-2.93	1.075	23.000
08.10.25	45.26	42.20	3.06	365.04	368.37	-3.33	0.434	0.431	368.63	371.52	-2.89	0.850	18.083
09.10.25	45.07	42.03	3.04	364.89	368.23	-3.34	0.442	0.438	368.44	371.34	-2.91	0.780	16.667
10.10.25	44.88	41.93	2.95	365.86	369.19	-3.32	0.449	0.446	369.39	372.30	-2.91	0.529	11.417
11.10.25	44.62	41.72	2.90	369.80	373.23	-3.42	0.449	0.444	373.33	376.34	-3.01	0.446	9.583
12.10.25	45.24	42.21	3.03	370.00	373.51	-3.50	0.450	0.446	373.63	376.70	-3.07	0.432	8.917
13.10.25	46.99	43.70	3.29	369.73	373.24	-3.50	0.452	0.447	373.63	376.65	-3.02	1.210	23.900
14.10.25	46.58	43.41	3.17	370.32	373.76	-3.43	0.451	0.447	374.16	377.13	-2.96	1.047	20.983
15.10.25	47.22	43.88	3.34	370.59	374.05	-3.45	0.451	0.447	374.54	377.50	-2.95	1.234	24.000
16.10.25	47.06	43.64	3.42	369.74	372.82	-3.08	0.448	0.444	373.66	376.23	-2.57	1.250	24.000
17.10.25	48.44	44.77	3.67	368.87	372.05	-3.18	0.450	0.446	373.01	375.63	-2.62	1.351	24.000
18.10.25	51.02	46.96	4.06	367.23	370.48	-3.25	0.446	0.442	371.78	374.39	-2.61	1.460	23.333
19.10.25	52.10	47.95	4.15	369.61	372.96	-3.34	0.447	0.442	374.38	377.06	-2.67	1.529	24.000
20.10.25	50.87	47.00	3.87	369.59	372.99	-3.40	0.444	0.439	374.14	376.93	-2.79	1.427	23.983
Итого	---	---	---	8359.16	8387.01	-27.84	---	---	8447.49	8463.66	-16.18	24.052	455.350
Среднее	46.97	43.66	3.31	---	---	---	0.445	0.437	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Фрунзе, 3
 Потребитель: АО "Жилуправление"
 Прибор: Взлёт ТСРВ-024 Заводской номер: 800749
 Тип системы: А32-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	15.86	15.69	0.17	0.00	0.00	0.00	0.274	0.346	0.00	0.00	0.00	0.000	24.000
20.09.25	15.85	15.54	0.31	0.00	0.00	0.00	0.209	0.281	0.00	0.00	0.00	0.000	24.000
21.09.25	15.81	15.52	0.29	0.00	0.00	0.00	0.105	0.177	0.00	0.00	0.00	0.000	24.000
22.09.25	15.84	15.52	0.32	0.00	0.00	0.00	0.134	0.206	0.00	0.00	0.00	0.000	24.000
23.09.25	15.92	15.53	0.39	0.00	0.00	0.00	0.435	0.506	0.00	0.00	0.00	0.000	24.000
24.09.25	16.08	15.64	0.44	0.00	0.00	0.00	0.446	0.496	0.00	0.00	0.00	0.000	24.000
25.09.25	16.10	15.66	0.44	0.00	0.00	0.00	0.547	0.489	0.00	0.00	0.00	0.000	24.000
26.09.25	18.37	17.30	1.07	19.20	19.08	0.11	0.590	0.466	19.27	19.25	0.02	0.141	24.000
27.09.25	39.91	36.98	2.93	280.38	280.43	-0.05	0.638	0.509	281.71	283.04	-1.33	0.821	24.000
28.09.25	40.27	37.89	2.38	280.00	280.00	0.00	0.649	0.520	281.37	282.69	-1.32	0.672	24.000
29.09.25	41.15	38.56	2.59	276.71	276.71	0.00	0.643	0.513	278.13	279.46	-1.32	0.722	24.000
30.09.25	46.81	42.37	4.44	270.08	270.08	0.00	0.634	0.512	272.04	273.25	-1.20	1.208	24.000
01.10.25	47.50	42.85	4.65	272.27	272.26	0.00	0.635	0.515	274.33	275.50	-1.16	1.269	24.000
02.10.25	47.58	43.02	4.56	273.84	273.51	0.32	0.633	0.515	275.96	276.74	-0.78	1.267	24.000
03.10.25	47.86	43.14	4.72	274.24	273.96	0.28	0.629	0.511	276.39	277.21	-0.83	1.309	24.000
04.10.25	48.32	43.21	5.11	273.77	273.74	0.03	0.635	0.518	275.99	276.99	-1.00	1.405	24.000
05.10.25	48.18	43.07	5.11	273.19	273.19	0	0.635	0.519	275.59	276.21	-0.62	1.400	24.000
06.10.25	48.21	43.18	5.03	273.28	273.28	0	0.632	0.517	275.71	276.29	-0.59	1.379	24.000
07.10.25	45.57	41.21	4.36	273.44	273.40	0.03	0.634	0.519	275.58	276.17	-0.59	1.197	24.000
08.10.25	45.15	40.87	4.28	273.43	273.43	0	0.633	0.518	275.57	276.11	-0.54	1.174	24.000
09.10.25	45.12	40.85	4.27	273.41	273.41	0.00	0.632	0.517	275.54	276.10	-0.56	1.172	24.000
10.10.25	45.08	40.81	4.27	273.38	273.35	0.02	0.647	0.531	275.49	276.04	-0.55	1.171	24.000
11.10.25	44.89	40.65	4.24	275.77	275.77	0	0.650	0.531	277.85	278.50	-0.64	1.174	24.000
12.10.25	44.51	40.37	4.14	276.89	276.89	0	0.652	0.531	278.91	279.63	-0.71	1.150	24.000
13.10.25	46.21	41.59	4.62	276.86	276.86	0.00	0.653	0.532	279.02	279.78	-0.76	1.285	24.000
14.10.25	47.11	42.43	4.68	276.85	276.85	0.00	0.653	0.532	279.08	279.91	-0.83	1.298	24.000
15.10.25	46.51	41.91	4.60	277.51	277.51	0	0.654	0.532	279.64	280.55	-0.92	1.281	24.000
16.10.25	47.16	42.31	4.85	276.83	276.83	0.00	0.651	0.529	279.01	279.94	-0.93	1.347	24.000
17.10.25	46.87	42.02	4.85	275.95	275.95	0	0.651	0.532	278.10	278.99	-0.89	1.343	24.000
18.10.25	50.93	45.09	5.84	275.10	275.10	0	0.649	0.530	277.67	278.57	-0.90	1.608	24.000
19.10.25	51.28	45.46	5.82	275.13	275.13	0.00	0.646	0.526	277.71	278.67	-0.97	1.606	24.000
20.10.25	51.92	46.09	5.83	276.20	276.20	0	0.645	0.524	278.85	279.87	-1.01	1.616	24.000
Итого	---	---	---	6623.70	6622.93	0.77	---	---	6674.51	6695.46	-20.95	30.015	768.000
Среднее	38.87	35.39	3.49	---	---	---	0.567	0.484	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Фрунзе, 5
 Потребитель: АО "Жилуправление"
 Прибор: Вzlёт ТСРВ-024 Заводской номер: 800012
 Тип системы: А32-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	17.57	17.33	0.24	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
20.09.25	17.66	17.42	0.24	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
21.09.25	17.77	17.54	0.23	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
22.09.25	17.79	17.57	0.22	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
23.09.25	17.82	17.61	0.21	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
24.09.25	17.90	17.69	0.21	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
25.09.25	17.92	17.71	0.21	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	24.000
26.09.25	26.95	25.68	1.27	36.34	36.36	-0.01	0.000	0.000	36.50	36.72	-0.22	0.086	23.667
27.09.25	40.11	38.12	1.99	94.97	94.97	0.00	0.000	0.000	95.32	96.04	-0.71	0.188	24.000
28.09.25	40.28	38.28	2.00	95.00	95.00	0.00	0.000	0.000	95.35	96.09	-0.75	0.189	24.000
29.09.25	42.62	39.22	3.40	94.12	94.00	0.12	0.000	0.000	94.74	94.93	-0.19	0.325	23.833
30.09.25	47.38	41.76	5.62	93.43	93.39	0.03	0.000	0.000	94.23	94.41	-0.18	0.527	24.000
01.10.25	47.22	41.11	6.11	91.49	91.42	0.07	0.000	0.000	92.08	92.58	-0.50	0.571	24.000
02.10.25	47.37	40.65	6.72	92.63	92.49	0.13	0.000	0.000	93.22	93.66	-0.44	0.633	23.917
03.10.25	48.04	40.27	7.77	94.85	94.76	0.08	0.000	0.000	95.46	95.97	-0.50	0.738	24.000
04.10.25	48.11	40.12	7.99	94.53	94.53	0.00	0.000	0.000	95.14	95.73	-0.59	0.754	24.000
05.10.25	48.01	40.19	7.82	94.45	94.45	0	0.000	0.000	95.05	95.66	-0.60	0.737	24.000
06.10.25	47.40	39.76	7.64	94.51	94.48	0.03	0.000	0.000	95.08	95.67	-0.58	0.722	24.000
07.10.25	45.00	38.15	6.85	94.59	94.59	0.00	0.000	0.000	95.04	95.75	-0.71	0.647	24.000
08.10.25	45.08	38.31	6.77	94.56	94.56	0	0.000	0.000	95.00	95.74	-0.73	0.640	24.000
09.10.25	44.90	38.21	6.69	94.54	94.54	0	0.000	0.000	94.96	95.72	-0.77	0.631	24.000
10.10.25	44.71	38.15	6.56	94.52	94.52	0.00	0.000	0.000	94.91	95.72	-0.81	0.619	24.000
11.10.25	44.49	38.05	6.44	95.69	95.69	0.00	0.000	0.000	96.07	96.91	-0.85	0.615	24.000
12.10.25	44.91	38.34	6.57	95.78	95.78	0.00	0.000	0.000	96.17	97.03	-0.86	0.628	24.000
13.10.25	46.69	39.51	7.18	95.68	95.68	0	0.000	0.000	96.13	96.97	-0.84	0.685	24.000
14.10.25	46.41	39.45	6.96	95.78	95.78	0	0.000	0.000	96.23	97.07	-0.84	0.665	24.000
15.10.25	46.94	39.69	7.25	95.85	95.85	0.00	0.000	0.000	96.31	97.15	-0.84	0.693	24.000
16.10.25	46.90	39.54	7.36	95.57	95.57	0.00	0.000	0.000	96.03	96.87	-0.84	0.702	24.000
17.10.25	47.80	40.08	7.72	95.32	95.32	0	0.000	0.000	95.81	96.64	-0.83	0.734	24.000
18.10.25	50.76	42.04	8.72	94.81	94.81	0	0.000	0.000	95.43	96.19	-0.75	0.825	24.000
19.10.25	51.76	42.78	8.98	95.52	95.52	0	0.000	0.000	96.20	96.93	-0.73	0.856	24.000
20.10.25	50.89	42.33	8.56	95.54	95.54	0	0.000	0.000	96.18	96.93	-0.74	0.817	24.000
Итого	---	---	---	2310.05	2309.57	0.48	---	---	2322.65	2339.07	-16.42	15.227	767.417
Среднее	39.54	34.46	5.08	---	---	---	0.000	0.000	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

**ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Фрунзе, 5
 Потребитель: АО "Жилуправление"
 Прибор: Взлёт ТСРВ-024 Заводской номер: 801948
 Тип системы: А32-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	0.00	0.00	0.00	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	0.000
21.09.25	0.00	0.00	0.00	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	0.000
22.09.25	0.00	0.00	0.00	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	0.000
23.09.25	0.00	0.00	0.00	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	0.000
24.09.25	0.00	0.00	0.00	0.00	0.00	0.00	0.000	0.000	0.00	0.00	0.00	0.000	0.000
25.09.25	17.12	16.60	0.52	0.00	0.00	0.00	0.268	0.168	0.00	0.00	0.00	0.000	0.067
26.09.25	22.30	20.51	1.79	18.80	18.72	0.07	0.345	0.255	18.93	18.84	0.10	0.100	5.583
27.09.25	40.02	36.65	3.37	98.60	98.60	0.00	0.689	0.659	99.27	99.29	-0.01	0.332	24.000
28.09.25	40.23	37.16	3.07	97.81	97.82	-0.01	0.694	0.660	98.52	98.50	0.02	0.262	20.667
29.09.25	41.67	38.36	3.31	95.97	95.69	0.28	0.683	0.648	96.73	96.38	0.35	0.277	19.500
30.09.25	47.26	42.64	4.62	96.00	94.90	1.10	0.687	0.645	97.02	95.72	1.30	0.491	24.000
01.10.25	47.31	42.83	4.48	91.93	91.14	0.78	0.688	0.635	92.90	91.95	0.95	0.464	23.317
02.10.25	47.56	42.44	5.12	95.90	95.47	0.43	0.688	0.641	96.91	96.30	0.61	0.509	24.000
03.10.25	48.01	42.48	5.53	96.23	96.21	0.01	0.685	0.640	97.25	97.07	0.18	0.532	24.000
04.10.25	48.23	42.67	5.56	95.91	95.91	0.00	0.697	0.646	96.94	96.77	0.17	0.534	24.000
05.10.25	48.15	42.65	5.50	95.78	95.78	0.00	0.697	0.645	96.78	96.65	0.13	0.527	24.000
06.10.25	48.00	42.54	5.46	95.81	95.81	0.00	0.692	0.642	96.78	96.70	0.08	0.522	24.000
07.10.25	45.33	40.54	4.79	95.93	95.93	0.00	0.697	0.645	96.76	96.77	-0.00	0.459	24.000
08.10.25	45.15	40.44	4.71	95.93	95.93	0.00	0.694	0.643	96.74	96.79	-0.05	0.452	24.000
09.10.25	45.07	40.36	4.71	95.95	95.95	0	0.698	0.645	96.74	96.82	-0.08	0.452	24.000
10.10.25	44.90	40.32	4.58	95.98	95.98	0	0.717	0.657	96.76	96.85	-0.09	0.440	24.000
11.10.25	44.74	40.26	4.48	96.93	96.93	-0.00	0.716	0.661	97.70	97.82	-0.12	0.429	23.333
12.10.25	44.77	40.26	4.51	97.31	97.31	0	0.718	0.664	98.07	98.21	-0.14	0.439	24.000
13.10.25	46.49	41.49	5.00	97.23	97.23	0.00	0.719	0.664	98.07	98.17	-0.09	0.486	24.000
14.10.25	46.89	41.99	4.90	97.27	97.27	0.00	0.718	0.664	98.14	98.21	-0.07	0.477	24.000
15.10.25	46.69	41.70	4.99	97.48	97.48	0	0.720	0.666	98.34	98.42	-0.09	0.487	24.000
16.10.25	47.09	41.98	5.11	97.23	97.23	0.00	0.715	0.662	98.10	98.19	-0.09	0.497	24.000
17.10.25	47.18	41.97	5.21	97.01	97.01	0.00	0.719	0.662	97.86	97.98	-0.12	0.505	24.000
18.10.25	51.13	44.97	6.16	96.34	96.34	0.00	0.714	0.657	97.40	97.39	0.00	0.594	24.000
19.10.25	51.45	45.26	6.19	97.18	97.18	0.00	0.712	0.659	98.27	98.25	0.02	0.601	24.000
20.10.25	51.57	45.52	6.05	97.14	97.14	0	0.705	0.655	98.26	98.19	0.07	0.588	24.000
Итого	---	---	---	2333.63	2330.94	2.68	---	---	2355.25	2352.21	3.03	11.455	572.467
Среднее	37.24	33.37	3.86	---	---	---	0.564	0.519	---	---	---	---	---

Представитель абонента _____/_____ Представитель поставщика _____/_____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Фрунзе, 56
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00177236

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0x7886

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	15.73	15.35	0.38	0.000	0.000	0.000	0.000	0.000	2.45	2.47	0.0000	0.0	24.0
20.09.25	15.72	15.37	0.35	0.000	0.000	0.000	0.000	0.000	2.45	2.47	0.0000	0.0	24.0
21.09.25	15.83	15.35	0.48	0.000	0.000	0.000	0.000	0.000	2.45	2.47	0.0000	0.0	24.0
22.09.25	16.22	15.87	0.35	0.000	0.000	0.000	0.000	0.000	2.45	2.47	0.0000	0.0	24.0
23.09.25	16.36	16.02	0.34	0.000	0.000	0.000	0.000	0.000	2.45	2.47	0.0000	0.0	24.0
24.09.25	16.81	16.37	0.44	0.000	0.000	0.000	0.000	0.000	2.45	2.47	0.0000	0.0	24.0
25.09.25	15.83	15.48	0.35	0.000	0.000	0.000	0.000	0.000	2.44	2.47	0.0000	0.0	24.0
26.09.25	39.87	37.39	2.48	161.170	160.130	160.010	159.110	0.900	4.91	3.93	0.4010	0.0	24.0
27.09.25	40.32	38.18	2.14	305.620	303.920	303.240	301.760	1.480	7.27	5.34	0.6600	0.0	24.0
28.09.25	40.51	38.27	2.24	306.580	305.230	304.200	303.080	1.120	7.24	5.33	0.6910	0.0	24.0
29.09.25	43.42	40.69	2.73	304.990	303.420	302.320	301.060	1.260	7.12	5.26	0.8320	0.0	24.0
30.09.25	47.62	44.35	3.27	302.980	301.200	299.800	298.360	1.440	7.11	5.31	0.9890	0.0	24.0
01.10.25	47.56	44.32	3.24	303.740	301.720	300.590	298.840	1.750	7.11	5.31	0.9830	0.0	24.0
02.10.25	47.62	44.41	3.21	303.050	300.970	299.920	298.090	1.830	7.08	5.28	0.9710	0.0	24.0
03.10.25	48.32	45.09	3.23	303.130	301.080	299.790	298.200	1.590	7.08	5.29	0.9740	0.0	24.0
04.10.25	48.31	45.07	3.24	302.320	300.280	298.960	297.400	1.560	7.13	5.34	0.9770	0.0	24.0
05.10.25	48.24	45.03	3.21	302.010	299.660	298.650	296.780	1.870	7.13	5.35	0.9690	0.0	24.0
06.10.25	47.26	44.23	3.03	301.900	298.980	298.730	296.210	2.520	7.09	5.32	0.9130	0.0	24.0
07.10.25	45.13	42.43	2.70	301.460	297.950	298.580	295.370	3.210	7.12	5.34	0.8150	0.0	24.0
08.10.25	45.22	42.51	2.71	301.250	297.530	298.370	294.950	3.420	7.10	5.32	0.8150	0.0	24.0
09.10.25	45.04	42.33	2.71	300.870	296.900	297.990	294.390	3.600	7.17	5.39	0.8140	0.0	24.0
10.10.25	44.84	42.20	2.64	301.360	297.310	298.520	294.790	3.730	7.25	5.47	0.7990	0.0	24.0
11.10.25	44.57	42.01	2.56	309.030	305.150	306.190	302.560	3.630	7.33	5.46	0.7940	0.0	24.0
12.10.25	45.22	42.52	2.70	310.910	306.930	307.980	304.290	3.690	7.35	5.48	0.8390	0.0	24.0
13.10.25	46.93	43.98	2.95	310.950	307.220	307.830	304.350	3.480	7.35	5.49	0.9130	0.0	24.0
14.10.25	46.51	43.68	2.83	311.150	307.390	308.060	304.600	3.460	7.35	5.48	0.8790	0.0	24.0
15.10.25	47.18	44.20	2.98	311.220	307.300	307.990	304.420	3.570	7.35	5.48	0.9280	0.0	24.0
16.10.25	47.02	44.00	3.02	310.250	305.630	307.060	302.810	4.250	7.32	5.46	0.9360	0.0	24.0
17.10.25	48.45	45.12	3.33	309.960	304.940	306.590	302.000	4.590	7.33	5.47	1.0290	0.0	24.0
18.10.25	50.99	47.31	3.68	309.880	304.880	306.130	301.620	4.510	7.28	5.43	1.1340	0.0	24.0
19.10.25	52.07	48.31	3.76	313.070	308.420	309.170	305.060	4.110	7.33	5.44	1.1730	0.0	24.0
20.10.25	50.77	47.27	3.50	312.340	307.830	308.520	304.590	3.930	7.28	5.40	1.0920	0.0	24.0
Итого	---	---	---	7511.1	7431.9	7435.19	7364.69	70.500	---	---	22.3200	0.0	768.0
Среднее	39.73	37.33	2.39	---	---	---	---	---	6.10	4.70	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	64136.660	63238.610	63270.420	62510.200	280.1540	760.220	3654.0	7330.0
20.10.25 24:00	71647.850	70670.579	70705.610	69874.889	302.4740	830.720	3654.0	8098.0
Итого за период	7511.190	7431.968	7435.190	7364.688	22.3200	---	0.0	768.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

ТВ-7 ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Фрунзе, 7
Потребитель: АО "Жилуправление"
Прибор: ТВ7-04 Заводской номер: 22178247

БД=1, ТВ1, СИ=6, КТЗ=0, ФРТ=0, КСН=0х86D2

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
26.09.25	28.11	24.85	н/д	3.26	5.90	5.70	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
27.09.25	40.33	36.62	н/д	3.71	5.90	5.70	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
28.09.25	40.51	36.66	н/д	3.85	5.90	5.70	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
29.09.25	43.27	37.96	н/д	5.31	5.90	5.70	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
30.09.25	47.58	41.32	н/д	6.26	5.90	5.70	н/д	0.000	0.000	н/д	0.000	0.000	н/д	0.000	0.000	н/д	24	0
01.10.25	47.48	40.38	н/д	7.10	5.16	4.96	н/д	134.170	133.771	н/д	132.779	132.788	н/д	-0.010	0.943	н/д	24	0
02.10.25	47.61	41.92	н/д	5.69	4.54	4.42	н/д	240.663	241.674	н/д	238.140	239.747	н/д	-1.607	1.354	н/д	24	0
03.10.25	48.13	42.11	н/д	6.02	4.48	4.41	н/д	195.878	194.902	н/д	193.774	193.339	н/д	0.435	1.165	н/д	24	0
04.10.25	48.31	41.34	н/д	6.97	4.55	4.48	н/д	243.081	244.296	н/д	240.446	242.400	н/д	-1.954	1.675	н/д	24	0
05.10.25	48.24	41.69	н/д	6.54	4.58	4.49	н/д	241.387	242.541	н/д	238.787	240.623	н/д	-1.836	1.562	н/д	24	0
06.10.25	47.33	41.51	н/д	5.81	4.56	4.45	н/д	240.479	241.450	н/д	237.987	239.557	н/д	-1.569	1.383	н/д	24	0
07.10.25	45.17	39.55	н/д	5.62	4.54	4.48	н/д	241.216	241.958	н/д	238.958	240.258	н/д	-1.300	1.341	н/д	24	0
08.10.25	45.26	39.31	н/д	5.95	4.51	4.46	н/д	243.749	244.940	н/д	241.446	243.242	н/д	-1.795	1.435	н/д	24	0
09.10.25	45.07	39.15	н/д	5.92	4.58	4.53	н/д	243.686	244.826	н/д	241.419	243.150	н/д	-1.731	1.428	н/д	24	0
10.10.25	44.88	39.16	н/д	5.72	4.66	4.61	н/д	244.143	245.211	н/д	241.876	243.529	н/д	-1.653	1.381	н/д	24	0
11.10.25	44.63	39.00	н/д	5.63	4.65	4.60	н/д	246.979	248.091	н/д	244.714	246.399	н/д	-1.685	1.376	н/д	24	0
12.10.25	45.23	39.31	н/д	5.92	4.67	4.62	н/д	247.258	248.383	н/д	244.926	246.669	н/д	-1.743	1.448	н/д	24	0
13.10.25	46.94	40.56	н/д	6.38	4.68	4.63	н/д	247.196	248.438	н/д	244.691	246.605	н/д	-1.914	1.560	н/д	24	0
14.10.25	46.54	40.45	н/д	6.09	4.67	4.62	н/д	247.580	248.794	н/д	245.112	246.956	н/д	-1.844	1.492	н/д	24	0
15.10.25	47.19	40.76	н/д	6.43	4.68	4.63	н/д	247.710	157.401	н/д	245.169	156.216	н/д	88.953	1.576	н/д	24	0
16.10.25	47.05	40.46	н/д	6.59	4.65	4.60	н/д	246.801	226.910	н/д	244.280	225.230	н/д	19.050	1.608	н/д	24	0
17.10.25	48.37	41.36	н/д	7.01	4.67	4.62	н/д	246.219	247.551	н/д	243.558	245.628	н/д	-2.069	1.707	н/д	24	0
18.10.25	50.97	43.15	н/д	7.83	4.63	4.58	н/д	245.536	247.150	н/д	242.583	245.050	н/д	-2.467	1.897	н/д	24	0
19.10.25	52.05	44.03	н/д	8.02	4.63	4.58	н/д	247.365	249.023	н/д	244.265	246.813	н/д	-2.549	1.958	н/д	24	0
20.10.25	50.83	43.26	н/д	7.57	4.59	4.54	н/д	247.246	215.360	н/д	244.279	213.510	н/д	30.769	1.847	н/д	24	0
Итого	---	---	---	---	---	---	---	4738.342	4612.670	---	4689.189	4577.709	---	111.481	30.136	---	600	0
Среднее	47.36	40.92	---	6.43	4.89	4.79	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
20.10.25 24:00	46151.706	37612.009	0.000	45489.835	37224.106	0.000	8265.729	430.842	0.000	8674	0
Итого за период	н/д	н/д	н/д	н/д	н/д	н/д	---	н/д	н/д	н/д	н/д

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Фрунзе, 9а
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00173043

БД=1, ТВ1, СИ=1, КТЗ=1, ФРТ=0, КСН=0х035С

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	16.42	16.35	0.07	0.000	0.000	0.000	0.000	0.000	2.78	2.85	0.0000	0.0	24.0
20.09.25	16.35	16.31	0.04	0.000	0.000	0.000	0.000	0.000	2.75	2.83	0.0000	0.0	24.0
21.09.25	16.29	16.26	0.03	0.000	0.000	0.000	0.000	0.000	2.74	2.81	0.0000	0.0	24.0
22.09.25	16.37	16.35	0.02	0.000	0.000	0.000	0.000	0.000	2.72	2.79	0.0000	0.0	24.0
23.09.25	15.62	15.11	0.51	0.000	0.000	0.000	0.000	0.000	2.62	2.69	0.0000	0.0	24.0
24.09.25	14.25	13.93	0.32	0.000	0.000	0.000	0.000	0.000	2.55	2.62	0.0000	0.0	24.0
25.09.25	15.13	14.77	0.36	0.000	0.000	0.000	0.000	0.000	2.54	2.61	0.0000	0.0	24.0
26.09.25	39.71	35.69	4.02	202.740	195.020	201.250	193.880	7.370	5.36	4.16	0.8110	0.0	24.0
27.09.25	39.75	36.03	3.72	355.510	339.780	352.870	337.640	15.230	7.64	5.38	1.3290	0.0	24.0
28.09.25	39.94	36.16	3.78	353.880	338.840	351.250	336.710	14.540	7.62	5.37	1.3430	0.0	24.0
29.09.25	42.80	38.29	4.51	351.450	336.390	348.410	334.060	14.350	7.51	5.31	1.5790	0.0	24.0
30.09.25	46.91	41.45	5.46	347.980	332.990	344.380	330.350	14.030	7.50	5.36	1.8880	0.0	24.0
01.10.25	46.86	41.34	5.52	349.710	334.370	346.110	331.730	14.380	7.50	5.36	1.9210	0.0	24.0
02.10.25	46.92	41.39	5.53	349.810	334.140	346.210	331.500	14.710	7.46	5.34	1.9230	0.0	24.0
03.10.25	47.61	42.02	5.59	350.760	335.070	347.100	332.280	14.820	7.46	5.34	1.9540	0.0	24.0
04.10.25	47.60	41.90	5.70	350.900	335.390	347.250	332.560	14.690	7.51	5.40	1.9940	0.0	24.0
05.10.25	47.54	41.90	5.64	351.150	335.710	347.470	332.930	14.540	7.51	5.40	1.9710	0.0	24.0
06.10.25	46.57	41.24	5.33	351.540	336.040	347.970	333.320	14.650	7.47	5.37	1.8640	0.0	24.0
07.10.25	44.50	39.71	4.79	351.780	336.220	348.480	333.790	14.690	7.50	5.40	1.6770	0.0	24.0
08.10.25	44.59	39.82	4.77	352.200	336.400	348.870	333.910	14.960	7.48	5.38	1.6780	0.0	24.0
09.10.25	44.40	39.66	4.74	352.090	336.220	348.850	333.770	15.080	7.55	5.45	1.6620	0.0	24.0
10.10.25	44.21	39.60	4.61	352.600	336.790	349.350	334.340	15.010	7.63	5.53	1.6190	0.0	24.0
11.10.25	43.95	39.44	4.51	356.770	340.750	353.530	338.210	15.320	7.68	5.52	1.6070	0.0	24.0
12.10.25	44.59	39.82	4.77	357.330	341.360	353.950	338.780	15.170	7.70	5.53	1.7010	0.0	24.0
13.10.25	46.26	41.11	5.15	357.390	341.620	353.790	338.980	14.810	7.71	5.55	1.8340	0.0	24.0
14.10.25	45.84	40.90	4.94	357.810	342.000	354.290	339.290	15.000	7.70	5.54	1.7630	0.0	24.0
15.10.25	46.51	41.29	5.22	357.940	342.260	354.340	339.540	14.800	7.71	5.54	1.8600	0.0	24.0
16.10.25	46.35	41.07	5.28	356.380	340.560	352.780	337.890	14.890	7.67	5.52	1.8750	0.0	24.0
17.10.25	47.76	42.05	5.71	355.340	339.770	351.530	336.950	14.580	7.68	5.53	2.0190	0.0	24.0
18.10.25	50.24	43.93	6.31	354.650	339.920	350.450	336.840	13.610	7.62	5.49	2.2210	0.0	24.0
19.10.25	51.31	44.85	6.46	357.570	342.990	353.250	339.680	13.570	7.66	5.50	2.2900	0.0	24.0
20.10.25	50.02	43.95	6.07	357.460	342.840	353.350	339.710	13.640	7.61	5.45	2.1560	0.0	24.0
Итого	---	---	---	8692.7	8313.4	8607.08	8248.64	358.440	---	---	44.5390	0.0	768.0
Среднее	39.16	35.11	4.04	---	---	---	---	---	6.44	4.81	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	86836.260	99101.920	82864.520	80963.590	581.4910	1900.930	3723.0	7237.0
20.10.25 24:00	95665.890	107530.939	91608.310	89327.639	626.0480	2280.670	3723.0	8029.0
Итого за период	8829.630	8429.019	8743.789	8364.048	44.5570	---	0.0	792.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Чапаева, 19
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ649

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	0.00	13.72	0.00	13.36	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	13.70	0.00	13.33	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	13.68	0.00	13.32	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	13.84	0.00	13.54	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	13.85	0.00	13.52	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	13.96	0.00	13.64	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	13.56	0.00	13.25	0.00	0.00	24.00	0.00	0.00
27.09.25	0.30	21.85	81.97	20.30	80.33	8.55	24.00	0.00	0.00
28.09.25	0.82	41.36	224.61	37.68	220.89	24.00	24.00	0.00	0.00
29.09.25	0.80	40.58	211.24	36.77	208.18	24.00	24.00	0.00	0.00
30.09.25	0.80	40.23	208.05	36.37	205.28	24.00	24.00	0.00	0.00
01.10.25	0.86	41.59	174.92	36.67	172.60	24.00	24.00	0.00	0.00
02.10.25	0.93	43.36	169.16	37.86	166.87	24.00	24.00	0.00	0.00
03.10.25	0.99	45.83	172.56	39.86	170.44	24.00	24.00	0.00	0.00
04.10.25	0.96	44.65	215.63	40.20	212.83	24.00	24.00	0.00	0.00
05.10.25	0.95	44.41	215.44	40.01	212.70	24.00	24.00	0.00	0.00
06.10.25	0.94	44.53	215.26	40.18	212.53	24.00	24.00	0.00	0.00
07.10.25	0.86	43.13	213.29	39.08	210.65	24.00	24.00	0.00	0.00
08.10.25	0.74	43.68	193.98	39.88	191.76	22.02	22.02	0.00	0.00
09.10.25	0.82	45.11	246.39	41.79	242.92	23.89	24.00	0.00	0.00
10.10.25	0.80	44.88	272.80	41.93	268.81	24.00	24.00	0.00	0.00
11.10.25	0.75	44.04	268.30	41.23	264.40	24.00	24.00	0.00	0.00
12.10.25	0.73	43.27	264.92	40.52	261.12	24.00	24.00	0.00	0.00
13.10.25	0.77	43.66	264.60	40.73	260.85	24.00	24.00	0.00	0.00
14.10.25	0.77	43.62	264.62	40.69	260.86	24.00	24.00	0.00	0.00
15.10.25	0.84	45.28	261.79	42.07	257.69	24.00	24.00	0.00	0.00
16.10.25	0.90	46.34	268.06	42.99	263.66	24.00	24.00	0.00	0.00
17.10.25	0.92	46.49	293.31	43.33	288.41	24.00	24.00	0.00	0.00
18.10.25	1.02	48.21	299.96	44.80	294.94	24.00	24.00	0.00	0.00
19.10.25	1.17	52.03	300.97	48.14	296.10	24.00	24.00	0.00	0.00
20.10.25	1.15	52.18	301.17	48.36	296.40	24.00	24.00	0.00	0.00
Итого	20.59	---	5603.00	---	5521.22	558.46	742.02	0.00	0.00
Среднее	---	36.988	---	34.045	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	1435.10	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

ИМ2300, Суточный с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Чапаева, 21
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВВ677

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.00	18.26	0.00	17.27	0.00	0.00	24.00	0.00	0.00
20.09.25	0.00	18.13	0.00	17.24	0.00	0.00	24.00	0.00	0.00
21.09.25	0.00	18.10	0.00	17.22	0.00	0.00	24.00	0.00	0.00
22.09.25	0.00	18.10	0.00	17.22	0.00	0.00	24.00	0.00	0.00
23.09.25	0.00	18.32	0.00	17.45	0.00	0.00	24.00	0.00	0.00
24.09.25	0.00	18.42	0.00	17.60	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	18.58	0.00	17.75	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	18.34	0.00	17.59	0.00	0.00	24.00	0.00	0.00
27.09.25	0.22	25.66	74.11	23.96	0.00	8.57	24.00	0.00	0.00
28.09.25	0.59	44.38	206.10	41.52	0.00	24.00	24.00	0.00	0.00
29.09.25	0.68	43.67	207.73	40.41	0.00	24.00	24.00	0.00	0.00
30.09.25	0.77	43.34	218.67	39.78	65.36	24.00	24.00	0.00	0.00
01.10.25	0.81	44.64	182.79	40.17	179.42	24.00	24.00	0.00	0.00
02.10.25	0.86	46.38	174.99	41.45	171.86	24.00	24.00	0.00	0.00
03.10.25	0.92	48.81	179.34	43.47	176.02	24.00	24.00	0.00	0.00
04.10.25	0.89	47.73	225.18	43.79	220.74	24.00	24.00	0.00	0.00
05.10.25	0.88	47.50	225.05	43.57	220.59	24.00	24.00	0.00	0.00
06.10.25	0.87	47.62	224.75	43.74	220.31	24.00	24.00	0.00	0.00
07.10.25	0.80	46.22	222.82	42.63	218.43	24.00	24.00	0.00	0.00
08.10.25	0.69	45.02	203.11	41.62	199.03	22.03	22.03	0.00	0.00
09.10.25	0.77	45.00	259.56	42.04	254.42	23.86	24.00	0.00	0.00
10.10.25	0.76	44.79	286.61	42.14	281.11	24.00	24.00	0.00	0.00
11.10.25	0.71	43.95	281.89	41.44	276.48	24.00	24.00	0.00	0.00
12.10.25	0.68	43.18	278.80	40.73	273.37	24.00	24.00	0.00	0.00
13.10.25	0.71	43.57	277.92	41.00	272.49	24.00	24.00	0.00	0.00
14.10.25	0.71	43.53	277.90	40.96	272.50	24.00	24.00	0.00	0.00
15.10.25	0.77	45.18	274.70	42.37	269.27	24.00	24.00	0.00	0.00
16.10.25	0.82	46.24	281.62	43.31	276.15	24.00	24.00	0.00	0.00
17.10.25	0.85	46.39	308.43	43.62	302.68	24.00	24.00	0.00	0.00
18.10.25	0.95	48.13	315.38	45.11	309.54	24.00	24.00	0.00	0.00
19.10.25	1.09	51.91	316.40	48.46	310.58	24.00	24.00	0.00	0.00
20.10.25	1.08	52.07	316.66	48.65	310.85	24.00	24.00	0.00	0.00
Итого	18.88	---	5820.51	---	5081.20	558.46	766.03	0.00	0.00
Среднее	---	38.474	---	35.790	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	1277.28	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Чапаева, 23
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BA718

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	0.00	14.76	12.72	14.65	11.87	24.00	24.00	0.00	0.00
21.09.25	0.00	14.75	11.75	14.64	10.66	24.00	24.00	0.00	0.00
22.09.25	0.00	14.69	11.03	14.57	9.93	24.00	24.00	0.00	0.00
23.09.25	0.00	15.02	11.58	14.83	32.85	23.60	24.00	0.00	0.00
24.09.25	0.00	15.20	12.78	14.99	82.43	24.00	24.00	0.00	0.00
25.09.25	0.00	15.44	13.83	15.16	75.24	24.00	24.00	0.00	0.00
26.09.25	0.00	15.19	12.59	14.97	50.02	24.00	24.00	0.00	0.00
27.09.25	0.26	20.86	71.90	20.09	75.98	23.35	24.00	0.00	0.00
28.09.25	1.14	54.52	285.41	50.52	204.60	24.00	24.00	0.00	0.00
29.09.25	1.15	55.84	295.13	51.94	291.86	24.00	24.00	0.00	0.00
30.09.25	1.04	55.22	238.02	50.62	235.74	24.00	24.00	0.00	0.00
01.10.25	0.94	56.50	146.94	49.99	145.66	24.00	24.00	0.00	0.00
02.10.25	1.05	56.59	120.70	47.79	119.79	20.13	24.00	0.00	0.00
03.10.25	1.22	55.97	149.58	47.85	148.48	24.00	24.00	0.00	0.00
04.10.25	1.23	57.26	149.09	48.95	147.98	24.00	24.00	0.00	0.00
05.10.25	1.24	57.26	155.18	49.24	153.80	24.00	24.00	0.00	0.00
06.10.25	1.26	57.96	155.25	49.85	154.13	24.00	24.00	0.00	0.00
07.10.25	1.25	58.08	161.69	50.31	160.58	24.00	24.00	0.00	0.00
08.10.25	1.26	58.56	182.62	51.63	181.37	24.00	24.00	0.00	0.00
09.10.25	1.25	58.83	188.72	52.17	187.28	24.00	24.00	0.00	0.00
10.10.25	1.24	58.51	186.40	51.83	185.03	24.00	24.00	0.00	0.00
11.10.25	1.22	58.59	183.66	51.85	182.24	23.45	24.00	0.00	0.00
12.10.25	1.15	57.11	170.28	50.36	169.01	24.00	24.00	0.00	0.00
13.10.25	1.17	56.96	173.07	50.21	171.78	24.00	24.00	0.00	0.00
14.10.25	1.15	56.64	166.09	49.68	164.87	24.00	24.00	0.00	0.00
15.10.25	0.91	50.50	163.72	44.92	162.43	23.48	24.00	0.00	0.00
16.10.25	1.18	56.47	163.89	49.25	162.82	24.00	24.00	0.00	0.00
17.10.25	1.22	56.96	163.41	49.48	162.31	24.00	24.00	0.00	0.00
18.10.25	1.20	56.75	163.21	49.37	162.08	24.00	24.00	0.00	0.00
19.10.25	1.23	56.65	163.57	49.14	162.22	24.00	24.00	0.00	0.00
20.10.25	1.22	56.82	163.39	49.37	162.00	24.00	24.00	0.00	0.00
Итого	27.18	---	4247.20	---	4327.04	738.01	744.00	0.00	0.00
Среднее	---	46.144	---	40.975	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	3747.26	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

ИМ2300, Суточный с 19.09.25 по 20.10.25

Объект: г. Октябрьский, Чапаева, 23
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: ВА719

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	0.01	15.81	48.70	15.58	9.35	24.00	24.00	0.00	0.00
20.09.25	0.01	15.79	43.11	15.56	8.61	24.00	24.00	0.00	0.00
21.09.25	0.01	15.75	38.73	15.52	8.04	24.00	24.00	0.00	0.00
22.09.25	0.01	15.69	35.03	15.45	7.49	24.00	24.00	0.00	0.00
23.09.25	0.01	16.22	28.96	15.66	4.66	15.29	24.00	0.00	0.00
24.09.25	0.00	16.18	0.00	15.83	0.00	0.00	24.00	0.00	0.00
25.09.25	0.00	16.45	0.00	16.11	0.00	0.00	24.00	0.00	0.00
26.09.25	0.00	16.30	0.00	15.99	0.00	0.00	24.00	0.00	0.00
27.09.25	0.00	15.03	0.00	16.23	0.00	0.00	24.00	0.00	0.00
28.09.25	0.00	15.16	0.00	21.07	0.00	0.00	24.00	0.00	0.00
29.09.25	0.00	14.85	0.00	21.09	0.00	0.00	24.00	0.00	0.00
30.09.25	0.52	27.17	76.41	29.36	77.02	7.22	24.00	0.00	0.00
01.10.25	1.44	57.55	234.03	51.37	236.48	24.00	24.00	0.00	0.00
02.10.25	1.48	59.71	224.47	53.09	226.85	24.00	24.00	0.00	0.00
03.10.25	1.30	56.89	217.02	50.92	219.42	24.00	24.00	0.00	0.00
04.10.25	1.32	58.29	213.91	52.13	216.29	24.00	24.00	0.00	0.00
05.10.25	1.30	58.29	216.78	52.26	218.98	24.00	24.00	0.00	0.00
06.10.25	1.31	58.98	217.40	52.94	219.63	24.00	24.00	0.00	0.00
07.10.25	1.31	59.08	224.69	53.25	226.93	24.00	24.00	0.00	0.00
08.10.25	1.21	59.62	225.83	54.25	227.76	22.01	22.01	0.00	0.00
09.10.25	1.31	59.83	253.23	54.65	255.23	24.00	24.00	0.00	0.00
10.10.25	1.31	59.54	250.63	54.31	252.57	24.00	24.00	0.00	0.00
11.10.25	1.28	59.57	249.00	54.43	250.82	24.00	24.00	0.00	0.00
12.10.25	1.12	58.09	210.51	52.74	230.04	22.26	24.00	0.00	0.00
13.10.25	1.23	57.93	232.33	52.65	234.11	24.00	24.00	0.00	0.00
14.10.25	1.21	57.64	226.00	52.26	227.79	24.00	24.00	0.00	0.00
15.10.25	0.94	51.26	223.14	47.04	225.04	23.49	24.00	0.00	0.00
16.10.25	1.24	57.55	216.53	51.80	218.53	23.39	24.00	0.00	0.00
17.10.25	1.27	57.95	220.09	52.18	222.46	24.00	24.00	0.00	0.00
18.10.25	1.25	57.73	219.73	52.01	221.76	24.00	24.00	0.00	0.00
19.10.25	1.25	57.64	220.13	51.94	222.00	24.00	24.00	0.00	0.00
20.10.25	1.25	57.82	219.89	52.12	221.80	24.00	24.00	0.00	0.00
Итого	25.90	---	4786.28	---	4689.66	593.66	766.01	0.00	0.00
Среднее	---	42.543	---	39.431	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	3686.39	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

**ТС1 Пульсар ДУ-40, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Чапаева, 7
Потребитель: АО "Жилуправление"
Прибор: 405 Заводской номер: 5578692

ТВ1

Дата	T1	T2	V1	Q	Время раб. (ч)
19.09.25	19.0	18.8	0.000	0.000	0.00
20.09.25	19.0	18.7	0.000	0.000	0.00
21.09.25	18.9	18.7	0.000	0.000	0.00
22.09.25	18.9	18.6	0.000	0.000	0.00
23.09.25	18.9	18.6	0.000	0.000	0.00
24.09.25	18.8	18.6	0.000	0.000	0.00
25.09.25	18.8	18.5	0.000	0.000	0.00
26.09.25	18.6	18.4	0.000	0.000	0.00
27.09.25	18.5	18.3	0.000	0.000	0.00
28.09.25	18.3	18.1	0.000	0.000	0.00
29.09.25	28.9	25.3	14.160	0.111	11.00
30.09.25	44.7	34.8	28.543	0.278	24.00
01.10.25	46.6	35.1	27.711	0.314	24.00
02.10.25	48.5	36.6	29.564	0.337	24.00
03.10.25	47.5	38.0	35.469	0.333	24.00
04.10.25	47.4	37.8	35.393	0.334	24.00
05.10.25	47.5	38.1	35.406	0.330	24.00
06.10.25	45.8	37.2	35.055	0.300	24.00
07.10.25	44.9	36.6	34.555	0.284	24.00
08.10.25	45.0	36.7	34.592	0.282	24.00
09.10.25	44.7	36.4	33.754	0.274	24.00
10.10.25	43.9	35.9	32.906	0.259	24.00
11.10.25	43.1	35.4	32.668	0.249	24.00
12.10.25	43.5	35.5	32.645	0.260	24.00
13.10.25	43.5	35.5	32.594	0.259	24.00
14.10.25	45.4	36.5	32.145	0.284	24.00
15.10.25	46.2	37.2	33.090	0.295	24.00
16.10.25	46.3	37.7	35.330	0.301	24.00
17.10.25	48.7	39.2	36.115	0.341	24.00
18.10.25	51.8	41.2	36.150	0.379	24.00
19.10.25	52.0	41.4	36.178	0.378	24.00
20.10.25	50.4	41.0	38.547	0.356	24.00
Итого	---	---	722.568	6.539	515.00
Среднее	37.3	31.1	---	---	---

Показания интеграторов

Дата	V1, м. куб	Q, Гкал	Время раб., ч
18.09.25 24:00	28770.594	346.669	17517.000
20.10.25 24:00	29493.162	353.207	18032.000
Итого за период	722.568	6.538	515.000

Представитель абонента _____/_____

Представитель поставщика _____/_____

Отчет о потреблении тепловой энергии и теплоносителя за Октябрь 2025 г.

Адрес: ул. Геофизиков 5

Тип прибора: ТСРВ-020
Номер прибора: 802355
Теплосистема: I

Дата	W1, Гкал	m1, т	t1, °C	P1, МПа	W2, Гкал	m2, т	t2, °C	P2, МПа	W3, Гкал	m3, т	t3, °C	P3, МПа	W4, Гкал	m4, т	t4, °C	P4, МПа
20.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
28.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
29.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
30.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
01.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
02.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
03.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
04.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
05.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
06.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
07.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
08.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
09.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
10.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
11.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
12.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
13.10.25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
14.10.25	1.367	29.781	42.86	0.52	1.158	29.135	36.24	0.84	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
15.10.25	2.337	50.666	46.00	0.56	1.990	49.559	39.03	0.90	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
16.10.25	2.627	56.432	46.42	0.59	2.256	55.167	39.77	0.90	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
17.10.25	2.827	58.237	48.41	0.59	2.413	56.922	41.22	0.90	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
18.10.25	3.060	58.772	51.95	0.60	2.586	57.429	43.81	0.90	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
19.10.25	3.079	58.921	52.14	0.60	2.608	57.572	44.06	0.90	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
20.10.25	1.893	36.953	43.34	0.41	1.596	35.982	38.82	0.90	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
Среднее:	2.553	51.901	47.79		2.170	50.719	40.76		0.000	0.000	0.00		0.000	0.000	0.00	
Итого:	17.190	349.761			14.607	341.766			0.000	0.000			0.000	0.000		

Ответственный за учет тепловой энергии: _____ / _____ /
Отчет принят _____ 200 г. _____ / _____ /

Отчет о потреблении тепловой энергии и теплоносителя за Октябрь 2025 г.

Адрес: ул. Геофизиков 5

Тип прибора: ТСПВ-020
Номер прибора: 802355
Теплосистема: 1

Дата	п, ч	Wтс, Гкал	Wгв, Гкал	Мтс, т	txв, °C
20.09.25	-	-	-	-	-
21.09.25	-	-	-	-	-
22.09.25	-	-	-	-	-
23.09.25	-	-	-	-	-
24.09.25	-	-	-	-	-
25.09.25	-	-	-	-	-
26.09.25	-	-	-	-	-
27.09.25	-	-	-	-	-
28.09.25	-	-	-	-	-
29.09.25	-	-	-	-	-
30.09.25	-	-	-	-	-
01.10.25	-	-	-	-	-
02.10.25	-	-	-	-	-
03.10.25	-	-	-	-	-
04.10.25	-	-	-	-	-
05.10.25	-	-	-	-	-
06.10.25	-	-	-	-	-
07.10.25	-	-	-	-	-
08.10.25	-	-	-	-	-
09.10.25	-	-	-	-	-
10.10.25	-	-	-	-	-
11.10.25	-	-	-	-	-
12.10.25	-	-	-	-	-
13.10.25	-	-	-	-	-
14.10.25	14.73	0.208	0.000	0.646	0.00
15.10.25	24.00	0.348	0.000	1.107	0.00
16.10.25	24.00	0.371	0.000	1.265	0.00
17.10.25	24.00	0.414	0.000	1.314	0.00
18.10.25	24.00	0.474	0.000	1.343	0.00
19.10.25	24.00	0.471	0.000	1.349	0.00
20.10.25	15.97	0.297	0.000	0.905	0.00
Среднее:		0.383	0.000	1.175	0.000
Итого:	150.70	2.583	0.000	7.929	

Ответственный за учет тепловой энергии: _____ / _____ /
Отчет принят _____ 200 г. _____ / _____ /

Отчет о потреблении тепловой энергии и теплоносителя за Октябрь 2025 г.

Адрес: ул. Геофизиков 5

Тип прибора: ТСПВ-020
 Номер прибора: 802355
 Теплосистема: 3

Дата	W1, Гкал	m1, т	t1, °C	P1, МПа	W2, Гкал	m2, т	t2, °C	P2, МПа	W3, Гкал	m3, т	t3, °C	P3, МПа	W4, Гкал	m4, т	t4, °C	P4, МПа
20.09.25	-	-	-	-	-	-	-		-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-		-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-		-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-		-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-		-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-		-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-		-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-		-	-	-	-	-	-	-	-
28.09.25	-	-	-	-	-	-	-		-	-	-	-	-	-	-	-
29.09.25	-	-	-	-	-	-	-		-	-	-	-	-	-	-	-
30.09.25	-	-	-	-	-	-	-		-	-	-	-	-	-	-	-
01.10.25	-	-	-	-	-	-	-		-	-	-	-	-	-	-	-
02.10.25	-	-	-	-	-	-	-		-	-	-	-	-	-	-	-
03.10.25	-	-	-	-	-	-	-		-	-	-	-	-	-	-	-
04.10.25	-	-	-	-	-	-	-		-	-	-	-	-	-	-	-
05.10.25	-	-	-	-	-	-	-		-	-	-	-	-	-	-	-
06.10.25	-	-	-	-	-	-	-		-	-	-	-	-	-	-	-
07.10.25	-	-	-	-	-	-	-		-	-	-	-	-	-	-	-
08.10.25	-	-	-	-	-	-	-		-	-	-	-	-	-	-	-
09.10.25	-	-	-	-	-	-	-		-	-	-	-	-	-	-	-
10.10.25	-	-	-	-	-	-	-		-	-	-	-	-	-	-	-
11.10.25	-	-	-	-	-	-	-		-	-	-	-	-	-	-	-
12.10.25	-	-	-	-	-	-	-		-	-	-	-	-	-	-	-
13.10.25	-	-	-	-	-	-	-		-	-	-	-	-	-	-	-
14.10.25	2.181	47.624	42.77	0.48	1.705	47.880	33.42		0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
15.10.25	3.727	80.947	45.91	0.52	2.936	81.356	36.11		0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
16.10.25	4.153	89.362	46.35	0.55	3.312	89.773	36.93		0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
17.10.25	4.459	92.046	48.32	0.55	3.524	92.528	38.14		0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
18.10.25	4.818	92.699	51.87	0.56	3.755	93.309	40.38		0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
19.10.25	4.847	92.919	52.05	0.56	3.788	93.527	40.64		0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
20.10.25	2.982	58.294	42.78	0.37	2.317	58.922	36.61		0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
Среднее:	4.030	82.099	47.64		3.167	82.592	37.75		0.000	0.000	0.00		0.000	0.000	0.00	
Итого:	27.167	553.891			21.339	557.295			0.000	0.000			0.000	0.000		

Ответственный за учет тепловой энергии: _____ / _____ /
 Отчет принят _____ 200 г. _____ / _____ /

Отчет о потреблении тепловой энергии и теплоносителя за Октябрь 2025 г.

Адрес: ул. Геофизиков 5

Тип прибора: ТСПВ-020
Номер прибора: 802355
Теплосистема: 3

Дата	п, ч	Wтс, Гкал	Wгв, Гкал	Mтс, т	tхв, °C
20.09.25	-	-	-	-	-
21.09.25	-	-	-	-	-
22.09.25	-	-	-	-	-
23.09.25	-	-	-	-	-
24.09.25	-	-	-	-	-
25.09.25	-	-	-	-	-
26.09.25	-	-	-	-	-
27.09.25	-	-	-	-	-
28.09.25	-	-	-	-	-
29.09.25	-	-	-	-	-
30.09.25	-	-	-	-	-
01.10.25	-	-	-	-	-
02.10.25	-	-	-	-	-
03.10.25	-	-	-	-	-
04.10.25	-	-	-	-	-
05.10.25	-	-	-	-	-
06.10.25	-	-	-	-	-
07.10.25	-	-	-	-	-
08.10.25	-	-	-	-	-
09.10.25	-	-	-	-	-
10.10.25	-	-	-	-	-
11.10.25	-	-	-	-	-
12.10.25	-	-	-	-	-
13.10.25	-	-	-	-	-
14.10.25	14.73	0.475	0.000	-0.257	0.00
15.10.25	24.00	0.791	0.000	-0.408	0.00
16.10.25	24.00	0.840	0.000	-0.411	0.00
17.10.25	24.00	0.935	0.000	-0.482	0.00
18.10.25	24.00	1.063	0.000	-0.610	0.00
19.10.25	24.00	1.059	0.000	-0.608	0.00
20.10.25	16.45	0.665	0.000	-0.456	0.00
Среднее:		0.863	0.000	-0.475	0.000
Итого:	151.18	5.828	0.000	-3.232	

Ответственный за учет тепловой энергии: _____ / _____ /
Отчет принят _____ 200 г. _____ / _____ /

Адрес: РБ, г. Октябрьский, ул. Девонская д.14

Тепловычислитель СПТ941.20; Сетевой номер NT=0; идентификатор ИД=92230

Схема учета СП=3

Сутки, час	НС	Время счета Ti	подающий труб.			обратный труб.			M3	Тепло Q
			t1	P1	M1	t2	P2	M2		
19.09.25	00:00	-	#н/д	#н/д	#н/д	#н/д	#н/д	#н/д	#н/д	#н/д
20.09.25	00:00	-	#н/д	#н/д	#н/д	#н/д	#н/д	#н/д	#н/д	#н/д
21.09.25	00:00	-	#н/д	#н/д	#н/д	#н/д	#н/д	#н/д	#н/д	#н/д
22.09.25	00:00	-	#н/д	#н/д	#н/д	#н/д	#н/д	#н/д	#н/д	#н/д
23.09.25	00:00	-	#н/д	#н/д	#н/д	#н/д	#н/д	#н/д	#н/д	#н/д
24.09.25	00:00	*	30.08	16.45	0.600	0.000	16.24	0.600	0.465	0.000
25.09.25	00:00	*	24.00	16.58	0.600	0.000	16.28	0.600	0.729	0.000
26.09.25	00:00	*	24.00	16.35	0.600	0.000	16.34	0.600	0.749	0.000
27.09.25	00:00	*	24.00	16.01	0.600	0.010	16.08	0.600	0.724	0.000
28.09.25	00:00	*	24.00	15.95	0.600	0.000	16.58	0.600	0.709	0.000
29.09.25	00:00	*	24.00	15.61	0.600	0.000	16.37	0.600	0.634	0.000
30.09.25	00:00	*	24.00	44.07	0.600	130.445	39.06	0.600	131.192	0.000
01.10.25	00:00	-	24.00	47.23	0.600	189.877	42.04	0.600	189.872	0.000
02.10.25	00:00	-	24.00	47.18	0.600	177.181	42.07	0.600	176.686	0.000
03.10.25	00:00	*	24.00	47.28	0.600	160.871	41.92	0.600	160.085	0.000
04.10.25	00:00	-	24.00	47.99	0.600	163.398	42.08	0.600	162.351	0.000
05.10.25	00:00	-	24.00	47.96	0.600	175.260	42.18	0.600	174.690	0.000
06.10.25	00:00	-	24.00	47.88	0.600	174.213	42.21	0.600	173.473	0.000
07.10.25	00:00	-	24.00	46.97	0.600	174.183	41.65	0.600	173.233	0.000
08.10.25	00:00	-	24.00	44.82	0.600	172.248	40.03	0.600	171.055	0.000
09.10.25	00:00	-	24.00	44.92	0.600	172.845	40.18	0.600	171.700	0.000
10.10.25	00:00	-	24.00	44.71	0.600	172.147	39.99	0.600	170.790	0.000
11.10.25	00:00	-	24.00	44.52	0.600	172.765	39.97	0.600	171.376	0.000
12.10.25	00:00	*	24.00	44.26	0.600	174.898	39.77	0.600	173.553	0.000
13.10.25	00:00	-	24.00	44.87	0.600	176.212	40.08	0.600	174.877	0.000
14.10.25	00:00	-	24.00	46.57	0.600	174.411	41.41	0.600	173.071	0.000
15.10.25	00:00	-	24.00	46.17	0.600	177.723	41.29	0.600	176.288	0.000
16.10.25	00:00	-	24.00	46.83	0.600	177.861	41.69	0.600	176.504	0.000
17.10.25	00:00	-	24.00	46.69	0.600	173.349	41.42	0.600	172.397	0.000
18.10.25	00:00	-	24.00	48.01	0.600	171.703	42.29	0.600	170.615	0.000
19.10.25	00:00	-	24.00	50.59	0.600	171.274	44.25	0.600	170.089	0.000
20.10.25	00:00	-	24.00	51.67	0.600	172.626	45.15	0.600	171.298	0.000
ИТОГО			654.08	39.93	0.600	3605.499	35.87	0.600	3589.207	0.000
		ч	°C	МПа	т	°C	МПа	т	т	Гкал

Ответственный за учет _____ Начальник СПОКПУ

Морозов И.Е.

Дата _____

КОМСОМОЛЬСКАЯ 17

ОТЧЕТ
о суточных параметрах теплоснабжения
19/09/25г.-20/10/25г.

Абонент: _____ Договор N: _____
Адрес: ул. Комсомольская 17 Тип расходомера: _____
Тепловычислитель ВКТ-7 сет. N 001 Пределы измерений: _____
Договорные расходи: G под max = 180.00 м3/ч G под min = 0.48 м3/ч
M сет. воды = _____ т.сут M ГВС = _____ т.сут G обр max = 180.00 м3/ч G обр min = 0.48 м3/ч
Тхв = 0.00 °C G3 max = 20.00 м3/ч G3 min = 0.20 м3/ч

Заводской номер 00169030 ВВОД 1 СХЕМА ПОДКЛЮЧЕНИЯ 3 БД 1 ФТ=0 Т3=1 КС=0х27DD по 2.7

Дата	t1	t2	dt	V1	M1	V2	M2	V3	MГ	P1	P2	Qo	QГ	ВНР	ВОС	НС
	°C	°C	°C	м3	т	м3	т	м3	т	кг/см2	кг/см2	Гкал	Гкал	ч	ч	
19/09/25	16.49	16.22	0.27	0.00	0.00	0.00	0.00	0.00	0.00	6.20	6.00	0.000	0.000	24	0	*
20/09/25	16.48	16.20	0.28	0.00	0.00	0.00	0.00	0.00	0.00	6.20	6.00	0.000	0.000	24	0	*
21/09/25	16.49	16.20	0.29	0.00	0.00	0.00	0.00	0.00	0.00	6.20	6.00	0.000	0.000	24	0	*
22/09/25	16.52	16.60	-0.08	0.00	0.00	0.00	0.00	0.00	0.00	6.20	6.00	0.000	0.000	24	0	*
23/09/25	16.53	16.20	0.33	0.00	0.00	0.00	0.00	0.00	0.00	6.20	6.00	0.000	0.000	24	0	*
24/09/25	16.59	16.23	0.36	0.00	0.00	0.00	0.00	0.00	0.00	6.20	6.00	0.000	0.000	24	0	*
25/09/25	16.63	16.26	0.37	0.00	0.00	0.00	0.00	0.00	0.00	6.20	6.00	0.000	0.000	24	0	*
26/09/25	38.89	27.19	11.70	91.06	90.41	0.00	0.00	0.00	90.41	6.20	6.00	0.248	2.460	24	0	*
27/09/25	40.09	38.06	2.03	347.55	344.94	0.00	0.00	0.00	344.94	6.20	6.00	0.703	13.127	24	0	*
28/09/25	40.27	38.22	2.05	354.16	351.46	0.00	0.00	0.00	351.46	6.20	6.00	0.721	13.431	24	0	*
29/09/25	43.01	40.46	2.55	343.70	340.72	0.00	0.00	0.00	340.72	6.20	6.00	0.882	13.782	24	0	*
30/09/25	47.33	43.22	4.11	372.24	368.34	0.00	0.00	0.00	368.34	6.20	6.00	1.525	15.914	24	0	*
01/10/25	47.28	42.92	4.36	393.07	388.99	0.00	0.00	0.00	388.99	6.20	6.00	1.696	16.690	24	0	*
02/10/25	47.35	43.19	4.16	385.43	381.35	0.00	0.00	0.00	381.35	6.20	6.00	1.587	16.465	24	0	*
03/10/25	48.05	43.57	4.48	377.68	373.61	0.00	0.00	0.00	373.61	6.20	6.00	1.664	16.272	24	0	*
04/10/25	48.06	43.57	4.49	384.89	380.80	0.00	0.00	0.00	380.80	6.20	6.00	1.706	16.585	24	0	*
05/10/25	47.98	43.57	4.41	385.41	381.30	0.00	0.00	0.00	381.30	6.20	6.00	1.677	16.607	24	0	*
06/10/25	47.07	42.91	4.16	385.51	381.49	0.00	0.00	0.00	381.49	6.20	6.00	1.584	16.364	24	0	*
07/10/25	44.91	41.21	3.70	384.65	381.05	0.00	0.00	0.00	381.05	6.20	6.00	1.411	15.699	24	0	*
08/10/25	45.01	41.33	3.68	384.33	380.73	0.00	0.00	0.00	380.73	6.20	6.00	1.399	15.731	24	0	*
09/10/25	44.82	41.14	3.68	382.88	379.28	0.00	0.00	0.00	379.28	6.20	6.00	1.395	15.599	24	0	*
10/10/25	44.63	41.06	3.57	385.18	381.62	0.00	0.00	0.00	381.62	6.20	6.00	1.357	15.665	24	0	*
11/10/25	44.38	40.85	3.53	387.27	383.73	0.00	0.00	0.00	383.73	6.20	6.00	1.351	15.671	24	0	*
12/10/25	44.97	41.20	3.77	387.44	383.80	0.00	0.00	0.00	383.80	6.20	6.00	1.443	15.808	24	0	*
13/10/25	46.68	42.58	4.10	386.96	383.01	0.00	0.00	0.00	383.01	6.20	6.00	1.572	16.303	24	0	*
14/10/25	46.28	42.36	3.92	388.23	384.28	0.00	0.00	0.00	384.28	6.20	6.00	1.503	16.273	24	0	*
15/10/25	46.94	42.83	4.11	389.19	385.11	0.00	0.00	0.00	385.11	6.20	6.00	1.582	16.489	24	0	*
16/10/25	46.80	42.60	4.20	386.55	382.62	0.00	0.00	0.00	382.62	6.20	6.00	1.604	16.294	24	0	*
17/10/25	48.12	43.62	4.50	385.77	381.60	0.00	0.00	0.00	381.60	6.20	6.00	1.716	16.639	24	0	*
18/10/25	50.71	45.70	5.01	384.02	379.35	0.00	0.00	0.00	379.35	6.20	6.00	1.898	17.328	24	0	*
19/10/25	51.79	46.64	5.15	386.07	381.27	0.00	0.00	0.00	381.27	6.20	6.00	1.960	17.774	24	0	*
20/10/25	50.58	45.74	4.84	385.01	380.44	0.00	0.00	0.00	380.44	6.20	6.00	1.836	17.393	24	0	*
Итого:				9224.2	9131.30	0.00	0.00	0.00	9131.30			36.020	386.363	768	0	
Средние:	39.61	36.23	3.37							6.20	6.00					

Период нормальной работы 768ч
Период отсутств.счета тепл.энергии 0ч
Время работы прибора после сброса 10944ч

представитель абонента

представитель теплоснабж.организации
комсомольская 17

комсомольская 206

ОТЧЕТ
о суточных параметрах теплоснабжения
19/09/25г.-20/10/25г.

Абонент: _____ Договор N: _____
Адрес: ул. Комсомольская 206 Тип расходомера: _____
Тепловычислитель ВКТ-7 сет. N 001 Пределы измерений: _____
Договорные расходы: G под max = 120.00 м3/ч G под min = 0.32 м3/ч
M сет. воды = _____ т.сут M ГВС = _____ т.сут G обр max = 120.00 м3/ч G обр min = 0.32 м3/ч
Тхв = 0.00 °C

Заводской номер 00121216 ВВОД 1 СХЕМА ПОДКЛЮЧЕНИЯ 3 БД 1 ФТ=0 ТЗ=0 КС=0хЕА7С ПО 2.7

Дата	t1	t2	dt	V1	M1	V2	M2	Mг	P1	P2	Qo	Qг	ВНР	ВОС	НС
	°C	°C	°C	м3	т	м3	т	т	кг/см2	кг/см2	Гкал	Гкал	ч	ч	
19/09/25	18.30	18.49	-0.19	0.00	0.00	0.00	0.00	0.00	16.00	6.70	0.000	0.000	24	0	*
20/09/25	18.26	18.42	-0.16	0.00	0.00	0.00	0.00	0.00	16.00	6.70	0.000	0.000	24	0	*
21/09/25	18.25	18.40	-0.15	0.00	0.00	0.00	0.00	0.00	16.00	6.70	0.000	0.000	24	0	*
22/09/25	18.37	18.48	-0.11	0.00	0.00	0.00	0.00	0.00	16.00	6.70	0.000	0.000	24	0	*
23/09/25	18.43	18.55	-0.12	0.00	0.00	0.00	0.00	0.00	16.00	6.70	0.000	0.000	24	0	*
24/09/25	18.57	18.67	-0.10	0.00	0.00	0.00	0.00	0.00	16.00	6.70	0.000	0.000	24	0	*
25/09/25	19.17	18.58	0.59	0.00	0.00	0.00	0.00	0.00	16.00	6.70	0.000	0.000	24	0	*
26/09/25	40.49	37.01	3.48	157.86	156.70	155.99	154.99	1.71	16.00	6.70	0.574	0.063	24	0	*
27/09/25	40.34	37.08	3.26	269.10	267.18	268.06	266.38	0.80	16.00	6.70	0.919	0.030	24	0	
28/09/25	40.52	37.01	3.51	267.79	265.86	266.64	264.96	0.90	16.00	6.70	0.982	0.033	24	0	
29/09/25	43.41	38.89	4.52	265.68	263.39	264.28	262.44	0.95	16.00	6.70	1.233	0.037	24	0	
30/09/25	47.64	42.12	5.52	265.30	262.65	263.50	261.34	1.31	16.00	6.70	1.494	0.055	24	0	
01/10/25	47.58	42.09	5.49	265.72	263.08	263.29	261.13	1.95	16.00	6.70	1.491	0.082	24	0	
02/10/25	47.64	42.16	5.48	265.41	262.77	262.61	260.45	2.32	16.00	6.70	1.482	0.098	24	0	
03/10/25	48.34	42.74	5.60	265.13	262.34	261.98	259.77	2.57	16.00	6.70	1.514	0.110	24	0	
04/10/25	48.33	42.70	5.63	264.79	261.92	261.46	259.30	2.62	16.00	6.70	1.517	0.112	24	0	
05/10/25	48.26	42.73	5.53	264.86	262.06	261.49	259.33	2.73	16.00	6.70	1.494	0.117	24	0	
06/10/25	47.29	42.08	5.21	264.00	261.33	260.78	258.64	2.69	16.00	6.70	1.409	0.113	24	0	
07/10/25	45.16	40.49	4.67	262.75	260.35	259.80	257.88	2.47	16.00	6.70	1.261	0.100	24	0	
08/10/25	45.26	40.61	4.65	262.70	260.30	259.78	257.86	2.44	16.00	6.70	1.255	0.099	24	0	
09/10/25	45.06	40.48	4.58	262.28	259.88	259.34	257.42	2.46	16.00	6.70	1.237	0.100	24	0	
10/10/25	44.87	40.36	4.51	262.26	259.90	259.38	257.44	2.46	16.00	6.70	1.221	0.099	24	0	
11/10/25	44.61	40.20	4.41	267.09	264.72	264.24	262.28	2.44	16.00	6.70	1.212	0.098	24	0	
12/10/25	45.24	40.59	4.65	267.47	265.03	264.54	262.57	2.46	16.00	6.70	1.278	0.100	24	0	
13/10/25	46.95	41.94	5.01	266.94	264.30	263.94	261.78	2.52	16.00	6.70	1.370	0.106	24	0	
14/10/25	46.54	41.72	4.82	266.77	264.19	263.78	261.65	2.54	16.00	6.70	1.322	0.106	24	0	
15/10/25	47.20	42.16	5.04	266.67	264.03	263.63	261.47	2.56	16.00	6.70	1.378	0.108	24	0	
16/10/25	47.04	41.95	5.09	266.40	263.76	263.22	261.06	2.70	16.00	6.70	1.386	0.113	24	0	
17/10/25	48.44	42.91	5.53	265.96	263.14	262.73	260.48	2.66	16.00	6.70	1.499	0.114	24	0	
18/10/25	51.00	44.89	6.11	265.42	262.35	262.18	259.69	2.66	16.00	6.70	1.648	0.119	24	0	
19/10/25	52.09	45.83	6.26	268.96	265.60	265.76	263.12	2.48	16.00	6.70	1.710	0.114	24	0	
20/10/25	50.81	44.94	5.87	269.09	265.97	265.95	263.43	2.54	16.00	6.70	1.605	0.114	24	0	
Итого:				6536.4	6472.80	6468.3	6416.86	55.94			33.491	2.340	768	0	
Средние:	40.29	36.41	3.88						16.00	6.70					

Период нормальной работы 768ч
Период отсутств.счета тепл.энергии 0ч
Время работы прибора после сброса 10801ч

представитель абонента

комсомольская 206
представитель теплоснабж.организации

ОТЧЕТ
о суточных параметрах теплоснабжения
19/09/25г.-20/10/25г.

Абонент: _____ Договор N: _____
 Адрес: Комсомольская 31 в ввод Тип расходомера: _____
 Тепловычислитель ВКТ-7 сет. N 001 Пределы измерений: _____
 Договорные расходы: G под max = 120.00 м3/ч G под min = 0.32
 м3/ч
 M сет. воды = _____ т.сут Mгвс = _____ т.сут G обр max = 120.00 м3/ч G обр min = 0.32
 м3/ч
 Tхв = 0.00 °C G3 max = 20.00 м3/ч G3 min = 0.20
 м3/ч

Заводской номер 00169027 ВВОД 1 СХЕМА ПОДКЛЮЧЕНИЯ 3 БД 1 ФТ=0 Т3=1 КС=
 0хС225 ПО 2.7

Дата	t1	t2	dt	V1	M1	V2	M2	V3	Mг	P1	P2	Qo
Qг	ВНР	ВОС	НС									

	°C	°C	°C	м3	т	м3	т	м3	т	кг/см2	кг/см2	
Гкал	Гкал	ч	ч									

19/09/25	16.21	15.95	0.26	45.34	45.34	17.42	17.42	0.00	27.92	1.00	1.01	
0.010	0.443	24	0	*								
20/09/25	16.16	15.92	0.24	52.51	52.51	9.10	9.10	0.00	43.41	1.00	1.01	
0.012	0.688	24	0	*								
21/09/25	16.13	15.84	0.29	59.88	59.88	6.08	6.08	0.00	53.80	1.00	1.01	
0.018	0.848	24	0	*								
22/09/25	16.46	16.17	0.29	69.11	69.11	0.00	0.00	0.00	69.11	1.00	1.01	
0.024	1.113	24	0	*								
23/09/25	16.55	16.25	0.30	70.39	70.39	0.00	0.00	0.00	70.39	1.00	1.01	
0.024	1.139	24	0	*								
24/09/25	16.85	16.47	0.38	62.78	62.78	0.00	0.00	0.00	62.78	1.00	1.01	
0.025	1.030	24	0	*								
25/09/25	17.37	38.46	-21.09	25.50	25.50	1.35	1.34	0.00	24.16	2.80	2.88	
0.015	0.928	24	0	*								
26/09/25	17.52	17.69	-0.17	0.00	0.00	0.00	0.00	0.00	0.00	3.93	4.07	
0.000	0.000	24	0	*								
27/09/25	18.10	19.62	-1.52	0.00	0.00	0.00	0.00	0.00	0.00	3.62	3.75	
0.000	0.000	24	0	*								
28/09/25	16.04	19.59	-3.55	3.20	3.20	8.01	8.01	0.00	-4.81	2.43	2.52	
0.000	-0.094	24	0	*								
29/09/25	43.64	36.17	7.47	104.80	103.95	114.24	113.40	0.00	-9.45	4.34	4.09	
0.636	-0.341	24	0	*								
30/09/25	47.48	39.71	7.77	175.28	173.74	174.75	173.06	0.00	0.68	6.31	5.91	
1.348	0.027	24	0	*								
01/10/25	47.43	39.17	8.26	182.37	180.77	182.32	180.61	0.00	0.16	6.35	5.94	
1.491	0.006	24	0	*								
02/10/25	47.49	39.34	8.15	181.82	180.31	182.19	180.31	0.00	0.00	6.34	5.93	
1.467	0.000	24	0	*								
03/10/25	48.18	40.03	8.15	182.39	180.92	182.94	180.92	0.00	0.00	6.36	5.94	
1.475	0.000	24	0	*								
04/10/25	48.19	40.04	8.15	181.08	179.62	181.67	179.62	0.00	0.00	6.43	6.01	
1.464	0.000	24	0	*								
05/10/25	48.12	40.11	8.01	180.66	179.23	181.24	179.23	0.00	0.00	6.45	6.02	
1.433	0.000	24	0	*								
06/10/25	47.19	39.63	7.56	180.70	179.34	181.33	179.34	0.00	0.00	6.43	5.99	
1.356	0.000	24	0	*								
07/10/25	45.06	38.29	6.77	180.49	179.34	181.20	179.34	0.00	0.00	6.47	6.02	
1.214	0.000	24	0	*								
08/10/25	45.15	38.46	6.69	180.17	179.05	180.94	179.05	0.00	0.00	6.46	6.01	

комсомольская 31 2ввод

ОТЧЕТ
о суточных параметрах теплоснабжения
19/09/25г.-20/10/25г.

Абонент: _____ Договор N: _____
Адрес: ул. Комсомольская 31 2ввод Тип расходомера: _____
Тепловычислитель ВКТ-7 сет. N 001 Пределы измерений: _____
Договорные расходи: G под max = 120.00 м3/ч G под min = 0.32 м3/ч
M сет. воды = _____ т.сут МГВС = _____ т.сут G обр max = 120.00 м3/ч G обр min = 0.32 м3/ч
Тхв = 0.00 °С G3 max = 20.00 м3/ч G3 min = 0.20 м3/ч

Заводской номер 00170304 ВВВОД 1 СХЕМА ПОДКЛЮЧЕНИЯ 3 БД 1 ФТ=0 Т3=1 КС=0х9В33 по 2.7

Дата	t1	t2	dt	V1	M1	V2	M2	V3	MГ	P1	P2	Qo	QГ	ВНР	ВОС	НС
	°С	°С	°С	м3	т	м3	т	м3	т	кг/см2	кг/см2	Гкал	Гкал	ч	ч	
19/09/25	16.45	16.21	0.24	0.00	0.00	0.00	0.00	0.00	0.00	2.81	2.81	0.000	0.000	24	0	*
20/09/25	16.47	16.21	0.26	0.00	0.00	0.00	0.00	0.00	0.00	2.82	2.82	0.000	0.000	24	0	*
21/09/25	16.45	16.18	0.27	0.00	0.00	0.00	0.00	0.00	0.00	2.82	2.83	0.000	0.000	24	0	*
22/09/25	16.65	16.42	0.23	0.00	0.00	0.00	0.00	0.00	0.00	2.82	2.83	0.000	0.000	24	0	*
23/09/25	16.73	16.54	0.19	0.00	0.00	0.00	0.00	0.00	0.00	2.83	2.83	0.000	0.000	24	0	*
24/09/25	16.93	16.67	0.26	0.00	0.00	0.00	0.00	0.00	0.00	2.83	2.83	0.000	0.000	24	0	*
25/09/25	17.37	33.87	-16.50	0.87	0.87	1.32	1.31	0.00	-0.44	3.10	3.10	0.000	-0.015	24	0	*
26/09/25	39.09	35.26	3.83	106.46	105.69	106.19	105.57	0.00	0.12	4.49	4.32	0.405	0.004	24	0	*
27/09/25	40.02	36.64	3.38	272.03	269.96	271.62	269.94	0.00	0.02	6.21	5.93	0.912	0.001	24	0	*
28/09/25	40.21	36.75	3.46	277.43	275.31	274.56	272.84	0.00	2.47	6.19	5.95	0.952	0.091	24	0	*
29/09/25	42.90	38.30	4.60	268.74	266.38	265.62	263.78	0.00	2.60	6.08	5.93	1.220	0.100	24	0	*
30/09/25	47.27	41.05	6.22	248.80	246.16	245.60	243.68	0.00	2.48	6.07	6.00	1.527	0.102	24	0	*
01/10/25	47.22	41.17	6.05	249.74	247.10	246.59	244.64	0.00	2.46	6.08	6.02	1.493	0.101	24	0	*
02/10/25	47.29	41.30	5.99	247.80	245.16	244.65	242.72	0.00	2.44	6.05	6.00	1.468	0.101	24	0	*
03/10/25	47.98	41.88	6.10	248.57	245.91	245.32	243.33	0.00	2.58	6.05	6.01	1.498	0.108	24	0	*
04/10/25	47.98	41.75	6.23	247.03	244.39	243.90	241.98	0.00	2.41	6.11	6.08	1.520	0.101	24	0	*
05/10/25	47.91	41.74	6.17	246.10	243.46	243.10	241.18	0.00	2.28	6.12	6.09	1.500	0.095	24	0	*
06/10/25	47.00	41.27	5.73	246.08	243.54	243.12	241.20	0.00	2.34	6.08	6.07	1.391	0.097	24	0	*
07/10/25	44.86	39.75	5.11	245.57	243.17	242.74	240.95	0.00	2.22	6.11	6.11	1.242	0.088	24	0	*
08/10/25	44.96	39.85	5.11	244.95	242.55	242.14	240.34	0.00	2.21	6.10	6.10	1.236	0.088	24	0	*
09/10/25	44.77	39.69	5.08	245.09	242.71	242.28	240.49	0.00	2.22	6.17	6.17	1.227	0.088	24	0	*
10/10/25	44.58	39.62	4.96	244.91	242.58	242.11	240.30	0.00	2.28	6.25	6.26	1.196	0.090	24	0	*
11/10/25	44.33	39.48	4.85	247.57	245.24	244.81	242.98	0.00	2.26	6.27	6.28	1.189	0.089	24	0	*
12/10/25	44.93	39.81	5.12	247.75	245.35	244.97	243.08	0.00	2.27	6.28	6.30	1.250	0.090	24	0	*
13/10/25	46.63	41.09	5.54	247.61	245.05	244.77	242.85	0.00	2.20	6.29	6.31	1.353	0.090	24	0	*
14/10/25	46.15	40.84	5.31	249.80	247.28	247.01	245.11	0.00	2.17	6.29	6.31	1.308	0.089	24	0	*
15/10/25	46.86	41.23	5.63	249.96	247.32	247.11	245.19	0.00	2.13	6.29	6.32	1.388	0.088	24	0	*
16/10/25	46.71	40.99	5.72	247.16	244.65	244.25	242.33	0.00	2.32	6.25	6.29	1.399	0.095	24	0	*
17/10/25	48.05	41.84	6.21	246.63	243.99	243.65	241.64	0.00	2.35	6.27	6.31	1.510	0.098	24	0	*
18/10/25	50.61	43.75	6.86	245.56	242.57	242.49	240.35	0.00	2.22	6.22	6.26	1.658	0.097	24	0	*
19/10/25	51.70	44.73	6.97	247.28	244.16	244.18	241.80	0.00	2.36	6.23	6.28	1.696	0.106	24	0	*
20/10/25	50.48	43.92	6.56	247.04	244.09	243.98	241.71	0.00	2.38	6.20	6.25	1.596	0.105	24	0	*
Итого:				6116.5	6054.64	6048.0	6001.29	0.00	53.35			33.134	2.187	768	0	
Средние:	39.61	35.80	3.80							5.39	5.37					

Период нормальной работы 768ч
Период отсутств.счета тепл.энергии 0ч
Время работы прибора после сброса 11882ч

представитель абонента

комсомольская 31 2ввод
представитель теплоснабж.организации

Кортунова 4

ОТЧЕТ
о суточных параметрах теплоснабжения
03/10/25г.-20/10/25г.

Абонент: _____ Договор N: _____
 Адрес: Кортунова 4 Тип расходомера: _____
 Тепловычислитель ВКТ-7 сет. N 001 Пределы измерений:
 Договорные расходы: G под max = 280.00 м3/ч G под min = 0.75 м3/ч
 M сет. воды = _____ т.сут M ГВС = _____ т.сут G обр max = 280.00 м3/ч G обр min = 0.75 м3/ч
 Тхв = 0.00 °C G3 max = 2.00 м3/ч G3 min = 1.00 м3/ч

Заводской номер 00182342 ВВОД 1 СХЕМА ПОДКЛЮЧЕНИЯ 1 БД 1 ФТ=1 ТЗ=1 КС=0xв6D1 ПО 2.7

Дата	t1	t2	dt	V1	M1	V2	M2	V3	Mг	P1	P2	Qo	Qг	ВНР	ВОС	НС
	°C	°C	°C	м3	т	м3	т	м3	т	кг/см2	кг/см2	Гкал	Гкал	ч	ч	
03/10/25	51.72	45.05	6.67	176.13	173.95	181.17	179.46	0.00	-5.51	16.77	-143.7	1.159	0.000	12	24	*
04/10/25	52.12	45.37	6.75	355.65	351.19	365.61	362.11	0.00	-10.92	8.52	8.42	2.367	0.000	24	0	*
05/10/25	48.95	42.81	6.14	331.58	327.88	342.21	339.28	0.00	-11.40	8.38	8.32	2.003	0.000	24	0	*
06/10/25	43.98	38.77	5.21	304.48	301.74	316.48	314.26	0.00	-12.52	8.19	8.17	1.566	0.000	24	0	*
07/10/25	42.93	38.03	4.90	316.02	313.32	328.18	325.94	0.00	-12.62	8.23	8.18	1.531	0.000	24	0	*
08/10/25	44.63	39.68	4.95	327.12	324.10	339.28	336.80	0.00	-12.70	8.29	8.24	1.599	0.000	24	0	*
09/10/25	44.01	39.21	4.80	326.48	323.52	338.63	336.23	0.00	-12.71	8.30	8.25	1.547	0.000	24	0	*
10/10/25	44.06	39.30	4.76	327.73	324.78	339.71	337.31	0.00	-12.53	8.23	8.17	1.542	0.000	24	0	*
11/10/25	44.06	39.26	4.80	329.51	326.53	341.51	339.11	0.00	-12.58	8.29	8.24	1.563	0.000	24	0	*
12/10/25	43.76	38.94	4.82	329.48	326.51	341.71	339.31	0.00	-12.80	8.29	8.24	1.570	0.000	24	0	*
13/10/25	43.55	38.72	4.83	329.11	326.20	341.51	339.11	0.00	-12.91	8.28	8.23	1.572	0.000	24	0	*
14/10/25	44.07	39.05	5.02	323.07	320.16	335.58	333.18	0.00	-13.02	8.21	8.16	1.604	0.000	24	0	*
15/10/25	44.77	39.43	5.34	320.45	317.46	332.94	330.54	0.00	-13.08	8.14	8.09	1.692	0.000	24	0	*
16/10/25	44.27	39.06	5.21	321.29	318.37	333.00	330.67	0.00	-12.30	8.78	8.74	1.656	0.000	24	0	*
17/10/25	43.96	38.69	5.27	314.84	312.06	323.44	321.22	0.00	-9.16	8.98	8.92	1.637	0.000	24	0	*
18/10/25	46.50	40.28	6.22	318.10	314.94	328.09	325.59	0.00	-10.65	8.84	8.79	1.954	0.000	24	0	*
19/10/25	49.14	42.37	6.77	316.46	312.90	327.33	324.59	0.00	-11.69	8.83	8.78	2.110	0.000	24	0	*
20/10/25	50.22	43.20	7.02	321.96	318.20	333.41	330.52	0.00	-12.32	8.88	8.81	2.231	0.000	24	0	*
Итого:				5689.4	5633.81	5889.7	5845.23	0.00	-211.42			30.903	0.000	420	24	
Средние:	45.92	40.40	5.52							8.91	-0.05					

Период нормальной работы 420ч
 Период отсутств.счета тепл.энергии 24ч
 Время работы прибора после сброса 434ч

Представитель абонента _____ Представитель теплоснабж.организации _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Куйбышева, 17
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00179040

БД=1, ТВ1, СИ=3, КТЗ=1, ФРТ=0, КСН=0хDCB4

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
20.09.25	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
21.09.25	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
22.09.25	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
23.09.25	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
24.09.25	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
25.09.25	-	-	-	-	-	-	-	-	-	-	-	-	-
26.09.25	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
27.09.25	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
28.09.25	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
29.09.25	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
30.09.25	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
01.10.25	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
02.10.25	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
03.10.25	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
04.10.25	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
05.10.25	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д	н/д
06.10.25	65.98	59.18	6.80	248.290	250.870	243.410	246.840	-3.430	161.25	19.41	1.6540	24.0	14.0
07.10.25	66.88	59.83	7.05	433.130	438.020	424.360	430.810	-6.450	6.20	6.00	2.9930	0.0	24.0
08.10.25	66.63	59.70	6.93	426.510	431.340	417.960	424.260	-6.300	6.20	6.00	2.8970	0.0	24.0
09.10.25	66.88	59.78	7.10	424.010	428.470	415.420	421.440	-6.020	6.20	6.00	2.9530	0.0	24.0
10.10.25	66.54	59.58	6.96	422.100	426.860	413.650	419.890	-6.240	6.20	6.00	2.8800	0.0	24.0
11.10.25	66.10	59.32	6.78	433.250	438.120	424.700	431.060	-6.360	6.20	6.00	2.8780	0.0	24.0
12.10.25	66.22	59.20	7.02	428.590	433.190	420.100	426.190	-6.090	6.20	6.00	2.9460	0.0	24.0
13.10.25	67.36	60.15	7.21	428.250	432.640	419.510	425.430	-5.920	6.20	6.00	3.0230	0.0	24.0
14.10.25	66.20	59.06	7.14	422.800	427.490	414.440	420.600	-6.160	6.20	6.00	2.9600	0.0	24.0
15.10.25	66.76	59.12	7.64	410.110	414.280	401.840	407.600	-5.760	6.20	6.00	3.0700	0.0	24.0
16.10.25	66.65	58.63	8.02	392.670	397.560	384.790	391.240	-6.450	6.20	6.00	3.0830	0.0	24.0
17.10.25	66.45	58.49	7.96	393.520	399.420	385.680	393.090	-7.410	6.20	6.00	3.0690	0.0	24.0
18.10.25	66.79	58.41	8.38	375.360	380.220	367.780	374.230	-6.450	6.20	6.00	3.0830	0.0	24.0
19.10.25	67.16	59.08	8.08	388.860	394.500	380.920	388.190	-7.270	6.20	6.00	3.0780	0.0	24.0
20.10.25	66.57	58.38	8.19	372.450	377.930	364.980	371.990	-7.010	6.20	6.00	2.9890	0.0	24.0
Итого	---	---	---	5999.8	6070.9	5879.54	5972.86	-93.320	---	---	43.5560	24.0	350.0
Среднее	66.61	59.19	7.41	---	---	---	---	---	16.54	6.89	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
04.10.25 24:00	0.000	0.000	0.000	0.000	0.0000	0.000	0.0	0.0
20.10.25 24:00	5999.899	6070.910	5879.540	5972.860	43.5560	-93.320	24.0	350.0
Итого за период	5999.899	6070.910	5879.540	5972.860	43.5560	---	24.0	350.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ТС1 Пульсар ДУ-40,
с 19.09.25 по 20.10.25**

Объект:

г. Октябрьский, Ленина , 21

Потребитель:

АО "Жилуправление"

Прибор

405 Заводской номер: 2816575

ТВ1

Дата	V	T1	T2	Q	Время раб. (ч)
19.09.2025	77094,898	16,42	16,22	762,8179	24
20.09.2025	77094,898	16,36	16,2	762,8179	24
21.09.2025	77094,898	16,31	16,18	762,8179	24
22.09.2025	77094,898	16,29	16,15	762,8179	24
23.09.2025	77094,898	16,38	16,23	762,8179	24
24.09.2025	77094,898	16,47	16,28	762,8179	24
25.09.2025	77094,898	16,78	16,45	762,8179	24
26.09.2025	77094,899	16,7	16,36	762,8179	24
27.09.2025	77123,39	45,93	23,53	762,9884	24
28.09.2025	77203,531	44,47	39,05	763,4185	24
29.09.2025	77299,351	43,75	38,96	763,8376	24
30.09.2025	77370,296	43,4	37,94	764,2443	24
01.10.2025	77425,835	44,94	37,27	764,6654	24
02.10.2025	77480,531	46,85	38,46	765,1187	24
03.10.2025	77539,031	48,78	40,1	765,6013	24
04.10.2025	77609,69	47,65	40,79	766,0818	24
05.10.2025	77680,851	47,53	40,76	766,5562	24
06.10.2025	77751,734	47,69	40,97	767,0264	24
07.10.2025	77822,46	45,91	39,8	767,4542	24
08.10.2025	77890,367	45,05	39,08	767,8558	24
09.10.2025	77956,132	45,1	39,09	768,252	24
10.10.2025	78021,585	44,77	38,8	768,6386	24
11.10.2025	78086,734	43,99	38,24	769,0093	24
12.10.2025	78151,64	43,19	37,71	769,3611	24
13.10.2025	78216,484	43,63	37,93	769,7272	24
14.10.2025	78281,312	43,63	37,92	770,0939	24
15.10.2025	78345,601	45,59	39,27	770,4957	24
16.10.2025	78412,75	46,37	40,01	770,9171	24
17.10.2025	78485,679	46,43	40,38	771,3533	24
18.10.2025	78560,273	48,89	42,14	771,8507	24
19.10.2025	78635,179	51,96	44,24	772,4077	24
20.10.2025	78710,148	52,19	44,62	772,9676	24
Итого	1615,25	---	---	10,1497	768
Среднее		38,73	33,35	---	---

Представитель абонента _____ / _____

Представитель поставщика _____ / _____

**ИМ2300, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, проспект Ленина, 41
Потребитель: АО "Жилуправление"
Прибор: ИМ2300 Заводской номер: BA871

ТВ1

Дата	Qt1, Гкал	T1, °C	Gm1, т	T2, °C	Gm2, т	tm1, ч	ts1, ч	Qt3 (Гкал)	dGm3 (тонн)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-
28.09.25	-	-	-	-	-	-	-	-	-
29.09.25	-	-	-	-	-	-	-	-	-
30.09.25	-	-	-	-	-	-	-	-	-
01.10.25	-	-	-	-	-	-	-	-	-
02.10.25	-	-	-	-	-	-	-	-	-
03.10.25	-	-	-	-	-	-	-	-	-
04.10.25	-	-	-	-	-	-	-	-	-
05.10.25	-	-	-	-	-	-	-	-	-
06.10.25	-	-	-	-	-	-	-	-	-
07.10.25	-	-	-	-	-	-	-	-	-
08.10.25	-	-	-	-	-	-	-	-	-
09.10.25	-	-	-	-	-	-	-	-	-
10.10.25	-	-	-	-	-	-	-	-	-
11.10.25	-	-	-	-	-	-	-	-	-
12.10.25	-	-	-	-	-	-	-	-	-
13.10.25	-	-	-	-	-	-	-	-	-
14.10.25	-	-	-	-	-	-	-	-	-
15.10.25	-	-	-	-	-	-	-	-	-
16.10.25	1.48	66.34	131.64	54.93	284.60	24.00	24.00	0.00	0.00
17.10.25	4.83	66.03	409.11	54.20	233.69	23.71	23.71	0.00	0.00
18.10.25	4.83	65.73	407.49	53.87	397.07	24.00	24.00	0.00	0.00
19.10.25	4.93	66.06	401.85	53.77	391.10	24.00	24.00	0.00	0.00
20.10.25	4.91	66.43	401.45	54.19	390.37	24.00	24.00	0.00	0.00
Итого	20.98	---	1751.54	---	1696.83	119.71	119.71	0.00	0.00
Среднее	---	66.118	---	54.192	---	---	---	---	---

Показания интеграторов

Дата	Qt1 итог, Гкал	Qt3 итог, Гкал
18.09.25 24:00	н/д	н/д
20.10.25 24:00	13586.96	0.00
Итого за период	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____

ОТЧЕТ
о суточных параметрах теплоснабжения
26/09/25г.-20/10/25г.

Абонент: _____ Договор N: _____
Адрес: пр. Ленина 51 Тип расходомера: _____
Тепловычислитель ВКТ-7 сет. N 001 Пределы измерений: _____
Договорные расходи: G под max = 2.00 м3/ч G под min = 1.00 м3/ч
M сет. воды = _____ т.сут MГВС = _____ т.сут G обр max = 2.00 м3/ч G обр min = 1.00 м3/ч
Тхв = 0.00 °C G3 max = 2.00 м3/ч G3 min = 1.00 м3/ч

Заводской номер 00179189 ВВОД 1 СХЕМА ПОДКЛЮЧЕНИЯ 1 БД 1 ФТ=0 Т3=1 КС=0x4B8E по 2.7

Дата	t1	t2	dt	V1	M1	V2	M2	V3	MГ	P1	P2	Qo	QГ	ВНР	ВОС	НС
	°C	°C	°C	м3	т	м3	т	м3	т	кг/см2	кг/см2	Гкал	Гкал	ч	ч	
26/09/25	56.10	49.02	7.08	161.60	160.03	110.57	109.55	0.00	50.48	-233.4	-197.0	0.627	2.935	37	0	*
27/09/25	57.02	49.90	7.12	245.38	241.67	241.95	239.14	0.00	2.53	7.00	7.00	1.714	0.126	24	0	*
28/09/25	57.35	49.66	7.69	238.29	234.69	237.96	235.24	0.00	-0.55	7.00	7.00	1.803	-0.027	24	0	*
29/09/25	56.11	47.96	8.15	239.16	235.68	237.97	235.43	0.00	0.25	7.00	7.00	1.915	0.012	24	0	*
30/09/25	54.35	46.55	7.80	231.34	228.17	231.53	229.18	0.00	-1.01	7.00	7.00	1.778	-0.047	24	0	*
01/10/25	54.75	46.76	7.99	234.55	231.28	231.31	228.93	0.00	2.35	7.00	7.00	1.853	0.110	24	0	*
02/10/25	56.33	48.01	8.32	242.53	238.93	240.66	238.03	0.00	0.90	7.00	7.00	1.987	0.043	24	0	*
03/10/25	57.98	49.29	8.69	244.95	241.19	240.45	237.72	0.00	3.47	7.00	7.00	2.096	0.171	24	0	*
04/10/25	58.65	49.81	8.84	244.72	240.87	240.55	237.73	0.00	3.14	7.00	7.00	2.127	0.157	24	0	*
05/10/25	57.89	49.36	8.53	243.56	239.76	238.60	235.94	0.00	3.82	7.00	7.00	2.044	0.189	24	0	*
06/10/25	57.47	49.08	8.39	241.77	238.08	236.57	233.93	0.00	4.15	7.00	7.00	1.996	0.204	24	0	*
07/10/25	57.15	49.38	7.77	259.97	256.07	253.88	250.99	0.00	5.08	7.00	7.00	1.985	0.251	24	0	*
08/10/25	54.21	47.54	6.67	265.87	262.26	263.00	260.19	0.00	2.07	7.00	7.00	1.746	0.099	24	0	*
09/10/25	47.71	41.84	5.87	203.12	200.97	200.81	199.13	0.00	1.84	7.00	7.00	1.176	0.077	24	0	*
10/10/25	42.46	37.21	5.25	175.13	173.69	173.44	172.29	0.00	1.40	7.00	7.00	0.907	0.052	24	0	*
11/10/25	43.07	37.13	5.94	156.63	155.31	153.55	152.53	0.01	2.78	7.00	7.00	0.918	0.104	24	0	*
12/10/25	47.36	40.81	6.55	198.27	196.21	194.79	193.22	0.06	2.99	7.00	7.00	1.272	0.122	24	0	*
13/10/25	51.86	44.72	7.14	184.09	181.73	181.54	179.80	3.74	1.93	7.00	7.00	1.321	0.087	24	0	*
14/10/25	46.44	37.93	8.51	125.36	124.08	122.78	121.96	0.00	2.12	7.00	7.00	1.058	0.081	24	0	*
15/10/25	48.07	39.01	9.06	130.16	128.72	127.79	126.85	0.00	1.87	7.00	7.00	1.161	0.073	24	0	*
16/10/25	47.69	38.61	9.08	130.23	128.79	126.27	125.36	0.00	3.43	7.00	7.00	1.170	0.133	24	0	*
17/10/25	47.37	38.36	9.01	129.91	128.47	127.38	126.46	0.00	2.01	7.00	7.00	1.153	0.077	24	0	*
18/10/25	47.17	38.10	9.07	128.73	127.31	127.79	126.88	0.00	0.43	7.00	7.00	1.152	0.016	24	0	*
19/10/25	47.46	38.28	9.18	129.10	127.68	124.58	123.70	0.00	3.98	7.00	7.00	1.170	0.153	24	0	*
20/10/25	47.20	38.16	9.04	129.44	128.05	125.91	125.04	0.00	3.01	7.00	7.00	1.157	0.115	24	0	*
Итого:				4913.8	4849.69	4791.6	4745.22	3.81	104.47			37.286	5.313	613	0	
Средние:	51.96	44.09	7.86							-2.61	-1.16					

Период нормальной работы 613ч
Период отсутств.счета тепл.энергии 0ч
Время работы прибора после сброса 627ч

Представитель абонента _____ Представитель теплоснабж.организации _____

Отчет о потреблении...
от 21-10-2025
За период с 19-09-2025 00:00:00 по 21-10-2025 00:00:00

Адрес :
Прибор :
Назначение :

Ленина 77
ИМ 2300 N BV582
Теплосчетчик с ЧД расхода для ЗСТ.

Канал	Qt1	T1	Gm1	T2	Gm2	tm1	ts1
Един.измерения.	Гкал	град.С	тонн	град.С	тонн	час:мин	час:мин
Макс.предел	1000000	150	1000000	150	1000000	1000000	1000000
Миним.предел	0	0	0	0	0	0	0

Отчетные данные поинтервально (за 1 сут.)

Дата, время							
19-09-2025 00:00:00	-	-	-	-	-	-	-
20-09-2025 00:00:00	0.00	20.16	0.00	21.62	0.00	0:00	24:00
21-09-2025 00:00:00	0.00	20.17	0.00	21.61	0.00	0:00	24:00
22-09-2025 00:00:00	0.00	20.20	0.00	21.63	0.00	0:00	24:00
23-09-2025 00:00:00	0.00	20.32	0.00	21.76	0.00	0:00	24:00
24-09-2025 00:00:00	0.00	20.71	0.00	22.19	0.00	0:00	24:00
25-09-2025 00:00:00	0.00	21.13	0.00	22.63	0.00	0:00	24:00
26-09-2025 00:00:00	0.10	28.42	21.82	27.87	6.64	7:59	24:00
27-09-2025 00:00:00	0.55	46.01	99.41	40.74	30.54	24:00	24:00
28-09-2025 00:00:00	0.88	48.61	127.98	41.72	39.42	24:00	24:00
29-09-2025 00:00:00	0.89	49.02	124.96	41.87	38.60	24:00	24:00
30-09-2025 00:00:00	1.03	48.75	130.53	40.86	40.63	24:00	24:00
01-10-2025 00:00:00	1.19	49.59	136.81	40.86	42.71	24:00	24:00
02-10-2025 00:00:00	1.33	51.97	144.59	42.93	44.96	24:00	24:00
03-10-2025 00:00:00	1.08	49.06	110.20	39.27	34.49	24:00	24:00
09-10-2025 00:00:00	1.06	48.16	219.78	42.01	67.58	22:37	22:37
10-10-2025 00:00:00	1.07	46.04	272.75	42.03	83.78	24:00	24:00
11-10-2025 00:00:00	1.02	46.18	212.36	41.36	65.53	24:00	24:00
12-10-2025 00:00:00	0.98	48.32	183.13	40.49	56.26	24:00	24:00
13-10-2025 00:00:00	1.01	45.76	211.31	40.96	65.48	24:00	24:00
14-10-2025 00:00:00	1.00	45.52	210.88	40.75	65.35	24:00	24:00
15-10-2025 00:00:00	1.10	47.20	215.47	42.11	66.71	24:00	24:00
16-10-2025 00:00:00	1.18	48.62	219.32	43.24	68.01	24:00	24:00
17-10-2025 00:00:00	1.22	49.10	221.03	43.58	68.57	24:00	24:00
18-10-2025 00:00:00	1.23	49.50	221.58	43.92	68.67	24:00	24:00
19-10-2025 00:00:00	1.20	49.27	219.86	43.81	68.08	24:00	24:00
20-10-2025 00:00:00	1.19	48.46	219.37	43.04	67.92	24:00	24:00
21-10-2025 00:00:00	1.23	49.19	220.98	43.64	68.57	24:00	24:00

Итого за отчетный период:

часов:минут	Гкал	град.С	тонн	град.С	тонн	час:мин	час:мин
768:00	21.53	41.30	3744.12	36.97	1158.51	486:36	646:37

Отв. лицо :

ОТЧЕТ
о суточных параметрах теплоснабжения
за 06/10/25г.-20/10/25г.

Абонент: Садовое кольцо 31

Адрес: г. Октябрьский, ул. Садовое кольцо д.31

Договор N: 000000000

Тип расходомера: _____

Тепловычислитель ТВ7-04.1М сет.N 001

Пределы измерений:

Договорные расходы:

G1 max = 30.00 м3/ч G1 min = 0.00 м3/ч

М сет. воды = _____ т.сут Мгвс = _____ т.сут

G2 max = 30.00 м3/ч G2 min = 0.00 м3/ч

тхв: не исп.

Серийный номер 20120695, ВД=1, ТВ1, СИ=6, КТ3=0, ФРТ=0 КСН=0хССАД

Дата/время	t1 °C	t2 °C	dt °C	P1 кгс/см2	P2 кгс/см2	V1 м3	V2 м3	M1 т	M2 т	dM т	Qтв Гкал	ВНР ч	ВОС ч	НС
06.10.25 23	45.29	40.22	5.07	4.63	4.66	25.625	24.919	25.383	24.738	0.645	0.129	12	0	
07.10.25 23	44.07	39.33	4.75	4.64	4.67	51.971	50.578	51.509	50.226	1.284	0.245	24	0	
08.10.25 23	44.16	39.35	4.81	4.62	4.65	51.978	50.622	51.512	50.270	1.242	0.248	24	0	
09.10.25 23	43.97	39.12	4.86	4.69	4.72	51.906	50.568	51.447	50.221	1.227	0.250	24	0	
10.10.25 23	43.79	39.13	4.65	4.77	4.80	52.096	50.778	51.637	50.429	1.208	0.241	24	0	
11.10.25 23	43.54	39.03	4.51	4.79	4.82	52.677	51.361	52.224	51.013	1.210	0.236	24	0	
12.10.25 23	44.14	39.24	4.90	4.81	4.83	52.680	51.377	52.213	51.023	1.190	0.256	24	0	
13.10.25 23	45.80	40.53	5.27	4.82	4.84	52.745	51.426	52.239	51.046	1.192	0.276	24	0	
14.10.25 23	45.38	40.37	5.01	4.81	4.84	52.837	51.520	52.338	51.140	1.198	0.263	24	0	
15.10.25 23	46.03	40.68	5.34	4.82	4.84	52.772	51.443	52.258	51.059	1.199	0.280	24	0	
16.10.25 23	45.89	40.47	5.42	4.78	4.81	52.720	51.358	52.207	50.975	1.232	0.284	24	0	
17.10.25 23	47.20	41.32	5.87	4.80	4.83	52.367	50.985	51.827	50.587	1.241	0.305	24	0	
18.10.25 23	49.71	43.19	6.52	4.76	4.78	52.057	50.661	51.459	50.229	1.231	0.336	24	0	
19.10.25 23	50.78	44.20	6.58	4.77	4.80	52.842	51.433	52.212	50.969	1.243	0.344	24	0	
20.10.25 23	49.58	43.30	6.28	4.73	4.76	52.763	51.380	52.164	50.939	1.225	0.328	24	0	
Итого/Средн	45.98	40.65	5.33	4.75	4.78	760.036	740.409	752.630	734.863	17.767	4.021	348	0	

Итоговое потребление на начало и конец периода:

Дата/время	V1 м3	V2 м3	M1 т	M2 т	dM т	Qтв Гкал	ВНР ч	ВОС ч
06.10.25 11	0.000	0.000	0.000	0.000	0.000	0.000	0	0
20.10.25 23	760.036	740.409	752.630	734.863	17.767	4.021	348	0
Итого	760.036	740.409	752.630	734.863	17.767	4.021	348	0

Условные обозначения:

(<) параметр < min
(>) параметр > max
(!) отсут. питания
(#) дисбаланс масс
(R) реверс
(o) отсут. теплонос.
(X) аппар. неиспр.

Представитель абонента _____ Представитель снабжающей организации _____

**ВКТ-7 ТС1, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Садовое кольцо, 59
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00179099

БД=1, ТВ1, СИ=3, КТЗ=0, ФРТ=0, КСН=0х60Е1

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	51.90	19.51	32.39	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
20.09.25	51.38	19.06	32.32	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
21.09.25	51.73	19.19	32.54	0.000	0.000	0.000	0.000	0.000	6.90	6.70	0.0000	0.0	24.0
22.09.25	49.47	19.80	29.67	0.480	0.480	0.470	0.480	-0.010	6.90	6.70	0.0140	0.0	24.0
23.09.25	40.76	19.91	20.85	0.960	0.000	0.960	0.000	0.960	6.90	6.70	0.0190	0.0	24.0
24.09.25	31.85	19.35	12.50	0.960	0.000	0.960	0.000	0.960	6.90	6.70	0.0120	0.0	24.0
25.09.25	32.55	18.67	13.88	5.280	0.000	5.280	0.000	5.280	6.90	6.70	0.0730	0.0	24.0
26.09.25	50.92	18.19	32.73	3.360	0.000	3.290	0.000	3.290	6.90	6.70	0.1070	0.0	24.0
27.09.25	62.96	56.79	6.17	471.240	467.430	462.730	460.490	2.240	6.90	6.70	2.8540	0.0	24.0
28.09.25	66.14	56.71	9.43	342.230	336.900	335.480	331.930	3.550	6.90	6.70	3.1610	0.0	24.0
29.09.25	65.90	56.83	9.07	347.960	344.100	341.110	339.000	2.110	6.90	6.70	3.0950	0.0	24.0
30.09.25	66.58	56.79	9.79	322.720	320.080	316.280	315.300	0.980	6.90	6.70	3.0950	0.0	24.0
01.10.25	63.23	54.63	8.60	332.860	331.540	326.800	326.940	-0.140	6.90	6.70	2.8110	0.0	24.0
02.10.25	66.59	57.53	9.06	337.330	335.590	330.560	330.490	0.070	6.90	6.70	2.9940	0.0	24.0
03.10.25	66.52	57.71	8.81	344.680	340.910	337.830	335.680	2.150	6.90	6.70	2.9760	0.0	24.0
04.10.25	67.76	58.84	8.92	348.260	343.650	341.080	338.160	2.920	6.90	6.70	3.0410	0.0	24.0
05.10.25	66.76	58.24	8.52	348.380	343.770	341.400	338.410	2.990	6.90	6.70	2.9090	0.0	24.0
06.10.25	66.07	57.59	8.48	490.970	484.770	481.290	477.400	3.890	6.90	6.70	4.0800	0.0	0.0
07.10.25	66.68	57.54	9.14	313.510	308.960	307.250	304.230	3.020	6.90	6.70	2.8090	0.0	24.0
08.10.25	66.41	57.54	8.87	311.270	306.630	305.060	301.950	3.110	6.90	6.70	2.7020	0.0	24.0
09.10.25	66.63	57.79	8.84	313.930	309.440	307.650	304.690	2.960	6.90	6.70	2.7200	0.0	24.0
10.10.25	66.33	57.49	8.84	306.400	301.930	300.300	297.300	3.000	6.90	6.70	2.6550	0.0	24.0
11.10.25	65.90	57.35	8.55	312.640	308.060	306.510	303.370	3.140	6.90	6.70	2.6230	0.0	24.0
12.10.25	66.02	57.20	8.82	309.080	304.310	303.000	299.710	3.290	6.90	6.70	2.6740	0.0	24.0
13.10.25	67.15	57.95	9.20	308.070	303.670	301.770	298.980	2.790	6.90	6.70	2.7740	0.0	24.0
14.10.25	66.00	56.94	9.06	300.800	296.300	294.860	291.830	3.030	6.90	6.70	2.6710	0.0	24.0
15.10.25	66.55	56.99	9.56	289.950	285.350	284.190	281.080	3.110	6.90	6.70	2.7150	0.0	24.0
16.10.25	66.43	56.55	9.88	284.040	279.490	278.390	275.390	3.000	6.90	6.70	2.7490	0.0	24.0
17.10.25	66.25	56.79	9.46	299.210	294.440	293.280	290.080	3.200	6.90	6.70	2.7760	0.0	24.0
18.10.25	66.59	56.50	10.09	283.360	278.580	277.650	274.510	3.140	6.90	6.70	2.8020	0.0	24.0
19.10.25	66.96	57.25	9.71	295.660	291.030	289.660	286.640	3.020	6.90	6.70	2.8130	0.0	24.0
20.10.25	66.37	56.45	9.92	281.000	276.440	275.400	272.410	2.990	6.90	6.70	2.7290	0.0	24.0
Итого	---	---	---	7906.5	7793.8	7750.49	7676.45	74.040	---	---	69.4530	0.0	744.0
Среднее	60.91	47.67	13.23	---	---	---	---	---	6.90	6.70	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	M1, (т)	M2, (т)	Qo, (Гкал)	Mг, (т)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	0.000	0.000	0.000	0.000	0.0000	0.000	0.0	552.0
20.10.25 24:00	7898.910	7793.370	7742.819	7675.969	69.3350	66.850	0.0	576.0
Итого за период	7898.910	7793.370	7742.819	7675.969	69.3350	---	0.0	24.0

Представитель абонента _____ / _____ Представитель поставщика _____ / _____

**ВКТ-7 ТС2, Суточный
с 19.09.25 по 20.10.25**

Объект: г. Октябрьский, Садовое кольцо, 59
Потребитель: АО "Жилуправление"
Прибор: ВКТ-7 Заводской номер: 00179099

БД=1, ТВ2, СИ=3, КТЗ=0, ФРТ=0, КСН=0x60E1

Дата	t1, (°C)	t2, (°C)	dt, (°C)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	Mг, (т)	P1, (кг/см2)	P2, (кг/см2)	Qo, (Гкал)	Qг, (Гкал)	ВОС, (ч)	ВНР, (ч)
19.09.25	17.64	18.76	-1.12	0.000	0.000	н/д	0.000	0.000	0.000	6.90	6.70	0.0000	н/д	0.0	24.0
20.09.25	17.64	18.80	-1.16	0.000	0.000	н/д	0.000	0.000	0.000	6.90	6.70	0.0000	н/д	0.0	24.0
21.09.25	17.69	18.88	-1.19	0.000	0.000	н/д	0.000	0.000	0.000	6.90	6.70	0.0000	н/д	0.0	24.0
22.09.25	18.23	19.69	-1.46	0.480	10.230	н/д	0.480	10.220	-9.740	6.90	6.70	0.0000	н/д	0.0	24.0
23.09.25	17.92	19.45	-1.53	0.000	280.830	н/д	0.000	280.470	-280.470	6.90	6.70	0.0000	н/д	0.0	24.0
24.09.25	17.89	19.14	-1.25	0.000	228.650	н/д	0.000	228.360	-228.360	6.90	6.70	0.0000	н/д	0.0	24.0
25.09.25	17.64	18.37	-0.73	0.000	223.490	н/д	0.000	223.240	-223.240	6.90	6.70	0.0000	н/д	0.0	24.0
26.09.25	19.38	17.78	1.60	0.000	393.370	н/д	0.000	392.960	-392.960	6.90	6.70	0.0000	н/д	0.0	24.0
27.09.25	62.98	22.67	40.31	644.280	339.050	н/д	632.630	338.070	294.560	6.90	6.70	2.9750	н/д	0.0	24.0
28.09.25	66.13	61.00	5.13	540.590	5.040	н/д	529.890	4.940	524.950	6.90	6.70	3.2190	н/д	0.0	24.0
29.09.25	65.90	60.62	5.28	546.530	0.480	н/д	535.810	0.470	535.340	6.90	6.70	3.1070	н/д	0.0	24.0
30.09.25	66.58	59.46	7.12	513.610	0.480	н/д	503.320	0.470	502.850	6.90	6.70	3.1660	н/д	0.0	24.0
01.10.25	63.22	57.73	5.49	533.570	0.000	н/д	523.870	0.000	523.870	6.90	6.70	2.8830	н/д	0.0	24.0
02.10.25	66.59	60.75	5.84	539.980	0.000	н/д	529.170	0.000	529.170	6.90	6.70	3.0940	н/д	0.0	24.0
03.10.25	66.51	60.76	5.75	543.530	0.000	н/д	532.640	0.000	532.640	6.90	6.70	3.0620	н/д	0.0	24.0
04.10.25	67.75	61.84	5.91	547.820	0.000	н/д	536.510	0.000	536.510	6.90	6.70	3.1750	н/д	0.0	24.0
05.10.25	66.75	61.06	5.69	550.210	0.000	н/д	539.170	0.000	539.170	6.90	6.70	3.0730	н/д	0.0	24.0
06.10.25	66.06	60.43	5.63	772.690	0.000	н/д	757.480	0.000	757.480	6.90	6.70	4.2490	н/д	0.0	0.0
07.10.25	66.66	60.68	5.98	496.390	0.000	н/д	486.410	0.000	486.410	6.90	6.70	2.9120	н/д	0.0	24.0
08.10.25	66.58	56.93	9.65	381.290	160.850	н/д	373.620	158.430	215.190	6.90	6.70	2.7120	н/д	0.0	24.0
09.10.25	66.25	59.16	7.09	288.270	280.280	н/д	282.540	275.760	6.780	6.90	6.70	2.0350	н/д	0.0	24.0
10.10.25	66.33	60.65	5.68	475.830	470.120	н/д	466.380	462.210	4.170	6.90	6.70	2.6490	н/д	0.0	24.0
11.10.25	65.90	60.28	5.62	493.780	486.970	н/д	484.110	478.870	5.240	6.90	6.70	2.7240	н/д	0.0	24.0
12.10.25	66.02	60.25	5.77	487.910	480.830	н/д	478.300	472.850	5.450	6.90	6.70	2.7570	н/д	0.0	24.0
13.10.25	67.14	61.22	5.92	487.590	480.650	н/д	477.700	472.420	5.280	6.90	6.70	2.8280	н/д	0.0	24.0
14.10.25	65.99	60.21	5.78	476.700	469.800	н/д	467.310	462.000	5.310	6.90	6.70	2.6970	н/д	0.0	24.0
15.10.25	66.54	60.34	6.20	459.510	452.810	н/д	450.330	445.270	5.060	6.90	6.70	2.7940	н/д	0.0	24.0
16.10.25	66.42	59.99	6.43	451.850	445.210	н/д	442.840	437.880	4.960	6.90	6.70	2.8500	н/д	0.0	24.0
17.10.25	66.25	60.21	6.04	477.850	470.890	н/д	468.390	463.070	5.320	6.90	6.70	2.8280	н/д	0.0	24.0
18.10.25	66.59	60.19	6.40	451.600	444.870	н/д	442.580	437.480	5.100	6.90	6.70	2.8320	н/д	0.0	24.0
19.10.25	66.96	60.80	6.16	470.870	464.000	н/д	461.360	456.150	5.210	6.90	6.70	2.8390	н/д	0.0	24.0
20.10.25	66.36	60.00	6.36	447.000	440.440	н/д	438.120	433.190	4.930	6.90	6.70	2.7890	н/д	0.0	24.0
Итого	---	---	---	12079.730	7029.340	---	11840.960	6934.780	4906.180	---	---	70.249	---	0.0	744.0
Среднее	54.14	48.69	5.45	---	---	---	---	---	---	6.90	6.70	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	Mг, (т)	Qo, (Гкал)	Qг, (Гкал)	ВОС, (ч)	ВНР, (ч)
18.09.25 24:00	0.000	0.000	н/д	0.000	0.000	0.000	0.0000	н/д	0.0	552.0
20.10.25 24:00	12079.250	6286.140	н/д	11840.480	6192.490	5647.990	70.2490	н/д	0.0	576.0
Итого за период	12079.250	6286.140	н/д	11840.480	6192.490	---	70.2490	н/д	0.0	24.0

Представитель абонента _____/_____ Представитель поставщика _____/_____

19/09/25	17.64	18.76	-1.12	0.00	0.00	0.00	0.00	0.00	0.00	6.90	6.70	0.000	
0.000	24	0	*										
20/09/25	17.64	18.80	-1.16	0.00	0.00	0.00	0.00	0.00	0.00	6.90	6.70	0.000	
0.000	24	0	*										
21/09/25	17.69	18.88	-1.19	0.00	0.00	0.00	0.00	0.00	0.00	6.90	6.70	0.000	
0.000	24	0	*										
22/09/25	18.23	19.69	-1.46	0.48	0.48	10.23	10.22	-9.74		6.90	6.70	0.000	-
0.192	24	0	*										
23/09/25	17.92	19.45	-1.53	0.00	0.00	280.83	280.47	-280.47		6.90	6.70	0.000	-
5.467	24	0	*										
24/09/25	17.89	19.14	-1.25	0.00	0.00	228.65	228.36	-228.36		6.90	6.70	0.000	-
4.381	24	0	*										
25/09/25	17.64	18.37	-0.73	0.00	0.00	223.49	223.24	-223.24		6.90	6.70	0.000	-
4.111	24	0	*										
26/09/25	19.38	17.78	1.60	0.00	0.00	393.37	392.96	-392.96		6.90	6.70	0.000	-
7.004	24	0	*										
27/09/25	62.98	22.67	40.31	644.28	632.63	339.05	338.07	294.56		6.90	6.70	2.975	
6.689	24	0	*										
28/09/25	66.13	61.00	5.13	540.59	529.89	5.04	4.94	524.95		6.90	6.70	3.219	
32.005	24	0	*										
29/09/25	65.90	60.62	5.28	546.53	535.81	0.48	0.47	535.34		6.90	6.70	3.107	
32.436	24	0	*										
30/09/25	66.58	59.46	7.12	513.61	503.32	0.48	0.47	502.85		6.90	6.70	3.166	
29.884	24	0	*										
01/10/25	63.22	57.73	5.49	533.57	523.87	0.00	0.00	523.87		6.90	6.70	2.883	
30.228	24	0	*										
02/10/25	66.59	60.75	5.84	539.98	529.17	0.00	0.00	529.17		6.90	6.70	3.094	
32.130	24	0	*										
03/10/25	66.51	60.76	5.75	543.53	532.64	0.00	0.00	532.64		6.90	6.70	3.062	
32.346	24	0	*										
04/10/25	67.75	61.84	5.91	547.82	536.51	0.00	0.00	536.51		6.90	6.70	3.175	
33.160	24	0	*										
05/10/25	66.75	61.06	5.69	550.21	539.17	0.00	0.00	539.17		6.90	6.70	3.073	
32.905	24	0	*										
06/10/25	66.06	60.43	5.63	772.69	757.48	0.00	0.00	757.48		6.90	6.70	4.249	
45.751	35	0	*										
07/10/25	66.66	60.68	5.98	496.39	486.41	0.00	0.00	486.41		6.90	6.70	2.912	
29.500	24	0	*										
08/10/25	66.58	56.93	9.65	381.29	373.62	160.85	158.43	215.19		6.90	6.70	2.712	
12.245	24	0	*										
09/10/25	66.25	59.16	7.09	288.27	282.54	280.28	275.76	6.78		6.90	6.70	2.035	
0.401	24	0	*										
10/10/25	66.33	60.65	5.68	475.83	466.38	470.12	462.21	4.17		6.90	6.70	2.649	
0.253	24	0	*										
11/10/25	65.90	60.28	5.62	493.78	484.11	486.97	478.87	5.24		6.90	6.70	2.724	
0.316	24	0	*										
12/10/25	66.02	60.25	5.77	487.91	478.30	480.83	472.85	5.45		6.90	6.70	2.757	
0.328	24	0	*										
13/10/25	67.14	61.22	5.92	487.59	477.70	480.65	472.42	5.28		6.90	6.70	2.828	
0.323	24	0	*										
14/10/25	65.99	60.21	5.78	476.70	467.31	469.80	462.00	5.31		6.90	6.70	2.697	
0.320	24	0	*										
15/10/25	66.54	60.34	6.20	459.51	450.33	452.81	445.27	5.06		6.90	6.70	2.794	
0.305	24	0	*										
16/10/25	66.42	59.99	6.43	451.85	442.84	445.21	437.88	4.96		6.90	6.70	2.850	
0.297	24	0	*										
17/10/25	66.25	60.21	6.04	477.85	468.39	470.89	463.07	5.32		6.90	6.70	2.828	
0.320	24	0	*										
18/10/25	66.59	60.19	6.40	451.60	442.58	444.87	437.48	5.10		6.90	6.70	2.832	
0.307	24	0	*										
19/10/25	66.96	60.80	6.16	470.87	461.36	464.00	456.15	5.21		6.90	6.70	2.839	
0.317	24	0	*										
20/10/25	66.36	60.00	6.36	447.00	438.12	440.44	433.19	4.93		6.90	6.70	2.789	

0.296 | 24 | 0 | * |

[illegible][illegible]

Период нормальной работы 779ч

Период отсутств.счета тепл.энергии 0ч

Время работы прибора после сброса 1803ч

Представитель абонента

Представитель теплоснабж. организации

свердлова 30

ОТЧЕТ
о суточных параметрах теплоснабжения
19/09/25г.-20/10/25г.

Абонент: _____ Договор N: _____
Адрес: ул. Свердлова 30 Тип расходомера: _____
Тепловычислитель ВКТ-7 сет. N 001 Пределы измерений: _____
Договорные расходы: G под max = 90.00 м3/ч G под min = 0.24 м3/ч
M сет. воды = _____ т.сут M ГВС = _____ т.сут G обр max = 90.00 м3/ч G обр min = 0.24 м3/ч
Тхв = 5.00 °C

Заводской номер 00182178 ВВОД 1 СХЕМА ПОДКЛЮЧЕНИЯ 3 БД 1 ФТ=0 ТЗ=0 КС=0х3380 по 2.7

Дата	t1	t2	dt	V1	M1	V2	M2	Mг	P1	P2	Qo	Qг	ВНР	ВОС	НС
	°C	°C	°C	м3	т	м3	т	т	кг/см2	кг/см2	Гкал	Гкал	ч	ч	
19/09/25	17.15	16.97	0.18	0.00	0.00	0.00	0.00	0.00	1.00	1.00	0.000	0.000	24	0	*
20/09/25	17.14	16.99	0.15	0.00	0.00	0.00	0.00	0.00	1.00	1.00	0.000	0.000	24	0	*
21/09/25	16.63	17.02	-0.39	0.72	0.72	0.00	0.00	0.72	1.00	1.00	0.000	0.009	24	0	*
22/09/25	17.99	17.61	0.38	5.52	5.52	0.00	0.00	5.52	1.00	1.00	0.000	0.069	24	0	*
23/09/25	18.18	17.78	0.40	5.76	5.76	0.00	0.00	5.76	1.00	1.00	0.000	0.073	24	0	*
24/09/25	19.02	18.36	0.66	5.76	5.76	0.00	0.00	5.76	1.00	1.00	0.000	0.076	24	0	*
25/09/25	17.79	17.63	0.16	5.76	5.76	0.00	0.00	5.76	1.00	1.00	0.000	0.072	24	0	*
26/09/25	14.99	15.31	-0.32	5.76	5.76	0.00	0.00	5.76	1.00	1.00	0.000	0.059	24	0	*
27/09/25	41.82	33.75	8.07	51.54	51.12	48.57	48.30	2.82	1.00	1.00	0.454	0.081	24	0	*
28/09/25	43.17	34.70	8.47	83.77	83.05	82.17	81.69	1.36	1.00	1.00	0.699	0.040	24	0	
29/09/25	42.84	34.63	8.21	85.53	84.81	83.41	82.93	1.88	1.00	1.00	0.692	0.055	24	0	
30/09/25	44.29	34.57	9.72	77.34	76.62	75.15	74.67	1.95	1.00	1.00	0.739	0.057	24	0	
01/10/25	46.33	35.70	10.63	76.16	75.38	73.61	73.13	2.25	1.00	1.00	0.800	0.069	24	0	
02/10/25	48.52	37.72	10.80	80.35	79.43	77.69	77.13	2.30	1.00	1.00	0.857	0.075	24	0	
03/10/25	47.51	38.73	8.78	93.93	92.97	91.39	90.67	2.30	1.00	1.00	0.815	0.077	24	0	
04/10/25	47.32	38.37	8.95	93.71	92.75	91.36	90.64	2.11	1.00	1.00	0.828	0.070	24	0	
05/10/25	47.45	38.62	8.83	93.52	92.56	91.34	90.62	1.94	1.00	1.00	0.816	0.065	24	0	
06/10/25	45.96	37.81	8.15	92.81	91.85	90.96	90.29	1.56	1.00	1.00	0.745	0.051	24	0	
07/10/25	44.84	37.13	7.71	91.89	90.93	90.36	89.69	1.24	1.00	1.00	0.697	0.040	24	0	
08/10/25	44.92	37.23	7.69	90.55	89.59	89.19	88.58	1.01	1.00	1.00	0.687	0.032	24	0	
09/10/25	44.64	36.96	7.68	88.85	87.91	87.64	87.16	0.75	1.00	1.00	0.675	0.024	24	0	
10/10/25	43.81	36.44	7.37	87.49	86.77	86.49	86.01	0.76	1.00	1.00	0.641	0.024	24	0	
11/10/25	43.03	35.97	7.06	87.13	86.41	86.25	85.77	0.64	1.00	1.00	0.612	0.020	24	0	
12/10/25	43.44	35.91	7.53	87.11	86.39	86.18	85.70	0.69	1.00	1.00	0.649	0.021	24	0	
13/10/25	43.41	35.94	7.47	87.02	86.30	86.17	85.69	0.61	1.00	1.00	0.648	0.019	24	0	
14/10/25	45.18	36.97	8.21	86.51	85.66	85.59	85.07	0.59	1.00	1.00	0.704	0.019	24	0	
15/10/25	46.13	37.68	8.45	88.80	87.84	87.91	87.35	0.49	1.00	1.00	0.740	0.016	24	0	
16/10/25	46.25	38.03	8.22	95.20	94.24	94.54	93.82	0.42	1.00	1.00	0.771	0.014	24	0	
17/10/25	48.21	39.24	8.97	96.94	95.89	96.21	95.49	0.40	1.00	1.00	0.858	0.014	24	0	
18/10/25	51.77	41.58	10.19	97.57	96.37	96.61	95.89	0.48	1.00	1.00	0.979	0.017	24	0	
19/10/25	51.95	41.86	10.09	97.35	96.15	96.56	95.84	0.31	1.00	1.00	0.965	0.011	24	0	
20/10/25	50.54	41.09	9.45	96.94	95.77	96.46	95.74	0.03	1.00	1.00	0.899	0.001	24	0	
Итого:				2137.2	2116.04	2071.8	2057.87	58.17			17.970	1.270	768	0	
Средние:	38.81	32.32	6.49						1.00	1.00					

Период нормальной работы 768ч
Период отсутств.счета тепл.энергии 0ч
Время работы прибора после сброса 10294ч

представитель абонента

свердлова 30
представитель теплоснабж.организации

**ТС1 Пульсар ДУ-40,
с 19.09.25 по 20.10.25**

Объект:

г. Октябрьский, Свердлова , 38

Потребитель:

АО "Жилуправление"

Прибор

405 Заводской номер: 4298336

ТВ1

Дата	V	T1	T2	Q	Время раб. (ч)
19.09.2025	27930,935	18,63	18,16	298,7118	24
20.09.2025	27930,935	18,78	18,46	298,7118	24
21.09.2025	27930,935	18,76	18,46	298,7118	24
22.09.2025	27930,935	18,70	18,41	298,7118	24
23.09.2025	27930,935	18,98	18,67	298,7118	24
24.09.2025	27930,935	19,09	18,77	298,7118	24
25.09.2025	27930,935	19,28	18,94	298,7118	24
26.09.2025	27930,935	19,06	18,72	298,7118	24
27.09.2025	27950,986	32,67	28,25	298,8468	24
28.09.2025	27983,744	44,02	37,23	299,0669	24
29.09.2025	28016,427	43,33	36,67	299,2822	24
30.09.2025	28046,386	42,97	35,81	299,4926	24
01.10.2025	28071,228	44,43	35,49	299,7124	24
02.10.2025	28095,699	46,31	36,61	299,9472	24
03.10.2025	28122,089	48,22	38,22	300,1986	24
04.10.2025	28153,908	47,20	39,31	300,4467	24
05.10.2025	28185,708	47,09	39,22	300,6942	24
06.10.2025	28217,507	47,25	39,47	300,9387	24
07.10.2025	28249,162	45,50	38,56	301,1516	24
08.10.2025	28280,537	44,67	38,08	301,3606	24
09.10.2025	28311,396	44,70	38,18	301,5618	24
10.10.2025	28341,75	44,37	37,77	301,7601	24
11.10.2025	28371,718	43,61	37,40	301,9446	24
12.10.2025	28401,578	42,90	36,78	302,1227	24
13.10.2025	28431,429	43,24	36,78	302,3136	24
14.10.2025	28461,273	43,25	36,70	302,5070	24
15.10.2025	28490,832	45,17	37,94	302,7185	24
16.10.2025	28521,71	45,95	38,60	302,9423	24
17.10.2025	28555,203	46,02	39,00	303,1748	24
18.10.2025	28589,476	48,47	40,61	303,4411	24
19.10.2025	28623,96	51,47	42,74	303,7381	24
20.10.2025	28658,468	51,71	43,04	304,0332	24
Итого	727,533	---	---	5,3214	768
Среднее		38,62	33,03	---	---

Представитель абонента _____ / _____

Представитель поставщика _____ / _____

**ТС1 Пульсар ДУ-40,
с 19.09.25 по 20.10.25**

Объект:

г. Октябрьский, Свердлова , 64

Потребитель:

АО "Жилуправление"

Прибор

405 Заводской номер: 5299631

ТВ1

Дата	V	T1	T2	Q	Время раб. (ч)
19.09.2025	7637,283	14,96	14,39	92,5128	24
20.09.2025	7637,283	14,84	14,44	92,5128	24
21.09.2025	7637,283	13,94	13,52	92,5128	24
22.09.2025	7637,283	14,36	13,75	92,5128	24
23.09.2025	7637,283	16,79	16,41	92,5128	24
24.09.2025	7637,283	17,16	16,34	92,5128	24
25.09.2025	7637,283	19,40	18,29	92,5128	24
26.09.2025	7657,990	23,95	22,36	92,6161	24
27.09.2025	7723,491	41,53	37,18	92,8941	24
28.09.2025	7780,884	44,67	39,10	93,2104	24
29.09.2025	7837,509	43,88	38,33	93,5217	24
30.09.2025	7891,978	43,53	37,49	93,8453	24
01.10.2025	7936,148	44,80	37,27	94,1741	24
02.10.2025	7979,507	46,55	38,37	94,5246	24
03.10.2025	8012,573	48,57	37,46	94,8580	24
04.10.2025	8035,438	47,25	34,40	95,1445	24
05.10.2025	8061,874	47,11	35,20	95,4400	24
06.10.2025	8090,361	47,33	36,00	95,7492	24
07.10.2025	8128,553	46,16	37,78	96,0641	24
08.10.2025	8165,950	45,00	36,97	96,3543	24
09.10.2025	8200,375	44,99	36,39	96,6301	24
10.10.2025	8238,020	44,78	36,75	96,9105	24
11.10.2025	8271,500	43,90	35,81	97,1646	24
12.10.2025	8303,281	43,08	35,18	97,4018	24
13.10.2025	8333,472	43,45	35,08	97,6521	24
14.10.2025	8361,239	43,34	34,30	97,8941	24
15.10.2025	8392,223	45,19	35,98	98,1666	24
16.10.2025	8424,786	46,16	36,83	98,4568	24
17.10.2025	8461,805	46,39	37,84	98,7688	24
18.10.2025	8498,231	48,16	38,58	99,1052	24
19.10.2025	8530,394	51,64	39,43	99,4699	24
20.10.2025	8567,452	51,86	40,64	99,8329	24
Итого	930,17	---	---	7,3202	768
Среднее		38,59	31,81	---	---

Представитель абонента _____ / _____

Представитель поставщика _____ / _____

северная 16

ОТЧЕТ
о суточных параметрах теплоснабжения
19/09/25г.-20/10/25г.

Абонент: _____ Договор N: _____
 Адрес: ул. Северная 16 Тип расходомера: _____
 Тепловычислитель ВКТ-7 сет. N 001 Пределы измерений: _____
 Договорные расходы: G под max = 120.00 м3/ч G под min = 0.32 м3/ч
 M сет. воды = _____ т.сут MГВС = _____ т.сут G обр max = 120.00 м3/ч G обр min = 0.32 м3/ч
 Тхв = 0.00 °C G3 max = 20.00 м3/ч G3 min = 0.20 м3/ч

Заводской номер 00182803 ВВОД 1 СХЕМА ПОДКЛЮЧЕНИЯ 3 БД 1 ФТ=0 Т3=1 КС=0x4CAF по 2.7

Дата	t1	t2	dt	V1	M1	V2	M2	V3	MГ	P1	P2	Qo	QГ	ВНР	ВОС	НС
	°C	°C	°C	м3	т	м3	т	м3	т	кг/см2	кг/см2	Гкал	Гкал	ч	ч	
19/09/25	16.00	15.97	0.03	0.00	0.00	0.00	0.00	0.00	0.00	6.90	6.70	0.000	0.000	24	0	*
20/09/25	15.93	15.78	0.15	0.00	0.00	0.00	0.00	0.00	0.00	6.90	6.70	0.000	0.000	24	0	*
21/09/25	15.86	15.72	0.14	0.00	0.00	0.00	0.00	0.00	0.00	6.90	6.70	0.000	0.000	24	0	*
22/09/25	15.86	15.72	0.14	0.00	0.00	0.00	0.00	0.00	0.00	6.90	6.70	0.000	0.000	24	0	*
23/09/25	15.95	15.80	0.15	0.00	0.00	0.00	0.00	0.00	0.00	6.90	6.70	0.000	0.000	24	0	*
24/09/25	16.01	15.85	0.16	0.00	0.00	0.00	0.00	0.00	0.00	6.90	6.70	0.000	0.000	24	0	*
25/09/25	16.08	15.91	0.17	0.00	0.00	0.00	0.00	0.00	0.00	6.90	6.70	0.000	0.000	24	0	*
26/09/25	39.36	34.80	4.56	91.51	90.85	93.31	92.77	0.00	-1.92	5.73	5.27	0.415	-0.067	24	0	*
27/09/25	40.31	36.31	4.00	303.92	301.54	309.71	307.79	0.00	-6.25	5.50	4.90	1.207	-0.227	24	0	*
28/09/25	40.50	36.50	4.00	316.49	314.02	322.63	320.62	0.00	-6.60	5.58	4.94	1.257	-0.241	24	0	*
29/09/25	43.28	38.48	4.80	318.90	316.08	324.91	322.64	0.00	-6.56	5.44	4.84	1.519	-0.252	24	0	*
30/09/25	47.55	41.50	6.05	307.83	304.55	312.92	310.36	0.00	-5.81	5.45	4.84	1.843	-0.241	24	0	*
01/10/25	47.50	41.41	6.09	299.89	296.77	304.47	302.06	0.00	-5.29	5.41	4.87	1.807	-0.219	24	0	*
02/10/25	47.56	41.43	6.13	301.08	297.95	305.00	302.60	0.00	-4.65	5.45	4.87	1.825	-0.192	24	0	*
03/10/25	48.26	42.00	6.26	302.73	299.40	305.48	302.91	0.00	-3.51	5.47	4.96	1.873	-0.147	24	0	*
04/10/25	48.26	41.93	6.33	305.01	301.65	307.41	304.77	0.00	-3.12	5.40	4.87	1.906	-0.131	24	0	*
05/10/25	48.19	41.97	6.22	305.39	302.03	307.22	304.60	0.00	-2.57	5.48	4.97	1.877	-0.108	24	0	*
06/10/25	47.25	41.37	5.88	305.79	302.58	307.35	304.84	0.00	-2.26	5.47	4.80	1.779	-0.093	24	0	*
07/10/25	45.13	39.77	5.36	296.27	293.47	298.89	296.59	0.00	-3.12	5.45	4.91	1.570	-0.124	24	0	*
08/10/25	45.22	39.96	5.26	306.12	303.22	309.34	306.94	0.00	-3.72	5.47	5.00	1.596	-0.149	24	0	*
09/10/25	45.03	39.79	5.24	305.43	302.55	308.46	306.08	0.00	-3.53	5.41	4.92	1.586	-0.140	24	0	*
10/10/25	44.84	39.75	5.09	306.05	303.19	308.69	306.34	0.00	-3.15	5.44	5.01	1.543	-0.125	24	0	*
11/10/25	44.58	39.55	5.03	310.63	307.78	313.18	310.83	0.00	-3.05	5.53	5.08	1.546	-0.121	24	0	*
12/10/25	45.20	39.92	5.28	311.09	308.16	313.67	311.27	0.00	-3.11	5.53	5.02	1.627	-0.124	24	0	*
13/10/25	46.90	41.20	5.70	311.30	308.12	313.42	310.93	0.00	-2.81	5.58	5.21	1.756	-0.116	24	0	*
14/10/25	46.49	40.99	5.50	311.65	308.45	313.98	311.44	0.00	-2.99	5.54	5.14	1.693	-0.122	24	0	*
15/10/25	47.16	41.34	5.82	311.89	308.56	314.13	311.50	0.00	-2.94	5.51	5.07	1.793	-0.121	24	0	*
16/10/25	47.00	41.15	5.85	311.21	308.00	313.58	311.10	0.00	-3.10	5.44	5.00	1.801	-0.127	24	0	*
17/10/25	48.36	42.06	6.30	309.81	306.45	312.26	309.69	0.00	-3.24	5.53	5.12	1.928	-0.136	24	0	*
18/10/25	50.92	43.94	6.98	308.35	304.59	310.41	307.58	0.00	-2.99	5.45	5.10	2.123	-0.131	24	0	*
19/10/25	52.00	44.87	7.13	312.78	308.84	314.80	311.82	0.00	-2.98	5.40	5.05	2.201	-0.134	24	0	*
20/10/25	50.76	44.07	6.69	312.50	308.67	314.47	311.58	0.00	-2.91	5.49	5.03	2.066	-0.128	24	0	*
Итого:				7483.6	7407.47	7559.6	7499.65	0.00	-92.18			42.137	-3.716	768	0	
Средние:	39.66	35.21	4.45							5.79	5.36					

Период нормальной работы 768ч
 Период отсутств.счета тепл.энергии 0ч
 Время работы прибора после сброса 9863ч

представитель абонента

северная 16
представитель теплоснабж.организации

северная 28

ОТЧЕТ
о суточных параметрах теплоснабжения
19/09/25г.-20/10/25г.

Абонент: _____

Договор N: _____

Адрес: ул. Северная 28

Тип расходомера: _____

Тепловычислитель ВКТ-7 сет. N 001

Пределы измерений:

Договорные расходы:

G под max = 180.00 м3/ч G под min = 0.48 м3/ч

M сет. воды = _____ т.сут M ГВС = _____ т.сут

G обр max = 180.00 м3/ч G обр min = 0.48 м3/ч

Тхв = 0.00 °C

G3 max = 60.00 м3/ч G3 min = 0.45 м3/ч

Заводской номер 00169021

ВВОД 1

СХЕМА ПОДКЛЮЧЕНИЯ 3

БД 1

ФТ=0

ТЗ=1

КС=0х9541

по 2.7

Дата	t1	t2	dt	V1	M1	V2	M2	V3	Mг	P1	P2	Qo	Qг	ВНР	ВОС	НС
	°C	°C	°C	м3	т	м3	т	м3	т	кг/см2	кг/см2	Гкал	Гкал	ч	ч	
19/09/25	17.62	17.25	0.37	0.00	0.00	0.00	0.00	0.00	0.00	6.20	1.05	0.000	0.000	24	0	*
20/09/25	17.63	17.26	0.37	0.00	0.00	0.00	0.00	0.00	0.00	6.20	1.05	0.000	0.000	24	0	*
21/09/25	17.63	17.24	0.39	0.00	0.00	0.00	0.00	0.00	0.00	6.20	1.05	0.000	0.000	24	0	*
22/09/25	17.67	17.25	0.42	0.00	0.00	0.00	0.00	0.00	0.00	6.20	1.05	0.000	0.000	24	0	*
23/09/25	17.78	17.31	0.47	0.00	0.00	0.00	0.00	0.00	0.00	6.20	1.05	0.000	0.000	24	0	*
24/09/25	17.96	17.41	0.55	0.00	0.00	0.00	0.00	0.00	0.00	6.20	1.05	0.000	0.000	24	0	*
25/09/25	44.79	40.20	4.59	111.67	110.64	111.67	110.80	0.00	-0.16	6.20	1.04	0.518	-0.006	24	0	*
26/09/25	42.53	39.68	2.85	285.59	283.17	285.59	283.43	0.00	-0.26	6.20	1.06	0.834	-0.010	24	0	*
27/09/25	40.14	36.87	3.27	267.96	265.92	267.96	266.23	0.00	-0.31	6.20	1.08	0.893	-0.011	24	0	*
28/09/25	40.32	36.77	3.55	272.72	270.61	272.72	270.97	0.00	-0.36	6.20	1.09	0.990	-0.013	24	0	*
29/09/25	43.10	39.04	4.06	268.09	265.76	268.09	266.10	0.00	-0.34	6.20	1.09	1.102	-0.013	24	0	*
30/09/25	47.35	42.45	4.90	259.89	257.17	259.89	257.66	0.00	-0.49	6.20	1.10	1.284	-0.021	24	0	*
01/10/25	47.29	42.36	4.93	258.37	255.73	258.37	256.21	0.00	-0.48	6.20	1.11	1.284	-0.020	24	0	*
02/10/25	47.36	42.03	5.33	254.04	251.44	254.04	251.92	0.00	-0.48	6.20	1.11	1.364	-0.020	24	0	*
03/10/25	48.05	42.53	5.52	259.01	256.17	259.01	256.79	0.00	-0.62	6.20	1.12	1.437	-0.026	24	0	*
04/10/25	48.06	42.51	5.55	259.27	256.39	259.27	257.07	0.00	-0.68	6.20	1.12	1.447	-0.029	24	0	*
05/10/25	47.99	42.56	5.43	260.09	257.21	260.09	257.84	0.00	-0.63	6.20	1.13	1.419	-0.027	24	0	*
06/10/25	47.06	41.97	5.09	260.69	257.96	260.69	258.47	0.00	-0.51	6.20	1.13	1.335	-0.021	24	0	*
07/10/25	44.93	40.40	4.53	260.89	258.49	260.89	258.75	0.00	-0.26	6.20	1.13	1.199	-0.010	24	0	*
08/10/25	45.02	40.58	4.44	264.91	262.45	264.91	262.73	0.00	-0.28	6.20	1.13	1.192	-0.011	24	0	*
09/10/25	44.83	40.35	4.48	260.51	258.11	260.51	258.45	0.00	-0.34	6.20	1.13	1.184	-0.014	24	0	*
10/10/25	44.64	40.30	4.34	261.06	258.66	261.06	258.97	0.00	-0.31	6.20	1.13	1.149	-0.012	24	0	*
11/10/25	44.39	40.13	4.26	264.06	261.69	264.06	261.96	0.00	-0.27	6.20	1.13	1.140	-0.011	24	0	*
12/10/25	45.00	40.52	4.48	264.39	261.94	264.39	262.23	0.00	-0.29	6.20	1.14	1.195	-0.012	24	0	*
13/10/25	46.69	41.80	4.89	264.46	261.82	264.46	262.30	0.00	-0.48	6.20	1.13	1.309	-0.020	24	0	*
14/10/25	46.29	41.60	4.69	264.86	262.25	264.86	262.71	0.00	-0.46	6.20	1.14	1.255	-0.019	24	0	*
15/10/25	46.95	42.03	4.92	264.97	262.32	264.97	262.81	0.00	-0.49	6.20	1.13	1.313	-0.021	24	0	*
16/10/25	46.80	41.83	4.97	264.05	261.36	264.05	261.89	0.00	-0.53	6.20	1.14	1.321	-0.022	24	0	*
17/10/25	48.14	42.72	5.42	262.67	259.84	262.67	260.39	0.00	-0.55	6.20	1.13	1.432	-0.023	24	0	*
18/10/25	50.70	44.65	6.05	261.48	258.39	261.48	258.91	0.00	-0.52	6.20	1.13	1.589	-0.023	24	0	*
19/10/25	51.79	45.64	6.15	265.21	261.85	265.21	262.57	0.00	-0.72	6.20	1.14	1.636	-0.033	24	0	*
20/10/25	50.56	44.79	5.77	264.92	261.78	264.92	262.39	0.00	-0.61	6.20	1.14	1.532	-0.027	24	0	*
Итого:				6705.8	6639.12	6705.8	6650.55	0.00	-11.43			32.353	-0.475	768	0	
Средние:	40.84	36.87	3.96							6.20	1.10					

северная 28

Период нормальной работы 768ч
Период отсутств.счета тепл.энергии 0ч
Время работы прибора после сброса 10321ч

Представитель абонента

Представитель теплоснабж.организации

ОТЧЕТ
о суточных параметрах теплоснабжения
за 19/09/25г.-20/10/25г.

Абонент:Советская 5
Адрес:г. Октябрьский, ул. Советская д.5
Договор N:000000000
Тепловычислитель ТВ7-04.1М сет.N 001
Договорные расходы:
М сет.воды=_____т.сут Мгвс=_____ т.сут
txh: не исп.

Тип расходомера:_____
Пределы измерений:
G1 max = 18.00 м3/ч G1 min = 0.12 м3/ч
G2 max = 18.00 м3/ч G2 min = 0.12 м3/ч

Серийный номер 24212703, ВД=1, ТВ1, СИ=6, КТ3=0, ФРТ=0 КСН=0х96В1

Дата/время	t1 °C	t2 °C	dt °C	P1 кгс/см2	P2 кгс/см2	V1 м3	V2 м3	M1 т	M2 т	dM т	Qтв Гкал	ВНР ч	ВОС ч	НС
19.09.25 23	16,7	16,59	0,11	6,12 <	6,12 <	0	0	0	0	0	0	24	0	*
20.09.25 23	16,57	16,45	0,12	6,12 <	6,12 <	0	0	0	0	0	0	24	0	*
21.09.25 23	16,51	16,4	0,12	6,12 <	6,12 <	0	0	0	0	0	0	24	0	*
22.09.25 23	16,52	16,41	0,11	6,12 <	6,12 <	0	0	0	0	0	0	24	0	*
23.09.25 23	16,58	16,47	0,11	6,12 <	6,12 <	0	0	0	0	0	0	24	0	*
24.09.25 23	16,61	16,5	0,11	6,12 <	6,12 <	0	0	0	0	0	0	24	0	*
25.09.25 23	16,64	16,51	0,13	6,12 <	6,12 <	0	0	0	0	0	0	24	0	*
26.09.25 23	22,13	20,23	1,9	6,12 <	6,12 <	0	0	0	0	0	0	24	0	*
27.09.25 23	39,32	33,48	5,84	6,12 <	6,12 <	0	0	0	0	0	0	24	0	*
28.09.25 23	39,62	34	5,62	6,12 <	6,12 <	0	0	0	0	0	0	24	0	*
29.09.25 23	43,35	35,67	7,68	2,57 <	5,37 <	46,305	53,813	45,897	53,514	-7,618 #	0,348	24	0	*
30.09.25 23	46,38	37,07	9,31	2,13 <	4,85	71,105	116,19	70,39	115,534	-45,144 #	0,65	24	0	*
01.10.25 23	46,27	36,6	9,67	4,95	4,94	69,707	69,665	69,022	69,255	-0,233	0,667	24	0	
02.10.25 23	46,35	36,5	9,85	4,91	4,9	68,518	68,475	67,84	68,076	-0,236	0,667	24	0	
03.10.25 23	47,01	37,01	10,01	4,91	4,91	68,192	68,158	67,498	67,747	-0,249	0,675	24	0	
04.10.25 23	47,02	36,89	10,13	4,97	4,96	67,1	67,045	66,414	66,647	-0,233	0,672	24	0	
05.10.25 23	46,96	37,01	9,95	4,97	4,96	67,5	67,47	66,813	67,065	-0,253	0,664	24	0	
06.10.25 23	46,15	36,67	9,47	4,94	4,93	67,217	67,16	66,561	66,767	-0,206	0,63	24	0	
07.10.25 23	44,07	35,65	8,42	4,96	4,96	68,158	68,122	67,551	67,75	-0,199	0,568	24	0	
08.10.25 23	44,13	35,69	8,44	4,95	4,94	66,9	66,86	66,304	66,493	-0,189	0,559	24	0	
09.10.25 23	43,95	35,52	8,43	5,02	5,01	66,868	66,8	66,275	66,437	-0,162	0,558	24	0	
10.10.25 23	43,76	35,57	8,18	5,1	5,09	66,9	66,838	66,317	66,468	-0,152	0,542	24	0	
11.10.25 23	43,53	35,5	8,04	5,11	5,11	67,64	67,605	67,055	67,236	-0,18	0,538	24	0	
12.10.25 23	44,07	35,56	8,51	5,13	5,12	66,293	66,25	65,705	65,887	-0,181	0,558	24	0	
13.10.25 23	45,73	36,62	9,11	5,14	5,13	67,798	67,757	67,146	67,363	-0,216	0,611	24	0	
14.10.25 23	45,38	36,71	8,67	5,14	5,13	69,033	68,99	68,382	68,582	-0,2	0,592	24	0	
15.10.25 23	45,95	36,66	9,29	5,14	5,13	66,408	66,353	65,764	65,969	-0,204	0,61	24	0	
16.10.25 23	45,84	36,42	9,42	5,11	5,1	66,342	66,31	65,703	65,926	-0,223	0,618	24	0	
17.10.25 23	46,98	36,88	10,1	5,12	5,11	65,92	65,857	65,249	65,463	-0,215	0,659	24	0	
18.10.25 23	49,54	38,43	11,11	5,07	5,07	66,467	66,425	65,716	65,989	-0,273	0,73	24	0	
19.10.25 23	50,63	39,53	11,1	5,1	5,08	69,518	69,457	68,693	68,973	-0,28	0,762	24	0	
20.10.25 23	49,56	38,99	10,57	5,05	5,04	68,585	68,535	67,806	68,069	-0,264	0,716	24	0	
Итого/Средн	46,07	36,71	9,37	5,21	5,38	1468,472	1520,135	1454,1	1511,211	-57,111	13,595	768	0	

Итоговое потребление на начало и конец периода:

Дата/время	V1 м3	V2 м3	M1 т	M2 т	dM т	Qтв Гкал	ВНР ч	ВОС ч
18.09.25 23	0,102	0,315	0,099	0,314	-0,215	0,002	2055	0
20.10.25 23	1468,575	1520,45	1454,2	1511,525	-57,325	13,597	2823	0
Итого	1468,473	1520,135	1454,1	1511,211	-57,111	13,595	768	0

Условные обозначения:
(<) параметр < min
(>) параметр > max
(!) отсут.питания
(#) дисбаланс масс
(R) реверс
(o) отсут.теплонос.
(X) аппар.неиспр.

Представитель абонента Советская 5 _____ Представитель снабжающей организации _____

Отчет о потреблении...
от 22-10-2025
За период с 19-09-2025 00:00:00 по 21-10-2025 00:00:00

Потребитель :	ОАО "Жилуправление"
Адрес :	ул. Лермонтова 4
Объект :	Жилой дом
Прибор :	ИМ 2300 N BV630
Назначение :	Теплосчетчик с ЧД расхода для ЦО и ГВС

Канал	Qt1	T1	Gm1	T2	Gm2	tm1	ts1
Един.измерения.	Гкал	град.С	тонн	град.С	тонн	час:мин	час:мин
Макс.предел	1000000	150	1000000	150	1000000	1000000	1000000
Миним.предел	0	0	0	0	0	0	0

Отчетные данные поинтервально (за 1 сут.)

Дата, время							
19-09-2025 00:00:00	-	-	-	-	-	-	-
20-09-2025 00:00:00	0.00	16.93	0.00	16.10	0.00	0:00	24:00
21-09-2025 00:00:00	0.00	16.89	0.00	16.09	0.00	0:00	24:00
22-09-2025 00:00:00	0.00	16.86	0.00	16.09	0.00	0:00	24:00
23-09-2025 00:00:00	0.00	16.93	0.00	16.13	0.00	0:00	24:00
24-09-2025 00:00:00	0.00	16.86	0.00	16.35	0.00	0:00	24:00
25-09-2025 00:00:00	0.00	16.94	0.00	16.52	0.00	0:00	24:00
26-09-2025 00:00:00	0.00	33.13	0.00	30.81	51.89	0:00	24:00
27-09-2025 00:00:00	0.00	40.85	0.00	37.29	79.98	0:00	24:00
28-09-2025 00:00:00	0.00	43.88	0.00	39.51	75.53	0:00	24:00
29-09-2025 00:00:00	0.00	43.12	0.00	38.78	73.52	0:00	24:00
30-09-2025 00:00:00	0.00	42.77	0.00	38.32	70.36	0:00	24:00
01-10-2025 00:00:00	0.00	44.15	0.00	38.40	59.97	0:00	24:00
02-10-2025 00:00:00	0.00	45.92	0.00	39.42	57.82	0:00	24:00
03-10-2025 00:00:00	0.00	48.19	0.00	41.10	61.96	0:00	24:00
04-10-2025 00:00:00	0.00	47.06	0.00	41.65	76.45	0:00	24:00
05-10-2025 00:00:00	0.00	46.86	0.00	41.49	76.31	0:00	24:00
06-10-2025 00:00:00	0.00	46.99	0.00	41.67	76.21	0:00	24:00
07-10-2025 00:00:00	0.00	45.52	0.00	40.62	75.71	0:00	24:00
08-10-2025 00:00:00	0.00	44.40	0.00	39.75	74.66	0:00	24:00
09-10-2025 00:00:00	0.00	43.95	0.00	39.36	53.38	0:00	24:00
10-10-2025 00:00:00	0.42	41.67	74.94	37.25	28.12	8:37	23:21
11-10-2025 00:00:00	0.95	43.38	188.48	38.34	0.00	21:38	21:40
12-10-2025 00:00:00	1.00	42.61	208.23	37.79	0.00	24:00	24:00
13-10-2025 00:00:00	1.04	43.02	207.65	38.00	0.00	24:00	24:00
14-10-2025 00:00:00	1.04	42.99	207.71	37.97	0.00	24:00	24:00
15-10-2025 00:00:00	1.13	44.75	205.19	39.22	0.00	24:00	24:00
16-10-2025 00:00:00	1.19	45.70	208.94	39.96	0.00	24:00	24:00
17-10-2025 00:00:00	1.24	45.81	226.17	40.33	0.00	24:00	24:00
18-10-2025 00:00:00	1.38	47.71	230.91	41.74	0.00	24:00	24:00
19-10-2025 00:00:00	1.56	51.27	231.64	44.50	0.00	24:00	24:00
20-10-2025 00:00:00	1.56	51.44	231.86	44.71	0.00	24:00	24:00
21-10-2025 00:00:00	1.46	50.05	239.16	43.90	0.00	24:00	24:00

Итого за отчетный период:

часов:минут	Гкал	град.С	тонн	град.С	тонн	час:мин	час:мин
768:00	13.98	39.63	2460.87	35.27	991.87	270:15	765:01

Отв. лицо :

Начальник СпОКПУ

Морозов И.Е.

Отчет о потреблении...
от 23-10-2025
За период с 19-09-2025 00:00:00 по 21-10-2025 00:00:00

Потребитель :	ОАО "Жилуправление"
Адрес :	ул. Фрунзе д.76
Объект :	Жилой дом
Прибор :	ИМ 2300 N BA724
Назначение :	Теплосчетчик с ЧД расхода для ЦО и ГВС

Канал	Qt1	T1	Gm1	T2	Gm2	tm1	ts1
Един.измерения.	Гкал	град.С	тонн	град.С	тонн	час:мин	час:мин
Макс.предел	1000000	150	1000000	150	1000000	1000000	1000000
Миним.предел	0	0	0	0	0	0	0

Отчетные данные поинтервально (за 1 сут.)

Дата, время							
19-09-2025 00:00:00	-	-	-	-	-	-	-
20-09-2025 00:00:00	0.00	17.05	0.00	16.75	0.00	0:00	24:00
21-09-2025 00:00:00	0.00	16.98	0.00	16.66	0.00	0:00	24:00
22-09-2025 00:00:00	0.00	16.97	0.00	16.66	0.00	0:00	24:00
23-09-2025 00:00:00	0.00	16.99	0.00	16.67	0.00	0:00	24:00
24-09-2025 00:00:00	0.00	17.01	0.00	16.67	0.00	0:00	24:00
25-09-2025 00:00:00	0.00	17.07	0.00	16.69	0.00	0:00	24:00
26-09-2025 00:00:00	0.00	17.08	0.00	16.69	0.00	0:00	24:00
27-09-2025 00:00:00	0.49	28.89	91.34	25.74	0.00	12:21	24:00
28-09-2025 00:00:00	1.06	40.46	203.50	35.23	0.00	24:00	24:00
29-09-2025 00:00:00	1.01	40.62	202.71	35.61	0.00	24:00	24:00
30-09-2025 00:00:00	1.20	43.24	201.64	37.26	0.00	24:00	24:00
01-10-2025 00:00:00	1.54	47.79	199.52	40.07	0.00	24:00	24:00
02-10-2025 00:00:00	1.53	47.70	199.55	40.03	0.00	24:00	24:00
03-10-2025 00:00:00	1.50	47.78	198.82	40.23	0.00	24:00	24:00
04-10-2025 00:00:00	1.53	48.46	198.98	40.74	0.00	24:00	24:00
05-10-2025 00:00:00	1.55	48.49	198.57	40.68	0.00	24:00	24:00
06-10-2025 00:00:00	1.53	48.40	198.43	40.68	0.00	24:00	24:00
07-10-2025 00:00:00	1.46	47.61	198.63	40.23	0.00	24:00	24:00
08-10-2025 00:00:00	1.30	45.31	198.79	38.77	0.00	24:00	24:00
09-10-2025 00:00:00	1.30	45.41	198.84	38.86	0.00	24:00	24:00
10-10-2025 00:00:00	1.30	45.22	198.79	38.67	0.00	24:00	24:00
11-10-2025 00:00:00	1.27	45.02	198.89	38.63	0.00	24:00	24:00
12-10-2025 00:00:00	1.27	44.78	201.34	38.45	0.00	24:00	24:00
13-10-2025 00:00:00	1.32	45.31	201.52	38.74	0.00	24:00	24:00
14-10-2025 00:00:00	1.44	47.07	201.42	39.93	0.00	24:00	24:00
15-10-2025 00:00:00	1.39	46.72	201.62	39.81	0.00	24:00	24:00
16-10-2025 00:00:00	1.45	47.33	201.79	40.13	0.00	24:00	24:00
17-10-2025 00:00:00	1.47	47.23	201.38	39.92	0.00	24:00	24:00
18-10-2025 00:00:00	1.56	48.37	200.85	40.58	0.00	24:00	24:00
19-10-2025 00:00:00	1.74	51.15	199.95	42.45	0.00	24:00	24:00
20-10-2025 00:00:00	1.80	52.22	201.49	43.26	0.00	24:00	24:00
21-10-2025 00:00:00	1.70	51.13	201.52	42.69	0.00	24:00	24:00

Итого за отчетный период:

часов:минут	Гкал	град.С	тонн	град.С	тонн	час:мин	час:мин
768:00	34.70	39.71	4899.87	34.19	0.00	588:21	768:00

Отв. лицо :

Начальник СпОКПУ

Морозов И.Е.